

**REFERENCE**

2425336

**RELEASE DATE**

October 2024

**SUBJECT**

Water quality results for the Gulladuff / Knockloughrim area

**REQUESTS & RESPONSES**

Thank you for your correspondence of 13 September, which included a specific request for recent water tests to confirm that water meeting the correct water standards.

Results for samples taken at the water treatment works and Service Reservoir supplying the Gulladuff / Knockloughrim area along with samples taken at customer taps within the Moyola Magherafelt water supply zone over the period of 1 August 2024 to 9 October are provided in the attached results.

Results show that the drinking water quality supplied to the area was safe to drink, with all results satisfactory with the regulatory requirements with the exception of taste and/or odour with a descriptor of Earthy/Musty in a total of 10 samples over the period.

These taste and odour exceedances were due to the compounds Methyl-Isoborneol (MIB) and Geosmin, which are associated with the algae in Lough Neagh. These compounds produce earthy / musty tastes and odours that can be detected by humans at very low levels, measured in ng/l or parts per trillion. However, MIB and Geosmin are compounds that we know are not harmful to health.

Sample Point	Location	Sample Id	Sample Date	Parameter	Units	Result	PCV Limit
W1301POUT	Moyola PPP Final Water Outlet	4949962	01/08/2024 10:55	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4949962	01/08/2024 10:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4949962	01/08/2024 10:55	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4949962	01/08/2024 10:55	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4949962	01/08/2024 10:55	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4949962	01/08/2024 10:55	Free - Residual disinfectant	mg Cl/l	1.3	
W1301POUT	Moyola PPP Final Water Outlet	4949962	01/08/2024 10:55	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4949962	01/08/2024 10:55	Total - Residual disinfectant	mg Cl/l	1.46	
W1301POUT	Moyola PPP Final Water Outlet	4949962	01/08/2024 10:55	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4949962	01/08/2024 10:55	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4950098	02/08/2024 10:08	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4950098	02/08/2024 10:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4950098	02/08/2024 10:08	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4950098	02/08/2024 10:08	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4950098	02/08/2024 10:08	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4950098	02/08/2024 10:08	Free - Residual disinfectant	mg Cl/l	1.45	
W1301POUT	Moyola PPP Final Water Outlet	4950098	02/08/2024 10:08	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4950098	02/08/2024 10:08	Total - Residual disinfectant	mg Cl/l	1.5	
W1301POUT	Moyola PPP Final Water Outlet	4950098	02/08/2024 10:08	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4950098	02/08/2024 10:08	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4950182	03/08/2024 08:44	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4950182	03/08/2024 08:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4950182	03/08/2024 08:44	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4950182	03/08/2024 08:44	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4950182	03/08/2024 08:44	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4950182	03/08/2024 08:44	Free - Residual disinfectant	mg Cl/l	1.07	
W1301POUT	Moyola PPP Final Water Outlet	4950182	03/08/2024 08:44	Hydrogen Ion	pH value	7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4950182	03/08/2024 08:44	Total - Residual disinfectant	mg Cl/l	1.17	
W1301POUT	Moyola PPP Final Water Outlet	4950182	03/08/2024 08:44	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4950182	03/08/2024 08:44	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4950206	04/08/2024 08:29	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4950206	04/08/2024 08:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4950206	04/08/2024 08:29	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4950206	04/08/2024 08:29	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4950206	04/08/2024 08:29	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4950206	04/08/2024 08:29	Free - Residual disinfectant	mg Cl/l	1.56	
W1301POUT	Moyola PPP Final Water Outlet	4950206	04/08/2024 08:29	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4950206	04/08/2024 08:29	Total - Residual disinfectant	mg Cl/l	1.66	

W1301POUT	Moyola PPP Final Water Outlet	4950206	04/08/2024 08:29	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4950206	04/08/2024 08:29	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4952368	05/08/2024 07:15	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4952368	05/08/2024 07:15	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4952368	05/08/2024 07:15	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4952368	05/08/2024 07:15	Conductivity	uS/cm 20 C		370	2500
W1301POUT	Moyola PPP Final Water Outlet	4952368	05/08/2024 07:15	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4952368	05/08/2024 07:15	Free - Residual disinfectant	mg Cl/l		1.43	
W1301POUT	Moyola PPP Final Water Outlet	4952368	05/08/2024 07:15	Hydrogen Ion	pH value		7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4952368	05/08/2024 07:15	Total - Residual disinfectant	mg Cl/l		1.55	
W1301POUT	Moyola PPP Final Water Outlet	4952368	05/08/2024 07:15	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4952368	05/08/2024 07:15	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	2,4-D	ug/l	<0.011		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	2,4-DB	ug/l	<0.016		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Asulam	ug/l	<0.015		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Bentazone	ug/l	<0.0044		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Bromoxynil	ug/l	<0.0079		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Chlorotoluron	ug/l	<0.0031		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Chlorpyrifos	ug/l	<0.0070		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Clopyralid	ug/l	<0.0097		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Conductivity	uS/cm 20 C		370	2500
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Cyanide	ug/l CN	<5.5		50
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Diazinon	ug/l	<0.0074		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Dicamba	ug/l	<0.028		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Dichlorprop	ug/l	<0.011		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Diflufenican	ug/l	<0.0072		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Dimethenamid	ug/l	<0.0063		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Diuron	ug/l	<0.0055		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Epoxiconazole	ug/l	<0.0049		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Fenpropimorph	ug/l	<0.0083		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Flufenacet	ug/l	<0.0052		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Fluroxypyr	ug/l	<0.0063		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Free - Residual disinfectant	mg Cl/l		1.53	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Glyphosate	ug/l	<0.0077		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Hydrogen Ion	pH value		7.5	9.5

W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Isoproturon	ug/l	<0.0025		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Linuron	ug/l	<0.0034		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	MCPA	ug/l	<0.0093		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	MCPB	ug/l	<0.015		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Mecoprop	ug/l	<0.011		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Metalaxyl	ug/l	<0.0097		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Metamitron	ug/l	<0.0074		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Metazachlor	ug/l	<0.015		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Metoxuron	ug/l	<0.0080		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Metribuzin	ug/l	<0.0060		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Oxamyl	ug/l	<0.0023		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Pendimethalin	ug/l	<0.0064		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Pesticides - Total Substances	ug/l		0	0.5
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Phorate	ug/l	<0.0092		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Pirimicarb	ug/l	<0.0063		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Propachlor	ug/l	<0.0096		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Propiconazole	ug/l	<0.0029		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Propyzamide	ug/l	<0.012		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Prothioconazole	ug/l	<0.0019		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Tebuconazole	ug/l	<0.0039		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Total - Residual disinfectant	mg Cl/l		1.88	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Triclopyr	ug/l	<0.012		0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Algae Blue Green Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Algae Diatom Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Algae Flagellate Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Algae Green Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Algae Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Aluminium	ug Al/l		31	200
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Geosmin	ng/l	<1.1		
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Iron	ug/l Fe		3.3	200
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Manganese	ug Mn/l	<0.80		50
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	MIB	ng/l	<1.9		
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Microcystin-LR	ug/l	<0.024		
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Most numerous Algae		---		
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Second most numerous Algae		---		
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Third most numerous Algae		---		
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Total Organic Carbon	mg C/l		2.8	

W1301POUT	Moyola PPP Final Water Outlet	4952889	07/08/2024 07:25	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4952889	07/08/2024 07:25	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4952889	07/08/2024 07:25	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4952889	07/08/2024 07:25	Conductivity	uS/cm 20 C		370	2500
W1301POUT	Moyola PPP Final Water Outlet	4952889	07/08/2024 07:25	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4952889	07/08/2024 07:25	Free - Residual disinfectant	mg Cl/l		1.43	
W1301POUT	Moyola PPP Final Water Outlet	4952889	07/08/2024 07:25	Hydrogen Ion	pH value		7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4952889	07/08/2024 07:25	Total - Residual disinfectant	mg Cl/l		1.62	
W1301POUT	Moyola PPP Final Water Outlet	4952889	07/08/2024 07:25	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4952889	07/08/2024 07:25	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4953043	08/08/2024 09:37	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4953043	08/08/2024 09:37	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4953043	08/08/2024 09:37	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4953043	08/08/2024 09:37	Conductivity	uS/cm 20 C		380	2500
W1301POUT	Moyola PPP Final Water Outlet	4953043	08/08/2024 09:37	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4953043	08/08/2024 09:37	Free - Residual disinfectant	mg Cl/l		1.41	
W1301POUT	Moyola PPP Final Water Outlet	4953043	08/08/2024 09:37	Hydrogen Ion	pH value		7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4953043	08/08/2024 09:37	Total - Residual disinfectant	mg Cl/l		1.56	
W1301POUT	Moyola PPP Final Water Outlet	4953043	08/08/2024 09:37	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4953043	08/08/2024 09:37	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4953168	09/08/2024 07:12	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4953168	09/08/2024 07:12	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4953168	09/08/2024 07:12	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4953168	09/08/2024 07:12	Conductivity	uS/cm 20 C		370	2500
W1301POUT	Moyola PPP Final Water Outlet	4953168	09/08/2024 07:12	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4953168	09/08/2024 07:12	Free - Residual disinfectant	mg Cl/l		1.53	
W1301POUT	Moyola PPP Final Water Outlet	4953168	09/08/2024 07:12	Hydrogen Ion	pH value		7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4953168	09/08/2024 07:12	Total - Residual disinfectant	mg Cl/l		1.57	
W1301POUT	Moyola PPP Final Water Outlet	4953168	09/08/2024 07:12	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4953168	09/08/2024 07:12	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4953238	10/08/2024 09:16	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4953238	10/08/2024 09:16	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4953238	10/08/2024 09:16	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4953238	10/08/2024 09:16	Conductivity	uS/cm 20 C		370	2500
W1301POUT	Moyola PPP Final Water Outlet	4953238	10/08/2024 09:16	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4953238	10/08/2024 09:16	Free - Residual disinfectant	mg Cl/l		1.43	
W1301POUT	Moyola PPP Final Water Outlet	4953238	10/08/2024 09:16	Hydrogen Ion	pH value		7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4953238	10/08/2024 09:16	Total - Residual disinfectant	mg Cl/l		1.47	
W1301POUT	Moyola PPP Final Water Outlet	4953238	10/08/2024 09:16	Total Coliforms	CFU/100 ml		0	0

W1301POUT	Moyola PPP Final Water Outlet	4953238	10/08/2024 09:16	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4953256	11/08/2024 09:32	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4953256	11/08/2024 09:32	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4953256	11/08/2024 09:32	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4953256	11/08/2024 09:32	Conductivity	uS/cm 20 C		370	2500
W1301POUT	Moyola PPP Final Water Outlet	4953256	11/08/2024 09:32	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4953256	11/08/2024 09:32	Free - Residual disinfectant	mg Cl/l		1.45	
W1301POUT	Moyola PPP Final Water Outlet	4953256	11/08/2024 09:32	Hydrogen Ion	pH value		7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4953256	11/08/2024 09:32	Total - Residual disinfectant	mg Cl/l		1.55	
W1301POUT	Moyola PPP Final Water Outlet	4953256	11/08/2024 09:32	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4953256	11/08/2024 09:32	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4955086	12/08/2024 07:10	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4955086	12/08/2024 07:10	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4955086	12/08/2024 07:10	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4955086	12/08/2024 07:10	Conductivity	uS/cm 20 C		370	2500
W1301POUT	Moyola PPP Final Water Outlet	4955086	12/08/2024 07:10	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4955086	12/08/2024 07:10	Free - Residual disinfectant	mg Cl/l		1.4	
W1301POUT	Moyola PPP Final Water Outlet	4955086	12/08/2024 07:10	Hydrogen Ion	pH value		7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4955086	12/08/2024 07:10	Total - Residual disinfectant	mg Cl/l		1.67	
W1301POUT	Moyola PPP Final Water Outlet	4955086	12/08/2024 07:10	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4955086	12/08/2024 07:10	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Clostridium perfringens (sulph red)	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Conductivity	uS/cm 20 C		370	2500
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Free - Residual disinfectant	mg Cl/l		1.44	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Hydrogen Ion	pH value		7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Total - Residual disinfectant	mg Cl/l		1.49	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	2,4-D	ug/l	<0.011		0.1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	2,4-DB	ug/l	<0.016		0.1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Algae Blue Green Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Algae Diatom Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Algae Flagellate Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Algae Green Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Algae Total	per ml		0	

W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Aluminium	ug Al/l		35	200
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Asulam	ug/l	<0.015		0.1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Bentazone	ug/l	<0.0044		0.1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Bromoxynil	ug/l	<0.0079		0.1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Clopyralid	ug/l	<0.0097		0.1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Dichlorprop	ug/l	<0.011		0.1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Geosmin	ng/l	<1.1		
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Iron	ug/l Fe	<1.538		200
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Manganese	ug Mn/l	<0.80		50
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	MCPA	ug/l		0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	MCPB	ug/l	<0.015		0.1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Mecoprop	ug/l	<0.011		0.1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	MIB	ng/l	<1.9		
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Microcystin-LR	ug/l	<0.024		
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Most numerous Algae		-		
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Odour	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Propyzamide	ug/l	<0.012		0.1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Second most numerous Algae		-		
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Taste	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Taste - Nature		No taste		
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Third most numerous Algae		-		
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Total Organic Carbon	mg C/l		2.9	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Triclopyr	ug/l	<0.012		0.1
W1301POUT	Moyola PPP Final Water Outlet	4955602	14/08/2024 10:18	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4955602	14/08/2024 10:18	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4955602	14/08/2024 10:18	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4955602	14/08/2024 10:18	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4955602	14/08/2024 10:18	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4955602	14/08/2024 10:18	Free - Residual disinfectant	mg Cl/l		1.39	
W1301POUT	Moyola PPP Final Water Outlet	4955602	14/08/2024 10:18	Hydrogen Ion	pH value		7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4955602	14/08/2024 10:18	Total - Residual disinfectant	mg Cl/l		1.45	
W1301POUT	Moyola PPP Final Water Outlet	4955602	14/08/2024 10:18	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4955602	14/08/2024 10:18	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4955793	15/08/2024 07:39	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4955793	15/08/2024 07:39	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4955793	15/08/2024 07:39	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4955793	15/08/2024 07:39	Conductivity	uS/cm 20 C		370	2500
W1301POUT	Moyola PPP Final Water Outlet	4955793	15/08/2024 07:39	E. coli	CFU/100 ml		0	0

W1301POUT	Moyola PPP Final Water Outlet	4955793	15/08/2024 07:39	Free - Residual disinfectant	mg Cl/l		1.33	
W1301POUT	Moyola PPP Final Water Outlet	4955793	15/08/2024 07:39	Hydrogen Ion	pH value		7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4955793	15/08/2024 07:39	Total - Residual disinfectant	mg Cl/l		1.44	
W1301POUT	Moyola PPP Final Water Outlet	4955793	15/08/2024 07:39	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4955793	15/08/2024 07:39	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4955965	16/08/2024 10:15	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4955965	16/08/2024 10:15	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4955965	16/08/2024 10:15	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4955965	16/08/2024 10:15	Conductivity	uS/cm 20 C		370	2500
W1301POUT	Moyola PPP Final Water Outlet	4955965	16/08/2024 10:15	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4955965	16/08/2024 10:15	Free - Residual disinfectant	mg Cl/l		1.38	
W1301POUT	Moyola PPP Final Water Outlet	4955965	16/08/2024 10:15	Hydrogen Ion	pH value		7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4955965	16/08/2024 10:15	Total - Residual disinfectant	mg Cl/l		1.42	
W1301POUT	Moyola PPP Final Water Outlet	4955965	16/08/2024 10:15	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4955965	16/08/2024 10:15	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4956050	17/08/2024 09:04	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4956050	17/08/2024 09:04	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4956050	17/08/2024 09:04	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4956050	17/08/2024 09:04	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4956050	17/08/2024 09:04	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4956050	17/08/2024 09:04	Free - Residual disinfectant	mg Cl/l		1.53	
W1301POUT	Moyola PPP Final Water Outlet	4956050	17/08/2024 09:04	Hydrogen Ion	pH value		7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4956050	17/08/2024 09:04	Total - Residual disinfectant	mg Cl/l		1.63	
W1301POUT	Moyola PPP Final Water Outlet	4956050	17/08/2024 09:04	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4956050	17/08/2024 09:04	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4956073	18/08/2024 08:47	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4956073	18/08/2024 08:47	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4956073	18/08/2024 08:47	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4956073	18/08/2024 08:47	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4956073	18/08/2024 08:47	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4956073	18/08/2024 08:47	Free - Residual disinfectant	mg Cl/l		1.46	
W1301POUT	Moyola PPP Final Water Outlet	4956073	18/08/2024 08:47	Hydrogen Ion	pH value		7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4956073	18/08/2024 08:47	Total - Residual disinfectant	mg Cl/l		1.55	
W1301POUT	Moyola PPP Final Water Outlet	4956073	18/08/2024 08:47	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4956073	18/08/2024 08:47	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4958185	19/08/2024 12:23	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4958185	19/08/2024 12:23	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4958185	19/08/2024 12:23	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4958185	19/08/2024 12:23	Conductivity	uS/cm 20 C		370	2500



W1301POUT	Moyola PPP Final Water Outlet	4958185	19/08/2024 12:23	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4958185	19/08/2024 12:23	Free - Residual disinfectant	mg Cl/l		1.38	
W1301POUT	Moyola PPP Final Water Outlet	4958185	19/08/2024 12:23	Hydrogen Ion	pH value		7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4958185	19/08/2024 12:23	Total - Residual disinfectant	mg Cl/l		1.42	
W1301POUT	Moyola PPP Final Water Outlet	4958185	19/08/2024 12:23	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4958185	19/08/2024 12:23	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Conductivity	uS/cm 20 C		370	2500
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Free - Residual disinfectant	mg Cl/l		1.79	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Hydrogen Ion	pH value		7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Total - Residual disinfectant	mg Cl/l		1.86	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	2,4-D	ug/l		0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	2,4-DB	ug/l	<0.016		0.1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Algae Blue Green Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Algae Diatom Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Algae Flagellate Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Algae Green Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Algae Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Aluminium	ug Al/l		29	200
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Asulam	ug/l	<0.015		0.1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Bentazone	ug/l	<0.0044		0.1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Bromoxynil	ug/l	<0.0079		0.1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Clopyralid	ug/l	<0.0097		0.1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Dichlorprop	ug/l	<0.011		0.1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Geosmin	ng/l	<1.1		
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Iron	ug/l Fe	<1.538		200
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Manganese	ug Mn/l	<0.80		50
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	MCPA	ug/l	<0.0093		0.1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	MCPB	ug/l	<0.015		0.1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Mecoprop	ug/l	<0.011		0.1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	MIB	ng/l	<1.9		
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Most numerous Algae		-		
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Propyzamide	ug/l	<0.012		0.1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Second most numerous Algae		-		

W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Third most numerous Algae		-		
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Total Organic Carbon	mg C/l		2.5	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Triclopyr	ug/l	<0.012		0.1
W1301POUT	Moyola PPP Final Water Outlet	4958622	21/08/2024 07:28	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4958622	21/08/2024 07:28	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4958622	21/08/2024 07:28	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4958622	21/08/2024 07:28	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4958622	21/08/2024 07:28	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4958622	21/08/2024 07:28	Free - Residual disinfectant	mg Cl/l		1.77	
W1301POUT	Moyola PPP Final Water Outlet	4958622	21/08/2024 07:28	Hydrogen Ion	pH value		7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4958622	21/08/2024 07:28	Total - Residual disinfectant	mg Cl/l		1.86	
W1301POUT	Moyola PPP Final Water Outlet	4958622	21/08/2024 07:28	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4958622	21/08/2024 07:28	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4958824	22/08/2024 09:31	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4958824	22/08/2024 09:31	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4958824	22/08/2024 09:31	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4958824	22/08/2024 09:31	Conductivity	uS/cm 20 C		370	2500
W1301POUT	Moyola PPP Final Water Outlet	4958824	22/08/2024 09:31	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4958824	22/08/2024 09:31	Free - Residual disinfectant	mg Cl/l		1.47	
W1301POUT	Moyola PPP Final Water Outlet	4958824	22/08/2024 09:31	Hydrogen Ion	pH value		7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4958824	22/08/2024 09:31	Total - Residual disinfectant	mg Cl/l		1.52	
W1301POUT	Moyola PPP Final Water Outlet	4958824	22/08/2024 09:31	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4958824	22/08/2024 09:31	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4958981	23/08/2024 07:51	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4958981	23/08/2024 07:51	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4958981	23/08/2024 07:51	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4958981	23/08/2024 07:51	Conductivity	uS/cm 20 C		370	2500
W1301POUT	Moyola PPP Final Water Outlet	4958981	23/08/2024 07:51	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4958981	23/08/2024 07:51	Free - Residual disinfectant	mg Cl/l		1.53	
W1301POUT	Moyola PPP Final Water Outlet	4958981	23/08/2024 07:51	Hydrogen Ion	pH value		7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4958981	23/08/2024 07:51	Total - Residual disinfectant	mg Cl/l		1.6	
W1301POUT	Moyola PPP Final Water Outlet	4958981	23/08/2024 07:51	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4958981	23/08/2024 07:51	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4959086	24/08/2024 09:11	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4959086	24/08/2024 09:11	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4959086	24/08/2024 09:11	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4959086	24/08/2024 09:11	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4959086	24/08/2024 09:11	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4959086	24/08/2024 09:11	Free - Residual disinfectant	mg Cl/l		1.48	

W1301POUT	Moyola PPP Final Water Outlet	4959086	24/08/2024 09:11	Hydrogen Ion	pH value	7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4959086	24/08/2024 09:11	Total - Residual disinfectant	mg Cl/l	1.62	
W1301POUT	Moyola PPP Final Water Outlet	4959086	24/08/2024 09:11	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4959086	24/08/2024 09:11	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4959104	25/08/2024 08:08	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4959104	25/08/2024 08:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4959104	25/08/2024 08:08	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4959104	25/08/2024 08:08	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4959104	25/08/2024 08:08	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4959104	25/08/2024 08:08	Free - Residual disinfectant	mg Cl/l	1.39	
W1301POUT	Moyola PPP Final Water Outlet	4959104	25/08/2024 08:08	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4959104	25/08/2024 08:08	Total - Residual disinfectant	mg Cl/l	1.47	
W1301POUT	Moyola PPP Final Water Outlet	4959104	25/08/2024 08:08	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4959104	25/08/2024 08:08	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4961137	26/08/2024 08:55	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4961137	26/08/2024 08:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4961137	26/08/2024 08:55	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4961137	26/08/2024 08:55	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4961137	26/08/2024 08:55	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4961137	26/08/2024 08:55	Free - Residual disinfectant	mg Cl/l	1.5	
W1301POUT	Moyola PPP Final Water Outlet	4961137	26/08/2024 08:55	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4961137	26/08/2024 08:55	Total - Residual disinfectant	mg Cl/l	1.57	
W1301POUT	Moyola PPP Final Water Outlet	4961137	26/08/2024 08:55	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4961137	26/08/2024 08:55	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Colony Counts 37 (48hrs)	CFU/1 ml	1	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Free - Residual disinfectant	mg Cl/l	1.39	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Total - Residual disinfectant	mg Cl/l	1.47	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	2,4-D	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	2,4-DB	ug/l	<0.016	0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Algae Blue Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Algae Diatom Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Algae Flagellate Total	per ml	0	

W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Algae Green Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Algae Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Aluminium	ug Al/l		27	200
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Asulam	ug/l	<0.015		0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Bentazone	ug/l	<0.0044		0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Bromodichloromethane	ug/l		4.6	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Bromoform	ug/l	<3.5		
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Bromoxynil	ug/l	<0.0079		0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Chloroform	ug/l		9.2	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Clopyralid	ug/l	<0.0097		0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Dibromochloromethane	ug/l		2.9	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Dichlorprop	ug/l	<0.011		0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Geosmin	ng/l	<1.1		
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Iron	ug/l Fe		1.8	200
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Manganese	ug Mn/l	<0.80		50
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	MCPA	ug/l		0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	MCPB	ug/l	<0.015		0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Mecoprop	ug/l	<0.011		0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	MIB	ng/l		9.5	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Microcystin-LR	ug/l	<0.024		
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Most numerous Algae		-		
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Odour	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Propyzamide	ug/l	<0.012		0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Second most numerous Algae		-		
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Taste	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Taste - Nature		No taste		
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Third most numerous Algae		-		
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Total Organic Carbon	mg C/l		2.9	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Total Trihalomethanes	ug/l		17	100
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Triclopyr	ug/l	<0.012		0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	WHO Index			0.14	1
W1301POUT	Moyola PPP Final Water Outlet	4961584	28/08/2024 10:50	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4961584	28/08/2024 10:50	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4961584	28/08/2024 10:50	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4961584	28/08/2024 10:50	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4961584	28/08/2024 10:50	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4961584	28/08/2024 10:50	Free - Residual disinfectant	mg Cl/l		1.25	
W1301POUT	Moyola PPP Final Water Outlet	4961584	28/08/2024 10:50	Hydrogen Ion	pH value		7.6	9.5

W1301POUT	Moyola PPP Final Water Outlet	4961584	28/08/2024 10:50	Total - Residual disinfectant	mg Cl/l		1.58	
W1301POUT	Moyola PPP Final Water Outlet	4961584	28/08/2024 10:50	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4961584	28/08/2024 10:50	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4961766	29/08/2024 11:23	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4961766	29/08/2024 11:23	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4961766	29/08/2024 11:23	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4961766	29/08/2024 11:23	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4961766	29/08/2024 11:23	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4961766	29/08/2024 11:23	Free - Residual disinfectant	mg Cl/l		1.4	
W1301POUT	Moyola PPP Final Water Outlet	4961766	29/08/2024 11:23	Hydrogen Ion	pH value		7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4961766	29/08/2024 11:23	Total - Residual disinfectant	mg Cl/l		1.56	
W1301POUT	Moyola PPP Final Water Outlet	4961766	29/08/2024 11:23	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4961766	29/08/2024 11:23	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4961912	30/08/2024 09:28	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4961912	30/08/2024 09:28	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4961912	30/08/2024 09:28	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4961912	30/08/2024 09:28	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4961912	30/08/2024 09:28	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4961912	30/08/2024 09:28	Free - Residual disinfectant	mg Cl/l		1.47	
W1301POUT	Moyola PPP Final Water Outlet	4961912	30/08/2024 09:28	Hydrogen Ion	pH value		7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4961912	30/08/2024 09:28	Total - Residual disinfectant	mg Cl/l		1.52	
W1301POUT	Moyola PPP Final Water Outlet	4961912	30/08/2024 09:28	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4961912	30/08/2024 09:28	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4961986	31/08/2024 08:38	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4961986	31/08/2024 08:38	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4961986	31/08/2024 08:38	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4961986	31/08/2024 08:38	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4961986	31/08/2024 08:38	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4961986	31/08/2024 08:38	Free - Residual disinfectant	mg Cl/l		1.31	
W1301POUT	Moyola PPP Final Water Outlet	4961986	31/08/2024 08:38	Hydrogen Ion	pH value		7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4961986	31/08/2024 08:38	Total - Residual disinfectant	mg Cl/l		1.62	
W1301POUT	Moyola PPP Final Water Outlet	4961986	31/08/2024 08:38	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4961986	31/08/2024 08:38	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4962004	01/09/2024 08:55	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4962004	01/09/2024 08:55	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4962004	01/09/2024 08:55	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4962004	01/09/2024 08:55	Conductivity	uS/cm 20 C		370	2500
W1301POUT	Moyola PPP Final Water Outlet	4962004	01/09/2024 08:55	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4962004	01/09/2024 08:55	Free - Residual disinfectant	mg Cl/l		1.18	

W1301POUT	Moyola PPP Final Water Outlet	4962004	01/09/2024 08:55	Hydrogen Ion	pH value		7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4962004	01/09/2024 08:55	Total - Residual disinfectant	mg Cl/l		1.33	
W1301POUT	Moyola PPP Final Water Outlet	4962004	01/09/2024 08:55	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4962004	01/09/2024 08:55	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4964191	02/09/2024 08:12	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4964191	02/09/2024 08:12	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4964191	02/09/2024 08:12	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4964191	02/09/2024 08:12	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4964191	02/09/2024 08:12	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4964191	02/09/2024 08:12	Free - Residual disinfectant	mg Cl/l		1.45	
W1301POUT	Moyola PPP Final Water Outlet	4964191	02/09/2024 08:12	Hydrogen Ion	pH value		7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4964191	02/09/2024 08:12	Total - Residual disinfectant	mg Cl/l		1.48	
W1301POUT	Moyola PPP Final Water Outlet	4964191	02/09/2024 08:12	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4964191	02/09/2024 08:12	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Free - Residual disinfectant	mg Cl/l		1.45	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Hydrogen Ion	pH value		7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Total - Residual disinfectant	mg Cl/l		1.53	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	2,4-D	ug/l	<0.011		0.1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	2,4-DB	ug/l	<0.016		0.1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Algae Blue Green Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Algae Diatom Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Algae Flagellate Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Algae Green Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Algae Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Aluminium	ug Al/l		34	200
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Asulam	ug/l	<0.015		0.1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Bentazone	ug/l	<0.0044		0.1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Bromoxynil	ug/l	<0.0079		0.1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Clopyralid	ug/l	<0.0097		0.1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Dichlorprop	ug/l	<0.011		0.1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Geosmin	ng/l	<1.1		
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Iron	ug/l Fe		2.6	200

W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Manganese	ug Mn/l	<0.80		50
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	MCPA	ug/l		0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	MCPB	ug/l	<0.015		0.1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Mecoprop	ug/l	<0.011		0.1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	MIB	ng/l		17	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Microcystin-LR	ug/l	<0.024		
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Most numerous Algae		---		
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Odour	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Propyzamide	ug/l	<0.012		0.1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Second most numerous Algae		---		
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Taste	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Taste - Nature		No taste		
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Third most numerous Algae		---		
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Total Organic Carbon	mg C/l		2.7	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Triclopyr	ug/l	<0.012		0.1
W1301POUT	Moyola PPP Final Water Outlet	4964809	04/09/2024 07:19	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4964809	04/09/2024 07:19	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4964809	04/09/2024 07:19	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4964809	04/09/2024 07:19	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4964809	04/09/2024 07:19	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4964809	04/09/2024 07:19	Free - Residual disinfectant	mg Cl/l		1.33	
W1301POUT	Moyola PPP Final Water Outlet	4964809	04/09/2024 07:19	Total - Residual disinfectant	mg Cl/l		1.39	
W1301POUT	Moyola PPP Final Water Outlet	4964809	04/09/2024 07:19	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4964809	04/09/2024 07:19	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4964966	05/09/2024 07:19	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4964966	05/09/2024 07:19	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4964966	05/09/2024 07:19	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4964966	05/09/2024 07:19	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4964966	05/09/2024 07:19	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4964966	05/09/2024 07:19	Free - Residual disinfectant	mg Cl/l		1.77	
W1301POUT	Moyola PPP Final Water Outlet	4964966	05/09/2024 07:19	Total - Residual disinfectant	mg Cl/l		2	
W1301POUT	Moyola PPP Final Water Outlet	4964966	05/09/2024 07:19	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4964966	05/09/2024 07:19	Turbidity	NTU		0.12	1
W1301POUT	Moyola PPP Final Water Outlet	4965152	06/09/2024 09:50	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4965152	06/09/2024 09:50	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4965152	06/09/2024 09:50	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4965152	06/09/2024 09:50	Conductivity	uS/cm 20 C		370	2500
W1301POUT	Moyola PPP Final Water Outlet	4965152	06/09/2024 09:50	E. coli	CFU/100 ml		0	0

W1301POUT	Moyola PPP Final Water Outlet	4965152	06/09/2024 09:50	Free - Residual disinfectant	mg Cl/l		1.5	
W1301POUT	Moyola PPP Final Water Outlet	4965152	06/09/2024 09:50	Total - Residual disinfectant	mg Cl/l		1.79	
W1301POUT	Moyola PPP Final Water Outlet	4965152	06/09/2024 09:50	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4965152	06/09/2024 09:50	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4965249	07/09/2024 09:36	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4965249	07/09/2024 09:36	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4965249	07/09/2024 09:36	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4965249	07/09/2024 09:36	Conductivity	uS/cm 20 C		370	2500
W1301POUT	Moyola PPP Final Water Outlet	4965249	07/09/2024 09:36	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4965249	07/09/2024 09:36	Free - Residual disinfectant	mg Cl/l		1.42	
W1301POUT	Moyola PPP Final Water Outlet	4965249	07/09/2024 09:36	Total - Residual disinfectant	mg Cl/l		1.48	
W1301POUT	Moyola PPP Final Water Outlet	4965249	07/09/2024 09:36	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4965249	07/09/2024 09:36	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4965267	08/09/2024 09:38	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4965267	08/09/2024 09:38	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4965267	08/09/2024 09:38	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4965267	08/09/2024 09:38	Conductivity	uS/cm 20 C		370	2500
W1301POUT	Moyola PPP Final Water Outlet	4965267	08/09/2024 09:38	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4965267	08/09/2024 09:38	Free - Residual disinfectant	mg Cl/l		1.58	
W1301POUT	Moyola PPP Final Water Outlet	4965267	08/09/2024 09:38	Total - Residual disinfectant	mg Cl/l		1.71	
W1301POUT	Moyola PPP Final Water Outlet	4965267	08/09/2024 09:38	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4965267	08/09/2024 09:38	Turbidity	NTU		0.13	1
W1301POUT	Moyola PPP Final Water Outlet	4967481	09/09/2024 07:16	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4967481	09/09/2024 07:16	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4967481	09/09/2024 07:16	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4967481	09/09/2024 07:16	Conductivity	uS/cm 20 C		370	2500
W1301POUT	Moyola PPP Final Water Outlet	4967481	09/09/2024 07:16	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4967481	09/09/2024 07:16	Free - Residual disinfectant	mg Cl/l		1.44	
W1301POUT	Moyola PPP Final Water Outlet	4967481	09/09/2024 07:16	Total - Residual disinfectant	mg Cl/l		1.51	
W1301POUT	Moyola PPP Final Water Outlet	4967481	09/09/2024 07:16	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4967481	09/09/2024 07:16	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4979076	09/09/2024 14:20	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4979076	09/09/2024 14:20	Free - Residual disinfectant	mg Cl/l		1.44	
W1301POUT	Moyola PPP Final Water Outlet	4979076	09/09/2024 14:20	Odour	Diln No		10	0
W1301POUT	Moyola PPP Final Water Outlet	4979076	09/09/2024 14:20	Odour - Nature		Earthy		
W1301POUT	Moyola PPP Final Water Outlet	4979076	09/09/2024 14:20	Taste	Diln No		10	0
W1301POUT	Moyola PPP Final Water Outlet	4979076	09/09/2024 14:20	Taste - Nature		Earthy		
W1301POUT	Moyola PPP Final Water Outlet	4979076	09/09/2024 14:20	Total - Residual disinfectant	mg Cl/l		1.62	
W1301POUT	Moyola PPP Final Water Outlet	4979076	09/09/2024 14:20	Total Coliforms	CFU/100 ml		0	0



W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Conductivity	uS/cm 20 C		370	2500
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Free - Residual disinfectant	mg Cl/l		1.54	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Hydrogen Ion	pH value		7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Total - Residual disinfectant	mg Cl/l		1.62	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	2,4-D	ug/l	<0.022		0.1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	2,4-DB	ug/l	<0.016		0.1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Algae Blue Green Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Algae Diatom Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Algae Flagellate Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Algae Green Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Algae Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Aluminium	ug Al/l		30	200
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Asulam	ug/l	<0.015		0.1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Bentazone	ug/l	<0.0044		0.1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Bromoxynil	ug/l	<0.0079		0.1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Clopyralid	ug/l	<0.019		0.1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Dichlorprop	ug/l	<0.011		0.1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Geosmin	ng/l	<1.1		
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Iron	ug/l Fe	<1.538		200
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Manganese	ug Mn/l	<0.80		50
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	MCPA	ug/l	<0.019		0.1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	MCPB	ug/l	<0.030		0.1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Mecoprop	ug/l		0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Microcystin-LR	ug/l	<0.024		
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Most numerous Algae		-		
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Odour	Diln No		10	0
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Odour - Nature		Earthy		
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Propyzamide	ug/l	<0.024		0.1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Second most numerous Algae		-		
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Taste	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Taste - Nature		No taste		
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Third most numerous Algae		-		
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Triclopyr	ug/l	<0.012		0.1

W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Conductivity	uS/cm 20 C		370	2500
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Free - Residual disinfectant	mg Cl/l		1.38	
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Hydrogen Ion	pH value		7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Total - Residual disinfectant	mg Cl/l		1.54	
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Odour	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Taste	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Taste - Nature		No taste		
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Conductivity	uS/cm 20 C		380	2500
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Free - Residual disinfectant	mg Cl/l		1.54	
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Hydrogen Ion	pH value		7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Total - Residual disinfectant	mg Cl/l		1.7	
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Odour	Diln No		7	0
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Odour - Nature		Earthy/Musty		
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Taste	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Taste - Nature		No taste		
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Conductivity	uS/cm 20 C		390	2500
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Free - Residual disinfectant	mg Cl/l		1.53	
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Hydrogen Ion	pH value		7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Total - Residual disinfectant	mg Cl/l		1.85	
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Odour	Diln No		0	0

W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Taste	Diln No		7	0
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Taste - Nature		Earthy/Musty		
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Conductivity	uS/cm 20 C		380	2500
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Free - Residual disinfectant	mg Cl/l		1.5	
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Hydrogen Ion	pH value		7.4	9.5
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Total - Residual disinfectant	mg Cl/l		1.64	
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Odour	Diln No		10	0
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Odour - Nature		Earthy		
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Taste	Diln No		10	0
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Taste - Nature		Earthy		
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Conductivity	uS/cm 20 C		390	2500
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Free - Residual disinfectant	mg Cl/l		1.51	
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Hydrogen Ion	pH value		7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Total - Residual disinfectant	mg Cl/l		1.58	
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Odour	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Taste	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Taste - Nature		No taste		
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Conductivity	uS/cm 20 C		380	2500
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Free - Residual disinfectant	mg Cl/l		1.48	
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Hydrogen Ion	pH value		7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Total - Residual disinfectant	mg Cl/l		1.55	

W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Odour	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Taste	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Taste - Nature		No taste		
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	2,4-D	ug/l	<0.011		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	2,4-DB	ug/l	<0.016		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Asulam	ug/l	<0.015		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Bentazone	ug/l	<0.0044		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Bromoxynil	ug/l	<0.0079		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Chlorotoluron	ug/l	<0.0031		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Chlorpyrifos	ug/l	<0.0070		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Clopyralid	ug/l	<0.0097		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Conductivity	uS/cm 20 C		380	2500
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Cyanide	ug/l CN	<5.5		50
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Dicamba	ug/l	<0.028		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Dichlorprop	ug/l	<0.011		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Diflufenican	ug/l	<0.0072		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Dimethenamid	ug/l	<0.0063		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Diuron	ug/l	<0.0055		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Epoxiconazole	ug/l	<0.0049		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Fenpropimorph	ug/l	<0.0083		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Flufenacet	ug/l	<0.0052		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Fluroxypyr	ug/l	<0.0063		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Free - Residual disinfectant	mg Cl/l		1.59	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Glyphosate	ug/l	<0.0077		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Hydrogen Ion	pH value		7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Isoproturon	ug/l	<0.0025		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Linuron	ug/l	<0.0034		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	MCPA	ug/l	<0.0093		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	MCPB	ug/l	<0.015		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Mecoprop	ug/l	<0.011		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Metalaxyl	ug/l	<0.0097		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Metamitron	ug/l	<0.0074		0.1

W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Metazachlor	ug/l	<0.015		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Metoxuron	ug/l	<0.0080		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Metribuzin	ug/l	<0.0060		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Oxamyl	ug/l	<0.0023		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Pendimethalin	ug/l	<0.0064		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Pesticides - Total Substances	ug/l		0	0.5
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Phorate	ug/l	<0.0092		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Pirimicarb	ug/l	<0.0063		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Propachlor	ug/l	<0.0096		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Propiconazole	ug/l	<0.0029		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Propyzamide	ug/l	<0.012		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Prothioconazole	ug/l	<0.0019		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Tebuconazole	ug/l	<0.0039		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Total - Residual disinfectant	mg Cl/l		1.67	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Triclopyr	ug/l	<0.012		0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Algae Blue Green Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Algae Diatom Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Algae Flagellate Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Algae Green Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Algae Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Aluminium	ug Al/l		36	200
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Geosmin	ng/l	<1.1		
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Iron	ug/l Fe		2	200
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Manganese	ug Mn/l	<0.80		50
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Microcystin-LR	ug/l	<0.024		
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Most numerous Algae		---		
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Odour	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Second most numerous Algae		---		
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Taste	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Taste - Nature		No taste		
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Third most numerous Algae		---		
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Total Organic Carbon	mg C/l		2.4	
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Conductivity	uS/cm 20 C		360	2500

W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Free - Residual disinfectant	mg Cl/l		1.39	
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Hydrogen Ion	pH value		7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Total - Residual disinfectant	mg Cl/l		1.44	
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Odour	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Taste	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Taste - Nature		No taste		
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Free - Residual disinfectant	mg Cl/l		1.41	
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Hydrogen Ion	pH value		7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Total - Residual disinfectant	mg Cl/l		1.45	
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Odour	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Taste	Diln No		7	0
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Taste - Nature		Earthy/Musty		
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Free - Residual disinfectant	mg Cl/l		1.42	
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Hydrogen Ion	pH value		7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Total - Residual disinfectant	mg Cl/l		1.6	
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Odour	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Taste	Diln No		10	0
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Taste - Nature		Earthy		
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Colony Counts 22	CFU/1 ml		0	

W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Free - Residual disinfectant	mg Cl/l		1.66	
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Hydrogen Ion	pH value		7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Total - Residual disinfectant	mg Cl/l		1.84	
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Odour	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Taste	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Taste - Nature		No taste		
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Free - Residual disinfectant	mg Cl/l		1.7	
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Hydrogen Ion	pH value		7.4	9.5
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Total - Residual disinfectant	mg Cl/l		1.9	
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Odour	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Taste	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Taste - Nature		No taste		
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Free - Residual disinfectant	mg Cl/l		1.48	
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Hydrogen Ion	pH value		7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Total - Residual disinfectant	mg Cl/l		1.6	
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Odour	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Odour - Nature		No odour		

W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Taste - Nature	No taste		
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Free - Residual disinfectant	mg Cl/l	1.29	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Hydrogen Ion	pH value	7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Nitrite	mg/l	<0.03	0.1
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Total - Residual disinfectant	mg Cl/l	1.58	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Algae Blue Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Algae Diatom Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Algae Flagellate Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Algae Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Algae Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Aluminium	ug Al/l	30	200
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Bromodichloromethane	ug/l	4.6	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Bromoform	ug/l	<3.5	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Chloroform	ug/l	7.3	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Dibromochloromethane	ug/l	3.7	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Iron	ug/l Fe	2.4	200
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Manganese	ug Mn/l	<0.642	50
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Most numerous Algae	-		
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Odour - Nature	No odour		
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Second most numerous Algae	-		
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Taste - Nature	No taste		
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Third most numerous Algae	-		
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Total Trihalomethanes	ug/l	16	100
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	WHO Index		0.14	1
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Conductivity	uS/cm 20 C	360	2500



W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Free - Residual disinfectant	mg Cl/l		1.44	
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Hydrogen Ion	pH value		7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Total - Residual disinfectant	mg Cl/l		1.62	
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Odour	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Taste	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Taste - Nature		No taste		
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Free - Residual disinfectant	mg Cl/l		1.45	
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Hydrogen Ion	pH value		7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Total - Residual disinfectant	mg Cl/l		1.47	
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Odour	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Taste	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Taste - Nature		No taste		
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Free - Residual disinfectant	mg Cl/l		1.35	
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Hydrogen Ion	pH value		7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Total - Residual disinfectant	mg Cl/l		1.5	
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Odour	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Taste	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Taste - Nature		No taste		
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Colony Counts 22	CFU/1 ml		0	

W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Conductivity	uS/cm 20 C		350	2500
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Free - Residual disinfectant	mg Cl/l		1.55	
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Hydrogen Ion	pH value		7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Total - Residual disinfectant	mg Cl/l		1.6	
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Odour	Diln No		2	0
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Odour - Nature		Earthy/Musty		
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Taste	Diln No		2	0
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Taste - Nature		Earthy/Musty		
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Conductivity	uS/cm 20 C		350	2500
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Free - Residual disinfectant	mg Cl/l		1.44	
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Hydrogen Ion	pH value		7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Total - Residual disinfectant	mg Cl/l		1.61	
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Odour	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Taste	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Taste - Nature		No taste		
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Colony Counts 22	CFU/1 ml		1	
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Free - Residual disinfectant	mg Cl/l		1.44	
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Hydrogen Ion	pH value		7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Nitrite	mg/l	<0.03		0.1
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Total - Residual disinfectant	mg Cl/l		1.55	
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Odour	Diln No		0	0

W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Taste	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Taste - Nature		No taste		
W1301POUT	Moyola PPP Final Water Outlet	4976647	01/10/2024 12:00	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4976647	01/10/2024 12:00	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4976647	01/10/2024 12:00	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4976647	01/10/2024 12:00	Conductivity	uS/cm 20 C		350	2500
W1301POUT	Moyola PPP Final Water Outlet	4976647	01/10/2024 12:00	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4976647	01/10/2024 12:00	Free - Residual disinfectant	mg Cl/l		1.41	
W1301POUT	Moyola PPP Final Water Outlet	4976647	01/10/2024 12:00	Hydrogen Ion	pH value		7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4976647	01/10/2024 12:00	Total - Residual disinfectant	mg Cl/l		1.47	
W1301POUT	Moyola PPP Final Water Outlet	4976647	01/10/2024 12:00	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4976647	01/10/2024 12:00	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4976647	01/10/2024 12:00	Algae Blue Green Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4976647	01/10/2024 12:00	Algae Diatom Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4976647	01/10/2024 12:00	Algae Flagellate Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4976647	01/10/2024 12:00	Algae Green Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4976647	01/10/2024 12:00	Algae Total	per ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4976647	01/10/2024 12:00	Most numerous Algae		---		
W1301POUT	Moyola PPP Final Water Outlet	4976647	01/10/2024 12:00	Odour	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4976647	01/10/2024 12:00	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4976647	01/10/2024 12:00	Second most numerous Algae		---		
W1301POUT	Moyola PPP Final Water Outlet	4976647	01/10/2024 12:00	Taste	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4976647	01/10/2024 12:00	Taste - Nature		No taste		
W1301POUT	Moyola PPP Final Water Outlet	4976647	01/10/2024 12:00	Third most numerous Algae		---		
W1301POUT	Moyola PPP Final Water Outlet	4976835	02/10/2024 07:01	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4976835	02/10/2024 07:01	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4976835	02/10/2024 07:01	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4976835	02/10/2024 07:01	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4976835	02/10/2024 07:01	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4976835	02/10/2024 07:01	Free - Residual disinfectant	mg Cl/l		1.43	
W1301POUT	Moyola PPP Final Water Outlet	4976835	02/10/2024 07:01	Hydrogen Ion	pH value		7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4976835	02/10/2024 07:01	Total - Residual disinfectant	mg Cl/l		1.48	
W1301POUT	Moyola PPP Final Water Outlet	4976835	02/10/2024 07:01	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4976835	02/10/2024 07:01	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4976835	02/10/2024 07:01	Odour	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4976835	02/10/2024 07:01	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4976835	02/10/2024 07:01	Taste	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4976835	02/10/2024 07:01	Taste - Nature		No taste		

W1301POUT	Moyola PPP Final Water Outlet	4976979	03/10/2024 12:13	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4976979	03/10/2024 12:13	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4976979	03/10/2024 12:13	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4976979	03/10/2024 12:13	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4976979	03/10/2024 12:13	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4976979	03/10/2024 12:13	Free - Residual disinfectant	mg Cl/l		1.39	
W1301POUT	Moyola PPP Final Water Outlet	4976979	03/10/2024 12:13	Hydrogen Ion	pH value		7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4976979	03/10/2024 12:13	Total - Residual disinfectant	mg Cl/l		1.49	
W1301POUT	Moyola PPP Final Water Outlet	4976979	03/10/2024 12:13	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4976979	03/10/2024 12:13	Turbidity	NTU		0.093	1
W1301POUT	Moyola PPP Final Water Outlet	4976979	03/10/2024 12:13	Odour	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4976979	03/10/2024 12:13	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4976979	03/10/2024 12:13	Taste	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4976979	03/10/2024 12:13	Taste - Nature		No taste		
W1301POUT	Moyola PPP Final Water Outlet	4977116	04/10/2024 11:19	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4977116	04/10/2024 11:19	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4977116	04/10/2024 11:19	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4977116	04/10/2024 11:19	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4977116	04/10/2024 11:19	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4977116	04/10/2024 11:19	Free - Residual disinfectant	mg Cl/l		1.46	
W1301POUT	Moyola PPP Final Water Outlet	4977116	04/10/2024 11:19	Hydrogen Ion	pH value		7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4977116	04/10/2024 11:19	Total - Residual disinfectant	mg Cl/l		1.58	
W1301POUT	Moyola PPP Final Water Outlet	4977116	04/10/2024 11:19	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4977116	04/10/2024 11:19	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4977180	05/10/2024 08:30	Colony Counts 22	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4977180	05/10/2024 08:30	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4977180	05/10/2024 08:30	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4977180	05/10/2024 08:30	Conductivity	uS/cm 20 C		370	2500
W1301POUT	Moyola PPP Final Water Outlet	4977180	05/10/2024 08:30	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4977180	05/10/2024 08:30	Free - Residual disinfectant	mg Cl/l		1.56	
W1301POUT	Moyola PPP Final Water Outlet	4977180	05/10/2024 08:30	Hydrogen Ion	pH value		7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4977180	05/10/2024 08:30	Total - Residual disinfectant	mg Cl/l		1.74	
W1301POUT	Moyola PPP Final Water Outlet	4977180	05/10/2024 08:30	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4977180	05/10/2024 08:30	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4977180	05/10/2024 08:30	Odour	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4977180	05/10/2024 08:30	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4977180	05/10/2024 08:30	Taste	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4977180	05/10/2024 08:30	Taste - Nature		No taste		
W1301POUT	Moyola PPP Final Water Outlet	4977213	06/10/2024 10:14	Colony Counts 22	CFU/1 ml		0	

W1301POUT	Moyola PPP Final Water Outlet	4977213	06/10/2024 10:14	Colony Counts 37 (48hrs)	CFU/1 ml		0	
W1301POUT	Moyola PPP Final Water Outlet	4977213	06/10/2024 10:14	Colour	mg/l Pt/Co	<4.56		20
W1301POUT	Moyola PPP Final Water Outlet	4977213	06/10/2024 10:14	Conductivity	uS/cm 20 C		360	2500
W1301POUT	Moyola PPP Final Water Outlet	4977213	06/10/2024 10:14	E. coli	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4977213	06/10/2024 10:14	Free - Residual disinfectant	mg Cl/l		1.47	
W1301POUT	Moyola PPP Final Water Outlet	4977213	06/10/2024 10:14	Hydrogen Ion	pH value		7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4977213	06/10/2024 10:14	Total - Residual disinfectant	mg Cl/l		1.68	
W1301POUT	Moyola PPP Final Water Outlet	4977213	06/10/2024 10:14	Total Coliforms	CFU/100 ml		0	0
W1301POUT	Moyola PPP Final Water Outlet	4977213	06/10/2024 10:14	Turbidity	NTU	<0.09		1
W1301POUT	Moyola PPP Final Water Outlet	4977213	06/10/2024 10:14	Odour	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4977213	06/10/2024 10:14	Odour - Nature		No odour		
W1301POUT	Moyola PPP Final Water Outlet	4977213	06/10/2024 10:14	Taste	Diln No		0	0
W1301POUT	Moyola PPP Final Water Outlet	4977213	06/10/2024 10:14	Taste - Nature		No taste		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4952847	07/08/2024 08:12	Colony Counts 22	CFU/1 ml		0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4952847	07/08/2024 08:12	Colony Counts 37 (48hrs)	CFU/1 ml		0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4952847	07/08/2024 08:12	E. coli	CFU/100 ml		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4952847	07/08/2024 08:12	Free - Residual disinfectant	mg Cl/l		0.47	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4952847	07/08/2024 08:12	Total - Residual disinfectant	mg Cl/l		0.58	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4952847	07/08/2024 08:12	Total Coliforms	CFU/100 ml		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4952847	07/08/2024 08:12	Odour	Diln No		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4952847	07/08/2024 08:12	Odour - Nature		No odour		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4952847	07/08/2024 08:12	Taste	Diln No		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4952847	07/08/2024 08:12	Taste - Nature		No taste		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4955767	15/08/2024 08:25	Colony Counts 22	CFU/1 ml		0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4955767	15/08/2024 08:25	Colony Counts 37 (48hrs)	CFU/1 ml		0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4955767	15/08/2024 08:25	E. coli	CFU/100 ml		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4955767	15/08/2024 08:25	Free - Residual disinfectant	mg Cl/l		0.74	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4955767	15/08/2024 08:25	Total - Residual disinfectant	mg Cl/l		1.02	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4955767	15/08/2024 08:25	Total Coliforms	CFU/100 ml		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4955767	15/08/2024 08:25	Odour	Diln No		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4955767	15/08/2024 08:25	Odour - Nature		No odour		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4955767	15/08/2024 08:25	Taste	Diln No		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4955767	15/08/2024 08:25	Taste - Nature		No taste		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4958967	23/08/2024 08:35	Colony Counts 22	CFU/1 ml		0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4958967	23/08/2024 08:35	Colony Counts 37 (48hrs)	CFU/1 ml		0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4958967	23/08/2024 08:35	E. coli	CFU/100 ml		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4958967	23/08/2024 08:35	Free - Residual disinfectant	mg Cl/l		0.9	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4958967	23/08/2024 08:35	Total - Residual disinfectant	mg Cl/l		1.05	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4958967	23/08/2024 08:35	Total Coliforms	CFU/100 ml		0	0

V1357OUT	Mullaghboy Magherafelt SR Outlet	4961110	27/08/2024 07:59	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4961110	27/08/2024 07:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4961110	27/08/2024 07:59	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4961110	27/08/2024 07:59	Free - Residual disinfectant	mg Cl/l	0.73	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4961110	27/08/2024 07:59	Total - Residual disinfectant	mg Cl/l	0.85	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4961110	27/08/2024 07:59	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4961110	27/08/2024 07:59	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4961110	27/08/2024 07:59	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4961110	27/08/2024 07:59	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4961110	27/08/2024 07:59	Taste - Nature		No taste	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4964568	03/09/2024 07:49	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4964568	03/09/2024 07:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4964568	03/09/2024 07:49	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4964568	03/09/2024 07:49	Free - Residual disinfectant	mg Cl/l	0.87	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4964568	03/09/2024 07:49	Total - Residual disinfectant	mg Cl/l	0.95	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4964568	03/09/2024 07:49	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4964568	03/09/2024 07:49	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4964568	03/09/2024 07:49	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4964568	03/09/2024 07:49	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4964568	03/09/2024 07:49	Taste - Nature		No taste	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979077	09/09/2024 14:30	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979077	09/09/2024 14:30	Free - Residual disinfectant	mg Cl/l	0.71	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979077	09/09/2024 14:30	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979077	09/09/2024 14:30	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979077	09/09/2024 14:30	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979077	09/09/2024 14:30	Taste - Nature		No taste	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979077	09/09/2024 14:30	Total - Residual disinfectant	mg Cl/l	0.83	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979077	09/09/2024 14:30	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4967962	11/09/2024 08:08	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4967962	11/09/2024 08:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4967962	11/09/2024 08:08	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4967962	11/09/2024 08:08	Free - Residual disinfectant	mg Cl/l	0.75	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4967962	11/09/2024 08:08	Total - Residual disinfectant	mg Cl/l	0.91	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4967962	11/09/2024 08:08	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4967962	11/09/2024 08:08	Odour	Diln No	6	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4967962	11/09/2024 08:08	Odour - Nature		Earthy	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4967962	11/09/2024 08:08	Taste	Diln No	6	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4967962	11/09/2024 08:08	Taste - Nature		Earthy	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979986	13/09/2024 07:14	Colony Counts 22	CFU/1 ml	0	

V1357OUT	Mullaghboy Magherafelt SR Outlet	4979986	13/09/2024 07:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979986	13/09/2024 07:14	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979986	13/09/2024 07:14	Free - Residual disinfectant	mg Cl/l	0.42	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979986	13/09/2024 07:14	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979986	13/09/2024 07:14	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979986	13/09/2024 07:14	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979986	13/09/2024 07:14	Taste - Nature		No taste	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979986	13/09/2024 07:14	Total - Residual disinfectant	mg Cl/l	1.02	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979986	13/09/2024 07:14	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4980494	15/09/2024 08:40	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4980494	15/09/2024 08:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4980494	15/09/2024 08:40	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4980494	15/09/2024 08:40	Free - Residual disinfectant	mg Cl/l	0.95	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4980494	15/09/2024 08:40	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4980494	15/09/2024 08:40	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4980494	15/09/2024 08:40	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4980494	15/09/2024 08:40	Taste - Nature		No taste	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4980494	15/09/2024 08:40	Total - Residual disinfectant	mg Cl/l	1.03	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4980494	15/09/2024 08:40	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4971441	17/09/2024 07:36	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4971441	17/09/2024 07:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4971441	17/09/2024 07:36	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4971441	17/09/2024 07:36	Free - Residual disinfectant	mg Cl/l	0.5	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4971441	17/09/2024 07:36	Total - Residual disinfectant	mg Cl/l	0.63	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4971441	17/09/2024 07:36	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4971441	17/09/2024 07:36	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4971441	17/09/2024 07:36	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4971441	17/09/2024 07:36	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4971441	17/09/2024 07:36	Taste - Nature		No taste	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4982037	19/09/2024 08:15	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4982037	19/09/2024 08:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4982037	19/09/2024 08:15	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4982037	19/09/2024 08:15	Free - Residual disinfectant	mg Cl/l	0.85	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4982037	19/09/2024 08:15	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4982037	19/09/2024 08:15	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4982037	19/09/2024 08:15	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4982037	19/09/2024 08:15	Taste - Nature		No taste	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4982037	19/09/2024 08:15	Total - Residual disinfectant	mg Cl/l	1.08	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4982037	19/09/2024 08:15	Total Coliforms	CFU/100 ml	0	0

V1357OUT	Mullaghboy Magherafelt SR Outlet	4983873	21/09/2024 08:49	Colony Counts 22	CFU/1 ml		1	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983873	21/09/2024 08:49	Colony Counts 37 (48hrs)	CFU/1 ml		0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983873	21/09/2024 08:49	E. coli	CFU/100 ml		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983873	21/09/2024 08:49	Free - Residual disinfectant	mg Cl/l		0.86	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983873	21/09/2024 08:49	Odour	Diln No		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983873	21/09/2024 08:49	Odour - Nature		No odour		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983873	21/09/2024 08:49	Taste	Diln No		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983873	21/09/2024 08:49	Taste - Nature		No taste		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983873	21/09/2024 08:49	Total - Residual disinfectant	mg Cl/l		1.07	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983873	21/09/2024 08:49	Total Coliforms	CFU/100 ml		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983882	23/09/2024 08:12	Colony Counts 22	CFU/1 ml		0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983882	23/09/2024 08:12	Colony Counts 37 (48hrs)	CFU/1 ml		0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983882	23/09/2024 08:12	E. coli	CFU/100 ml		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983882	23/09/2024 08:12	Free - Residual disinfectant	mg Cl/l		0.8	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983882	23/09/2024 08:12	Odour	Diln No		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983882	23/09/2024 08:12	Odour - Nature		No odour		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983882	23/09/2024 08:12	Taste	Diln No		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983882	23/09/2024 08:12	Taste - Nature		No taste		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983882	23/09/2024 08:12	Total - Residual disinfectant	mg Cl/l		1.15	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983882	23/09/2024 08:12	Total Coliforms	CFU/100 ml		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983886	25/09/2024 07:59	Colony Counts 22	CFU/1 ml		0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983886	25/09/2024 07:59	Colony Counts 37 (48hrs)	CFU/1 ml		0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983886	25/09/2024 07:59	E. coli	CFU/100 ml		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983886	25/09/2024 07:59	Free - Residual disinfectant	mg Cl/l		1.07	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983886	25/09/2024 07:59	Odour	Diln No		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983886	25/09/2024 07:59	Odour - Nature		No odour		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983886	25/09/2024 07:59	Taste	Diln No		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983886	25/09/2024 07:59	Taste - Nature		No taste		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983886	25/09/2024 07:59	Total - Residual disinfectant	mg Cl/l		1.35	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983886	25/09/2024 07:59	Total Coliforms	CFU/100 ml		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4974183	27/09/2024 10:58	Colony Counts 22	CFU/1 ml		0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4974183	27/09/2024 10:58	Colony Counts 37 (48hrs)	CFU/1 ml		0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4974183	27/09/2024 10:58	E. coli	CFU/100 ml		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4974183	27/09/2024 10:58	Free - Residual disinfectant	mg Cl/l		0.9	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4974183	27/09/2024 10:58	Total - Residual disinfectant	mg Cl/l		1.04	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4974183	27/09/2024 10:58	Total Coliforms	CFU/100 ml		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4974183	27/09/2024 10:58	Odour	Diln No		0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4974183	27/09/2024 10:58	Odour - Nature		No odour		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4974183	27/09/2024 10:58	Taste	Diln No		0	0



V1357OUT	Mullaghboy Magherafelt SR Outlet	4974183	27/09/2024 10:58	Taste - Nature		No taste		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985301	29/09/2024 10:24	Colony Counts 22	CFU/1 ml	0		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985301	29/09/2024 10:24	Colony Counts 37 (48hrs)	CFU/1 ml	0		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985301	29/09/2024 10:24	E. coli	CFU/100 ml	0		0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985301	29/09/2024 10:24	Free - Residual disinfectant	mg Cl/l	0.8		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985301	29/09/2024 10:24	Odour	Diln No	0		0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985301	29/09/2024 10:24	Odour - Nature		No odour		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985301	29/09/2024 10:24	Taste	Diln No	0		0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985301	29/09/2024 10:24	Taste - Nature		No taste		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985301	29/09/2024 10:24	Total - Residual disinfectant	mg Cl/l	0.97		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985301	29/09/2024 10:24	Total Coliforms	CFU/100 ml	0		0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4976378	01/10/2024 10:49	Colony Counts 22	CFU/1 ml	0		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4976378	01/10/2024 10:49	Colony Counts 37 (48hrs)	CFU/1 ml	0		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4976378	01/10/2024 10:49	E. coli	CFU/100 ml	0		0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4976378	01/10/2024 10:49	Free - Residual disinfectant	mg Cl/l	0.94		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4976378	01/10/2024 10:49	Total - Residual disinfectant	mg Cl/l	1.05		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4976378	01/10/2024 10:49	Total Coliforms	CFU/100 ml	0		0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4976378	01/10/2024 10:49	Odour	Diln No	0		0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4976378	01/10/2024 10:49	Odour - Nature		No odour		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4976378	01/10/2024 10:49	Taste	Diln No	0		0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4976378	01/10/2024 10:49	Taste - Nature		No taste		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985310	03/10/2024 11:07	Colony Counts 22	CFU/1 ml	0		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985310	03/10/2024 11:07	Colony Counts 37 (48hrs)	CFU/1 ml	0		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985310	03/10/2024 11:07	E. coli	CFU/100 ml	0		0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985310	03/10/2024 11:07	Free - Residual disinfectant	mg Cl/l	0.94		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985310	03/10/2024 11:07	Odour	Diln No	0		0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985310	03/10/2024 11:07	Odour - Nature		No odour		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985310	03/10/2024 11:07	Taste	Diln No	0		0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985310	03/10/2024 11:07	Taste - Nature		No taste		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985310	03/10/2024 11:07	Total - Residual disinfectant	mg Cl/l	1.08		
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985310	03/10/2024 11:07	Total Coliforms	CFU/100 ml	0		0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	1,2 Dichloroethane	ug/l	<0.4		3
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	Antimony	ug/l Sb	0.13		5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	Arsenic	ug/l As	0.26		10
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	Benzene	ug/l	<0.15		1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	Boron	mg/l B	<0.0586		1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	Bromodichloromethane	ug/l	15		
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	Bromoform	ug/l	<3.5		
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	Cadmium	ug/l Cd	<0.042		5

ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	Chloroform	ug/l		38	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	Chromium	ug/l Cr	<0.260		50
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	Dibromochloromethane	ug/l		4.5	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	E. coli	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	Free - Residual disinfectant	mg Cl/l		0.56	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	Selenium	ug/l Se		0.085	10
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	Tetrachloroethene	ug/l	<0.8		
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	Tetrachloroethene/Trichloroethene - St	ug/l	<0.8		10
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	Tetrachloromethane	ug/l	<0.4		3
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	Total - Residual disinfectant	mg Cl/l		0.69	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	Total Coliforms	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	Total Organic Carbon	mg C/l		2.9	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	Total Trihalomethanes	ug/l		58	100
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	Trichloroethene	ug/l	<0.7		
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955329	13/08/2024 11:36	WHO Index			0.43	1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976601	03/10/2024 11:45	E. coli	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976601	03/10/2024 11:45	Free - Residual disinfectant	mg Cl/l		0.88	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976601	03/10/2024 11:45	Odour	Diln No		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976601	03/10/2024 11:45	Odour - Nature		No odour		
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976601	03/10/2024 11:45	Taste	Diln No		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976601	03/10/2024 11:45	Taste - Nature		No taste		
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976601	03/10/2024 11:45	Total - Residual disinfectant	mg Cl/l		1.03	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976601	03/10/2024 11:45	Total Coliforms	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	1,2 Dichloroethane	ug/l	<0.4		3
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Ammonium	mg NH4/l	<0.01		0.5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Antimony	ug/l Sb		0.17	5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Arsenic	ug/l As		0.27	10
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Benzene	ug/l	<0.15		1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Benzo(a)pyrene	ug/l	<0.0021		0.01
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Benzo(b)fluoranthene	ug/l	<0.0046		0.1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Benzo(ghi)perylene	ug/l	<0.0022		0.1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Benzo(k)fluoranthene	ug/l	<0.0040		0.1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Boron	mg/l B	<0.0586		1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Bromate	ug BrO3/l	<0.50		10
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Bromodichloromethane	ug/l		13	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Bromoform	ug/l	<3.5		
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Cadmium	ug/l Cd	<0.042		5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Calcium	mg/l		56	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Chloroform	ug/l		33	

ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Chromium	ug/l Cr	<0.260		50
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Copper	mg Cu/l	<0.546		2
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Dibromochloromethane	ug/l		5.7	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Enterococci	CFU/100ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021		0.1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Lead	ug Pb/l	<0.095		10
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Magnesium	mg/l		8.8	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Mercury	ug per l	<0.041		1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Nickel	ug Ni/l		2.7	20
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	PAH - Sum of four substances	ug/l		0	0.1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Potassium	mg/l		3.6	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Selenium	ug/l Se		0.062	10
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Sodium	mg Na/l		13	200
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Tetrachloroethene	ug/l	<0.8		
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8		10
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Tetrachloromethane	ug/l	<0.4		3
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Total hardness	mg/l		71	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Total Organic Carbon	mg C/l		2.3	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Total Trihalomethanes	ug/l		52	100
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	Trichloroethene	ug/l	<0.7		
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4971114	17/09/2024 11:36	WHO Index			0.39	1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4961542	29/08/2024 10:56	E. coli	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4961542	29/08/2024 10:56	Free - Residual disinfectant	mg Cl/l		0.74	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4961542	29/08/2024 10:56	Total - Residual disinfectant	mg Cl/l		0.86	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4961542	29/08/2024 10:56	Total Coliforms	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4952656	07/08/2024 10:31	E. coli	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4952656	07/08/2024 10:31	Free - Residual disinfectant	mg Cl/l		0.52	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4952656	07/08/2024 10:31	Total - Residual disinfectant	mg Cl/l		0.7	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4952656	07/08/2024 10:31	Total Coliforms	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958126	19/08/2024 11:42	Aluminium	ug Al/l		34	200
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958126	19/08/2024 11:42	Colony Counts 22	CFU/1 ml		0	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958126	19/08/2024 11:42	Colony Counts 37 (48hrs)	CFU/1 ml		0	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958126	19/08/2024 11:42	Colour	mg/l Pt/Co	<4.56		20
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958126	19/08/2024 11:42	Conductivity	uS/cm 20 C		370	2500
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958126	19/08/2024 11:42	E. coli	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958126	19/08/2024 11:42	Free - Residual disinfectant	mg Cl/l		0.52	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958126	19/08/2024 11:42	Hydrogen Ion	pH value		7.7	9.5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958126	19/08/2024 11:42	Iron	ug/l Fe	<1.538		200
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958126	19/08/2024 11:42	Manganese	ug Mn/l	<0.80		50

ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958126	19/08/2024 11:42	Odour	Diln No	0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958126	19/08/2024 11:42	Odour - Nature		No odour	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958126	19/08/2024 11:42	Taste	Diln No	0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958126	19/08/2024 11:42	Taste - Nature		No taste	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958126	19/08/2024 11:42	Total - Residual disinfectant	mg Cl/l	0.76	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958126	19/08/2024 11:42	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958126	19/08/2024 11:42	Turbidity	NTU	<0.09	4
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4952302	06/08/2024 11:01	Aluminium	ug Al/l	33	200
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4952302	06/08/2024 11:01	Colony Counts 22	CFU/1 ml	0	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4952302	06/08/2024 11:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4952302	06/08/2024 11:01	Colour	mg/l Pt/Co	<4.56	20
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4952302	06/08/2024 11:01	Conductivity	uS/cm 20 C	370	2500
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4952302	06/08/2024 11:01	E. coli	CFU/100 ml	0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4952302	06/08/2024 11:01	Free - Residual disinfectant	mg Cl/l	0.08	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4952302	06/08/2024 11:01	Hydrogen Ion	pH value	7.8	9.5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4952302	06/08/2024 11:01	Iron	ug/l Fe	<1.538	200
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4952302	06/08/2024 11:01	Manganese	ug Mn/l	<0.642	50
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4952302	06/08/2024 11:01	Odour	Diln No	0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4952302	06/08/2024 11:01	Odour - Nature		No odour	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4952302	06/08/2024 11:01	Taste	Diln No	0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4952302	06/08/2024 11:01	Taste - Nature		No taste	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4952302	06/08/2024 11:01	Total - Residual disinfectant	mg Cl/l	0.33	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4952302	06/08/2024 11:01	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4952302	06/08/2024 11:01	Turbidity	NTU	<0.09	4
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4961259	28/08/2024 10:30	Aluminium	ug Al/l	26	200
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4961259	28/08/2024 10:30	Colony Counts 22	CFU/1 ml	0	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4961259	28/08/2024 10:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4961259	28/08/2024 10:30	Colour	mg/l Pt/Co	<4.56	20
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4961259	28/08/2024 10:30	Conductivity	uS/cm 20 C	370	2500
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4961259	28/08/2024 10:30	E. coli	CFU/100 ml	0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4961259	28/08/2024 10:30	Free - Residual disinfectant	mg Cl/l	<0.05	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4961259	28/08/2024 10:30	Hydrogen Ion	pH value	7.6	9.5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4961259	28/08/2024 10:30	Iron	ug/l Fe	3.6	200
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4961259	28/08/2024 10:30	Manganese	ug Mn/l	<0.80	50
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4961259	28/08/2024 10:30	Odour	Diln No	0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4961259	28/08/2024 10:30	Odour - Nature		No odour	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4961259	28/08/2024 10:30	Taste	Diln No	0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4961259	28/08/2024 10:30	Taste - Nature		No taste	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4961259	28/08/2024 10:30	Total - Residual disinfectant	mg Cl/l	0.24	

ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4961259	28/08/2024 10:30	Total Coliforms	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4961259	28/08/2024 10:30	Turbidity	NTU	<0.09		4
ZN0501CUST	(MOYOLA MAGHERAFELT) Customer Tap	4980216	11/09/2024 11:39	Free - Residual disinfectant	mg Cl/l		0.26	
ZN0501CUST	(MOYOLA MAGHERAFELT) Customer Tap	4980216	11/09/2024 11:39	Total - Residual disinfectant	mg Cl/l		0.39	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973656	24/09/2024 09:15	Colour	mg/l Pt/Co	<4.56		20
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973656	24/09/2024 09:15	Conductivity	uS/cm 20 C		370	2500
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973656	24/09/2024 09:15	E. coli	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973656	24/09/2024 09:15	Free - Residual disinfectant	mg Cl/l		0.54	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973656	24/09/2024 09:15	Hydrogen Ion	pH value		7.6	9.5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973656	24/09/2024 09:15	Odour	Diln No		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973656	24/09/2024 09:15	Odour - Nature		No odour		
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973656	24/09/2024 09:15	Taste	Diln No		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973656	24/09/2024 09:15	Taste - Nature		No taste		
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973656	24/09/2024 09:15	Total - Residual disinfectant	mg Cl/l		0.71	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973656	24/09/2024 09:15	Total Coliforms	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973656	24/09/2024 09:15	Turbidity	NTU		0.18	4
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4949586	02/08/2024 09:51	E. coli	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4949586	02/08/2024 09:51	Free - Residual disinfectant	mg Cl/l		0.49	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4949586	02/08/2024 09:51	Total - Residual disinfectant	mg Cl/l		0.59	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4949586	02/08/2024 09:51	Total Coliforms	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	1,2 Dichloroethane	ug/l	<0.4		3
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Ammonium	mg NH4/l	<0.01		0.5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Antimony	ug/l Sb		0.16	5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Arsenic	ug/l As		0.29	10
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Benzene	ug/l	<0.15		1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Boron	mg/l B	<0.0586		1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Bromodichloromethane	ug/l		13	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Bromoform	ug/l	<3.5		
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Cadmium	ug/l Cd	<0.042		5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Calcium	mg/l		55	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Chloride	mg Cl/l		21	250
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Chloroform	ug/l		34	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Chromium	ug/l Cr		0.62	50
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Copper	mg Cu/l	<0.546		2
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Dibromochloromethane	ug/l		6.3	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	E. coli	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Enterococci	CFU/100ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Fluoride	mg F/l	<0.150		1.5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Free - Residual disinfectant	mg Cl/l		0.05	

ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Lead	ug Pb/l	<0.095		10
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Magnesium	mg/l		9.1	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Mercury	ug per l	<0.041		1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Nickel	ug Ni/l		1.3	20
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Nitrate	mg/l		3.1	50
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Nitrate/Nitrite Formula	mg/l	<0.062		1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Nitrite	mg/l	<0.03		0.5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Odour	Diln No		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Odour - Nature		No odour		
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Potassium	mg/l		3.8	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Selenium	ug/l Se		0.08	10
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Sodium	mg Na/l		14	200
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Sulphate	mg SO4/l		78	250
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Taste	Diln No		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Taste - Nature		No taste		
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Tetrachloroethene	ug/l	<0.8		
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Tetrachloroethene/Trichloroethene - Su	ug/l	<0.8		10
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Tetrachloromethane	ug/l	<0.4		3
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Total - Residual disinfectant	mg Cl/l		0.26	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Total Coliforms	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Total hardness	mg/l		70	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Total Trihalomethanes	ug/l		54	100
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	Trichloroethene	ug/l	<0.7		
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4973327	23/09/2024 12:43	WHO Index			0.4	1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4967754	16/09/2024 11:31	E. coli	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4967754	16/09/2024 11:31	Free - Residual disinfectant	mg Cl/l		0.15	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4967754	16/09/2024 11:31	Total - Residual disinfectant	mg Cl/l		0.27	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4967754	16/09/2024 11:31	Total Coliforms	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4964127	02/09/2024 09:47	E. coli	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4964127	02/09/2024 09:47	Free - Residual disinfectant	mg Cl/l		0.18	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4964127	02/09/2024 09:47	Total - Residual disinfectant	mg Cl/l		0.29	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4964127	02/09/2024 09:47	Total Coliforms	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4964596	03/09/2024 10:55	E. coli	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4964596	03/09/2024 10:55	Free - Residual disinfectant	mg Cl/l		0.6	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4964596	03/09/2024 10:55	Total - Residual disinfectant	mg Cl/l		0.88	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4964596	03/09/2024 10:55	Total Coliforms	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958412	20/08/2024 10:15	Antimony	ug/l Sb		0.16	5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958412	20/08/2024 10:15	Arsenic	ug/l As		0.26	10
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958412	20/08/2024 10:15	Boron	mg/l B	<0.0586		1

ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958412	20/08/2024 10:15	Cadmium	ug/l Cd	<0.042	5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958412	20/08/2024 10:15	Chromium	ug/l Cr	0.33	50
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958412	20/08/2024 10:15	E. coli	CFU/100 ml	0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958412	20/08/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.1	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958412	20/08/2024 10:15	Selenium	ug/l Se	0.064	10
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958412	20/08/2024 10:15	Total - Residual disinfectant	mg Cl/l	0.14	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4958412	20/08/2024 10:15	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4970777	18/09/2024 09:27	Aluminium	ug Al/l	28	200
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4970777	18/09/2024 09:27	Colony Counts 22	CFU/1 ml	0	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4970777	18/09/2024 09:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4970777	18/09/2024 09:27	Colour	mg/l Pt/Co	<4.56	20
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4970777	18/09/2024 09:27	Conductivity	uS/cm 20 C	390	2500
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4970777	18/09/2024 09:27	E. coli	CFU/100 ml	0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4970777	18/09/2024 09:27	Free - Residual disinfectant	mg Cl/l	0.77	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4970777	18/09/2024 09:27	Hydrogen Ion	pH value	7.6	9.5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4970777	18/09/2024 09:27	Iron	ug/l Fe	<1.538	200
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4970777	18/09/2024 09:27	Manganese	ug Mn/l	<0.80	50
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4970777	18/09/2024 09:27	Odour	Diln No	0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4970777	18/09/2024 09:27	Odour - Nature		No odour	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4970777	18/09/2024 09:27	Taste	Diln No	0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4970777	18/09/2024 09:27	Taste - Nature		No taste	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4970777	18/09/2024 09:27	Total - Residual disinfectant	mg Cl/l	1	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4970777	18/09/2024 09:27	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4970777	18/09/2024 09:27	Turbidity	NTU	0.12	4
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	Aluminium	ug Al/l	26	200
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	Chloride	mg Cl/l	21	250
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	Colony Counts 22	CFU/1 ml	0	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	Colour	mg/l Pt/Co	<4.56	20
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	Conductivity	uS/cm 20 C	380	2500
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	E. coli	CFU/100 ml	0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	Fluoride	mg F/l	<0.150	1.5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	Free - Residual disinfectant	mg Cl/l	0.87	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	Hydrogen Ion	pH value	7.3	9.5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	Iron	ug/l Fe	<1.538	200
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	Manganese	ug Mn/l	<0.80	50
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	Nitrate	mg/l	3.4	50
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	Nitrate/Nitrite Formula	mg/l	<0.068	1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	Nitrite	mg/l	<0.03	0.5

ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	Odour	Diln No	0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	Odour - Nature		No odour	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	Sulphate	mg SO4/l	76	250
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	Taste	Diln No	0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	Taste - Nature		No taste	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	Total - Residual disinfectant	mg Cl/l	1.02	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4976411	01/10/2024 11:24	Turbidity	NTU	<0.09	4
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	1,2 Dichloroethane	ug/l	<0.4	3
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Ammonium	mg NH4/l	<0.01	0.5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Antimony	ug/l Sb	0.13	5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Arsenic	ug/l As	0.26	10
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Benzene	ug/l	<0.15	1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Boron	mg/l B	<0.0586	1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Bromodichloromethane	ug/l	16	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Bromoform	ug/l	<3.5	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Cadmium	ug/l Cd	<0.042	5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Calcium	mg/l	52	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Chloride	mg Cl/l	21	250
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Chloroform	ug/l	39	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Chromium	ug/l Cr	<0.260	50
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Copper	mg Cu/l	<0.546	2
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Dibromochloromethane	ug/l	4.5	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	E. coli	CFU/100 ml	0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Enterococci	CFU/100ml	0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Fluoride	mg F/l	<0.150	1.5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Free - Residual disinfectant	mg Cl/l	0.62	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Lead	ug Pb/l	<0.095	10
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Magnesium	mg/l	8.4	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Mercury	ug per l	<0.041	1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Nickel	ug Ni/l	1.4	20
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Nitrate	mg/l	3.2	50
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Nitrate/Nitrite Formula	mg/l	<0.064	1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Nitrite	mg/l	<0.03	0.5
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Potassium	mg/l	3.7	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Selenium	ug/l Se	0.089	10
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Sodium	mg Na/l	14	200
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Sulphate	mg SO4/l	81	250
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Tetrachloroethene	ug/l	<0.8	



ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Tetrachloroethene/Trichloroethene - St	ug/l	<0.8		10
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Tetrachloromethane	ug/l	<0.4		3
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Total - Residual disinfectant	mg Cl/l		0.89	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Total Coliforms	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Total hardness	mg/l		66	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Total Organic Carbon	mg C/l		2.8	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Total Trihalomethanes	ug/l		60	100
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	Trichloroethene	ug/l	<0.7		
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4955020	12/08/2024 10:21	WHO Index			0.45	1
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4967411	11/09/2024 11:39	Aluminium	ug Al/l		25	200
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4967411	11/09/2024 11:39	Colony Counts 22	CFU/1 ml		0	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4967411	11/09/2024 11:39	Colony Counts 37 (48hrs)	CFU/1 ml		0	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4967411	11/09/2024 11:39	E. coli	CFU/100 ml		0	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4967411	11/09/2024 11:39	Free - Residual disinfectant	mg Cl/l		0.07	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4967411	11/09/2024 11:39	Iron	ug/l Fe		3.4	200
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4967411	11/09/2024 11:39	Manganese	ug Mn/l	<0.80		50
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4967411	11/09/2024 11:39	Odour	Diln No		3	0
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4967411	11/09/2024 11:39	Odour - Nature		Musty/Earthy		
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4967411	11/09/2024 11:39	Total - Residual disinfectant	mg Cl/l		0.21	
ZN0501AE	(MOYOLA MAGHERAFELT) Customer Tap	4967411	11/09/2024 11:39	Total Coliforms	CFU/100 ml		0	0