

REFERENCE

2425340

RELEASE DATE

October 2024

SUBJECT

Lough Neagh water quality

REQUESTS & RESPONSES

Details of NI Water's testing methods and proof that NI Water's test samples from the last 4 weeks are in fact safe to consume under Article 295 of the Water and Sewerage Services (NI) Order 2006.

NI Water undertake sampling and analysis for drinking water quality monitoring as required under the Drinking Water Regulations [The Water Supply (Water Quality) Regulations (NI) 2017] with samples taken at the water treatment works, the Service Reservoirs and at customer taps. Samples are taken by trained and accredited samplers and samples are analysed in our laboratories by trained and competent analysts as required by the drinking water regulations. Analysis is undertaken as per drinking water industry methods of analysis, with results accredited under ISO17025 to the Drinking Water Testing Specification (DWTS), as required under the drinking water regulations.

Results for samples taken at the water treatment works and Service Reservoir supplying the Moira area along with samples taken at customer taps within the Moira water supply zone over the period of 1 August 2024 to 18 September 2024 are provided in Annex A. The results are satisfactory for all water quality parameters tested, with the exception of one final water sample on 12 September 2024 which was unsatisfactory for Taste & Odour with a descriptor of Earthy/Musty.

Sample Point	Location	Sample Id	Sample Date	Parameter	Units	Result	PCV Limit
W2308POUT	Castor Bay PPP Final Water Outlet	4949961	01/08/2024 09:56	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4949961	01/08/2024 09:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4949961	01/08/2024 09:56	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4949961	01/08/2024 09:56	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4949961	01/08/2024 09:56	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4949961	01/08/2024 09:56	Free - Residual disinfectant	mg Cl/l	1.53	
W2308POUT	Castor Bay PPP Final Water Outlet	4949961	01/08/2024 09:56	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4949961	01/08/2024 09:56	Total - Residual disinfectant	mg Cl/l	1.7	
W2308POUT	Castor Bay PPP Final Water Outlet	4949961	01/08/2024 09:56	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4949961	01/08/2024 09:56	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4950097	02/08/2024 08:07	Colony Counts 22	CFU/1 ml	1	
W2308POUT	Castor Bay PPP Final Water Outlet	4950097	02/08/2024 08:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4950097	02/08/2024 08:07	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4950097	02/08/2024 08:07	Conductivity	uS/cm 20 C	360	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4950097	02/08/2024 08:07	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4950097	02/08/2024 08:07	Free - Residual disinfectant	mg Cl/l	1.46	
W2308POUT	Castor Bay PPP Final Water Outlet	4950097	02/08/2024 08:07	Hydrogen Ion	pH value	7.7	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4950097	02/08/2024 08:07	Total - Residual disinfectant	mg Cl/l	1.63	
W2308POUT	Castor Bay PPP Final Water Outlet	4950097	02/08/2024 08:07	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4950097	02/08/2024 08:07	Turbidity	NTU	0.11	1
W2308POUT	Castor Bay PPP Final Water Outlet	4950181	03/08/2024 06:55	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4950181	03/08/2024 06:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4950181	03/08/2024 06:55	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4950181	03/08/2024 06:55	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4950181	03/08/2024 06:55	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4950181	03/08/2024 06:55	Free - Residual disinfectant	mg Cl/l	1.48	
W2308POUT	Castor Bay PPP Final Water Outlet	4950181	03/08/2024 06:55	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4950181	03/08/2024 06:55	Total - Residual disinfectant	mg Cl/l	1.6	
W2308POUT	Castor Bay PPP Final Water Outlet	4950181	03/08/2024 06:55	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4950181	03/08/2024 06:55	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4950205	04/08/2024 07:50	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4950205	04/08/2024 07:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4950205	04/08/2024 07:50	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4950205	04/08/2024 07:50	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4950205	04/08/2024 07:50	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4950205	04/08/2024 07:50	Free - Residual disinfectant	mg Cl/l	1.39	
W2308POUT	Castor Bay PPP Final Water Outlet	4950205	04/08/2024 07:50	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4950205	04/08/2024 07:50	Total - Residual disinfectant	mg Cl/l	1.57	
W2308POUT	Castor Bay PPP Final Water Outlet	4950205	04/08/2024 07:50	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4950205	04/08/2024 07:50	Turbidity	NTU	<0.09	1

W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Free - Residual disinfectant	mg Cl/l	1.66	
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Hydrogen Ion	pH value	7.8	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Total - Residual disinfectant	mg Cl/l	1.71	
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	2,4-D	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	2,4-DB	ug/l	<0.016	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Asulam	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Bentazone	ug/l	<0.0044	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Bromoxynil	ug/l	<0.0079	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Chlorotoluron	ug/l	<0.0031	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Chlorpyrifos	ug/l	<0.0070	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Clopyralid	ug/l	<0.0097	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Cyanide	ug/l CN	<5.5	50
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Diazinon	ug/l	<0.0074	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Dicamba	ug/l	<0.028	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Dichlorprop	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Diflufenican	ug/l	<0.0072	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Dimethenamid	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Diuron	ug/l	<0.0055	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Epoxiconazole	ug/l	<0.0049	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Fenpropimorph	ug/l	<0.0083	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Flufenacet	ug/l	<0.0052	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Fluroxypyr	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Free - Residual disinfectant	mg Cl/l	1.53	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Glyphosate	ug/l	<0.0077	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Hydrogen Ion	pH value	7.8	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Isoproturon	ug/l	<0.0025	0.1

W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Linuron	ug/l	<0.0034	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	MCPA	ug/l	0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	MCPB	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Mecoprop	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Metalaxyl	ug/l	<0.0097	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Metamitron	ug/l	<0.0074	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Metazachlor	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Metoxuron	ug/l	<0.0080	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Metribuzin	ug/l	<0.0060	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Oxamyl	ug/l	<0.0023	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Pendimethalin	ug/l	<0.0064	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Pesticides - Total Substances	ug/l	0.012	0.5
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Phorate	ug/l	<0.0092	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Pirimicarb	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Propachlor	ug/l	<0.0096	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Propiconazole	ug/l	<0.0029	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Propyzamide	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Prothioconazole	ug/l	<0.0019	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Tebuconazole	ug/l	<0.0039	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Total - Residual disinfectant	mg Cl/l	1.7	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Triclopyr	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Algae Diatom Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Algae Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Aluminium	ug Al/l	24	200
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Bromodichloromethane	ug/l	7.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Chloroform	ug/l	12	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Dibromochloromethane	ug/l	4.7	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Iron	ug/l Fe	<1.538	200
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Manganese	ug Mn/l	<0.80	50
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	MIB	ng/l	<1.9	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Microcystin-LR	ug/l	<0.024	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Taste - Nature		No taste	

W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Total Organic Carbon	mg C/l	2.7	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Total Trihalomethanes	ug/l	24	100
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	WHO Index		0.21	1
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Colony Counts 22	CFU/1 ml	1	
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Free - Residual disinfectant	mg Cl/l	1.66	
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Total - Residual disinfectant	mg Cl/l	1.78	
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4953040	08/08/2024 10:04	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4953040	08/08/2024 10:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4953040	08/08/2024 10:04	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4953040	08/08/2024 10:04	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4953040	08/08/2024 10:04	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4953040	08/08/2024 10:04	Free - Residual disinfectant	mg Cl/l	1.52	
W2308POUT	Castor Bay PPP Final Water Outlet	4953040	08/08/2024 10:04	Hydrogen Ion	pH value	7.7	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4953040	08/08/2024 10:04	Total - Residual disinfectant	mg Cl/l	1.62	
W2308POUT	Castor Bay PPP Final Water Outlet	4953040	08/08/2024 10:04	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4953040	08/08/2024 10:04	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4953167	09/08/2024 09:53	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4953167	09/08/2024 09:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4953167	09/08/2024 09:53	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4953167	09/08/2024 09:53	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4953167	09/08/2024 09:53	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4953167	09/08/2024 09:53	Free - Residual disinfectant	mg Cl/l	1.37	
W2308POUT	Castor Bay PPP Final Water Outlet	4953167	09/08/2024 09:53	Hydrogen Ion	pH value	7.7	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4953167	09/08/2024 09:53	Total - Residual disinfectant	mg Cl/l	1.46	
W2308POUT	Castor Bay PPP Final Water Outlet	4953167	09/08/2024 09:53	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4953167	09/08/2024 09:53	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4953237	10/08/2024 09:59	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4953237	10/08/2024 09:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4953237	10/08/2024 09:59	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4953237	10/08/2024 09:59	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4953237	10/08/2024 09:59	E. coli	CFU/100 ml	0	0

W2308POUT	Castor Bay PPP Final Water Outlet	4953237	10/08/2024 09:59	Free - Residual disinfectant	mg Cl/l	1.44	
W2308POUT	Castor Bay PPP Final Water Outlet	4953237	10/08/2024 09:59	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4953237	10/08/2024 09:59	Total - Residual disinfectant	mg Cl/l	1.54	
W2308POUT	Castor Bay PPP Final Water Outlet	4953237	10/08/2024 09:59	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4953237	10/08/2024 09:59	Turbidity	NTU	0.12	1
W2308POUT	Castor Bay PPP Final Water Outlet	4953255	11/08/2024 10:47	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4953255	11/08/2024 10:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4953255	11/08/2024 10:47	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4953255	11/08/2024 10:47	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4953255	11/08/2024 10:47	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4953255	11/08/2024 10:47	Free - Residual disinfectant	mg Cl/l	1.65	
W2308POUT	Castor Bay PPP Final Water Outlet	4953255	11/08/2024 10:47	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4953255	11/08/2024 10:47	Total - Residual disinfectant	mg Cl/l	1.78	
W2308POUT	Castor Bay PPP Final Water Outlet	4953255	11/08/2024 10:47	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4953255	11/08/2024 10:47	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Free - Residual disinfectant	mg Cl/l	1.18	
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Total - Residual disinfectant	mg Cl/l	1.35	
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Free - Residual disinfectant	mg Cl/l	1.3	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Total - Residual disinfectant	mg Cl/l	1.47	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Algae Diatom Total	per ml	0	

W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Algae Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Aluminium	ug Al/l	36	200
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Bromodichloromethane	ug/l	7.4	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Chloroform	ug/l	13	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Dibromochloromethane	ug/l	3.7	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Iron	ug/l Fe	<1.538	200
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Manganese	ug Mn/l	<0.80	50
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	MIB	ng/l	<1.9	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Microcystin-LR	ug/l	<0.024	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Total Organic Carbon	mg C/l	3	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Total Trihalomethanes	ug/l	25	100
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	WHO Index		0.21	1
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Free - Residual disinfectant	mg Cl/l	1.4	
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Total - Residual disinfectant	mg Cl/l	1.63	
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4955791	15/08/2024 08:01	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955791	15/08/2024 08:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955791	15/08/2024 08:01	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4955791	15/08/2024 08:01	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4955791	15/08/2024 08:01	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955791	15/08/2024 08:01	Free - Residual disinfectant	mg Cl/l	1.26	
W2308POUT	Castor Bay PPP Final Water Outlet	4955791	15/08/2024 08:01	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4955791	15/08/2024 08:01	Total - Residual disinfectant	mg Cl/l	1.36	

W2308POUT	Castor Bay PPP Final Water Outlet	4955791	15/08/2024 08:01	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955791	15/08/2024 08:01	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4955964	16/08/2024 08:03	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955964	16/08/2024 08:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955964	16/08/2024 08:03	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4955964	16/08/2024 08:03	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4955964	16/08/2024 08:03	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955964	16/08/2024 08:03	Free - Residual disinfectant	mg Cl/l	1.17	
W2308POUT	Castor Bay PPP Final Water Outlet	4955964	16/08/2024 08:03	Hydrogen Ion	pH value	7.7	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4955964	16/08/2024 08:03	Total - Residual disinfectant	mg Cl/l	1.29	
W2308POUT	Castor Bay PPP Final Water Outlet	4955964	16/08/2024 08:03	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955964	16/08/2024 08:03	Turbidity	NTU	0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4956049	17/08/2024 06:55	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4956049	17/08/2024 06:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4956049	17/08/2024 06:55	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4956049	17/08/2024 06:55	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4956049	17/08/2024 06:55	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4956049	17/08/2024 06:55	Free - Residual disinfectant	mg Cl/l	1.32	
W2308POUT	Castor Bay PPP Final Water Outlet	4956049	17/08/2024 06:55	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4956049	17/08/2024 06:55	Total - Residual disinfectant	mg Cl/l	1.44	
W2308POUT	Castor Bay PPP Final Water Outlet	4956049	17/08/2024 06:55	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4956049	17/08/2024 06:55	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4956072	18/08/2024 07:11	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4956072	18/08/2024 07:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4956072	18/08/2024 07:11	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4956072	18/08/2024 07:11	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4956072	18/08/2024 07:11	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4956072	18/08/2024 07:11	Free - Residual disinfectant	mg Cl/l	1.21	
W2308POUT	Castor Bay PPP Final Water Outlet	4956072	18/08/2024 07:11	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4956072	18/08/2024 07:11	Total - Residual disinfectant	mg Cl/l	1.39	
W2308POUT	Castor Bay PPP Final Water Outlet	4956072	18/08/2024 07:11	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4956072	18/08/2024 07:11	Turbidity	NTU	0.12	1
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Free - Residual disinfectant	mg Cl/l	1.51	
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Hydrogen Ion	pH value	7.8	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Total - Residual disinfectant	mg Cl/l	1.66	
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Turbidity	NTU	0.092	1

W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	2,4-D	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	2,4-DB	ug/l	<0.016	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Asulam	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Bentazone	ug/l	<0.0044	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Bromoxynil	ug/l	<0.0079	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Chlorotoluron	ug/l	<0.0031	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Chlorpyrifos	ug/l	<0.0070	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Clopyralid	ug/l	<0.0097	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Cyanide	ug/l CN	<5.5	50
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Dicamba	ug/l	<0.028	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Dichlorprop	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Diflufenican	ug/l	<0.0072	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Dimethenamid	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Diuron	ug/l	<0.0055	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Epoxiconazole	ug/l	<0.0049	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Fenpropimorph	ug/l	<0.0083	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Flufenacet	ug/l	<0.0052	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Fluroxypyr	ug/l	0.0073	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Free - Residual disinfectant	mg Cl/l	1.52	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Glyphosate	ug/l	<0.0077	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Isoproturon	ug/l	<0.0025	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Linuron	ug/l	<0.0034	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	MCPA	ug/l	0.016	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	MCPB	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Mecoprop	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Metalaxyl	ug/l	<0.0097	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Metamitron	ug/l	<0.0074	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Metazachlor	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Metoxuron	ug/l	<0.0080	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Metribuzin	ug/l	<0.0060	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Oxamyl	ug/l	<0.0023	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Pendimethalin	ug/l	<0.0064	0.1

W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Pesticides - Total Substances	ug/l	0.0233	0.5
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Phorate	ug/l	<0.0092	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Pirimicarb	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Propachlor	ug/l	<0.0096	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Propiconazole	ug/l	<0.0029	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Propyzamide	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Prothioconazole	ug/l	<0.0019	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Tebuconazole	ug/l	<0.0039	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Total - Residual disinfectant	mg Cl/l	1.66	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Triclopyr	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Algae Diatom Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Algae Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Aluminium	ug Al/l	22	200
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Bromodichloromethane	ug/l	11	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Chloroform	ug/l	23	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Diazinon	ug/l	<0.0074	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Dibromochloromethane	ug/l	2.6	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Iron	ug/l Fe	<1.538	200
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Manganese	ug Mn/l	<0.80	50
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	MIB	ng/l	<1.9	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Microcystin-LR	ug/l	<0.024	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Total Organic Carbon	mg C/l	3	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Total Trihalomethanes	ug/l	37	100
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	WHO Index		0.29	1
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Free - Residual disinfectant	mg Cl/l	1.43	
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Hydrogen Ion	pH value	7.6	9.5

W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Total - Residual disinfectant	mg Cl/l	1.49	
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Turbidity	NTU	0.12	1
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4958821	22/08/2024 08:15	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958821	22/08/2024 08:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958821	22/08/2024 08:15	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4958821	22/08/2024 08:15	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4958821	22/08/2024 08:15	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958821	22/08/2024 08:15	Free - Residual disinfectant	mg Cl/l	1.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4958821	22/08/2024 08:15	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4958821	22/08/2024 08:15	Total - Residual disinfectant	mg Cl/l	1.64	
W2308POUT	Castor Bay PPP Final Water Outlet	4958821	22/08/2024 08:15	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958821	22/08/2024 08:15	Turbidity	NTU	0.14	1
W2308POUT	Castor Bay PPP Final Water Outlet	4958980	23/08/2024 08:40	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958980	23/08/2024 08:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958980	23/08/2024 08:40	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4958980	23/08/2024 08:40	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4958980	23/08/2024 08:40	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958980	23/08/2024 08:40	Free - Residual disinfectant	mg Cl/l	1.57	
W2308POUT	Castor Bay PPP Final Water Outlet	4958980	23/08/2024 08:40	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4958980	23/08/2024 08:40	Total - Residual disinfectant	mg Cl/l	1.66	
W2308POUT	Castor Bay PPP Final Water Outlet	4958980	23/08/2024 08:40	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958980	23/08/2024 08:40	Turbidity	NTU	0.13	1
W2308POUT	Castor Bay PPP Final Water Outlet	4959085	24/08/2024 08:02	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4959085	24/08/2024 08:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4959085	24/08/2024 08:02	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4959085	24/08/2024 08:02	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4959085	24/08/2024 08:02	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4959085	24/08/2024 08:02	Free - Residual disinfectant	mg Cl/l	1.07	
W2308POUT	Castor Bay PPP Final Water Outlet	4959085	24/08/2024 08:02	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4959085	24/08/2024 08:02	Total - Residual disinfectant	mg Cl/l	1.18	
W2308POUT	Castor Bay PPP Final Water Outlet	4959085	24/08/2024 08:02	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4959085	24/08/2024 08:02	Turbidity	NTU	0.35	1
W2308POUT	Castor Bay PPP Final Water Outlet	4959103	25/08/2024 07:34	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4959103	25/08/2024 07:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4959103	25/08/2024 07:34	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4959103	25/08/2024 07:34	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4959103	25/08/2024 07:34	E. coli	CFU/100 ml	0	0

W2308POUT	Castor Bay PPP Final Water Outlet	4959103	25/08/2024 07:34	Free - Residual disinfectant	mg Cl/l	1.48	
W2308POUT	Castor Bay PPP Final Water Outlet	4959103	25/08/2024 07:34	Hydrogen Ion	pH value	7.7	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4959103	25/08/2024 07:34	Total - Residual disinfectant	mg Cl/l	1.7	
W2308POUT	Castor Bay PPP Final Water Outlet	4959103	25/08/2024 07:34	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4959103	25/08/2024 07:34	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4961134	26/08/2024 09:31	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961134	26/08/2024 09:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961134	26/08/2024 09:31	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4961134	26/08/2024 09:31	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4961134	26/08/2024 09:31	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961134	26/08/2024 09:31	Free - Residual disinfectant	mg Cl/l	1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4961134	26/08/2024 09:31	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4961134	26/08/2024 09:31	Total - Residual disinfectant	mg Cl/l	1.28	
W2308POUT	Castor Bay PPP Final Water Outlet	4961134	26/08/2024 09:31	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961134	26/08/2024 09:31	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Free - Residual disinfectant	mg Cl/l	1.45	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Nitrite	mg/l	<0.03	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Total - Residual disinfectant	mg Cl/l	1.62	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Algae Diatom Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Algae Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Aluminium	ug Al/l	16	200
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Bromodichloromethane	ug/l	6	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Dibromochloromethane	ug/l	4.2	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Iron	ug/l Fe	2.2	200
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Manganese	ug Mn/l	<0.80	50
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	MIB	ng/l	<1.9	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Microcystin-LR	ug/l	<0.024	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Odour	Diln No	0	0

W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Total Organic Carbon	mg C/l	2.7	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Total Trihalomethanes	ug/l	21	100
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	WHO Index		0.18	1
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Free - Residual disinfectant	mg Cl/l	1.77	
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Total - Residual disinfectant	mg Cl/l	1.92	
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	Free - Residual disinfectant	mg Cl/l	1.61	
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	Total - Residual disinfectant	mg Cl/l	1.79	
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	BromoChloroAcetic Acid	ug/l	2.9	
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	BromoDiChloroAcetic Acid	ug/l	2.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	Dalapon	ug/l	<2.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	DiBromoAcetic Acid	ug/l	<1.8	
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	DiBromoChloroAcetic Acid	ug/l	<1.8	
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	DiChloroAcetic Acid	ug/l	4.7	
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	MonoBromoAcetic Acid	ug/l	<1.8	
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	TriBromoAcetic Acid	ug/l	<2.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	TriChloroAcetic Acid	ug/l	2.6	
W2308POUT	Castor Bay PPP Final Water Outlet	4961911	30/08/2024 11:27	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961911	30/08/2024 11:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961911	30/08/2024 11:27	Colour	mg/l Pt/Co	<4.56	20

W2308POUT	Castor Bay PPP Final Water Outlet	4961911	30/08/2024 11:27	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4961911	30/08/2024 11:27	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961911	30/08/2024 11:27	Free - Residual disinfectant	mg Cl/l	1.4	
W2308POUT	Castor Bay PPP Final Water Outlet	4961911	30/08/2024 11:27	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4961911	30/08/2024 11:27	Total - Residual disinfectant	mg Cl/l	1.61	
W2308POUT	Castor Bay PPP Final Water Outlet	4961911	30/08/2024 11:27	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961911	30/08/2024 11:27	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4961911	30/08/2024 11:27	Chlorate	ug/l CL03	<8.2	
W2308POUT	Castor Bay PPP Final Water Outlet	4961911	30/08/2024 11:27	Chlorite	mg/l	<0.005	
W2308POUT	Castor Bay PPP Final Water Outlet	4961985	31/08/2024 10:59	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961985	31/08/2024 10:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961985	31/08/2024 10:59	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4961985	31/08/2024 10:59	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4961985	31/08/2024 10:59	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961985	31/08/2024 10:59	Free - Residual disinfectant	mg Cl/l	1.66	
W2308POUT	Castor Bay PPP Final Water Outlet	4961985	31/08/2024 10:59	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4961985	31/08/2024 10:59	Total - Residual disinfectant	mg Cl/l	1.83	
W2308POUT	Castor Bay PPP Final Water Outlet	4961985	31/08/2024 10:59	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961985	31/08/2024 10:59	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4962002	01/09/2024 09:59	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4962002	01/09/2024 09:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4962002	01/09/2024 09:59	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4962002	01/09/2024 09:59	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4962002	01/09/2024 09:59	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4962002	01/09/2024 09:59	Free - Residual disinfectant	mg Cl/l	0.98	
W2308POUT	Castor Bay PPP Final Water Outlet	4962002	01/09/2024 09:59	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4962002	01/09/2024 09:59	Total - Residual disinfectant	mg Cl/l	1.11	
W2308POUT	Castor Bay PPP Final Water Outlet	4962002	01/09/2024 09:59	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4962002	01/09/2024 09:59	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Free - Residual disinfectant	mg Cl/l	1.75	
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Total - Residual disinfectant	mg Cl/l	1.91	
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Taste	Diln No	0	0

W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	2,4-D	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	2,4-DB	ug/l	<0.016	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Asulam	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Bentazone	ug/l	<0.0044	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Bromoxynil	ug/l	<0.0079	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Chlorotoluron	ug/l	<0.0031	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Chlorpyrifos	ug/l	<0.0070	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Clopyralid	ug/l	<0.0097	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Cyanide	ug/l CN	<5.5	50
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Diazinon	ug/l	<0.0074	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Dicamba	ug/l	<0.028	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Dichlorprop	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Diflufenican	ug/l	<0.0072	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Dimethenamid	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Diuron	ug/l	<0.0055	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Epoxiconazole	ug/l	<0.0049	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Fenpropimorph	ug/l	<0.0083	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Flufenacet	ug/l	<0.0052	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Fluroxypyr	ug/l	0.0084	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Free - Residual disinfectant	mg Cl/l	1.74	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Glyphosate	ug/l	<0.0077	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Isoproturon	ug/l	<0.0025	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Linuron	ug/l	<0.0034	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	MCPA	ug/l	0.017	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	MCPB	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Mecoprop	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Metalaxyl	ug/l	<0.0097	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Metamitron	ug/l	<0.0074	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Metazachlor	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Metoxuron	ug/l	<0.0080	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Metribuzin	ug/l	<0.0060	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Oxamyl	ug/l	<0.0023	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Pendimethalin	ug/l	<0.0064	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Pesticides - Total Substances	ug/l	0.0254	0.5

W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Phorate	ug/l	<0.0092	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Pirimicarb	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Propachlor	ug/l	<0.0096	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Propiconazole	ug/l	<0.0029	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Propyzamide	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Prothioconazole	ug/l	<0.0019	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Tebuconazole	ug/l	<0.0039	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Total - Residual disinfectant	mg Cl/l	1.92	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Triclopyr	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Algae Diatom Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Algae Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Aluminium	ug Al/l	24	200
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Bromodichloromethane	ug/l	8.2	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Chloroform	ug/l	16	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Dibromochloromethane	ug/l	3.2	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Iron	ug/l Fe	<1.538	200
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Manganese	ug Mn/l	<0.80	50
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	MIB	ng/l	<1.9	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Microcystin-LR	ug/l	<0.024	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Total Organic Carbon	mg C/l	2.7	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Total Trihalomethanes	ug/l	28	100
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	WHO Index		0.23	1
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Free - Residual disinfectant	mg Cl/l	1.72	
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Total - Residual disinfectant	mg Cl/l	1.91	
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Turbidity	NTU	<0.09	1

W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4964963	05/09/2024 08:53	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964963	05/09/2024 08:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964963	05/09/2024 08:53	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4964963	05/09/2024 08:53	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4964963	05/09/2024 08:53	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964963	05/09/2024 08:53	Free - Residual disinfectant	mg Cl/l	1.35	
W2308POUT	Castor Bay PPP Final Water Outlet	4964963	05/09/2024 08:53	Total - Residual disinfectant	mg Cl/l	1.44	
W2308POUT	Castor Bay PPP Final Water Outlet	4964963	05/09/2024 08:53	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964963	05/09/2024 08:53	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4965151	06/09/2024 10:22	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4965151	06/09/2024 10:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4965151	06/09/2024 10:22	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4965151	06/09/2024 10:22	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4965151	06/09/2024 10:22	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4965151	06/09/2024 10:22	Free - Residual disinfectant	mg Cl/l	1.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4965151	06/09/2024 10:22	Total - Residual disinfectant	mg Cl/l	1.64	
W2308POUT	Castor Bay PPP Final Water Outlet	4965151	06/09/2024 10:22	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4965151	06/09/2024 10:22	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4965248	07/09/2024 12:34	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4965248	07/09/2024 12:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4965248	07/09/2024 12:34	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4965248	07/09/2024 12:34	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4965248	07/09/2024 12:34	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4965248	07/09/2024 12:34	Free - Residual disinfectant	mg Cl/l	1.24	
W2308POUT	Castor Bay PPP Final Water Outlet	4965248	07/09/2024 12:34	Total - Residual disinfectant	mg Cl/l	1.27	
W2308POUT	Castor Bay PPP Final Water Outlet	4965248	07/09/2024 12:34	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4965248	07/09/2024 12:34	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4965266	08/09/2024 12:11	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4965266	08/09/2024 12:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4965266	08/09/2024 12:11	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4965266	08/09/2024 12:11	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4965266	08/09/2024 12:11	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4965266	08/09/2024 12:11	Free - Residual disinfectant	mg Cl/l	1.53	
W2308POUT	Castor Bay PPP Final Water Outlet	4965266	08/09/2024 12:11	Total - Residual disinfectant	mg Cl/l	1.6	
W2308POUT	Castor Bay PPP Final Water Outlet	4965266	08/09/2024 12:11	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4965266	08/09/2024 12:11	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	

W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Free - Residual disinfectant	mg Cl/l	1.35	
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Total - Residual disinfectant	mg Cl/l	1.46	
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Turbidity	NTU	0.091	1
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Free - Residual disinfectant	mg Cl/l	1.07	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Total - Residual disinfectant	mg Cl/l	1.13	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Algae Diatom Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Algae Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Aluminium	ug Al/l	22	200
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Bromodichloromethane	ug/l	8	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Chloroform	ug/l	20	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Dibromochloromethane	ug/l	2	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Iron	ug/l Fe	<1.538	200
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Manganese	ug Mn/l	<0.80	50
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	MIB	ng/l	17	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Microcystin-LR	ug/l	<0.024	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Total Trihalomethanes	ug/l	31	100
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	WHO Index		0.23	1

W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Free - Residual disinfectant	mg Cl/l	1.47	
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Total - Residual disinfectant	mg Cl/l	1.63	
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Free - Residual disinfectant	mg Cl/l	1.55	
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Hydrogen Ion	pH value	7.4	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Total - Residual disinfectant	mg Cl/l	1.66	
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Odour	Diln No	7	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Odour - Nature		Earthy/Musty	
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Taste	Diln No	6	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Taste - Nature		Earthy	
W2308POUT	Castor Bay PPP Final Water Outlet	4968364	13/09/2024 08:17	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4968364	13/09/2024 08:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4968364	13/09/2024 08:17	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4968364	13/09/2024 08:17	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4968364	13/09/2024 08:17	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968364	13/09/2024 08:17	Free - Residual disinfectant	mg Cl/l	1.53	
W2308POUT	Castor Bay PPP Final Water Outlet	4968364	13/09/2024 08:17	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4968364	13/09/2024 08:17	Total - Residual disinfectant	mg Cl/l	1.63	
W2308POUT	Castor Bay PPP Final Water Outlet	4968364	13/09/2024 08:17	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968364	13/09/2024 08:17	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Conductivity	uS/cm 20 C	360	2500

W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Free - Residual disinfectant	mg Cl/l	1.48	
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Hydrogen Ion	pH value	7.4	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Total - Residual disinfectant	mg Cl/l	1.64	
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Free - Residual disinfectant	mg Cl/l	1.51	
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Total - Residual disinfectant	mg Cl/l	1.71	
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Free - Residual disinfectant	mg Cl/l	1.48	
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Hydrogen Ion	pH value	7.4	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Total - Residual disinfectant	mg Cl/l	1.55	
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Conductivity	uS/cm 20 C	380	2500

W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Free - Residual disinfectant	mg Cl/l	1.42	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Total - Residual disinfectant	mg Cl/l	1.52	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Turbidity	NTU	0.096	1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Algae Diatom Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Algae Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Aluminium	ug Al/l	26	200
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Bromodichloromethane	ug/l	4.6	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Chloroform	ug/l	7.3	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Dibromochloromethane	ug/l	4	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Iron	ug/l Fe	2.1	200
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Manganese	ug Mn/l	<0.80	50
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	MIB	ng/l	17	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Microcystin-LR	ug/l	<0.024	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Total Trihalomethanes	ug/l	17	100
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	WHO Index		0.15	1
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Free - Residual disinfectant	mg Cl/l	1.48	
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Total - Residual disinfectant	mg Cl/l	1.56	
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Taste - Nature		No taste	
V2305OUT	Magheraliskmisk SR Outlet	4949888	01/08/2024 09:31	Colony Counts 22	CFU/1 ml	0	

V2305OUT	Magheraliskmisk SR Outlet	4949888	01/08/2024 09:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2305OUT	Magheraliskmisk SR Outlet	4949888	01/08/2024 09:31	E. coli	CFU/100 ml	0	0
V2305OUT	Magheraliskmisk SR Outlet	4949888	01/08/2024 09:31	Free - Residual disinfectant	mg Cl/l	0.64	
V2305OUT	Magheraliskmisk SR Outlet	4949888	01/08/2024 09:31	Total - Residual disinfectant	mg Cl/l	0.76	
V2305OUT	Magheraliskmisk SR Outlet	4949888	01/08/2024 09:31	Total Coliforms	CFU/100 ml	0	0
V2305OUT	Magheraliskmisk SR Outlet	4949888	01/08/2024 09:31	Odour	Diln No	0	0
V2305OUT	Magheraliskmisk SR Outlet	4949888	01/08/2024 09:31	Odour - Nature		No odour	
V2305OUT	Magheraliskmisk SR Outlet	4949888	01/08/2024 09:31	Taste	Diln No	0	0
V2305OUT	Magheraliskmisk SR Outlet	4949888	01/08/2024 09:31	Taste - Nature		No taste	
V2305OUT	Magheraliskmisk SR Outlet	4953091	09/08/2024 09:28	Colony Counts 22	CFU/1 ml	0	
V2305OUT	Magheraliskmisk SR Outlet	4953091	09/08/2024 09:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2305OUT	Magheraliskmisk SR Outlet	4953091	09/08/2024 09:28	E. coli	CFU/100 ml	0	0
V2305OUT	Magheraliskmisk SR Outlet	4953091	09/08/2024 09:28	Free - Residual disinfectant	mg Cl/l	0.53	
V2305OUT	Magheraliskmisk SR Outlet	4953091	09/08/2024 09:28	Total - Residual disinfectant	mg Cl/l	0.63	
V2305OUT	Magheraliskmisk SR Outlet	4953091	09/08/2024 09:28	Total Coliforms	CFU/100 ml	0	0
V2305OUT	Magheraliskmisk SR Outlet	4954943	12/08/2024 09:25	Colony Counts 22	CFU/1 ml	0	
V2305OUT	Magheraliskmisk SR Outlet	4954943	12/08/2024 09:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2305OUT	Magheraliskmisk SR Outlet	4954943	12/08/2024 09:25	E. coli	CFU/100 ml	0	0
V2305OUT	Magheraliskmisk SR Outlet	4954943	12/08/2024 09:25	Free - Residual disinfectant	mg Cl/l	0.44	
V2305OUT	Magheraliskmisk SR Outlet	4954943	12/08/2024 09:25	Total - Residual disinfectant	mg Cl/l	0.54	
V2305OUT	Magheraliskmisk SR Outlet	4954943	12/08/2024 09:25	Total Coliforms	CFU/100 ml	0	0
V2305OUT	Magheraliskmisk SR Outlet	4954943	12/08/2024 09:25	Odour	Diln No	0	0
V2305OUT	Magheraliskmisk SR Outlet	4954943	12/08/2024 09:25	Odour - Nature		No odour	
V2305OUT	Magheraliskmisk SR Outlet	4954943	12/08/2024 09:25	Taste	Diln No	0	0
V2305OUT	Magheraliskmisk SR Outlet	4954943	12/08/2024 09:25	Taste - Nature		No taste	
V2305OUT	Magheraliskmisk SR Outlet	4958328	20/08/2024 08:22	Colony Counts 22	CFU/1 ml	2	
V2305OUT	Magheraliskmisk SR Outlet	4958328	20/08/2024 08:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2305OUT	Magheraliskmisk SR Outlet	4958328	20/08/2024 08:22	E. coli	CFU/100 ml	0	0
V2305OUT	Magheraliskmisk SR Outlet	4958328	20/08/2024 08:22	Free - Residual disinfectant	mg Cl/l	0.45	
V2305OUT	Magheraliskmisk SR Outlet	4958328	20/08/2024 08:22	Total - Residual disinfectant	mg Cl/l	0.54	
V2305OUT	Magheraliskmisk SR Outlet	4958328	20/08/2024 08:22	Total Coliforms	CFU/100 ml	0	0
V2305OUT	Magheraliskmisk SR Outlet	4958328	20/08/2024 08:22	Odour	Diln No	0	0
V2305OUT	Magheraliskmisk SR Outlet	4958328	20/08/2024 08:22	Odour - Nature		No odour	
V2305OUT	Magheraliskmisk SR Outlet	4958328	20/08/2024 08:22	Taste	Diln No	0	0
V2305OUT	Magheraliskmisk SR Outlet	4958328	20/08/2024 08:22	Taste - Nature		No taste	
V2305OUT	Magheraliskmisk SR Outlet	4961455	28/08/2024 09:04	Colony Counts 22	CFU/1 ml	0	
V2305OUT	Magheraliskmisk SR Outlet	4961455	28/08/2024 09:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2305OUT	Magheraliskmisk SR Outlet	4961455	28/08/2024 09:04	E. coli	CFU/100 ml	0	0
V2305OUT	Magheraliskmisk SR Outlet	4961455	28/08/2024 09:04	Free - Residual disinfectant	mg Cl/l	0.58	
V2305OUT	Magheraliskmisk SR Outlet	4961455	28/08/2024 09:04	Total - Residual disinfectant	mg Cl/l	0.71	
V2305OUT	Magheraliskmisk SR Outlet	4961455	28/08/2024 09:04	Total Coliforms	CFU/100 ml	0	0
V2305OUT	Magheraliskmisk SR Outlet	4961455	28/08/2024 09:04	Odour	Diln No	0	0

V2305OUT	Magheraliskmisk SR Outlet	4961455	28/08/2024 09:04	Odour - Nature		No odour	
V2305OUT	Magheraliskmisk SR Outlet	4961455	28/08/2024 09:04	Taste	Diln No	0	0
V2305OUT	Magheraliskmisk SR Outlet	4961455	28/08/2024 09:04	Taste - Nature		No taste	
V2305OUT	Magheraliskmisk SR Outlet	4964890	05/09/2024 08:20	Colony Counts 22	CFU/1 ml	0	
V2305OUT	Magheraliskmisk SR Outlet	4964890	05/09/2024 08:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2305OUT	Magheraliskmisk SR Outlet	4964890	05/09/2024 08:20	E. coli	CFU/100 ml	0	0
V2305OUT	Magheraliskmisk SR Outlet	4964890	05/09/2024 08:20	Free - Residual disinfectant	mg Cl/l	0.52	
V2305OUT	Magheraliskmisk SR Outlet	4964890	05/09/2024 08:20	Total - Residual disinfectant	mg Cl/l	0.6	
V2305OUT	Magheraliskmisk SR Outlet	4964890	05/09/2024 08:20	Total Coliforms	CFU/100 ml	0	0
V2305OUT	Magheraliskmisk SR Outlet	4964890	05/09/2024 08:20	Odour	Diln No	0	0
V2305OUT	Magheraliskmisk SR Outlet	4964890	05/09/2024 08:20	Odour - Nature		No odour	
V2305OUT	Magheraliskmisk SR Outlet	4964890	05/09/2024 08:20	Taste	Diln No	0	0
V2305OUT	Magheraliskmisk SR Outlet	4964890	05/09/2024 08:20	Taste - Nature		No taste	
V2305OUT	Magheraliskmisk SR Outlet	4968300	13/09/2024 07:46	Colony Counts 22	CFU/1 ml	0	
V2305OUT	Magheraliskmisk SR Outlet	4968300	13/09/2024 07:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2305OUT	Magheraliskmisk SR Outlet	4968300	13/09/2024 07:46	E. coli	CFU/100 ml	0	0
V2305OUT	Magheraliskmisk SR Outlet	4968300	13/09/2024 07:46	Free - Residual disinfectant	mg Cl/l	0.52	
V2305OUT	Magheraliskmisk SR Outlet	4968300	13/09/2024 07:46	Total - Residual disinfectant	mg Cl/l	0.62	
V2305OUT	Magheraliskmisk SR Outlet	4968300	13/09/2024 07:46	Total Coliforms	CFU/100 ml	0	0
V2305OUT	Magheraliskmisk SR Outlet	4968300	13/09/2024 07:46	Odour	Diln No	0	0
V2305OUT	Magheraliskmisk SR Outlet	4968300	13/09/2024 07:46	Odour - Nature		No odour	
V2305OUT	Magheraliskmisk SR Outlet	4968300	13/09/2024 07:46	Taste	Diln No	0	0
V2305OUT	Magheraliskmisk SR Outlet	4968300	13/09/2024 07:46	Taste - Nature		No taste	
V2305OUT	Magheraliskmisk SR Outlet	4970702	16/09/2024 09:41	Colony Counts 22	CFU/1 ml	0	
V2305OUT	Magheraliskmisk SR Outlet	4970702	16/09/2024 09:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2305OUT	Magheraliskmisk SR Outlet	4970702	16/09/2024 09:41	E. coli	CFU/100 ml	0	0
V2305OUT	Magheraliskmisk SR Outlet	4970702	16/09/2024 09:41	Free - Residual disinfectant	mg Cl/l	0.61	
V2305OUT	Magheraliskmisk SR Outlet	4970702	16/09/2024 09:41	Total - Residual disinfectant	mg Cl/l	0.66	
V2305OUT	Magheraliskmisk SR Outlet	4970702	16/09/2024 09:41	Total Coliforms	CFU/100 ml	0	0
V2305OUT	Magheraliskmisk SR Outlet	4970702	16/09/2024 09:41	Odour	Diln No	0	0
V2305OUT	Magheraliskmisk SR Outlet	4970702	16/09/2024 09:41	Odour - Nature		No odour	
V2305OUT	Magheraliskmisk SR Outlet	4970702	16/09/2024 09:41	Taste	Diln No	0	0
V2305OUT	Magheraliskmisk SR Outlet	4970702	16/09/2024 09:41	Taste - Nature		No taste	
V2305OUT	Magheraliskmisk SR Outlet	4981625	18/09/2024 08:15	Colony Counts 22	CFU/1 ml	0	
V2305OUT	Magheraliskmisk SR Outlet	4981625	18/09/2024 08:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2305OUT	Magheraliskmisk SR Outlet	4981625	18/09/2024 08:15	E. coli	CFU/100 ml	0	0
V2305OUT	Magheraliskmisk SR Outlet	4981625	18/09/2024 08:15	Free - Residual disinfectant	mg Cl/l	0.48	
V2305OUT	Magheraliskmisk SR Outlet	4981625	18/09/2024 08:15	Odour	Diln No	0	0
V2305OUT	Magheraliskmisk SR Outlet	4981625	18/09/2024 08:15	Odour - Nature		No odour	
V2305OUT	Magheraliskmisk SR Outlet	4981625	18/09/2024 08:15	Taste	Diln No	0	0
V2305OUT	Magheraliskmisk SR Outlet	4981625	18/09/2024 08:15	Taste - Nature		No taste	
V2305OUT	Magheraliskmisk SR Outlet	4981625	18/09/2024 08:15	Total - Residual disinfectant	mg Cl/l	0.57	

V2305OUT	Magheraliskmisk SR Outlet	4981625	18/09/2024 08:15	Total Coliforms	CFU/100 ml	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4952303	05/08/2024 12:48	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4952303	05/08/2024 12:48	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4952303	05/08/2024 12:48	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4952303	05/08/2024 12:48	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4952303	05/08/2024 12:48	Bromate	ug BrO3/l	<0.50	10
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4952303	05/08/2024 12:48	E. coli	CFU/100 ml	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4952303	05/08/2024 12:48	Free - Residual disinfectant	mg Cl/l	0.15	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4952303	05/08/2024 12:48	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4952303	05/08/2024 12:48	PAH - Sum of four substances	ug/l	0	0.1
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4952303	05/08/2024 12:48	Total - Residual disinfectant	mg Cl/l	0.38	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4952303	05/08/2024 12:48	Total Coliforms	CFU/100 ml	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4952303	05/08/2024 12:48	Copper	mg Cu/l	<0.546	2
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4952303	05/08/2024 12:48	Lead	ug Pb/l	<0.095	10
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4952303	05/08/2024 12:48	Nickel	ug Ni/l	1.2	20
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4952303	05/08/2024 12:48	Phosphorous (TOT)	mg P/l	1.9	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4952303	05/08/2024 12:48	Zinc	mg Zn/l	16	
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4965888	07/08/2024 10:00	Aluminium	ug Al/l	26	200
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4965888	07/08/2024 10:00	Colour	mg/l Pt/Co	<4.56	20
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4965888	07/08/2024 10:00	E. coli	CFU/100 ml	0	0
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4965888	07/08/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.14	
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4965888	07/08/2024 10:00	Hydrogen Ion	pH value	7.7	9.5
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4965888	07/08/2024 10:00	Iron	ug/l Fe	1.6	200
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4965888	07/08/2024 10:00	Manganese	ug Mn/l	<0.642	50
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4965888	07/08/2024 10:00	Odour	DiIn No	0	0
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4965888	07/08/2024 10:00	Odour - Nature		No odour	
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4965888	07/08/2024 10:00	Taste	DiIn No	0	0
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4965888	07/08/2024 10:00	Taste - Nature		No taste	
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4965888	07/08/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.37	
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4965888	07/08/2024 10:00	Total Coliforms	CFU/100 ml	0	0
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4965888	07/08/2024 10:00	Turbidity	NTU	0.095	4
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	1,2 Dichloroethane	ug/l	<0.4	3
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Aluminium	ug Al/l	17	200
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Ammonium	mg NH4/l	<0.01	0.5
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Antimony	ug/l Sb	0.14	5
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Arsenic	ug/l As	0.24	10
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Benzene	ug/l	<0.15	1
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Boron	mg/l B	<0.0586	1
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Bromodichloromethane	ug/l	16	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Bromoform	ug/l	<3.5	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Cadmium	ug/l Cd	<0.042	5
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Calcium	mg/l	52	

ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Chloride	mg Cl/l	22	250
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Chloroform	ug/l	41	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Chromium	ug/l Cr	<0.260	50
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Colony Counts 22	CFU/1 ml	0	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Colour	mg/l Pt/Co	<4.56	20
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Conductivity	uS/cm 20 C	370	2500
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Copper	mg Cu/l	<0.546	2
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Dibromochloromethane	ug/l	7.4	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	E. coli	CFU/100 ml	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Enterococci	CFU/100ml	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Fluoride	mg F/l	<0.150	1.5
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Free - Residual disinfectant	mg Cl/l	0.33	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Hydrogen Ion	pH value	7.7	9.5
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Iron	ug/l Fe	2.6	200
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Lead	ug Pb/l	<0.095	10
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Magnesium	mg/l	8.2	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Manganese	ug Mn/l	<0.642	50
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Mercury	ug per l	<0.041	1
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Nickel	ug Ni/l	1.3	20
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Nitrate	mg/l	2.8	50
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Nitrate/Nitrite Formula	mg/l	<0.056	1
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Nitrite	mg/l	<0.03	0.5
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Odour	Diln No	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Odour - Nature		No odour	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Potassium	mg/l	3.7	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Selenium	ug/l Se	0.061	10
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Sodium	mg Na/l	16	200
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Sulphate	mg SO4/l	80	250
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Taste	Diln No	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Taste - Nature		No taste	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Tetrachloroethene	ug/l	<0.8	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Tetrachloromethane	ug/l	<0.4	3
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Total - Residual disinfectant	mg Cl/l	0.48	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Total Coliforms	CFU/100 ml	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Total hardness	mg/l	66	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Total Organic Carbon	mg C/l	2.7	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Total Trihalomethanes	ug/l	65	100
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Trichloroethene	ug/l	<0.7	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	Turbidity	NTU	<0.09	4
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955021	12/08/2024 12:43	WHO Index		0.49	1

ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4968827	13/08/2024 09:00	Aluminium	ug Al/l	23	200
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4968827	13/08/2024 09:00	Colour	mg/l Pt/Co	<4.56	20
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4968827	13/08/2024 09:00	E. coli	CFU/100 ml	0	0
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4968827	13/08/2024 09:00	Free - Residual disinfectant	mg Cl/l	0.07	
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4968827	13/08/2024 09:00	Hydrogen Ion	pH value	7.7	9.5
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4968827	13/08/2024 09:00	Iron	ug/l Fe	5.5	200
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4968827	13/08/2024 09:00	Manganese	ug Mn/l	<0.642	50
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4968827	13/08/2024 09:00	Odour	Diln No	0	0
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4968827	13/08/2024 09:00	Odour - Nature		No odour	
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4968827	13/08/2024 09:00	Taste	Diln No	0	0
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4968827	13/08/2024 09:00	Taste - Nature		No taste	
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4968827	13/08/2024 09:00	Total - Residual disinfectant	mg Cl/l	0.2	
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4968827	13/08/2024 09:00	Total Coliforms	CFU/100 ml	0	0
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4968827	13/08/2024 09:00	Turbidity	NTU	0.19	4
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955330	14/08/2024 09:32	E. coli	CFU/100 ml	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955330	14/08/2024 09:32	Free - Residual disinfectant	mg Cl/l	0.19	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955330	14/08/2024 09:32	Total - Residual disinfectant	mg Cl/l	0.38	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4955330	14/08/2024 09:32	Total Coliforms	CFU/100 ml	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4958127	21/08/2024 13:04	Antimony	ug/l Sb	0.15	5
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4958127	21/08/2024 13:04	Arsenic	ug/l As	0.24	10
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4958127	21/08/2024 13:04	Boron	mg/l B	<0.0586	1
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4958127	21/08/2024 13:04	Cadmium	ug/l Cd	<0.042	5
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4958127	21/08/2024 13:04	Chromium	ug/l Cr	0.37	50
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4958127	21/08/2024 13:04	E. coli	CFU/100 ml	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4958127	21/08/2024 13:04	Free - Residual disinfectant	mg Cl/l	0.35	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4958127	21/08/2024 13:04	Selenium	ug/l Se	0.064	10
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4958127	21/08/2024 13:04	Total - Residual disinfectant	mg Cl/l	0.5	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4958127	21/08/2024 13:04	Total Coliforms	CFU/100 ml	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4958127	21/08/2024 13:04	Copper	mg Cu/l	<0.546	2
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4958127	21/08/2024 13:04	Lead	ug Pb/l	<0.095	10
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4958127	21/08/2024 13:04	Nickel	ug Ni/l	2.7	20
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4958127	21/08/2024 13:04	Zinc	mg Zn/l	20	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961260	27/08/2024 09:30	Aluminium	ug Al/l	24	200
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961260	27/08/2024 09:30	Colony Counts 22	CFU/1 ml	0	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961260	27/08/2024 09:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961260	27/08/2024 09:30	Colour	mg/l Pt/Co	<4.56	20
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961260	27/08/2024 09:30	Conductivity	uS/cm 20 C	320	2500
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961260	27/08/2024 09:30	E. coli	CFU/100 ml	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961260	27/08/2024 09:30	Free - Residual disinfectant	mg Cl/l	0.11	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961260	27/08/2024 09:30	Hydrogen Ion	pH value	7.6	9.5
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961260	27/08/2024 09:30	Iron	ug/l Fe	26	200
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961260	27/08/2024 09:30	Manganese	ug Mn/l	<0.80	50

ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961260	27/08/2024 09:30	Odour	Diln No	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961260	27/08/2024 09:30	Odour - Nature		No odour	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961260	27/08/2024 09:30	Taste	Diln No	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961260	27/08/2024 09:30	Taste - Nature		No taste	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961260	27/08/2024 09:30	Total - Residual disinfectant	mg Cl/l	0.27	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961260	27/08/2024 09:30	Total Coliforms	CFU/100 ml	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961260	27/08/2024 09:30	Turbidity	NTU	0.096	4
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961260	27/08/2024 09:30	Copper	mg Cu/l	<0.546	2
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961260	27/08/2024 09:30	Lead	ug Pb/l	<0.095	10
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961260	27/08/2024 09:30	Nickel	ug Ni/l	1	20
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961260	27/08/2024 09:30	Zinc	mg Zn/l	6.4	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961543	29/08/2024 12:53	E. coli	CFU/100 ml	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961543	29/08/2024 12:53	Free - Residual disinfectant	mg Cl/l	0.28	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961543	29/08/2024 12:53	Total - Residual disinfectant	mg Cl/l	0.44	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4961543	29/08/2024 12:53	Total Coliforms	CFU/100 ml	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4964128	02/09/2024 12:38	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4964128	02/09/2024 12:38	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4964128	02/09/2024 12:38	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4964128	02/09/2024 12:38	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4964128	02/09/2024 12:38	Bromate	ug BrO3/l	<0.50	10
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4964128	02/09/2024 12:38	E. coli	CFU/100 ml	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4964128	02/09/2024 12:38	Free - Residual disinfectant	mg Cl/l	0.18	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4964128	02/09/2024 12:38	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4964128	02/09/2024 12:38	PAH - Sum of four substances	ug/l	0	0.1
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4964128	02/09/2024 12:38	Total - Residual disinfectant	mg Cl/l	0.35	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4964128	02/09/2024 12:38	Total Coliforms	CFU/100 ml	0	0
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4978879	09/09/2024 09:00	Aluminium	ug Al/l	31	200
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4978879	09/09/2024 09:00	Colour	mg/l Pt/Co	<4.56	20
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4978879	09/09/2024 09:00	E. coli	CFU/100 ml	0	0
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4978879	09/09/2024 09:00	Free - Residual disinfectant	mg Cl/l	0.13	
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4978879	09/09/2024 09:00	Hydrogen Ion	pH value	7.7	9.5
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4978879	09/09/2024 09:00	Iron	ug/l Fe	<1.538	200
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4978879	09/09/2024 09:00	Manganese	ug Mn/l	<0.642	50
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4978879	09/09/2024 09:00	Odour	Diln No	0	0
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4978879	09/09/2024 09:00	Odour - Nature		No odour	
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4978879	09/09/2024 09:00	Taste	Diln No	0	0
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4978879	09/09/2024 09:00	Taste - Nature		No taste	
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4978879	09/09/2024 09:00	Total - Residual disinfectant	mg Cl/l	0.2	
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4978879	09/09/2024 09:00	Total Coliforms	CFU/100 ml	0	0
ZS0814CUST	(CASTOR BAY MOIRA) customer tap sample	4978879	09/09/2024 09:00	Turbidity	NTU	0.35	4
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4967412	09/09/2024 12:44	Aluminium	ug Al/l	29	200
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4967412	09/09/2024 12:44	Colony Counts 22	CFU/1 ml	0	

ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4967412	09/09/2024 12:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4967412	09/09/2024 12:44	Colour	mg/l Pt/Co	<4.56	20
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4967412	09/09/2024 12:44	Conductivity	uS/cm 20 C	350	2500
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4967412	09/09/2024 12:44	E. coli	CFU/100 ml	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4967412	09/09/2024 12:44	Free - Residual disinfectant	mg Cl/l	0.36	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4967412	09/09/2024 12:44	Hydrogen Ion	pH value	7.6	9.5
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4967412	09/09/2024 12:44	Iron	ug/l Fe	<1.538	200
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4967412	09/09/2024 12:44	Manganese	ug Mn/l	<0.80	50
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4967412	09/09/2024 12:44	Odour	Diln No	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4967412	09/09/2024 12:44	Odour - Nature		No odour	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4967412	09/09/2024 12:44	Taste	Diln No	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4967412	09/09/2024 12:44	Taste - Nature		No taste	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4967412	09/09/2024 12:44	Total - Residual disinfectant	mg Cl/l	0.52	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4967412	09/09/2024 12:44	Total Coliforms	CFU/100 ml	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4967412	09/09/2024 12:44	Turbidity	NTU	<0.09	4
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4967412	09/09/2024 12:44	Copper	mg Cu/l	<0.546	2
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4967412	09/09/2024 12:44	Lead	ug Pb/l	<0.095	10
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4967412	09/09/2024 12:44	Nickel	ug Ni/l	1.1	20
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4967412	09/09/2024 12:44	Phosphorous (TOT)	mg P/l	1.7	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4967412	09/09/2024 12:44	Zinc	mg Zn/l	1.8	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4971050	17/09/2024 12:14	E. coli	CFU/100 ml	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4971050	17/09/2024 12:14	Free - Residual disinfectant	mg Cl/l	0.18	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4971050	17/09/2024 12:14	Total - Residual disinfectant	mg Cl/l	0.21	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4971050	17/09/2024 12:14	Total Coliforms	CFU/100 ml	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4970778	18/09/2024 08:33	E. coli	CFU/100 ml	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4970778	18/09/2024 08:33	Free - Residual disinfectant	mg Cl/l	0.14	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4970778	18/09/2024 08:33	Total - Residual disinfectant	mg Cl/l	0.21	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4970778	18/09/2024 08:33	Total Coliforms	CFU/100 ml	0	0
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4970778	18/09/2024 08:33	Copper	mg Cu/l	<0.546	2
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4970778	18/09/2024 08:33	Lead	ug Pb/l	0.39	10
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4970778	18/09/2024 08:33	Nickel	ug Ni/l	1.1	20
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4970778	18/09/2024 08:33	Phosphorous (TOT)	mg P/l	1.6	
ZS0814AE	(CASTOR BAY MOIRA) customer tap sample	4970778	18/09/2024 08:33	Zinc	mg Zn/l	15	