

REFERENCE

2425341

RELEASE DATE

November 2024

SUBJECT

NI Water internal communications regarding water quality in Mid Ulster

REQUESTS & RESPONSES

NI Water can assure our customers that the water supplied from all our Water Treatment Works, which includes water abstracted from Lough Neagh, is safe to drink and was safe to drink during the specific period you reference in your request (June 2024 - September 2024).

On a daily basis, we monitor our raw water intakes from all sources, at our treatment works and at customer taps to ensure that drinking water supplied meets strict quality standards.

NI Water has a robust testing and sampling system which sees over 120,000 samples lifted and analysed each year. Sampling and analysis are carried out 365 days per year. Samples are taken from customer homes, reservoirs and treatment plants.

Drinking water supplied from the water treatment works which use Lough Neagh as their raw water sources, are designed with the potential for algae to be present and robust treatment processes are in place to manage this effectively.

We increase the frequency of algae monitoring over the summer months when the risk for algae in the raw water would generally be higher.

Increased levels of algae can cause an unusual taste and smell to water from your tap but does not pose a risk to health. The taste and smell can be earthy and/or musty. Therefore, while the water from your tap can be used in the normal way, we fully appreciate some customers might notice a difference in the taste and/or odour to their drinking water at this time.

- <https://www.niwater.com/news-detail/12350/Your-water-is-safe-to-drink/>
<https://www.niwater.com/news-detail/12565/Taste-and-smell-issues-affecting-water-supply/>
- <https://www.niwater.com/news-detail/12552/NI-Water-welcomes-stakeholders-to-Moyola-Water-Treatment-Works/>

For full transparency, Annex A attached also provides full water quality results for the period June 2024 to September 2024, for Mid-Ulster (defined by NI Water as Mid Ulster District Council areas, as shown in the map taken from our annual drinking water quality report (Page 57 refers), which also shows the water quality supply zones marked which are wholly or partially in the council area.) and includes the following water supply zones (wholly or partially).

2023 water supply zones wholly or partially within the council area:

Zone Code	Zone Name	Zone Code	Zone Name
ZN0103	Ballinrees South	ZN0706	Lough Macrory Killyclogher
ZN0501	Moyola Magherafelt	ZN0804	Killyhevlin East
ZN0502	Lough Fea Cookstown	ZN1102	Seagahan Armagh
ZN0504	Moyola Unagh Mormeal	ZS0809	Castor Bay Dungannon
ZN0505	Moneymore	ZS0811	Castor Bay Portadown
ZN0705	Lough Macrory Beragh		

The above supply zones include the following Water Treatment Works – Moyola, Moneymore, Lough Fea, Lough Macrory, Castor Bay, Killyhevlin and Seagahan, the water quality results for same are detailed in pages 1-256.

Service Reservoir water quality is provided on pages 257-455 and customer tap water quality on pages 456-608.

Specific to your information access requests: -

Mobile phone communications

Communications (calls and text messages) from the work mobiles of NI Water staff are only held by the mobile phone network provider EE and not disclosable without a Court Order or Police Summons.

<https://ee.co.uk/help/cyber-security/getting-started/request-my-personal-data>

As such Regulation 12(4)(a) (Information not held) provides that a public authority may refuse to disclose information to the extent that it does not hold that information when an applicant's request is received. All exceptions under the Regulations are qualified and so, in deciding whether or not to disclose the requested information, NI Water must consider the public interest. However, this is not possible where the information is not held.

Emails, letters, memos and briefing documents

There is a public interest in the information requested being released because this would demonstrate NI Water's willingness to be open and transparent about topical issues.

Against this, NI Water has considered that the information requested relates to communications at Senior Management and Director level. As such, these types of communication must be handled more sensitively than more routine correspondence, especially given the external scrutiny such discussions would attract if disclosed to the public domain via the EIR.

The Information Commissioner accepts that a public authority like NI Water needs a safe, private, thinking space to debate live issues, various options and reach decisions and deliberations away from external interference and distraction.

There is a strong public interest in companies (whether they are government-owned or not) having a space in which to thoroughly discuss matters of public concern and the disclosure of such discussions, can cause a "chilling effect", meaning that such discussions may not be as thorough or as open, which would not serve the public interest in ensuring NI Water's number one priority, the quality and safety of public drinking water.

Releasing such internal communications into the public domain would distract public debate away from the substantive environmental issues that the information relates to. Instead, debate could focus on secondary issues. As such NI Water find the release of same lawfully exempt under Regulation 12(4)(e) of the EIRs, Internal Communications.

WATER TREATMENT WORKS

Sample Point	Location	Sample Id	Sample Date	Parameter	Units	Auth Result	PCV Limit
W2308POUT	Castor Bay PPP Final Water Outlet	4922019	01/06/2024 07:53	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4922019	01/06/2024 07:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4922019	01/06/2024 07:53	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4922019	01/06/2024 07:53	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4922019	01/06/2024 07:53	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4922019	01/06/2024 07:53	Free - Residual disinfectant	mg Cl/l	1.64	
W2308POUT	Castor Bay PPP Final Water Outlet	4922019	01/06/2024 07:53	Hydrogen Ion	pH value	7.4	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4922019	01/06/2024 07:53	Total - Residual disinfectant	mg Cl/l	1.82	
W2308POUT	Castor Bay PPP Final Water Outlet	4922019	01/06/2024 07:53	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4922019	01/06/2024 07:53	Turbidity	NTU	0.16	1
W1301POUT	Moyola PPP Final Water Outlet	4922021	01/06/2024 08:45	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4922021	01/06/2024 08:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4922021	01/06/2024 08:45	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4922021	01/06/2024 08:45	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4922021	01/06/2024 08:45	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4922021	01/06/2024 08:45	Free - Residual disinfectant	mg Cl/l	1.33	
W1301POUT	Moyola PPP Final Water Outlet	4922021	01/06/2024 08:45	Hydrogen Ion	pH value	7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4922021	01/06/2024 08:45	Total - Residual disinfectant	mg Cl/l	1.41	
W1301POUT	Moyola PPP Final Water Outlet	4922021	01/06/2024 08:45	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4922021	01/06/2024 08:45	Turbidity	NTU	0.15	1
W1302OUT	Lough Fea Final Water Outlet	4922016	01/06/2024 09:21	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4922016	01/06/2024 09:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4922016	01/06/2024 09:21	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4922016	01/06/2024 09:21	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4922016	01/06/2024 09:21	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4922016	01/06/2024 09:21	Free - Residual disinfectant	mg Cl/l	0.9	
W1302OUT	Lough Fea Final Water Outlet	4922016	01/06/2024 09:21	Hydrogen Ion	pH value	7.1	9.5
W1302OUT	Lough Fea Final Water Outlet	4922016	01/06/2024 09:21	Total - Residual disinfectant	mg Cl/l	0.95	
W1302OUT	Lough Fea Final Water Outlet	4922016	01/06/2024 09:21	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4922016	01/06/2024 09:21	Turbidity	NTU	0.17	1
W4701OUT	Killyhevlin Final Water Outlet	4922017	01/06/2024 10:46	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4922017	01/06/2024 10:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4922017	01/06/2024 10:46	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4922017	01/06/2024 10:46	Conductivity	uS/cm 20 C	460	2500
W4701OUT	Killyhevlin Final Water Outlet	4922017	01/06/2024 10:46	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4922017	01/06/2024 10:46	Free - Residual disinfectant	mg Cl/l	1.62	
W4701OUT	Killyhevlin Final Water Outlet	4922017	01/06/2024 10:46	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4922017	01/06/2024 10:46	Total - Residual disinfectant	mg Cl/l	1.71	
W4701OUT	Killyhevlin Final Water Outlet	4922017	01/06/2024 10:46	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4922017	01/06/2024 10:46	Turbidity	NTU	0.26	1
W2308POUT	Castor Bay PPP Final Water Outlet	4922037	02/06/2024 07:09	Colony Counts 22	CFU/1 ml	1	

W2308POUT	Castor Bay PPP Final Water Outlet	4922037	02/06/2024 07:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4922037	02/06/2024 07:09	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4922037	02/06/2024 07:09	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4922037	02/06/2024 07:09	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4922037	02/06/2024 07:09	Free - Residual disinfectant	mg Cl/l	1.17	
W2308POUT	Castor Bay PPP Final Water Outlet	4922037	02/06/2024 07:09	Hydrogen Ion	pH value	7.4	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4922037	02/06/2024 07:09	Total - Residual disinfectant	mg Cl/l	1.41	
W2308POUT	Castor Bay PPP Final Water Outlet	4922037	02/06/2024 07:09	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4922037	02/06/2024 07:09	Turbidity	NTU	0.18	1
W1301POUT	Moyola PPP Final Water Outlet	4922039	02/06/2024 08:49	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4922039	02/06/2024 08:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4922039	02/06/2024 08:49	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4922039	02/06/2024 08:49	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4922039	02/06/2024 08:49	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4922039	02/06/2024 08:49	Free - Residual disinfectant	mg Cl/l	1.51	
W1301POUT	Moyola PPP Final Water Outlet	4922039	02/06/2024 08:49	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4922039	02/06/2024 08:49	Total - Residual disinfectant	mg Cl/l	1.59	
W1301POUT	Moyola PPP Final Water Outlet	4922039	02/06/2024 08:49	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4922039	02/06/2024 08:49	Turbidity	NTU	0.14	1
W1302OUT	Lough Fea Final Water Outlet	4922034	02/06/2024 09:29	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4922034	02/06/2024 09:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4922034	02/06/2024 09:29	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4922034	02/06/2024 09:29	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4922034	02/06/2024 09:29	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4922034	02/06/2024 09:29	Free - Residual disinfectant	mg Cl/l	0.9	
W1302OUT	Lough Fea Final Water Outlet	4922034	02/06/2024 09:29	Hydrogen Ion	pH value	7.1	9.5
W1302OUT	Lough Fea Final Water Outlet	4922034	02/06/2024 09:29	Total - Residual disinfectant	mg Cl/l	0.94	
W1302OUT	Lough Fea Final Water Outlet	4922034	02/06/2024 09:29	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4922034	02/06/2024 09:29	Turbidity	NTU	0.15	1
W4701OUT	Killyhevlin Final Water Outlet	4922035	02/06/2024 09:52	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4922035	02/06/2024 09:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4922035	02/06/2024 09:52	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4922035	02/06/2024 09:52	Conductivity	uS/cm 20 C	460	2500
W4701OUT	Killyhevlin Final Water Outlet	4922035	02/06/2024 09:52	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4922035	02/06/2024 09:52	Free - Residual disinfectant	mg Cl/l	1.51	
W4701OUT	Killyhevlin Final Water Outlet	4922035	02/06/2024 09:52	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4922035	02/06/2024 09:52	Total - Residual disinfectant	mg Cl/l	1.62	
W4701OUT	Killyhevlin Final Water Outlet	4922035	02/06/2024 09:52	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4922035	02/06/2024 09:52	Turbidity	NTU	0.28	1
W1301POUT	Moyola PPP Final Water Outlet	4924106	03/06/2024 07:41	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4924106	03/06/2024 07:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4924106	03/06/2024 07:41	Colour	mg/l Pt/Co	<4.56	20

W1301POUT	Moyola PPP Final Water Outlet	4924106	03/06/2024 07:41	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4924106	03/06/2024 07:41	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4924106	03/06/2024 07:41	Free - Residual disinfectant	mg Cl/l	1.51	
W1301POUT	Moyola PPP Final Water Outlet	4924106	03/06/2024 07:41	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4924106	03/06/2024 07:41	Total - Residual disinfectant	mg Cl/l	1.66	
W1301POUT	Moyola PPP Final Water Outlet	4924106	03/06/2024 07:41	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4924106	03/06/2024 07:41	Turbidity	NTU	0.28	1
W1302OUT	Lough Fea Final Water Outlet	4924076	03/06/2024 08:39	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4924076	03/06/2024 08:39	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4924076	03/06/2024 08:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4924076	03/06/2024 08:39	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4924076	03/06/2024 08:39	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4924076	03/06/2024 08:39	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4924076	03/06/2024 08:39	Free - Residual disinfectant	mg Cl/l	0.85	
W1302OUT	Lough Fea Final Water Outlet	4924076	03/06/2024 08:39	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4924076	03/06/2024 08:39	Nitrite	mg/l	<0.03	0.1
W1302OUT	Lough Fea Final Water Outlet	4924076	03/06/2024 08:39	Total - Residual disinfectant	mg Cl/l	0.9	
W1302OUT	Lough Fea Final Water Outlet	4924076	03/06/2024 08:39	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4924076	03/06/2024 08:39	Turbidity	NTU	0.15	1
W1302OUT	Lough Fea Final Water Outlet	4924076	03/06/2024 08:39	Aluminium	ug Al/l	21	200
W1302OUT	Lough Fea Final Water Outlet	4924076	03/06/2024 08:39	Bromodichloromethane	ug/l	8.1	
W1302OUT	Lough Fea Final Water Outlet	4924076	03/06/2024 08:39	Bromoform	ug/l	<3.5	
W1302OUT	Lough Fea Final Water Outlet	4924076	03/06/2024 08:39	Dibromochloromethane	ug/l	<1.6	
W1302OUT	Lough Fea Final Water Outlet	4924076	03/06/2024 08:39	Iron	ug/l Fe	2.7	200
W1302OUT	Lough Fea Final Water Outlet	4924076	03/06/2024 08:39	Manganese	ug Mn/l	<0.642	50
W1302OUT	Lough Fea Final Water Outlet	4924076	03/06/2024 08:39	Total Organic Carbon	mg C/l	1.6	
W1302OUT	Lough Fea Final Water Outlet	4924076	03/06/2024 08:39	WHO Index		0.28	1
W4701OUT	Killyhevlin Final Water Outlet	4924094	03/06/2024 09:27	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4924094	03/06/2024 09:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4924094	03/06/2024 09:27	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4924094	03/06/2024 09:27	Conductivity	uS/cm 20 C	470	2500
W4701OUT	Killyhevlin Final Water Outlet	4924094	03/06/2024 09:27	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4924094	03/06/2024 09:27	Free - Residual disinfectant	mg Cl/l	1.51	
W4701OUT	Killyhevlin Final Water Outlet	4924094	03/06/2024 09:27	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4924094	03/06/2024 09:27	Total - Residual disinfectant	mg Cl/l	1.62	
W4701OUT	Killyhevlin Final Water Outlet	4924094	03/06/2024 09:27	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4924094	03/06/2024 09:27	Turbidity	NTU	0.24	1
W2308POUT	Castor Bay PPP Final Water Outlet	4924103	03/06/2024 09:37	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4924103	03/06/2024 09:37	Colony Counts 37 (48hrs)	CFU/1 ml	1	
W2308POUT	Castor Bay PPP Final Water Outlet	4924103	03/06/2024 09:37	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4924103	03/06/2024 09:37	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4924103	03/06/2024 09:37	E. coli	CFU/100 ml	0	0

W2308POUT	Castor Bay PPP Final Water Outlet	4924103	03/06/2024 09:37	Free - Residual disinfectant	mg Cl/l	1.89	
W2308POUT	Castor Bay PPP Final Water Outlet	4924103	03/06/2024 09:37	Hydrogen Ion	pH value	7.4	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4924103	03/06/2024 09:37	Total - Residual disinfectant	mg Cl/l	1.98	
W2308POUT	Castor Bay PPP Final Water Outlet	4924103	03/06/2024 09:37	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4924103	03/06/2024 09:37	Turbidity	NTU	0.16	1
W2308POUT	Castor Bay PPP Final Water Outlet	4924103	03/06/2024 09:37	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4924103	03/06/2024 09:37	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4924103	03/06/2024 09:37	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4924103	03/06/2024 09:37	Taste - Nature		No taste	
W2514OUT	Seagahan Final Water Outlet	4924084	03/06/2024 10:55	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4924084	03/06/2024 10:55	Colony Counts 37 (48hrs)	CFU/1 ml	1	
W2514OUT	Seagahan Final Water Outlet	4924084	03/06/2024 10:55	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4924084	03/06/2024 10:55	Conductivity	uS/cm 20 C	320	2500
W2514OUT	Seagahan Final Water Outlet	4924084	03/06/2024 10:55	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4924084	03/06/2024 10:55	Free - Residual disinfectant	mg Cl/l	1.22	
W2514OUT	Seagahan Final Water Outlet	4924084	03/06/2024 10:55	Hydrogen Ion	pH value	7.3	9.5
W2514OUT	Seagahan Final Water Outlet	4924084	03/06/2024 10:55	Total - Residual disinfectant	mg Cl/l	1.41	
W2514OUT	Seagahan Final Water Outlet	4924084	03/06/2024 10:55	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4924084	03/06/2024 10:55	Turbidity	NTU	0.15	1
W1301POUT	Moyola PPP Final Water Outlet	4935830	03/06/2024 11:27	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4935830	03/06/2024 11:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4935830	03/06/2024 11:27	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4935830	03/06/2024 11:27	Free - Residual disinfectant	mg Cl/l	1.34	
W1301POUT	Moyola PPP Final Water Outlet	4935830	03/06/2024 11:27	Total - Residual disinfectant	mg Cl/l	1.43	
W1301POUT	Moyola PPP Final Water Outlet	4935830	03/06/2024 11:27	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4935830	03/06/2024 11:27	Turbidity	NTU	0.16	1
W4523OUT	Lough Macrory Final Water Outlet	4924077	03/06/2024 11:38	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4924077	03/06/2024 11:38	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4924077	03/06/2024 11:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4924077	03/06/2024 11:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4924077	03/06/2024 11:38	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4924077	03/06/2024 11:38	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4924077	03/06/2024 11:38	Conductivity	uS/cm 20 C	140	2500
W4523OUT	Lough Macrory Final Water Outlet	4924077	03/06/2024 11:38	Conductivity	uS/cm 20 C	140	2500
W4523OUT	Lough Macrory Final Water Outlet	4924077	03/06/2024 11:38	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4924077	03/06/2024 11:38	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4924077	03/06/2024 11:38	Free - Residual disinfectant	mg Cl/l	1.04	
W4523OUT	Lough Macrory Final Water Outlet	4924077	03/06/2024 11:38	Free - Residual disinfectant	mg Cl/l	1.04	
W4523OUT	Lough Macrory Final Water Outlet	4924077	03/06/2024 11:38	Hydrogen Ion	pH value	7.4	9.5
W4523OUT	Lough Macrory Final Water Outlet	4924077	03/06/2024 11:38	Hydrogen Ion	pH value	7.4	9.5
W4523OUT	Lough Macrory Final Water Outlet	4924077	03/06/2024 11:38	Total - Residual disinfectant	mg Cl/l	1.1	
W4523OUT	Lough Macrory Final Water Outlet	4924077	03/06/2024 11:38	Total - Residual disinfectant	mg Cl/l	1.1	

W4523OUT	Lough Macrory Final Water Outlet	4924077	03/06/2024 11:38	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4924077	03/06/2024 11:38	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4924077	03/06/2024 11:38	Turbidity	NTU	0.15	1
W4523OUT	Lough Macrory Final Water Outlet	4924077	03/06/2024 11:38	Turbidity	NTU	0.15	1
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Free - Residual disinfectant	mg Cl/l	1.4	
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Total - Residual disinfectant	mg Cl/l	1.45	
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Turbidity	NTU	0.15	1
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	2,4-D	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	2,4-DB	ug/l	<0.016	0.1
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Algae Blue Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Algae Diatom Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Algae Flagellate Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Algae Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Algae Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Aluminium	ug Al/l	25	200
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Asulam	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Bentazone	ug/l	<0.0044	0.1
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Bromoxynil	ug/l	<0.0079	0.1
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Clopyralid	ug/l	<0.0097	0.1
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Dichlorprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Geosmin	ng/l	<1.1	
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Iron	ug Fe/l	<14	200
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Manganese	ug Mn/l	<0.8	50
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	MCPA	ug/l	0.054	0.1
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	MCPB	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Mecoprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	MIB	ng/l	<1.9	
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Microcystin-LR	ug/l	<0.024	
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Propyzamide	ug/l	<0.012	0.1
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Second most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Third most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Total Organic Carbon	mg C/l	2.7	
W1301POUT	Moyola PPP Final Water Outlet	4924426	04/06/2024 07:49	Triclopyr	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4937362	04/06/2024 08:00	Colony Counts 22	CFU/1 ml	0	

W2308POUT	Castor Bay PPP Final Water Outlet	4937362	04/06/2024 08:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4937362	04/06/2024 08:00	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4937362	04/06/2024 08:00	Free - Residual disinfectant	mg Cl/l	1.34	
W2308POUT	Castor Bay PPP Final Water Outlet	4937362	04/06/2024 08:00	Total - Residual disinfectant	mg Cl/l	1.51	
W2308POUT	Castor Bay PPP Final Water Outlet	4937362	04/06/2024 08:00	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4937362	04/06/2024 08:00	Turbidity	NTU	0.17	1
W1316OUT	Money more Borewell Final Water Outlet	4924434	04/06/2024 08:38	Colony Counts 22	CFU/1 ml	0	
W1316OUT	Money more Borewell Final Water Outlet	4924434	04/06/2024 08:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1316OUT	Money more Borewell Final Water Outlet	4924434	04/06/2024 08:38	Colour	mg/l Pt/Co	<4.56	20
W1316OUT	Money more Borewell Final Water Outlet	4924434	04/06/2024 08:38	Conductivity	uS/cm 20 C	350	2500
W1316OUT	Money more Borewell Final Water Outlet	4924434	04/06/2024 08:38	E. coli	CFU/100 ml	0	0
W1316OUT	Money more Borewell Final Water Outlet	4924434	04/06/2024 08:38	Free - Residual disinfectant	mg Cl/l	0.52	
W1316OUT	Money more Borewell Final Water Outlet	4924434	04/06/2024 08:38	Hydrogen Ion	pH value	7.8	9.5
W1316OUT	Money more Borewell Final Water Outlet	4924434	04/06/2024 08:38	Nitrite	mg/l	<0.03	0.1
W1316OUT	Money more Borewell Final Water Outlet	4924434	04/06/2024 08:38	Total - Residual disinfectant	mg Cl/l	0.58	
W1316OUT	Money more Borewell Final Water Outlet	4924434	04/06/2024 08:38	Total Coliforms	CFU/100 ml	0	0
W1316OUT	Money more Borewell Final Water Outlet	4924434	04/06/2024 08:38	Turbidity	NTU	0.17	1
W1316OUT	Money more Borewell Final Water Outlet	4924434	04/06/2024 08:38	Aluminium	ug Al/l	27	200
W1316OUT	Money more Borewell Final Water Outlet	4924434	04/06/2024 08:38	Bromodichloromethane	ug/l	11	
W1316OUT	Money more Borewell Final Water Outlet	4924434	04/06/2024 08:38	Bromoform	ug/l	<3.5	
W1316OUT	Money more Borewell Final Water Outlet	4924434	04/06/2024 08:38	Dibromochloromethane	ug/l	7.3	
W1316OUT	Money more Borewell Final Water Outlet	4924434	04/06/2024 08:38	Iron	ug Fe/l	16	200
W1316OUT	Money more Borewell Final Water Outlet	4924434	04/06/2024 08:38	Manganese	ug Mn/l	<0.8	50
W1316OUT	Money more Borewell Final Water Outlet	4924434	04/06/2024 08:38	Total Organic Carbon	mg C/l	2.1	
W1316OUT	Money more Borewell Final Water Outlet	4924434	04/06/2024 08:38	WHO Index		0.34	1
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Conductivity	uS/cm 20 C	460	2500
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Free - Residual disinfectant	mg Cl/l	1.54	
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Nitrite	mg/l	<0.03	0.1
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Total - Residual disinfectant	mg Cl/l	1.62	
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Turbidity	NTU	0.26	1
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Algae Blue Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Algae Diatom Total	per ml	40	
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Algae Flagellate Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Algae Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Algae Total	per ml	40	

W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Aluminium	ug Al/l	45	200
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Bromodichloromethane	ug/l	9.5	
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Bromoform	ug/l	<3.5	
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Chloroform	ug/l	26	
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Dibromochloromethane	ug/l	4	
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Geosmin	ng/l	<1.1	
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Iron	ug Fe/l	<14	200
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Manganese	ug Mn/l	15	50
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	MIB	ng/l	<1.9	
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Most numerous Algae		Fragilaria	
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Odour	Diln No	0	0
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Odour - Nature		No odour	
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Second most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Taste	Diln No	0	0
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Taste - Nature		No taste	
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Third most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Total Organic Carbon	mg C/l	2	
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	Total Trihalomethanes	ug/l	40	100
W4701OUT	Killyhevlin Final Water Outlet	4924417	04/06/2024 09:17	WHO Index		0.29	1
W4523OUT	Lough Macrory Final Water Outlet	4924406	04/06/2024 10:09	Colony Counts 22	CFU/1 ml	1	
W4523OUT	Lough Macrory Final Water Outlet	4924406	04/06/2024 10:09	Colony Counts 22	CFU/1 ml	1	
W4523OUT	Lough Macrory Final Water Outlet	4924406	04/06/2024 10:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4924406	04/06/2024 10:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4924406	04/06/2024 10:09	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4924406	04/06/2024 10:09	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4924406	04/06/2024 10:09	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4924406	04/06/2024 10:09	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4924406	04/06/2024 10:09	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4924406	04/06/2024 10:09	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4924406	04/06/2024 10:09	Free - Residual disinfectant	mg Cl/l	0.88	
W4523OUT	Lough Macrory Final Water Outlet	4924406	04/06/2024 10:09	Free - Residual disinfectant	mg Cl/l	0.88	
W4523OUT	Lough Macrory Final Water Outlet	4924406	04/06/2024 10:09	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4924406	04/06/2024 10:09	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4924406	04/06/2024 10:09	Total - Residual disinfectant	mg Cl/l	0.96	
W4523OUT	Lough Macrory Final Water Outlet	4924406	04/06/2024 10:09	Total - Residual disinfectant	mg Cl/l	0.96	
W4523OUT	Lough Macrory Final Water Outlet	4924406	04/06/2024 10:09	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4924406	04/06/2024 10:09	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4924406	04/06/2024 10:09	Turbidity	NTU	0.17	1
W4523OUT	Lough Macrory Final Water Outlet	4924406	04/06/2024 10:09	Turbidity	NTU	0.17	1
W1302OUT	Lough Fea Final Water Outlet	4924405	04/06/2024 10:44	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4924405	04/06/2024 10:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4924405	04/06/2024 10:44	Colour	mg/l Pt/Co	<4.56	20

W1302OUT	Lough Fea Final Water Outlet	4924405	04/06/2024 10:44	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4924405	04/06/2024 10:44	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4924405	04/06/2024 10:44	Free - Residual disinfectant	mg Cl/l	0.78	
W1302OUT	Lough Fea Final Water Outlet	4924405	04/06/2024 10:44	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4924405	04/06/2024 10:44	Nitrite	mg/l	<0.03	0.1
W1302OUT	Lough Fea Final Water Outlet	4924405	04/06/2024 10:44	Total - Residual disinfectant	mg Cl/l	0.8	
W1302OUT	Lough Fea Final Water Outlet	4924405	04/06/2024 10:44	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4924405	04/06/2024 10:44	Turbidity	NTU	0.14	1
W2514OUT	Seagahan Final Water Outlet	4924410	04/06/2024 10:59	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4924410	04/06/2024 10:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4924410	04/06/2024 10:59	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4924410	04/06/2024 10:59	Conductivity	uS/cm 20 C	340	2500
W2514OUT	Seagahan Final Water Outlet	4924410	04/06/2024 10:59	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4924410	04/06/2024 10:59	Free - Residual disinfectant	mg Cl/l	1.15	
W2514OUT	Seagahan Final Water Outlet	4924410	04/06/2024 10:59	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4924410	04/06/2024 10:59	Total - Residual disinfectant	mg Cl/l	1.28	
W2514OUT	Seagahan Final Water Outlet	4924410	04/06/2024 10:59	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4924410	04/06/2024 10:59	Turbidity	NTU	0.15	1
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Conductivity	uS/cm 20 C	400	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Free - Residual disinfectant	mg Cl/l	1.54	
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Hydrogen Ion	pH value	7.3	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Total - Residual disinfectant	mg Cl/l	1.68	
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Turbidity	NTU	0.17	1
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Algae Diatom Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Algae Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Aluminium	ug Al/l	21	200
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Bromodichloromethane	ug/l	7.3	
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Chloroform	ug/l	14	
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Dibromochloromethane	ug/l	3.9	
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Iron	ug Fe/l	<14	200
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Manganese	ug Mn/l	<0.8	50
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	MIB	ng/l	<1.9	

W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Microcystin-LR	ug/l	<0.024	
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Second most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Third most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Total Organic Carbon	mg C/l	2.6	
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	Total Trihalomethanes	ug/l	26	100
W2308POUT	Castor Bay PPP Final Water Outlet	4924421	04/06/2024 11:10	WHO Index		0.21	1
W1302OUT	Lough Fea Final Water Outlet	4924609	05/06/2024 09:35	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4924609	05/06/2024 09:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4924609	05/06/2024 09:35	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4924609	05/06/2024 09:35	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4924609	05/06/2024 09:35	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4924609	05/06/2024 09:35	Free - Residual disinfectant	mg Cl/l	0.8	
W1302OUT	Lough Fea Final Water Outlet	4924609	05/06/2024 09:35	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4924609	05/06/2024 09:35	Total - Residual disinfectant	mg Cl/l	0.99	
W1302OUT	Lough Fea Final Water Outlet	4924609	05/06/2024 09:35	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4924609	05/06/2024 09:35	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Conductivity	uS/cm 20 C	340	2500
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Free - Residual disinfectant	mg Cl/l	1.18	
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Hydrogen Ion	pH value	7.4	9.5
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Nitrite	mg/l	<0.03	0.1
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Total - Residual disinfectant	mg Cl/l	1.31	
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Algae Blue Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Algae Diatom Total	per ml	40	
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Algae Flagellate Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Algae Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Algae Total	per ml	40	
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Aluminium	ug Al/l	6.2	200
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Bromodichloromethane	ug/l	11	
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Bromoform	ug/l	<3.5	
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Chloroform	ug/l	22	

W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Dibromochloromethane	ug/l	4.2	
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Geosmin	ng/l	<1.1	
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Iron	ug Fe/l	<14	200
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Manganese	ug Mn/l	<0.8	50
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	MIB	ng/l	<1.9	
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Microcystin-LR	ug/l	<0.024	
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Most numerous Algae		Diatoma	
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Second most numerous Algae		---	
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Third most numerous Algae		---	
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Total Organic Carbon	mg C/l	2.3	
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	Total Trihalomethanes	ug/l	38	100
W2514OUT	Seagahan Final Water Outlet	4924614	05/06/2024 10:02	WHO Index		0.3	1
W1301POUT	Moyola PPP Final Water Outlet	4924624	05/06/2024 10:16	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4924624	05/06/2024 10:16	Colony Counts 37 (48hrs)	CFU/1 ml	1	
W1301POUT	Moyola PPP Final Water Outlet	4924624	05/06/2024 10:16	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4924624	05/06/2024 10:16	Conductivity	uS/cm 20 C	350	2500
W1301POUT	Moyola PPP Final Water Outlet	4924624	05/06/2024 10:16	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4924624	05/06/2024 10:16	Free - Residual disinfectant	mg Cl/l	1.28	
W1301POUT	Moyola PPP Final Water Outlet	4924624	05/06/2024 10:16	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4924624	05/06/2024 10:16	Total - Residual disinfectant	mg Cl/l	1.41	
W1301POUT	Moyola PPP Final Water Outlet	4924624	05/06/2024 10:16	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4924624	05/06/2024 10:16	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4924610	05/06/2024 10:54	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4924610	05/06/2024 10:54	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4924610	05/06/2024 10:54	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4924610	05/06/2024 10:54	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4924610	05/06/2024 10:54	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4924610	05/06/2024 10:54	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4924610	05/06/2024 10:54	Conductivity	uS/cm 20 C	140	2500
W4523OUT	Lough Macrory Final Water Outlet	4924610	05/06/2024 10:54	Conductivity	uS/cm 20 C	140	2500
W4523OUT	Lough Macrory Final Water Outlet	4924610	05/06/2024 10:54	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4924610	05/06/2024 10:54	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4924610	05/06/2024 10:54	Free - Residual disinfectant	mg Cl/l	0.89	
W4523OUT	Lough Macrory Final Water Outlet	4924610	05/06/2024 10:54	Free - Residual disinfectant	mg Cl/l	0.89	
W4523OUT	Lough Macrory Final Water Outlet	4924610	05/06/2024 10:54	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4924610	05/06/2024 10:54	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4924610	05/06/2024 10:54	Total - Residual disinfectant	mg Cl/l	1	
W4523OUT	Lough Macrory Final Water Outlet	4924610	05/06/2024 10:54	Total - Residual disinfectant	mg Cl/l	1	
W4523OUT	Lough Macrory Final Water Outlet	4924610	05/06/2024 10:54	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4924610	05/06/2024 10:54	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4924610	05/06/2024 10:54	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4924610	05/06/2024 10:54	Turbidity	NTU	<0.09	1

W2308POUT	Castor Bay PPP Final Water Outlet	4924622	05/06/2024 11:10	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4924622	05/06/2024 11:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4924622	05/06/2024 11:10	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4924622	05/06/2024 11:10	Conductivity	uS/cm 20 C	400	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4924622	05/06/2024 11:10	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4924622	05/06/2024 11:10	Free - Residual disinfectant	mg Cl/l	1.52	
W2308POUT	Castor Bay PPP Final Water Outlet	4924622	05/06/2024 11:10	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4924622	05/06/2024 11:10	Total - Residual disinfectant	mg Cl/l	1.64	
W2308POUT	Castor Bay PPP Final Water Outlet	4924622	05/06/2024 11:10	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4924622	05/06/2024 11:10	Turbidity	NTU	0.11	1
W2308POUT	Castor Bay PPP Final Water Outlet	4924622	05/06/2024 11:10	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4924622	05/06/2024 11:10	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4924622	05/06/2024 11:10	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4924622	05/06/2024 11:10	Taste - Nature		No taste	
W4701OUT	Killyhevlin Final Water Outlet	4924617	05/06/2024 11:30	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4924617	05/06/2024 11:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4924617	05/06/2024 11:30	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4924617	05/06/2024 11:30	Conductivity	uS/cm 20 C	470	2500
W4701OUT	Killyhevlin Final Water Outlet	4924617	05/06/2024 11:30	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4924617	05/06/2024 11:30	Free - Residual disinfectant	mg Cl/l	1.82	
W4701OUT	Killyhevlin Final Water Outlet	4924617	05/06/2024 11:30	Hydrogen Ion	pH value	7.6	9.5
W4701OUT	Killyhevlin Final Water Outlet	4924617	05/06/2024 11:30	Total - Residual disinfectant	mg Cl/l	1.9	
W4701OUT	Killyhevlin Final Water Outlet	4924617	05/06/2024 11:30	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4924617	05/06/2024 11:30	Turbidity	NTU	0.11	1
W2514OUT	Seagahan Final Water Outlet	4924802	06/06/2024 00:00	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4924802	06/06/2024 00:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4924802	06/06/2024 00:00	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4924802	06/06/2024 00:00	Conductivity	uS/cm 20 C	340	2500
W2514OUT	Seagahan Final Water Outlet	4924802	06/06/2024 00:00	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4924802	06/06/2024 00:00	Free - Residual disinfectant	mg Cl/l	1.28	
W2514OUT	Seagahan Final Water Outlet	4924802	06/06/2024 00:00	Hydrogen Ion	pH value	7.4	9.5
W2514OUT	Seagahan Final Water Outlet	4924802	06/06/2024 00:00	Total - Residual disinfectant	mg Cl/l	1.45	
W2514OUT	Seagahan Final Water Outlet	4924802	06/06/2024 00:00	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4924802	06/06/2024 00:00	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4924813	06/06/2024 08:27	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4924813	06/06/2024 08:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4924813	06/06/2024 08:27	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4924813	06/06/2024 08:27	Conductivity	uS/cm 20 C	350	2500
W1301POUT	Moyola PPP Final Water Outlet	4924813	06/06/2024 08:27	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4924813	06/06/2024 08:27	Free - Residual disinfectant	mg Cl/l	1.59	
W1301POUT	Moyola PPP Final Water Outlet	4924813	06/06/2024 08:27	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4924813	06/06/2024 08:27	Total - Residual disinfectant	mg Cl/l	1.68	

W1301POUT	Moyola PPP Final Water Outlet	4924813	06/06/2024 08:27	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4924813	06/06/2024 08:27	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4924807	06/06/2024 09:17	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4924807	06/06/2024 09:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4924807	06/06/2024 09:17	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4924807	06/06/2024 09:17	Conductivity	uS/cm 20 C	470	2500
W4701OUT	Killyhevlin Final Water Outlet	4924807	06/06/2024 09:17	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4924807	06/06/2024 09:17	Free - Residual disinfectant	mg Cl/l	1.76	
W4701OUT	Killyhevlin Final Water Outlet	4924807	06/06/2024 09:17	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4924807	06/06/2024 09:17	Total - Residual disinfectant	mg Cl/l	1.88	
W4701OUT	Killyhevlin Final Water Outlet	4924807	06/06/2024 09:17	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4924807	06/06/2024 09:17	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4924798	06/06/2024 10:21	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4924798	06/06/2024 10:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4924798	06/06/2024 10:21	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4924798	06/06/2024 10:21	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4924798	06/06/2024 10:21	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4924798	06/06/2024 10:21	Free - Residual disinfectant	mg Cl/l	0.79	
W1302OUT	Lough Fea Final Water Outlet	4924798	06/06/2024 10:21	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4924798	06/06/2024 10:21	Total - Residual disinfectant	mg Cl/l	0.81	
W1302OUT	Lough Fea Final Water Outlet	4924798	06/06/2024 10:21	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4924798	06/06/2024 10:21	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Free - Residual disinfectant	mg Cl/l	0.88	
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Free - Residual disinfectant	mg Cl/l	0.88	
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Nitrite	mg/l	<0.03	0.1
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Nitrite	mg/l	<0.03	0.1
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Total - Residual disinfectant	mg Cl/l	1	
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Total - Residual disinfectant	mg Cl/l	1	

W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Aluminium	ug Al/l	3.5	200
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Aluminium	ug Al/l	3.5	200
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Iron	ug Fe/l	<14	200
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Iron	ug Fe/l	<14	200
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Manganese	ug Mn/l	<0.8	50
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Manganese	ug Mn/l	<0.8	50
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Total Organic Carbon	mg C/l	1.4	
W4523OUT	Lough Macrory Final Water Outlet	4924799	06/06/2024 11:18	Total Organic Carbon	mg C/l	1.4	
W2308POUT	Castor Bay PPP Final Water Outlet	4924812	06/06/2024 11:25	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4924812	06/06/2024 11:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4924812	06/06/2024 11:25	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4924812	06/06/2024 11:25	Conductivity	uS/cm 20 C	400	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4924812	06/06/2024 11:25	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4924812	06/06/2024 11:25	Free - Residual disinfectant	mg Cl/l	1.57	
W2308POUT	Castor Bay PPP Final Water Outlet	4924812	06/06/2024 11:25	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4924812	06/06/2024 11:25	Total - Residual disinfectant	mg Cl/l	1.68	
W2308POUT	Castor Bay PPP Final Water Outlet	4924812	06/06/2024 11:25	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4924812	06/06/2024 11:25	Turbidity	NTU	0.1	1
W1301POUT	Moyola PPP Final Water Outlet	4924978	07/06/2024 07:39	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4924978	07/06/2024 07:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4924978	07/06/2024 07:39	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4924978	07/06/2024 07:39	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4924978	07/06/2024 07:39	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4924978	07/06/2024 07:39	Free - Residual disinfectant	mg Cl/l	1.3	
W1301POUT	Moyola PPP Final Water Outlet	4924978	07/06/2024 07:39	Hydrogen Ion	pH value	7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4924978	07/06/2024 07:39	Total - Residual disinfectant	mg Cl/l	1.58	
W1301POUT	Moyola PPP Final Water Outlet	4924978	07/06/2024 07:39	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4924978	07/06/2024 07:39	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4924971	07/06/2024 08:25	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4924971	07/06/2024 08:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4924971	07/06/2024 08:25	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4924971	07/06/2024 08:25	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4924971	07/06/2024 08:25	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4924971	07/06/2024 08:25	Free - Residual disinfectant	mg Cl/l	0.77	
W1302OUT	Lough Fea Final Water Outlet	4924971	07/06/2024 08:25	Hydrogen Ion	pH value	6.9	9.5
W1302OUT	Lough Fea Final Water Outlet	4924971	07/06/2024 08:25	Total - Residual disinfectant	mg Cl/l	0.79	
W1302OUT	Lough Fea Final Water Outlet	4924971	07/06/2024 08:25	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4924971	07/06/2024 08:25	Turbidity	NTU	<0.09	1

W2514OUT	Seagahan Final Water Outlet	4932913	07/06/2024 10:24	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4932913	07/06/2024 10:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4932913	07/06/2024 10:24	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4932913	07/06/2024 10:24	Free - Residual disinfectant	mg Cl/l	1.18	
W2514OUT	Seagahan Final Water Outlet	4932913	07/06/2024 10:24	Total - Residual disinfectant	mg Cl/l	1.37	
W2514OUT	Seagahan Final Water Outlet	4932913	07/06/2024 10:24	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4932913	07/06/2024 10:24	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4924973	07/06/2024 10:30	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4924973	07/06/2024 10:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4924973	07/06/2024 10:30	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4924973	07/06/2024 10:30	Conductivity	uS/cm 20 C	460	2500
W4701OUT	Killyhevlin Final Water Outlet	4924973	07/06/2024 10:30	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4924973	07/06/2024 10:30	Free - Residual disinfectant	mg Cl/l	1.48	
W4701OUT	Killyhevlin Final Water Outlet	4924973	07/06/2024 10:30	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4924973	07/06/2024 10:30	Total - Residual disinfectant	mg Cl/l	1.6	
W4701OUT	Killyhevlin Final Water Outlet	4924973	07/06/2024 10:30	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4924973	07/06/2024 10:30	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4924977	07/06/2024 10:58	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4924977	07/06/2024 10:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4924977	07/06/2024 10:58	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4924977	07/06/2024 10:58	Conductivity	uS/cm 20 C	400	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4924977	07/06/2024 10:58	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4924977	07/06/2024 10:58	Free - Residual disinfectant	mg Cl/l	1.73	
W2308POUT	Castor Bay PPP Final Water Outlet	4924977	07/06/2024 10:58	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4924977	07/06/2024 10:58	Total - Residual disinfectant	mg Cl/l	1.86	
W2308POUT	Castor Bay PPP Final Water Outlet	4924977	07/06/2024 10:58	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4924977	07/06/2024 10:58	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4925497	07/06/2024 11:13	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4925497	07/06/2024 11:13	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4925497	07/06/2024 11:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4925497	07/06/2024 11:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4925497	07/06/2024 11:13	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4925497	07/06/2024 11:13	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4925497	07/06/2024 11:13	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4925497	07/06/2024 11:13	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4925497	07/06/2024 11:13	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4925497	07/06/2024 11:13	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4925497	07/06/2024 11:13	Free - Residual disinfectant	mg Cl/l	0.8	
W4523OUT	Lough Macrory Final Water Outlet	4925497	07/06/2024 11:13	Free - Residual disinfectant	mg Cl/l	0.8	
W4523OUT	Lough Macrory Final Water Outlet	4925497	07/06/2024 11:13	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4925497	07/06/2024 11:13	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4925497	07/06/2024 11:13	Total - Residual disinfectant	mg Cl/l	0.89	

W4523OUT	Lough Macrory Final Water Outlet	4925497	07/06/2024 11:13	Total - Residual disinfectant	mg Cl/l	0.89	
W4523OUT	Lough Macrory Final Water Outlet	4925497	07/06/2024 11:13	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4925497	07/06/2024 11:13	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4925497	07/06/2024 11:13	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4925497	07/06/2024 11:13	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4925023	08/06/2024 08:37	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4925023	08/06/2024 08:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4925023	08/06/2024 08:37	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4925023	08/06/2024 08:37	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4925023	08/06/2024 08:37	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4925023	08/06/2024 08:37	Free - Residual disinfectant	mg Cl/l	1.39	
W1301POUT	Moyola PPP Final Water Outlet	4925023	08/06/2024 08:37	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4925023	08/06/2024 08:37	Total - Residual disinfectant	mg Cl/l	1.42	
W1301POUT	Moyola PPP Final Water Outlet	4925023	08/06/2024 08:37	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4925023	08/06/2024 08:37	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4925019	08/06/2024 09:06	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4925019	08/06/2024 09:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4925019	08/06/2024 09:06	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4925019	08/06/2024 09:06	Conductivity	uS/cm 20 C	460	2500
W4701OUT	Killyhevlin Final Water Outlet	4925019	08/06/2024 09:06	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4925019	08/06/2024 09:06	Free - Residual disinfectant	mg Cl/l	1.1	
W4701OUT	Killyhevlin Final Water Outlet	4925019	08/06/2024 09:06	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4925019	08/06/2024 09:06	Total - Residual disinfectant	mg Cl/l	1.22	
W4701OUT	Killyhevlin Final Water Outlet	4925019	08/06/2024 09:06	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4925019	08/06/2024 09:06	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4925018	08/06/2024 09:15	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4925018	08/06/2024 09:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4925018	08/06/2024 09:15	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4925018	08/06/2024 09:15	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4925018	08/06/2024 09:15	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4925018	08/06/2024 09:15	Free - Residual disinfectant	mg Cl/l	0.85	
W1302OUT	Lough Fea Final Water Outlet	4925018	08/06/2024 09:15	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4925018	08/06/2024 09:15	Total - Residual disinfectant	mg Cl/l	0.9	
W1302OUT	Lough Fea Final Water Outlet	4925018	08/06/2024 09:15	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4925018	08/06/2024 09:15	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4925022	08/06/2024 09:58	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4925022	08/06/2024 09:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4925022	08/06/2024 09:58	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4925022	08/06/2024 09:58	Conductivity	uS/cm 20 C	390	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4925022	08/06/2024 09:58	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4925022	08/06/2024 09:58	Free - Residual disinfectant	mg Cl/l	1.59	
W2308POUT	Castor Bay PPP Final Water Outlet	4925022	08/06/2024 09:58	Hydrogen Ion	pH value	7.5	9.5

W2308POUT	Castor Bay PPP Final Water Outlet	4925022	08/06/2024 09:58	Total - Residual disinfectant	mg Cl/l	1.72	
W2308POUT	Castor Bay PPP Final Water Outlet	4925022	08/06/2024 09:58	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4925022	08/06/2024 09:58	Turbidity	NTU	0.25	1
W1301POUT	Moyola PPP Final Water Outlet	4925041	09/06/2024 08:30	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4925041	09/06/2024 08:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4925041	09/06/2024 08:30	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4925041	09/06/2024 08:30	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4925041	09/06/2024 08:30	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4925041	09/06/2024 08:30	Free - Residual disinfectant	mg Cl/l	1.34	
W1301POUT	Moyola PPP Final Water Outlet	4925041	09/06/2024 08:30	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4925041	09/06/2024 08:30	Total - Residual disinfectant	mg Cl/l	1.39	
W1301POUT	Moyola PPP Final Water Outlet	4925041	09/06/2024 08:30	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4925041	09/06/2024 08:30	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4925037	09/06/2024 09:02	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4925037	09/06/2024 09:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4925037	09/06/2024 09:02	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4925037	09/06/2024 09:02	Conductivity	uS/cm 20 C	460	2500
W4701OUT	Killyhevlin Final Water Outlet	4925037	09/06/2024 09:02	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4925037	09/06/2024 09:02	Free - Residual disinfectant	mg Cl/l	0.98	
W4701OUT	Killyhevlin Final Water Outlet	4925037	09/06/2024 09:02	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4925037	09/06/2024 09:02	Total - Residual disinfectant	mg Cl/l	1.14	
W4701OUT	Killyhevlin Final Water Outlet	4925037	09/06/2024 09:02	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4925037	09/06/2024 09:02	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4925036	09/06/2024 09:03	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4925036	09/06/2024 09:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4925036	09/06/2024 09:03	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4925036	09/06/2024 09:03	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4925036	09/06/2024 09:03	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4925036	09/06/2024 09:03	Free - Residual disinfectant	mg Cl/l	0.66	
W1302OUT	Lough Fea Final Water Outlet	4925036	09/06/2024 09:03	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4925036	09/06/2024 09:03	Total - Residual disinfectant	mg Cl/l	0.69	
W1302OUT	Lough Fea Final Water Outlet	4925036	09/06/2024 09:03	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4925036	09/06/2024 09:03	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4925040	09/06/2024 10:42	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4925040	09/06/2024 10:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4925040	09/06/2024 10:42	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4925040	09/06/2024 10:42	Conductivity	uS/cm 20 C	400	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4925040	09/06/2024 10:42	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4925040	09/06/2024 10:42	Free - Residual disinfectant	mg Cl/l	1.55	
W2308POUT	Castor Bay PPP Final Water Outlet	4925040	09/06/2024 10:42	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4925040	09/06/2024 10:42	Total - Residual disinfectant	mg Cl/l	1.69	
W2308POUT	Castor Bay PPP Final Water Outlet	4925040	09/06/2024 10:42	Total Coliforms	CFU/100 ml	0	0

W2308POUT	Castor Bay PPP Final Water Outlet	4925040	09/06/2024 10:42	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4927299	10/06/2024 07:13	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4927299	10/06/2024 07:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4927299	10/06/2024 07:13	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4927299	10/06/2024 07:13	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4927299	10/06/2024 07:13	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4927299	10/06/2024 07:13	Free - Residual disinfectant	mg Cl/l	1.44	
W1301POUT	Moyola PPP Final Water Outlet	4927299	10/06/2024 07:13	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4927299	10/06/2024 07:13	Total - Residual disinfectant	mg Cl/l	1.5	
W1301POUT	Moyola PPP Final Water Outlet	4927299	10/06/2024 07:13	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4927299	10/06/2024 07:13	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4927270	10/06/2024 08:00	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4927270	10/06/2024 08:00	Colony Counts 37 (48hrs)	CFU/1 ml	4	
W1302OUT	Lough Fea Final Water Outlet	4927270	10/06/2024 08:00	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4927270	10/06/2024 08:00	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4927270	10/06/2024 08:00	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4927270	10/06/2024 08:00	Free - Residual disinfectant	mg Cl/l	0.59	
W1302OUT	Lough Fea Final Water Outlet	4927270	10/06/2024 08:00	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4927270	10/06/2024 08:00	Total - Residual disinfectant	mg Cl/l	0.73	
W1302OUT	Lough Fea Final Water Outlet	4927270	10/06/2024 08:00	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4927270	10/06/2024 08:00	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	2,4-D	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	2,4-D	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	2,4-DB	ug/l	<0.016	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	2,4-DB	ug/l	<0.016	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Asulam	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Asulam	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Bentazone	ug/l	<0.0044	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Bentazone	ug/l	<0.0044	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Bromoxynil	ug/l	<0.0079	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Bromoxynil	ug/l	<0.0079	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Chlorotoluron	ug/l	<0.0031	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Chlorotoluron	ug/l	<0.0031	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Clopyralid	ug/l	<0.0097	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Clopyralid	ug/l	<0.0097	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Conductivity	uS/cm 20 C	130	2500

W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Cyanide	ug/l CN	<5.5	50
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Cyanide	ug/l CN	<5.5	50
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Dicamba	ug/l	<0.028	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Dicamba	ug/l	<0.028	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Dichlorprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Dichlorprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Diffenican	ug/l	<0.0072	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Diffenican	ug/l	<0.0072	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Dimethenamid	ug/l	<0.0063	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Dimethenamid	ug/l	<0.0063	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Diuron	ug/l	<0.0055	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Diuron	ug/l	<0.0055	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Epoxiconazole	ug/l	<0.0049	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Epoxiconazole	ug/l	<0.0049	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Fenpropimorph	ug/l	<0.0083	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Fenpropimorph	ug/l	<0.0083	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Flufenacet	ug/l	<0.0052	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Flufenacet	ug/l	<0.0052	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Fluroxypyr	ug/l	<0.0063	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Fluroxypyr	ug/l	<0.0063	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Free - Residual disinfectant	mg Cl/l	1.29	
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Free - Residual disinfectant	mg Cl/l	1.29	
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Glyphosate	ug/l	<0.0077	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Glyphosate	ug/l	<0.0077	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Hydrogen Ion	pH value	7.2	9.5
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Hydrogen Ion	pH value	7.2	9.5
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Isoproturon	ug/l	<0.0025	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Isoproturon	ug/l	<0.0025	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Linuron	ug/l	<0.0034	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Linuron	ug/l	<0.0034	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	MCPA	ug/l	<0.0093	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	MCPA	ug/l	<0.0093	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	MCPB	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	MCPB	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Mecoprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Mecoprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Metalaxyl	ug/l	<0.0097	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Metalaxyl	ug/l	<0.0097	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Metamitron	ug/l	<0.0074	0.1

W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Metamitron	ug/l	<0.0074	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Metoxuron	ug/l	<0.0080	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Metoxuron	ug/l	<0.0080	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Metribuzin	ug/l	<0.0060	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Metribuzin	ug/l	<0.0060	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Oxamyl	ug/l	<0.0023	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Oxamyl	ug/l	<0.0023	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Pesticides - Total Substances	ug/l	0	0.5
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Pesticides - Total Substances	ug/l	0	0.5
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Phorate	ug/l	<0.0092	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Phorate	ug/l	<0.0092	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Pirimicarb	ug/l	<0.0063	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Pirimicarb	ug/l	<0.0063	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Propiconazole	ug/l	<0.0029	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Propiconazole	ug/l	<0.0029	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Propyzamide	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Propyzamide	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Prothioconazole	ug/l	<0.0019	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Prothioconazole	ug/l	<0.0019	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Tebuconazole	ug/l	<0.0039	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Tebuconazole	ug/l	<0.0039	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Total - Residual disinfectant	mg Cl/l	1.54	
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Total - Residual disinfectant	mg Cl/l	1.54	
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Triclopyr	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Triclopyr	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Aluminium	ug Al/l	5.7	200
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Aluminium	ug Al/l	5.7	200
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Bromodichloromethane	ug/l	6.5	
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Bromodichloromethane	ug/l	6.5	
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Bromoform	ug/l	<3.5	
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Bromoform	ug/l	<3.5	
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Chloroform	ug/l	21	
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Chloroform	ug/l	21	
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Dibromochloromethane	ug/l	1.6	
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Dibromochloromethane	ug/l	1.6	
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Iron	ug Fe/l	<14	200
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Iron	ug Fe/l	<14	200
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Manganese	ug Mn/l	<0.8	50

W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Manganese	ug Mn/l	<0.8	50
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Total Organic Carbon	mg C/l	1.3	
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Total Organic Carbon	mg C/l	1.3	
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Total Trihalomethanes	ug/l	30	100
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	Total Trihalomethanes	ug/l	30	100
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	WHO Index		0.2	1
W4523OUT	Lough Macrory Final Water Outlet	4927271	10/06/2024 10:14	WHO Index		0.2	1
W4701OUT	Killyhevlin Final Water Outlet	4927287	10/06/2024 10:53	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4927287	10/06/2024 10:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4927287	10/06/2024 10:53	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4927287	10/06/2024 10:53	Conductivity	uS/cm 20 C	460	2500
W4701OUT	Killyhevlin Final Water Outlet	4927287	10/06/2024 10:53	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4927287	10/06/2024 10:53	Free - Residual disinfectant	mg Cl/l	1.56	
W4701OUT	Killyhevlin Final Water Outlet	4927287	10/06/2024 10:53	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4927287	10/06/2024 10:53	Total - Residual disinfectant	mg Cl/l	1.63	
W4701OUT	Killyhevlin Final Water Outlet	4927287	10/06/2024 10:53	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4927287	10/06/2024 10:53	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	2,4-D	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	2,4-DB	ug/l	<0.016	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Asulam	ug/l	<0.015	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Bentazone	ug/l	<0.0044	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Bromoxynil	ug/l	<0.0079	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Chlorotoluron	ug/l	<0.0031	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Clopyralid	ug/l	<0.0097	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Conductivity	uS/cm 20 C	340	2500
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Cyanide	ug/l CN	<5.5	50
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Dicamba	ug/l	<0.028	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Dichlorprop	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Diflufenican	ug/l	<0.0072	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Dimethenamid	ug/l	<0.0063	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Diuron	ug/l	<0.0055	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Epoxiconazole	ug/l	<0.0049	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Fenpropimorph	ug/l	<0.0083	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Flufenacet	ug/l	<0.0052	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Fluroxypyr	ug/l	<0.0063	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Free - Residual disinfectant	mg Cl/l	1.12	
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Glyphosate	ug/l	<0.0077	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Hydrogen Ion	pH value	7.5	9.5

W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Isoproturon	ug/l	<0.0025	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Linuron	ug/l	<0.0034	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	MCPA	ug/l	0.01	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	MCPB	ug/l	<0.015	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Mecoprop	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Metalaxyl	ug/l	<0.0097	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Metamitron	ug/l	<0.0074	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Metoxuron	ug/l	<0.0080	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Metribuzin	ug/l	<0.0060	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Oxamyl	ug/l	<0.0023	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Pesticides - Total Substances	ug/l	0.01	0.5
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Phorate	ug/l	<0.0092	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Pirimicarb	ug/l	<0.0063	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Propiconazole	ug/l	<0.0029	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Propyzamide	ug/l	<0.012	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Prothioconazole	ug/l	<0.0019	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Tebuconazole	ug/l	<0.0039	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Total - Residual disinfectant	mg Cl/l	1.3	
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Triclopyr	ug/l	<0.012	0.1
W2514OUT	Seagahan Final Water Outlet	4927277	10/06/2024 10:54	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4927296	10/06/2024 11:12	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4927296	10/06/2024 11:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4927296	10/06/2024 11:12	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4927296	10/06/2024 11:12	Conductivity	uS/cm 20 C	390	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4927296	10/06/2024 11:12	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4927296	10/06/2024 11:12	Free - Residual disinfectant	mg Cl/l	1.68	
W2308POUT	Castor Bay PPP Final Water Outlet	4927296	10/06/2024 11:12	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4927296	10/06/2024 11:12	Total - Residual disinfectant	mg Cl/l	1.8	
W2308POUT	Castor Bay PPP Final Water Outlet	4927296	10/06/2024 11:12	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4927296	10/06/2024 11:12	Turbidity	NTU	0.33	1
W2308POUT	Castor Bay PPP Final Water Outlet	4927296	10/06/2024 11:12	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4927296	10/06/2024 11:12	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4927296	10/06/2024 11:12	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4927296	10/06/2024 11:12	Taste - Nature		No taste	
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	2,4-D	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	2,4-DB	ug/l	<0.016	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Asulam	ug/l	<0.015	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Bentazone	ug/l	<0.0044	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Bromoxynil	ug/l	<0.0079	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Chlorotoluron	ug/l	<0.0031	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Clopyralid	ug/l	<0.0097	0.1

W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Cyanide	ug/l CN	<5.5	50
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Dicamba	ug/l	<0.028	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Dichlorprop	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Diffufenican	ug/l	<0.0072	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Dimethenamid	ug/l	<0.0063	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Diuron	ug/l	<0.0055	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Epoconazole	ug/l	<0.0049	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Fenpropimorph	ug/l	<0.0083	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Flufenacet	ug/l	<0.0052	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Fluroxypyr	ug/l	<0.0063	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Free - Residual disinfectant	mg Cl/l	0.72	
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Glyphosate	ug/l	<0.0077	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Isoproturon	ug/l	<0.0025	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Linuron	ug/l	<0.0034	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	MCPA	ug/l	<0.0093	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	MCPB	ug/l	<0.015	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Mecoprop	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Metalaxyl	ug/l	<0.0097	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Metamitron	ug/l	<0.0074	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Metoxuron	ug/l	<0.0080	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Metribuzin	ug/l	<0.0060	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Oxamyl	ug/l	<0.0023	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Pesticides - Total Substances	ug/l	0	0.5
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Phorate	ug/l	<0.0092	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Pirimicarb	ug/l	<0.0063	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Propiconazole	ug/l	<0.0029	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Propyzamide	ug/l	<0.012	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Prothioconazole	ug/l	<0.0019	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Tebuconazole	ug/l	<0.0039	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Total - Residual disinfectant	mg Cl/l	0.8	
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Triclopyr	ug/l	<0.012	0.1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Aluminium	ug Al/l	36	200
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Bromodichloromethane	ug/l	7.9	
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Bromoform	ug/l	<3.5	

W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Chloroform	ug/l	36	
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Dibromochloromethane	ug/l	<1.6	
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Iron	ug Fe/l	<14	200
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Manganese	ug Mn/l	<0.8	50
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Total Organic Carbon	mg C/l	1.6	
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	Total Trihalomethanes	ug/l	46	100
W1302OUT	Lough Fea Final Water Outlet	4927617	11/06/2024 08:15	WHO Index		0.27	1
W4701OUT	Killyhevlin Final Water Outlet	4927629	11/06/2024 08:46	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4927629	11/06/2024 08:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4927629	11/06/2024 08:46	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4927629	11/06/2024 08:46	Conductivity	uS/cm 20 C	480	2500
W4701OUT	Killyhevlin Final Water Outlet	4927629	11/06/2024 08:46	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4927629	11/06/2024 08:46	Free - Residual disinfectant	mg Cl/l	1.38	
W4701OUT	Killyhevlin Final Water Outlet	4927629	11/06/2024 08:46	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4927629	11/06/2024 08:46	Total - Residual disinfectant	mg Cl/l	1.46	
W4701OUT	Killyhevlin Final Water Outlet	4927629	11/06/2024 08:46	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4927629	11/06/2024 08:46	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	2,4-D	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	2,4-DB	ug/l	<0.016	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Asulam	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Bentazone	ug/l	<0.0044	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Bromoxynil	ug/l	<0.0079	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Chlorotoluron	ug/l	<0.0031	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Clopyralid	ug/l	<0.0097	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Conductivity	uS/cm 20 C	390	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Cyanide	ug/l CN	<5.5	50
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Dicamba	ug/l	<0.028	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Dichlorprop	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Diflufenican	ug/l	<0.0072	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Dimethenamid	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Diuron	ug/l	<0.0055	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Epoxiconazole	ug/l	<0.0049	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Fenpropimorph	ug/l	<0.0083	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Flufenacet	ug/l	<0.0052	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Fluroxypyr	ug/l	0.0081	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Free - Residual disinfectant	mg Cl/l	1.33	
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Glyphosate	ug/l	<0.0077	0.1

W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Isoproturon	ug/l	<0.0025	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Linuron	ug/l	<0.0034	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	MCPA	ug/l	0.021	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	MCPB	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Mecoprop	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Metalaxyl	ug/l	<0.0097	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Metamitron	ug/l	<0.0074	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Metoxuron	ug/l	<0.0080	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Metribuzin	ug/l	<0.0060	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Nitrite	mg/l	<0.03	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Oxamyl	ug/l	<0.0023	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Pesticides - Total Substances	ug/l	0.0461	0.5
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Phorate	ug/l	<0.0092	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Pirimicarb	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Propiconazole	ug/l	<0.0029	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Propyzamide	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Prothioconazole	ug/l	<0.0019	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Tebuconazole	ug/l	<0.0039	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Total - Residual disinfectant	mg Cl/l	1.46	
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Triclopyr	ug/l	0.017	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Algae Diatom Total	per ml	40	
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Algae Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Algae Total	per ml	40	
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Aluminium	ug Al/l	19	200
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Bromodichloromethane	ug/l	7.2	
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Chloroform	ug/l	12	
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Dibromochloromethane	ug/l	4.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Iron	ug Fe/l	<14	200
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Manganese	ug Mn/l	<0.8	50
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	MIB	ng/l	<1.9	
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Microcystin-LR	ug/l	<0.024	
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Most numerous Algae		Melosira	
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Second most numerous Algae		---	

W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Third most numerous Algae		---	
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Total Organic Carbon	mg C/l	3.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	Total Trihalomethanes	ug/l	24	100
W2308POUT	Castor Bay PPP Final Water Outlet	4927633	11/06/2024 09:24	WHO Index		0.21	1
W2514OUT	Seagahan Final Water Outlet	4927626	11/06/2024 10:32	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4927626	11/06/2024 10:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4927626	11/06/2024 10:32	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4927626	11/06/2024 10:32	Conductivity	uS/cm 20 C	320	2500
W2514OUT	Seagahan Final Water Outlet	4927626	11/06/2024 10:32	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4927626	11/06/2024 10:32	Free - Residual disinfectant	mg Cl/l	1.13	
W2514OUT	Seagahan Final Water Outlet	4927626	11/06/2024 10:32	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4927626	11/06/2024 10:32	Total - Residual disinfectant	mg Cl/l	1.25	
W2514OUT	Seagahan Final Water Outlet	4927626	11/06/2024 10:32	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4927626	11/06/2024 10:32	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4927618	11/06/2024 11:30	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4927618	11/06/2024 11:30	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4927618	11/06/2024 11:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4927618	11/06/2024 11:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4927618	11/06/2024 11:30	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4927618	11/06/2024 11:30	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4927618	11/06/2024 11:30	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4927618	11/06/2024 11:30	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4927618	11/06/2024 11:30	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4927618	11/06/2024 11:30	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4927618	11/06/2024 11:30	Free - Residual disinfectant	mg Cl/l	0.88	
W4523OUT	Lough Macrory Final Water Outlet	4927618	11/06/2024 11:30	Free - Residual disinfectant	mg Cl/l	0.88	
W4523OUT	Lough Macrory Final Water Outlet	4927618	11/06/2024 11:30	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4927618	11/06/2024 11:30	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4927618	11/06/2024 11:30	Total - Residual disinfectant	mg Cl/l	0.97	
W4523OUT	Lough Macrory Final Water Outlet	4927618	11/06/2024 11:30	Total - Residual disinfectant	mg Cl/l	0.97	
W4523OUT	Lough Macrory Final Water Outlet	4927618	11/06/2024 11:30	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4927618	11/06/2024 11:30	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4927618	11/06/2024 11:30	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4927618	11/06/2024 11:30	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Free - Residual disinfectant	mg Cl/l	1.39	

W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Total - Residual disinfectant	mg Cl/l	1.52	
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	2,4-D	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	2,4-DB	ug/l	<0.016	0.1
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Algae Blue Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Algae Diatom Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Algae Flagellate Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Algae Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Algae Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Aluminium	ug Al/l	28	200
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Asulam	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Bentazone	ug/l	<0.0044	0.1
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Bromoxynil	ug/l	<0.0079	0.1
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Clopyralid	ug/l	<0.0097	0.1
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Dichlorprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Geosmin	ng/l	<1.1	
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Iron	ug Fe/l	<14	200
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Manganese	ug Mn/l	<0.8	50
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	MCPA	ug/l	<0.0093	0.1
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	MCPB	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Mecoprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	MIB	ng/l	<1.9	
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Microcystin-LR	ug/l	<0.024	
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Most numerous Algae		---	
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Propyzamide	ug/l	<0.012	0.1
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Second most numerous Algae		---	
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Taste - Nature		No taste	
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Third most numerous Algae		---	
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Total Organic Carbon	mg C/l	2.6	
W1301POUT	Moyola PPP Final Water Outlet	4927638	11/06/2024 11:52	Triclopyr	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4927826	12/06/2024 08:20	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4927826	12/06/2024 08:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4927826	12/06/2024 08:20	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4927826	12/06/2024 08:20	Conductivity	uS/cm 20 C	390	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4927826	12/06/2024 08:20	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4927826	12/06/2024 08:20	Free - Residual disinfectant	mg Cl/l	1.51	
W2308POUT	Castor Bay PPP Final Water Outlet	4927826	12/06/2024 08:20	Hydrogen Ion	pH value	7.6	9.5

W2308POUT	Castor Bay PPP Final Water Outlet	4927826	12/06/2024 08:20	Total - Residual disinfectant	mg Cl/l	1.65	
W2308POUT	Castor Bay PPP Final Water Outlet	4927826	12/06/2024 08:20	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4927826	12/06/2024 08:20	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4927826	12/06/2024 08:20	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4927826	12/06/2024 08:20	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4927826	12/06/2024 08:20	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4927826	12/06/2024 08:20	Taste - Nature		No taste	
W1302OUT	Lough Fea Final Water Outlet	4927810	12/06/2024 09:15	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4927810	12/06/2024 09:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4927810	12/06/2024 09:15	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4927810	12/06/2024 09:15	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4927810	12/06/2024 09:15	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4927810	12/06/2024 09:15	Free - Residual disinfectant	mg Cl/l	0.79	
W1302OUT	Lough Fea Final Water Outlet	4927810	12/06/2024 09:15	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4927810	12/06/2024 09:15	Total - Residual disinfectant	mg Cl/l	0.82	
W1302OUT	Lough Fea Final Water Outlet	4927810	12/06/2024 09:15	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4927810	12/06/2024 09:15	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4927811	12/06/2024 10:10	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4927811	12/06/2024 10:10	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4927811	12/06/2024 10:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4927811	12/06/2024 10:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4927811	12/06/2024 10:10	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4927811	12/06/2024 10:10	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4927811	12/06/2024 10:10	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4927811	12/06/2024 10:10	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4927811	12/06/2024 10:10	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4927811	12/06/2024 10:10	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4927811	12/06/2024 10:10	Free - Residual disinfectant	mg Cl/l	0.89	
W4523OUT	Lough Macrory Final Water Outlet	4927811	12/06/2024 10:10	Free - Residual disinfectant	mg Cl/l	0.89	
W4523OUT	Lough Macrory Final Water Outlet	4927811	12/06/2024 10:10	Hydrogen Ion	pH value	7.1	9.5
W4523OUT	Lough Macrory Final Water Outlet	4927811	12/06/2024 10:10	Hydrogen Ion	pH value	7.1	9.5
W4523OUT	Lough Macrory Final Water Outlet	4927811	12/06/2024 10:10	Total - Residual disinfectant	mg Cl/l	0.97	
W4523OUT	Lough Macrory Final Water Outlet	4927811	12/06/2024 10:10	Total - Residual disinfectant	mg Cl/l	0.97	
W4523OUT	Lough Macrory Final Water Outlet	4927811	12/06/2024 10:10	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4927811	12/06/2024 10:10	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4927811	12/06/2024 10:10	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4927811	12/06/2024 10:10	Turbidity	NTU	<0.09	1
W1316OUT	Moneymore Borewell Final Water Outlet	4927834	12/06/2024 10:29	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W1316OUT	Moneymore Borewell Final Water Outlet	4927834	12/06/2024 10:29	Colony Counts 22	CFU/1 ml	0	
W1316OUT	Moneymore Borewell Final Water Outlet	4927834	12/06/2024 10:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1316OUT	Moneymore Borewell Final Water Outlet	4927834	12/06/2024 10:29	Colour	mg/l Pt/Co	<4.56	20
W1316OUT	Moneymore Borewell Final Water Outlet	4927834	12/06/2024 10:29	Conductivity	uS/cm 20 C	360	2500

W1316OUT	Money more Borewell Final Water Outlet	4927834	12/06/2024 10:29	E. coli	CFU/100 ml	0	0
W1316OUT	Money more Borewell Final Water Outlet	4927834	12/06/2024 10:29	Free - Residual disinfectant	mg Cl/l	0.46	
W1316OUT	Money more Borewell Final Water Outlet	4927834	12/06/2024 10:29	Hydrogen Ion	pH value	7.7	9.5
W1316OUT	Money more Borewell Final Water Outlet	4927834	12/06/2024 10:29	Total - Residual disinfectant	mg Cl/l	0.58	
W1316OUT	Money more Borewell Final Water Outlet	4927834	12/06/2024 10:29	Total Coliforms	CFU/100 ml	0	0
W1316OUT	Money more Borewell Final Water Outlet	4927834	12/06/2024 10:29	Turbidity	NTU	<0.09	1
W1316OUT	Money more Borewell Final Water Outlet	4927834	12/06/2024 10:29	Aluminium	ug Al/l	26	200
W1316OUT	Money more Borewell Final Water Outlet	4927834	12/06/2024 10:29	Antimony	ug/l Sb	<0.18	5
W1316OUT	Money more Borewell Final Water Outlet	4927834	12/06/2024 10:29	Arsenic	ug/l As	1.1	10
W1316OUT	Money more Borewell Final Water Outlet	4927834	12/06/2024 10:29	Boron	mg/l B	<0.038	1000
W1316OUT	Money more Borewell Final Water Outlet	4927834	12/06/2024 10:29	Cadmium	ug/l Cd	<0.30	5
W1316OUT	Money more Borewell Final Water Outlet	4927834	12/06/2024 10:29	Chromium	ug/l Cr	1.4	50
W1316OUT	Money more Borewell Final Water Outlet	4927834	12/06/2024 10:29	Iron	ug Fe/l	17	200
W1316OUT	Money more Borewell Final Water Outlet	4927834	12/06/2024 10:29	Manganese	ug Mn/l	<0.8	50
W1316OUT	Money more Borewell Final Water Outlet	4927834	12/06/2024 10:29	Selenium	ug/l Se	<0.4	10
W1316OUT	Money more Borewell Final Water Outlet	4927834	12/06/2024 10:29	Total Organic Carbon	mg C/l	1.7	
W1301POUT	Moyola PPP Final Water Outlet	4927827	12/06/2024 11:01	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4927827	12/06/2024 11:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4927827	12/06/2024 11:01	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4927827	12/06/2024 11:01	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4927827	12/06/2024 11:01	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4927827	12/06/2024 11:01	Free - Residual disinfectant	mg Cl/l	1.38	
W1301POUT	Moyola PPP Final Water Outlet	4927827	12/06/2024 11:01	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4927827	12/06/2024 11:01	Total - Residual disinfectant	mg Cl/l	1.52	
W1301POUT	Moyola PPP Final Water Outlet	4927827	12/06/2024 11:01	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4927827	12/06/2024 11:01	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4927821	12/06/2024 11:04	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4927821	12/06/2024 11:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4927821	12/06/2024 11:04	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4927821	12/06/2024 11:04	Conductivity	uS/cm 20 C	470	2500
W4701OUT	Killyhevlin Final Water Outlet	4927821	12/06/2024 11:04	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4927821	12/06/2024 11:04	Free - Residual disinfectant	mg Cl/l	1.73	
W4701OUT	Killyhevlin Final Water Outlet	4927821	12/06/2024 11:04	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4927821	12/06/2024 11:04	Total - Residual disinfectant	mg Cl/l	2.16	
W4701OUT	Killyhevlin Final Water Outlet	4927821	12/06/2024 11:04	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4927821	12/06/2024 11:04	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4927821	12/06/2024 11:04	Algae Blue Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4927821	12/06/2024 11:04	Algae Diatom Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4927821	12/06/2024 11:04	Algae Flagellate Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4927821	12/06/2024 11:04	Algae Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4927821	12/06/2024 11:04	Algae Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4927821	12/06/2024 11:04	Aluminium	ug Al/l	32	200

W4701OUT	Killyhevlin Final Water Outlet	4927821	12/06/2024 11:04	Iron	ug Fe/l	<14	200
W4701OUT	Killyhevlin Final Water Outlet	4927821	12/06/2024 11:04	Manganese	ug Mn/l	6.7	50
W4701OUT	Killyhevlin Final Water Outlet	4927821	12/06/2024 11:04	Most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4927821	12/06/2024 11:04	Second most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4927821	12/06/2024 11:04	Third most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4927821	12/06/2024 11:04	Total Organic Carbon	mg C/l	2	
W2514OUT	Seagahan Final Water Outlet	4927814	12/06/2024 11:12	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4927814	12/06/2024 11:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4927814	12/06/2024 11:12	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4927814	12/06/2024 11:12	Conductivity	uS/cm 20 C	320	2500
W2514OUT	Seagahan Final Water Outlet	4927814	12/06/2024 11:12	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4927814	12/06/2024 11:12	Free - Residual disinfectant	mg Cl/l	1.03	
W2514OUT	Seagahan Final Water Outlet	4927814	12/06/2024 11:12	Hydrogen Ion	pH value	7.4	9.5
W2514OUT	Seagahan Final Water Outlet	4927814	12/06/2024 11:12	Total - Residual disinfectant	mg Cl/l	1.1	
W2514OUT	Seagahan Final Water Outlet	4927814	12/06/2024 11:12	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4927814	12/06/2024 11:12	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4927995	13/06/2024 08:19	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4927995	13/06/2024 08:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4927995	13/06/2024 08:19	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4927995	13/06/2024 08:19	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4927995	13/06/2024 08:19	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4927995	13/06/2024 08:19	Free - Residual disinfectant	mg Cl/l	1.41	
W1301POUT	Moyola PPP Final Water Outlet	4927995	13/06/2024 08:19	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4927995	13/06/2024 08:19	Total - Residual disinfectant	mg Cl/l	1.54	
W1301POUT	Moyola PPP Final Water Outlet	4927995	13/06/2024 08:19	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4927995	13/06/2024 08:19	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4927980	13/06/2024 09:07	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4927980	13/06/2024 09:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4927980	13/06/2024 09:07	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4927980	13/06/2024 09:07	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4927980	13/06/2024 09:07	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4927980	13/06/2024 09:07	Free - Residual disinfectant	mg Cl/l	0.89	
W1302OUT	Lough Fea Final Water Outlet	4927980	13/06/2024 09:07	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4927980	13/06/2024 09:07	Total - Residual disinfectant	mg Cl/l	0.96	
W1302OUT	Lough Fea Final Water Outlet	4927980	13/06/2024 09:07	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4927980	13/06/2024 09:07	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4927985	13/06/2024 09:35	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4927985	13/06/2024 09:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4927985	13/06/2024 09:35	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4927985	13/06/2024 09:35	Conductivity	uS/cm 20 C	340	2500
W2514OUT	Seagahan Final Water Outlet	4927985	13/06/2024 09:35	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4927985	13/06/2024 09:35	Free - Residual disinfectant	mg Cl/l	1.13	

W2514OUT	Seagahan Final Water Outlet	4927985	13/06/2024 09:35	Hydrogen Ion	pH value	7.4	9.5
W2514OUT	Seagahan Final Water Outlet	4927985	13/06/2024 09:35	Total - Residual disinfectant	mg Cl/l	1.24	
W2514OUT	Seagahan Final Water Outlet	4927985	13/06/2024 09:35	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4927985	13/06/2024 09:35	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4927985	13/06/2024 09:35	Algae Blue Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4927985	13/06/2024 09:35	Algae Diatom Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4927985	13/06/2024 09:35	Algae Flagellate Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4927985	13/06/2024 09:35	Algae Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4927985	13/06/2024 09:35	Algae Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4927985	13/06/2024 09:35	Aluminium	ug Al/l	5.8	200
W2514OUT	Seagahan Final Water Outlet	4927985	13/06/2024 09:35	Iron	ug Fe/l	<14	200
W2514OUT	Seagahan Final Water Outlet	4927985	13/06/2024 09:35	Manganese	ug Mn/l	<0.8	50
W2514OUT	Seagahan Final Water Outlet	4927985	13/06/2024 09:35	Most numerous Algae		---	
W2514OUT	Seagahan Final Water Outlet	4927985	13/06/2024 09:35	Second most numerous Algae		---	
W2514OUT	Seagahan Final Water Outlet	4927985	13/06/2024 09:35	Third most numerous Algae		---	
W2514OUT	Seagahan Final Water Outlet	4927985	13/06/2024 09:35	Total Organic Carbon	mg C/l	2.3	
W4523OUT	Lough Macrory Final Water Outlet	4927981	13/06/2024 11:02	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4927981	13/06/2024 11:02	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4927981	13/06/2024 11:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4927981	13/06/2024 11:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4927981	13/06/2024 11:02	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4927981	13/06/2024 11:02	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4927981	13/06/2024 11:02	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4927981	13/06/2024 11:02	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4927981	13/06/2024 11:02	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4927981	13/06/2024 11:02	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4927981	13/06/2024 11:02	Free - Residual disinfectant	mg Cl/l	0.96	
W4523OUT	Lough Macrory Final Water Outlet	4927981	13/06/2024 11:02	Free - Residual disinfectant	mg Cl/l	0.96	
W4523OUT	Lough Macrory Final Water Outlet	4927981	13/06/2024 11:02	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4927981	13/06/2024 11:02	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4927981	13/06/2024 11:02	Total - Residual disinfectant	mg Cl/l	1.04	
W4523OUT	Lough Macrory Final Water Outlet	4927981	13/06/2024 11:02	Total - Residual disinfectant	mg Cl/l	1.04	
W4523OUT	Lough Macrory Final Water Outlet	4927981	13/06/2024 11:02	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4927981	13/06/2024 11:02	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4927981	13/06/2024 11:02	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4927981	13/06/2024 11:02	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4927988	13/06/2024 11:33	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4927988	13/06/2024 11:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4927988	13/06/2024 11:33	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4927988	13/06/2024 11:33	Conductivity	uS/cm 20 C	450	2500
W4701OUT	Killyhevlin Final Water Outlet	4927988	13/06/2024 11:33	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4927988	13/06/2024 11:33	Free - Residual disinfectant	mg Cl/l	1.5	

W4701OUT	Killyhevlin Final Water Outlet	4927988	13/06/2024 11:33	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4927988	13/06/2024 11:33	Total - Residual disinfectant	mg Cl/l	1.8	
W4701OUT	Killyhevlin Final Water Outlet	4927988	13/06/2024 11:33	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4927988	13/06/2024 11:33	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4927992	13/06/2024 11:45	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4927992	13/06/2024 11:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4927992	13/06/2024 11:45	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4927992	13/06/2024 11:45	Conductivity	uS/cm 20 C	390	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4927992	13/06/2024 11:45	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4927992	13/06/2024 11:45	Free - Residual disinfectant	mg Cl/l	1.65	
W2308POUT	Castor Bay PPP Final Water Outlet	4927992	13/06/2024 11:45	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4927992	13/06/2024 11:45	Total - Residual disinfectant	mg Cl/l	1.81	
W2308POUT	Castor Bay PPP Final Water Outlet	4927992	13/06/2024 11:45	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4927992	13/06/2024 11:45	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4928160	14/06/2024 07:48	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4928160	14/06/2024 07:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4928160	14/06/2024 07:48	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4928160	14/06/2024 07:48	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4928160	14/06/2024 07:48	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4928160	14/06/2024 07:48	Free - Residual disinfectant	mg Cl/l	1.47	
W1301POUT	Moyola PPP Final Water Outlet	4928160	14/06/2024 07:48	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4928160	14/06/2024 07:48	Total - Residual disinfectant	mg Cl/l	1.5	
W1301POUT	Moyola PPP Final Water Outlet	4928160	14/06/2024 07:48	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4928160	14/06/2024 07:48	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4928153	14/06/2024 09:31	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4928153	14/06/2024 09:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4928153	14/06/2024 09:31	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4928153	14/06/2024 09:31	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4928153	14/06/2024 09:31	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4928153	14/06/2024 09:31	Free - Residual disinfectant	mg Cl/l	0.89	
W1302OUT	Lough Fea Final Water Outlet	4928153	14/06/2024 09:31	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4928153	14/06/2024 09:31	Total - Residual disinfectant	mg Cl/l	0.93	
W1302OUT	Lough Fea Final Water Outlet	4928153	14/06/2024 09:31	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4928153	14/06/2024 09:31	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4932880	14/06/2024 10:28	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4932880	14/06/2024 10:28	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4932880	14/06/2024 10:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4932880	14/06/2024 10:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4932880	14/06/2024 10:28	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4932880	14/06/2024 10:28	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4932880	14/06/2024 10:28	Free - Residual disinfectant	mg Cl/l	0.93	
W4523OUT	Lough Macrory Final Water Outlet	4932880	14/06/2024 10:28	Free - Residual disinfectant	mg Cl/l	0.93	

W4523OUT	Lough Macrory Final Water Outlet	4932880	14/06/2024 10:28	Total - Residual disinfectant	mg Cl/l	1.01	
W4523OUT	Lough Macrory Final Water Outlet	4932880	14/06/2024 10:28	Total - Residual disinfectant	mg Cl/l	1.01	
W4523OUT	Lough Macrory Final Water Outlet	4932880	14/06/2024 10:28	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4932880	14/06/2024 10:28	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4932880	14/06/2024 10:28	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4932880	14/06/2024 10:28	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4928155	14/06/2024 10:29	Colony Counts 22	CFU/1 ml	1	
W4701OUT	Killyhevlin Final Water Outlet	4928155	14/06/2024 10:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4928155	14/06/2024 10:29	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4928155	14/06/2024 10:29	Conductivity	uS/cm 20 C	460	2500
W4701OUT	Killyhevlin Final Water Outlet	4928155	14/06/2024 10:29	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4928155	14/06/2024 10:29	Free - Residual disinfectant	mg Cl/l	1.25	
W4701OUT	Killyhevlin Final Water Outlet	4928155	14/06/2024 10:29	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4928155	14/06/2024 10:29	Total - Residual disinfectant	mg Cl/l	1.36	
W4701OUT	Killyhevlin Final Water Outlet	4928155	14/06/2024 10:29	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4928155	14/06/2024 10:29	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4928159	14/06/2024 11:03	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4928159	14/06/2024 11:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4928159	14/06/2024 11:03	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4928159	14/06/2024 11:03	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4928159	14/06/2024 11:03	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4928159	14/06/2024 11:03	Free - Residual disinfectant	mg Cl/l	1.39	
W2308POUT	Castor Bay PPP Final Water Outlet	4928159	14/06/2024 11:03	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4928159	14/06/2024 11:03	Total - Residual disinfectant	mg Cl/l	1.53	
W2308POUT	Castor Bay PPP Final Water Outlet	4928159	14/06/2024 11:03	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4928159	14/06/2024 11:03	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4928253	15/06/2024 07:36	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4928253	15/06/2024 07:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4928253	15/06/2024 07:36	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4928253	15/06/2024 07:36	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4928253	15/06/2024 07:36	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4928253	15/06/2024 07:36	Free - Residual disinfectant	mg Cl/l	0.85	
W1302OUT	Lough Fea Final Water Outlet	4928253	15/06/2024 07:36	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4928253	15/06/2024 07:36	Total - Residual disinfectant	mg Cl/l	0.88	
W1302OUT	Lough Fea Final Water Outlet	4928253	15/06/2024 07:36	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4928253	15/06/2024 07:36	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4928258	15/06/2024 08:11	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4928258	15/06/2024 08:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4928258	15/06/2024 08:11	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4928258	15/06/2024 08:11	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4928258	15/06/2024 08:11	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4928258	15/06/2024 08:11	Free - Residual disinfectant	mg Cl/l	1.33	

W1301POUT	Moyola PPP Final Water Outlet	4928258	15/06/2024 08:11	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4928258	15/06/2024 08:11	Total - Residual disinfectant	mg Cl/l	1.41	
W1301POUT	Moyola PPP Final Water Outlet	4928258	15/06/2024 08:11	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4928258	15/06/2024 08:11	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4928254	15/06/2024 09:16	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4928254	15/06/2024 09:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4928254	15/06/2024 09:16	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4928254	15/06/2024 09:16	Conductivity	uS/cm 20 C	440	2500
W4701OUT	Killyhevlin Final Water Outlet	4928254	15/06/2024 09:16	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4928254	15/06/2024 09:16	Free - Residual disinfectant	mg Cl/l	1.27	
W4701OUT	Killyhevlin Final Water Outlet	4928254	15/06/2024 09:16	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4928254	15/06/2024 09:16	Total - Residual disinfectant	mg Cl/l	1.36	
W4701OUT	Killyhevlin Final Water Outlet	4928254	15/06/2024 09:16	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4928254	15/06/2024 09:16	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4928257	15/06/2024 12:05	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4928257	15/06/2024 12:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4928257	15/06/2024 12:05	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4928257	15/06/2024 12:05	Conductivity	uS/cm 20 C	390	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4928257	15/06/2024 12:05	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4928257	15/06/2024 12:05	Free - Residual disinfectant	mg Cl/l	1.53	
W2308POUT	Castor Bay PPP Final Water Outlet	4928257	15/06/2024 12:05	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4928257	15/06/2024 12:05	Total - Residual disinfectant	mg Cl/l	1.67	
W2308POUT	Castor Bay PPP Final Water Outlet	4928257	15/06/2024 12:05	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4928257	15/06/2024 12:05	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4928282	16/06/2024 07:59	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4928282	16/06/2024 07:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4928282	16/06/2024 07:59	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4928282	16/06/2024 07:59	Conductivity	uS/cm 20 C	350	2500
W1301POUT	Moyola PPP Final Water Outlet	4928282	16/06/2024 07:59	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4928282	16/06/2024 07:59	Free - Residual disinfectant	mg Cl/l	1.49	
W1301POUT	Moyola PPP Final Water Outlet	4928282	16/06/2024 07:59	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4928282	16/06/2024 07:59	Total - Residual disinfectant	mg Cl/l	1.77	
W1301POUT	Moyola PPP Final Water Outlet	4928282	16/06/2024 07:59	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4928282	16/06/2024 07:59	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4928277	16/06/2024 08:43	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4928277	16/06/2024 08:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4928277	16/06/2024 08:43	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4928277	16/06/2024 08:43	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4928277	16/06/2024 08:43	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4928277	16/06/2024 08:43	Free - Residual disinfectant	mg Cl/l	0.81	
W1302OUT	Lough Fea Final Water Outlet	4928277	16/06/2024 08:43	Hydrogen Ion	pH value	6.8	9.5
W1302OUT	Lough Fea Final Water Outlet	4928277	16/06/2024 08:43	Total - Residual disinfectant	mg Cl/l	0.86	

W1302OUT	Lough Fea Final Water Outlet	4928277	16/06/2024 08:43	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4928277	16/06/2024 08:43	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4928278	16/06/2024 09:00	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4928278	16/06/2024 09:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4928278	16/06/2024 09:00	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4928278	16/06/2024 09:00	Conductivity	uS/cm 20 C	450	2500
W4701OUT	Killyhevlin Final Water Outlet	4928278	16/06/2024 09:00	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4928278	16/06/2024 09:00	Free - Residual disinfectant	mg Cl/l	1.28	
W4701OUT	Killyhevlin Final Water Outlet	4928278	16/06/2024 09:00	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4928278	16/06/2024 09:00	Total - Residual disinfectant	mg Cl/l	1.4	
W4701OUT	Killyhevlin Final Water Outlet	4928278	16/06/2024 09:00	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4928278	16/06/2024 09:00	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4928281	16/06/2024 11:54	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4928281	16/06/2024 11:54	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4928281	16/06/2024 11:54	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4928281	16/06/2024 11:54	Conductivity	uS/cm 20 C	390	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4928281	16/06/2024 11:54	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4928281	16/06/2024 11:54	Free - Residual disinfectant	mg Cl/l	1.38	
W2308POUT	Castor Bay PPP Final Water Outlet	4928281	16/06/2024 11:54	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4928281	16/06/2024 11:54	Total - Residual disinfectant	mg Cl/l	1.64	
W2308POUT	Castor Bay PPP Final Water Outlet	4928281	16/06/2024 11:54	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4928281	16/06/2024 11:54	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4930628	17/06/2024 07:57	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4930628	17/06/2024 07:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4930628	17/06/2024 07:57	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4930628	17/06/2024 07:57	Conductivity	uS/cm 20 C	350	2500
W1301POUT	Moyola PPP Final Water Outlet	4930628	17/06/2024 07:57	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4930628	17/06/2024 07:57	Free - Residual disinfectant	mg Cl/l	1.42	
W1301POUT	Moyola PPP Final Water Outlet	4930628	17/06/2024 07:57	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4930628	17/06/2024 07:57	Total - Residual disinfectant	mg Cl/l	1.51	
W1301POUT	Moyola PPP Final Water Outlet	4930628	17/06/2024 07:57	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4930628	17/06/2024 07:57	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4930618	17/06/2024 08:30	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4930618	17/06/2024 08:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4930618	17/06/2024 08:30	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4930618	17/06/2024 08:30	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4930618	17/06/2024 08:30	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4930618	17/06/2024 08:30	Free - Residual disinfectant	mg Cl/l	1.26	
W4701OUT	Killyhevlin Final Water Outlet	4930618	17/06/2024 08:30	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4930618	17/06/2024 08:30	Total - Residual disinfectant	mg Cl/l	1.42	
W4701OUT	Killyhevlin Final Water Outlet	4930618	17/06/2024 08:30	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4930618	17/06/2024 08:30	Turbidity	NTU	<0.09	1

W1302OUT	Lough Fea Final Water Outlet	4930604	17/06/2024 09:18	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4930604	17/06/2024 09:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4930604	17/06/2024 09:18	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4930604	17/06/2024 09:18	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4930604	17/06/2024 09:18	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4930604	17/06/2024 09:18	Free - Residual disinfectant	mg Cl/l	0.86	
W1302OUT	Lough Fea Final Water Outlet	4930604	17/06/2024 09:18	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4930604	17/06/2024 09:18	Total - Residual disinfectant	mg Cl/l	0.9	
W1302OUT	Lough Fea Final Water Outlet	4930604	17/06/2024 09:18	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4930604	17/06/2024 09:18	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Conductivity	uS/cm 20 C	340	2500
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Free - Residual disinfectant	mg Cl/l	1.06	
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Total - Residual disinfectant	mg Cl/l	1.18	
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	2,4-D	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	2,4-DB	ug/l	<0.016	0.1
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Algae Blue Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Algae Diatom Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Algae Flagellate Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Algae Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Algae Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Aluminium	ug Al/l	31	200
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Asulam	ug/l	<0.015	0.1
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Bentazone	ug/l	<0.0044	0.1
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Bromodichloromethane	ug/l	10	
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Bromoform	ug/l	<3.5	
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Bromoxynil	ug/l	<0.0079	0.1
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Chloroform	ug/l	24	
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Clopyralid	ug/l	<0.0097	0.1
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Dibromochloromethane	ug/l	3.4	
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Dichlorprop	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Geosmin	ng/l	<1.1	
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Iron	ug Fe/l	<14	200
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Manganese	ug Mn/l	<0.8	50
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	MCPA	ug/l	0.01	0.1
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	MCPB	ug/l	<0.015	0.1

W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Mecoprop	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	MIB	ng/l	<1.9	
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Microcystin-LR	ug/l	<0.024	
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Propyzamide	ug/l	<0.012	0.1
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Second most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Third most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Total Organic Carbon	mg C/l	2.2	
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Total Trihalomethanes	ug/l	38	100
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	Triclopyr	ug/l	<0.012	0.1
W2514OUT	Seagahan Final Water Outlet	4930610	17/06/2024 10:30	WHO Index		0.29	1
W2308POUT	Castor Bay PPP Final Water Outlet	4930626	17/06/2024 11:06	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4930626	17/06/2024 11:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4930626	17/06/2024 11:06	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4930626	17/06/2024 11:06	Conductivity	uS/cm 20 C	390	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4930626	17/06/2024 11:06	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4930626	17/06/2024 11:06	Free - Residual disinfectant	mg Cl/l	1.62	
W2308POUT	Castor Bay PPP Final Water Outlet	4930626	17/06/2024 11:06	Hydrogen Ion	pH value	7.4	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4930626	17/06/2024 11:06	Total - Residual disinfectant	mg Cl/l	1.73	
W2308POUT	Castor Bay PPP Final Water Outlet	4930626	17/06/2024 11:06	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4930626	17/06/2024 11:06	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4930626	17/06/2024 11:06	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4930626	17/06/2024 11:06	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4930626	17/06/2024 11:06	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4930626	17/06/2024 11:06	Taste - Nature		No taste	
W4523OUT	Lough Macrory Final Water Outlet	4930605	17/06/2024 11:13	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4930605	17/06/2024 11:13	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4930605	17/06/2024 11:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4930605	17/06/2024 11:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4930605	17/06/2024 11:13	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4930605	17/06/2024 11:13	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4930605	17/06/2024 11:13	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4930605	17/06/2024 11:13	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4930605	17/06/2024 11:13	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4930605	17/06/2024 11:13	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4930605	17/06/2024 11:13	Free - Residual disinfectant	mg Cl/l	1.18	
W4523OUT	Lough Macrory Final Water Outlet	4930605	17/06/2024 11:13	Free - Residual disinfectant	mg Cl/l	1.18	
W4523OUT	Lough Macrory Final Water Outlet	4930605	17/06/2024 11:13	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4930605	17/06/2024 11:13	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4930605	17/06/2024 11:13	Total - Residual disinfectant	mg Cl/l	1.24	
W4523OUT	Lough Macrory Final Water Outlet	4930605	17/06/2024 11:13	Total - Residual disinfectant	mg Cl/l	1.24	
W4523OUT	Lough Macrory Final Water Outlet	4930605	17/06/2024 11:13	Total Coliforms	CFU/100 ml	0	0

W4523OUT	Lough Macrory Final Water Outlet	4930605	17/06/2024 11:13	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4930605	17/06/2024 11:13	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4930605	17/06/2024 11:13	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4930885	18/06/2024 08:42	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4930885	18/06/2024 08:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4930885	18/06/2024 08:42	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4930885	18/06/2024 08:42	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4930885	18/06/2024 08:42	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4930885	18/06/2024 08:42	Free - Residual disinfectant	mg Cl/l	0.8	
W1302OUT	Lough Fea Final Water Outlet	4930885	18/06/2024 08:42	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4930885	18/06/2024 08:42	Total - Residual disinfectant	mg Cl/l	0.86	
W1302OUT	Lough Fea Final Water Outlet	4930885	18/06/2024 08:42	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4930885	18/06/2024 08:42	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Free - Residual disinfectant	mg Cl/l	1.1	
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Free - Residual disinfectant	mg Cl/l	1.1	
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Total - Residual disinfectant	mg Cl/l	1.16	
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Total - Residual disinfectant	mg Cl/l	1.16	
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Aluminium	ug Al/l	<3	200
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Aluminium	ug Al/l	<3	200
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Iron	ug Fe/l	<14	200
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Iron	ug Fe/l	<14	200
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Manganese	ug Mn/l	<0.8	50
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Manganese	ug Mn/l	<0.8	50
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Total Organic Carbon	mg C/l	1.5	
W4523OUT	Lough Macrory Final Water Outlet	4930886	18/06/2024 10:02	Total Organic Carbon	mg C/l	1.5	
W4701OUT	Killyhevlin Final Water Outlet	4930893	18/06/2024 10:25	Colony Counts 22	CFU/1 ml	0	

W4701OUT	Killyhevlin Final Water Outlet	4930893	18/06/2024 10:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4930893	18/06/2024 10:25	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4930893	18/06/2024 10:25	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4930893	18/06/2024 10:25	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4930893	18/06/2024 10:25	Free - Residual disinfectant	mg Cl/l	1.39	
W4701OUT	Killyhevlin Final Water Outlet	4930893	18/06/2024 10:25	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4930893	18/06/2024 10:25	Total - Residual disinfectant	mg Cl/l	1.62	
W4701OUT	Killyhevlin Final Water Outlet	4930893	18/06/2024 10:25	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4930893	18/06/2024 10:25	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Conductivity	uS/cm 20 C	350	2500
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Free - Residual disinfectant	mg Cl/l	1.35	
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Total - Residual disinfectant	mg Cl/l	1.5	
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	2,4-D	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	2,4-DB	ug/l	<0.016	0.1
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Algae Blue Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Algae Diatom Total	per ml	40	
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Algae Flagellate Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Algae Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Algae Total	per ml	40	
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Aluminium	ug Al/l	35	200
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Asulam	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Bentazone	ug/l	<0.0044	0.1
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Bromoxynil	ug/l	<0.0079	0.1
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Clopyralid	ug/l	<0.0097	0.1
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Dichlorprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Geosmin	ng/l	<1.1	
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Iron	ug Fe/l	<14	200
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Manganese	ug Mn/l	<0.8	50
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	MCPA	ug/l	0.0098	0.1
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	MCPB	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Mecoprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	MIB	ng/l	<1.9	
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Microcystin-LR	ug/l	<0.048	
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Most numerous Algae		Melosira	
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Propyzamide	ug/l	<0.012	0.1

W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Second most numerous Algae		---	
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Third most numerous Algae		---	
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Total Organic Carbon	mg C/l	2.5	
W1301POUT	Moyola PPP Final Water Outlet	4930901	18/06/2024 11:10	Triclopyr	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Conductivity	uS/cm 20 C	390	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Free - Residual disinfectant	mg Cl/l	1.6	
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Total - Residual disinfectant	mg Cl/l	1.72	
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Algae Diatom Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Algae Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Bromodichloromethane	ug/l	6.2	
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Chloroform	ug/l	10	
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Dibromochloromethane	ug/l	4.9	
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	MIB	ng/l	<1.9	
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Microcystin-LR	ug/l	<0.048	
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Most numerous Algae		---	
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Second most numerous Algae		---	
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Third most numerous Algae		---	
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Total Organic Carbon	mg C/l	2.6	
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	Total Trihalomethanes	ug/l	22	100
W2308POUT	Castor Bay PPP Final Water Outlet	4930897	18/06/2024 11:27	WHO Index		0.19	1
W2514OUT	Seagahan Final Water Outlet	4930889	18/06/2024 11:27	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4930889	18/06/2024 11:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4930889	18/06/2024 11:27	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4930889	18/06/2024 11:27	Conductivity	uS/cm 20 C	350	2500
W2514OUT	Seagahan Final Water Outlet	4930889	18/06/2024 11:27	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4930889	18/06/2024 11:27	Free - Residual disinfectant	mg Cl/l	1.05	

W2514OUT	Seagahan Final Water Outlet	4930889	18/06/2024 11:27	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4930889	18/06/2024 11:27	Total - Residual disinfectant	mg Cl/l	1.15	
W2514OUT	Seagahan Final Water Outlet	4930889	18/06/2024 11:27	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4930889	18/06/2024 11:27	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4931088	19/06/2024 07:56	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4931088	19/06/2024 07:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4931088	19/06/2024 07:56	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4931088	19/06/2024 07:56	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4931088	19/06/2024 07:56	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4931088	19/06/2024 07:56	Free - Residual disinfectant	mg Cl/l	1.4	
W1301POUT	Moyola PPP Final Water Outlet	4931088	19/06/2024 07:56	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4931088	19/06/2024 07:56	Total - Residual disinfectant	mg Cl/l	1.66	
W1301POUT	Moyola PPP Final Water Outlet	4931088	19/06/2024 07:56	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4931088	19/06/2024 07:56	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4931072	19/06/2024 08:41	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4931072	19/06/2024 08:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4931072	19/06/2024 08:41	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4931072	19/06/2024 08:41	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4931072	19/06/2024 08:41	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4931072	19/06/2024 08:41	Free - Residual disinfectant	mg Cl/l	0.8	
W1302OUT	Lough Fea Final Water Outlet	4931072	19/06/2024 08:41	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4931072	19/06/2024 08:41	Total - Residual disinfectant	mg Cl/l	0.84	
W1302OUT	Lough Fea Final Water Outlet	4931072	19/06/2024 08:41	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4931072	19/06/2024 08:41	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4931072	19/06/2024 08:41	Aluminium	ug Al/l	14	200
W1302OUT	Lough Fea Final Water Outlet	4931072	19/06/2024 08:41	Bromodichloromethane	ug/l	8	
W1302OUT	Lough Fea Final Water Outlet	4931072	19/06/2024 08:41	Bromoform	ug/l	<3.5	
W1302OUT	Lough Fea Final Water Outlet	4931072	19/06/2024 08:41	Chloroform	ug/l	33	
W1302OUT	Lough Fea Final Water Outlet	4931072	19/06/2024 08:41	Dibromochloromethane	ug/l	<1.6	
W1302OUT	Lough Fea Final Water Outlet	4931072	19/06/2024 08:41	Iron	ug Fe/l	<14	200
W1302OUT	Lough Fea Final Water Outlet	4931072	19/06/2024 08:41	Manganese	ug Mn/l	<0.8	50
W1302OUT	Lough Fea Final Water Outlet	4931072	19/06/2024 08:41	Total Organic Carbon	mg C/l	1.3	
W1302OUT	Lough Fea Final Water Outlet	4931072	19/06/2024 08:41	Total Trihalomethanes	ug/l	43	100
W1302OUT	Lough Fea Final Water Outlet	4931072	19/06/2024 08:41	WHO Index		0.26	1
W4523OUT	Lough Macrory Final Water Outlet	4931073	19/06/2024 09:14	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4931073	19/06/2024 09:14	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4931073	19/06/2024 09:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4931073	19/06/2024 09:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4931073	19/06/2024 09:14	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4931073	19/06/2024 09:14	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4931073	19/06/2024 09:14	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4931073	19/06/2024 09:14	Conductivity	uS/cm 20 C	120	2500

W4523OUT	Lough Macrory Final Water Outlet	4931073	19/06/2024 09:14	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4931073	19/06/2024 09:14	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4931073	19/06/2024 09:14	Free - Residual disinfectant	mg Cl/l	1.06	
W4523OUT	Lough Macrory Final Water Outlet	4931073	19/06/2024 09:14	Free - Residual disinfectant	mg Cl/l	1.06	
W4523OUT	Lough Macrory Final Water Outlet	4931073	19/06/2024 09:14	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4931073	19/06/2024 09:14	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4931073	19/06/2024 09:14	Total - Residual disinfectant	mg Cl/l	1.12	
W4523OUT	Lough Macrory Final Water Outlet	4931073	19/06/2024 09:14	Total - Residual disinfectant	mg Cl/l	1.12	
W4523OUT	Lough Macrory Final Water Outlet	4931073	19/06/2024 09:14	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4931073	19/06/2024 09:14	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4931073	19/06/2024 09:14	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4931073	19/06/2024 09:14	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4931086	19/06/2024 09:26	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4931086	19/06/2024 09:26	Colony Counts 37 (48hrs)	CFU/1 ml	1	
W2308POUT	Castor Bay PPP Final Water Outlet	4931086	19/06/2024 09:26	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4931086	19/06/2024 09:26	Conductivity	uS/cm 20 C	390	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4931086	19/06/2024 09:26	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4931086	19/06/2024 09:26	Free - Residual disinfectant	mg Cl/l	1.71	
W2308POUT	Castor Bay PPP Final Water Outlet	4931086	19/06/2024 09:26	Hydrogen Ion	pH value	7.7	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4931086	19/06/2024 09:26	Total - Residual disinfectant	mg Cl/l	1.91	
W2308POUT	Castor Bay PPP Final Water Outlet	4931086	19/06/2024 09:26	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4931086	19/06/2024 09:26	Turbidity	NTU	0.1	1
W2308POUT	Castor Bay PPP Final Water Outlet	4931086	19/06/2024 09:26	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4931086	19/06/2024 09:26	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4931086	19/06/2024 09:26	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4931086	19/06/2024 09:26	Taste - Nature		No taste	
W4701OUT	Killyhevlin Final Water Outlet	4931082	19/06/2024 10:16	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4931082	19/06/2024 10:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4931082	19/06/2024 10:16	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4931082	19/06/2024 10:16	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4931082	19/06/2024 10:16	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4931082	19/06/2024 10:16	Free - Residual disinfectant	mg Cl/l	1.78	
W4701OUT	Killyhevlin Final Water Outlet	4931082	19/06/2024 10:16	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4931082	19/06/2024 10:16	Total - Residual disinfectant	mg Cl/l	1.98	
W4701OUT	Killyhevlin Final Water Outlet	4931082	19/06/2024 10:16	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4931082	19/06/2024 10:16	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4931079	19/06/2024 10:58	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4931079	19/06/2024 10:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4931079	19/06/2024 10:58	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4931079	19/06/2024 10:58	Conductivity	uS/cm 20 C	350	2500
W2514OUT	Seagahan Final Water Outlet	4931079	19/06/2024 10:58	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4931079	19/06/2024 10:58	Free - Residual disinfectant	mg Cl/l	1.2	

W2514OUT	Seagahan Final Water Outlet	4931079	19/06/2024 10:58	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4931079	19/06/2024 10:58	Total - Residual disinfectant	mg Cl/l	1.35	
W2514OUT	Seagahan Final Water Outlet	4931079	19/06/2024 10:58	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4931079	19/06/2024 10:58	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4931261	20/06/2024 08:31	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4931261	20/06/2024 08:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4931261	20/06/2024 08:31	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4931261	20/06/2024 08:31	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4931261	20/06/2024 08:31	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4931261	20/06/2024 08:31	Free - Residual disinfectant	mg Cl/l	1.38	
W1301POUT	Moyola PPP Final Water Outlet	4931261	20/06/2024 08:31	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4931261	20/06/2024 08:31	Total - Residual disinfectant	mg Cl/l	1.56	
W1301POUT	Moyola PPP Final Water Outlet	4931261	20/06/2024 08:31	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4931261	20/06/2024 08:31	Turbidity	NTU	<0.09	1
W1316OUT	Money more Borewell Final Water Outlet	4931270	20/06/2024 09:16	Colony Counts 22	CFU/1 ml	0	
W1316OUT	Money more Borewell Final Water Outlet	4931270	20/06/2024 09:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1316OUT	Money more Borewell Final Water Outlet	4931270	20/06/2024 09:16	Colour	mg/l Pt/Co	<4.56	20
W1316OUT	Money more Borewell Final Water Outlet	4931270	20/06/2024 09:16	Conductivity	uS/cm 20 C	350	2500
W1316OUT	Money more Borewell Final Water Outlet	4931270	20/06/2024 09:16	E. coli	CFU/100 ml	0	0
W1316OUT	Money more Borewell Final Water Outlet	4931270	20/06/2024 09:16	Free - Residual disinfectant	mg Cl/l	0.44	
W1316OUT	Money more Borewell Final Water Outlet	4931270	20/06/2024 09:16	Hydrogen Ion	pH value	7.8	9.5
W1316OUT	Money more Borewell Final Water Outlet	4931270	20/06/2024 09:16	Total - Residual disinfectant	mg Cl/l	0.6	
W1316OUT	Money more Borewell Final Water Outlet	4931270	20/06/2024 09:16	Total Coliforms	CFU/100 ml	0	0
W1316OUT	Money more Borewell Final Water Outlet	4931270	20/06/2024 09:16	Turbidity	NTU	<0.09	1
W1316OUT	Money more Borewell Final Water Outlet	4931270	20/06/2024 09:16	Aluminium	ug Al/l	27	200
W1316OUT	Money more Borewell Final Water Outlet	4931270	20/06/2024 09:16	Bromodichloromethane	ug/l	10	
W1316OUT	Money more Borewell Final Water Outlet	4931270	20/06/2024 09:16	Bromoform	ug/l	<3.5	
W1316OUT	Money more Borewell Final Water Outlet	4931270	20/06/2024 09:16	Chloroform	ug/l	21	
W1316OUT	Money more Borewell Final Water Outlet	4931270	20/06/2024 09:16	Dibromochloromethane	ug/l	6.9	
W1316OUT	Money more Borewell Final Water Outlet	4931270	20/06/2024 09:16	Iron	ug Fe/l	16	200
W1316OUT	Money more Borewell Final Water Outlet	4931270	20/06/2024 09:16	Manganese	ug Mn/l	<0.8	50
W1316OUT	Money more Borewell Final Water Outlet	4931270	20/06/2024 09:16	Total Organic Carbon	mg C/l	1.7	
W1316OUT	Money more Borewell Final Water Outlet	4931270	20/06/2024 09:16	Total Trihalomethanes	ug/l	39	100
W1316OUT	Money more Borewell Final Water Outlet	4931270	20/06/2024 09:16	WHO Index		0.32	1
W1302OUT	Lough Fea Final Water Outlet	4931244	20/06/2024 09:49	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4931244	20/06/2024 09:49	Colony Counts 37 (48hrs)	CFU/1 ml	1	
W1302OUT	Lough Fea Final Water Outlet	4931244	20/06/2024 09:49	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4931244	20/06/2024 09:49	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4931244	20/06/2024 09:49	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4931244	20/06/2024 09:49	Free - Residual disinfectant	mg Cl/l	0.85	
W1302OUT	Lough Fea Final Water Outlet	4931244	20/06/2024 09:49	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4931244	20/06/2024 09:49	Total - Residual disinfectant	mg Cl/l	0.88	

W1302OUT	Lough Fea Final Water Outlet	4931244	20/06/2024 09:49	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4931244	20/06/2024 09:49	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4931245	20/06/2024 10:04	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4931245	20/06/2024 10:04	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4931245	20/06/2024 10:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4931245	20/06/2024 10:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4931245	20/06/2024 10:04	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4931245	20/06/2024 10:04	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4931245	20/06/2024 10:04	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4931245	20/06/2024 10:04	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4931245	20/06/2024 10:04	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4931245	20/06/2024 10:04	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4931245	20/06/2024 10:04	Free - Residual disinfectant	mg Cl/l	0.89	
W4523OUT	Lough Macrory Final Water Outlet	4931245	20/06/2024 10:04	Free - Residual disinfectant	mg Cl/l	0.89	
W4523OUT	Lough Macrory Final Water Outlet	4931245	20/06/2024 10:04	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4931245	20/06/2024 10:04	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4931245	20/06/2024 10:04	Total - Residual disinfectant	mg Cl/l	1	
W4523OUT	Lough Macrory Final Water Outlet	4931245	20/06/2024 10:04	Total - Residual disinfectant	mg Cl/l	1	
W4523OUT	Lough Macrory Final Water Outlet	4931245	20/06/2024 10:04	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4931245	20/06/2024 10:04	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4931245	20/06/2024 10:04	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4931245	20/06/2024 10:04	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4931260	20/06/2024 11:09	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4931260	20/06/2024 11:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4931260	20/06/2024 11:09	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4931260	20/06/2024 11:09	Conductivity	uS/cm 20 C	390	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4931260	20/06/2024 11:09	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4931260	20/06/2024 11:09	Free - Residual disinfectant	mg Cl/l	1.51	
W2308POUT	Castor Bay PPP Final Water Outlet	4931260	20/06/2024 11:09	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4931260	20/06/2024 11:09	Total - Residual disinfectant	mg Cl/l	1.65	
W2308POUT	Castor Bay PPP Final Water Outlet	4931260	20/06/2024 11:09	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4931260	20/06/2024 11:09	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4931249	20/06/2024 11:10	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4931249	20/06/2024 11:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4931249	20/06/2024 11:10	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4931249	20/06/2024 11:10	Conductivity	uS/cm 20 C	360	2500
W2514OUT	Seagahan Final Water Outlet	4931249	20/06/2024 11:10	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4931249	20/06/2024 11:10	Free - Residual disinfectant	mg Cl/l	0.98	
W2514OUT	Seagahan Final Water Outlet	4931249	20/06/2024 11:10	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4931249	20/06/2024 11:10	Total - Residual disinfectant	mg Cl/l	1.06	
W2514OUT	Seagahan Final Water Outlet	4931249	20/06/2024 11:10	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4931249	20/06/2024 11:10	Turbidity	NTU	<0.09	1

W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Conductivity	uS/cm 20 C	440	2500
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Free - Residual disinfectant	mg Cl/l	1.32	
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Total - Residual disinfectant	mg Cl/l	1.39	
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Algae Blue Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Algae Diatom Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Algae Flagellate Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Algae Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Algae Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Aluminium	ug Al/l	29	200
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Bromodichloromethane	ug/l	12	
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Bromoform	ug/l	<3.5	
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Chloroform	ug/l	33	
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Dibromochloromethane	ug/l	4.1	
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Geosmin	ng/l	<1.1	
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Iron	ug Fe/l	<14	200
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Manganese	ug Mn/l	6.4	50
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	MIB	ng/l	<1.9	
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Microcystin-LR	ug/l	<0.024	
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Most numerous Algae		-	
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Second most numerous Algae		-	
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Third most numerous Algae		-	
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Total Organic Carbon	mg C/l	2.3	
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	Total Trihalomethanes	ug/l	50	100
W4701OUT	Killyhevlin Final Water Outlet	4931256	20/06/2024 11:17	WHO Index		0.36	1
W1301POUT	Moyola PPP Final Water Outlet	4931407	21/06/2024 08:51	Colony Counts 22	CFU/1 ml	1	
W1301POUT	Moyola PPP Final Water Outlet	4931407	21/06/2024 08:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4931407	21/06/2024 08:51	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4931407	21/06/2024 08:51	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4931407	21/06/2024 08:51	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4931407	21/06/2024 08:51	Free - Residual disinfectant	mg Cl/l	1.43	
W1301POUT	Moyola PPP Final Water Outlet	4931407	21/06/2024 08:51	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4931407	21/06/2024 08:51	Total - Residual disinfectant	mg Cl/l	1.53	
W1301POUT	Moyola PPP Final Water Outlet	4931407	21/06/2024 08:51	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4931407	21/06/2024 08:51	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4931400	21/06/2024 09:51	Colony Counts 22	CFU/1 ml	0	

W1302OUT	Lough Fea Final Water Outlet	4931400	21/06/2024 09:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4931400	21/06/2024 09:51	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4931400	21/06/2024 09:51	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4931400	21/06/2024 09:51	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4931400	21/06/2024 09:51	Free - Residual disinfectant	mg Cl/l	0.82	
W1302OUT	Lough Fea Final Water Outlet	4931400	21/06/2024 09:51	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4931400	21/06/2024 09:51	Total - Residual disinfectant	mg Cl/l	0.88	
W1302OUT	Lough Fea Final Water Outlet	4931400	21/06/2024 09:51	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4931400	21/06/2024 09:51	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4932917	21/06/2024 10:24	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4932917	21/06/2024 10:24	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4932917	21/06/2024 10:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4932917	21/06/2024 10:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4932917	21/06/2024 10:24	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4932917	21/06/2024 10:24	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4932917	21/06/2024 10:24	Free - Residual disinfectant	mg Cl/l	0.89	
W4523OUT	Lough Macrory Final Water Outlet	4932917	21/06/2024 10:24	Free - Residual disinfectant	mg Cl/l	0.89	
W4523OUT	Lough Macrory Final Water Outlet	4932917	21/06/2024 10:24	Total - Residual disinfectant	mg Cl/l	0.99	
W4523OUT	Lough Macrory Final Water Outlet	4932917	21/06/2024 10:24	Total - Residual disinfectant	mg Cl/l	0.99	
W4523OUT	Lough Macrory Final Water Outlet	4932917	21/06/2024 10:24	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4932917	21/06/2024 10:24	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4932917	21/06/2024 10:24	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4932917	21/06/2024 10:24	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4931406	21/06/2024 10:50	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4931406	21/06/2024 10:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4931406	21/06/2024 10:50	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4931406	21/06/2024 10:50	Conductivity	uS/cm 20 C	400	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4931406	21/06/2024 10:50	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4931406	21/06/2024 10:50	Free - Residual disinfectant	mg Cl/l	1.78	
W2308POUT	Castor Bay PPP Final Water Outlet	4931406	21/06/2024 10:50	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4931406	21/06/2024 10:50	Total - Residual disinfectant	mg Cl/l	1.9	
W2308POUT	Castor Bay PPP Final Water Outlet	4931406	21/06/2024 10:50	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4931406	21/06/2024 10:50	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4931402	21/06/2024 11:48	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4931402	21/06/2024 11:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4931402	21/06/2024 11:48	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4931402	21/06/2024 11:48	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4931402	21/06/2024 11:48	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4931402	21/06/2024 11:48	Free - Residual disinfectant	mg Cl/l	1.24	
W4701OUT	Killyhevlin Final Water Outlet	4931402	21/06/2024 11:48	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4931402	21/06/2024 11:48	Total - Residual disinfectant	mg Cl/l	1.38	
W4701OUT	Killyhevlin Final Water Outlet	4931402	21/06/2024 11:48	Total Coliforms	CFU/100 ml	0	0

W4701OUT	Killyhevlin Final Water Outlet	4931402	21/06/2024 11:48	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4931493	22/06/2024 07:02	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4931493	22/06/2024 07:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4931493	22/06/2024 07:02	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4931493	22/06/2024 07:02	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4931493	22/06/2024 07:02	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4931493	22/06/2024 07:02	Free - Residual disinfectant	mg Cl/l	1.38	
W2308POUT	Castor Bay PPP Final Water Outlet	4931493	22/06/2024 07:02	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4931493	22/06/2024 07:02	Total - Residual disinfectant	mg Cl/l	1.44	
W2308POUT	Castor Bay PPP Final Water Outlet	4931493	22/06/2024 07:02	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4931493	22/06/2024 07:02	Turbidity	NTU	0.14	1
W1301POUT	Moyola PPP Final Water Outlet	4931494	22/06/2024 07:58	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4931494	22/06/2024 07:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4931494	22/06/2024 07:58	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4931494	22/06/2024 07:58	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4931494	22/06/2024 07:58	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4931494	22/06/2024 07:58	Free - Residual disinfectant	mg Cl/l	1.49	
W1301POUT	Moyola PPP Final Water Outlet	4931494	22/06/2024 07:58	Hydrogen Ion	pH value	7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4931494	22/06/2024 07:58	Total - Residual disinfectant	mg Cl/l	1.6	
W1301POUT	Moyola PPP Final Water Outlet	4931494	22/06/2024 07:58	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4931494	22/06/2024 07:58	Turbidity	NTU	0.1	1
W4701OUT	Killyhevlin Final Water Outlet	4931490	22/06/2024 08:38	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4931490	22/06/2024 08:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4931490	22/06/2024 08:38	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4931490	22/06/2024 08:38	Conductivity	uS/cm 20 C	440	2500
W4701OUT	Killyhevlin Final Water Outlet	4931490	22/06/2024 08:38	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4931490	22/06/2024 08:38	Free - Residual disinfectant	mg Cl/l	1.21	
W4701OUT	Killyhevlin Final Water Outlet	4931490	22/06/2024 08:38	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4931490	22/06/2024 08:38	Total - Residual disinfectant	mg Cl/l	1.4	
W4701OUT	Killyhevlin Final Water Outlet	4931490	22/06/2024 08:38	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4931490	22/06/2024 08:38	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4931489	22/06/2024 08:44	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4931489	22/06/2024 08:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4931489	22/06/2024 08:44	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4931489	22/06/2024 08:44	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4931489	22/06/2024 08:44	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4931489	22/06/2024 08:44	Free - Residual disinfectant	mg Cl/l	0.84	
W1302OUT	Lough Fea Final Water Outlet	4931489	22/06/2024 08:44	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4931489	22/06/2024 08:44	Total - Residual disinfectant	mg Cl/l	0.9	
W1302OUT	Lough Fea Final Water Outlet	4931489	22/06/2024 08:44	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4931489	22/06/2024 08:44	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4931521	23/06/2024 06:58	Colony Counts 22	CFU/1 ml	0	

W2308POUT	Castor Bay PPP Final Water Outlet	4931521	23/06/2024 06:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4931521	23/06/2024 06:58	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4931521	23/06/2024 06:58	Conductivity	uS/cm 20 C	390	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4931521	23/06/2024 06:58	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4931521	23/06/2024 06:58	Free - Residual disinfectant	mg Cl/l	1.52	
W2308POUT	Castor Bay PPP Final Water Outlet	4931521	23/06/2024 06:58	Hydrogen Ion	pH value	7.4	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4931521	23/06/2024 06:58	Total - Residual disinfectant	mg Cl/l	1.57	
W2308POUT	Castor Bay PPP Final Water Outlet	4931521	23/06/2024 06:58	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4931521	23/06/2024 06:58	Turbidity	NTU	0.095	1
W1301POUT	Moyola PPP Final Water Outlet	4931522	23/06/2024 08:35	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4931522	23/06/2024 08:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4931522	23/06/2024 08:35	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4931522	23/06/2024 08:35	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4931522	23/06/2024 08:35	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4931522	23/06/2024 08:35	Free - Residual disinfectant	mg Cl/l	1.41	
W1301POUT	Moyola PPP Final Water Outlet	4931522	23/06/2024 08:35	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4931522	23/06/2024 08:35	Total - Residual disinfectant	mg Cl/l	1.61	
W1301POUT	Moyola PPP Final Water Outlet	4931522	23/06/2024 08:35	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4931522	23/06/2024 08:35	Turbidity	NTU	0.092	1
W4701OUT	Killyhevlin Final Water Outlet	4931518	23/06/2024 08:58	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4931518	23/06/2024 08:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4931518	23/06/2024 08:58	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4931518	23/06/2024 08:58	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4931518	23/06/2024 08:58	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4931518	23/06/2024 08:58	Free - Residual disinfectant	mg Cl/l	1.14	
W4701OUT	Killyhevlin Final Water Outlet	4931518	23/06/2024 08:58	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4931518	23/06/2024 08:58	Total - Residual disinfectant	mg Cl/l	1.32	
W4701OUT	Killyhevlin Final Water Outlet	4931518	23/06/2024 08:58	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4931518	23/06/2024 08:58	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4931517	23/06/2024 09:13	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4931517	23/06/2024 09:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4931517	23/06/2024 09:13	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4931517	23/06/2024 09:13	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4931517	23/06/2024 09:13	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4931517	23/06/2024 09:13	Free - Residual disinfectant	mg Cl/l	0.8	
W1302OUT	Lough Fea Final Water Outlet	4931517	23/06/2024 09:13	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4931517	23/06/2024 09:13	Total - Residual disinfectant	mg Cl/l	0.9	
W1302OUT	Lough Fea Final Water Outlet	4931517	23/06/2024 09:13	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4931517	23/06/2024 09:13	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4933388	24/06/2024 07:21	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4933388	24/06/2024 07:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4933388	24/06/2024 07:21	Colour	mg/l Pt/Co	<4.56	20

W1301POUT	Moyola PPP Final Water Outlet	4933388	24/06/2024 07:21	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4933388	24/06/2024 07:21	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4933388	24/06/2024 07:21	Free - Residual disinfectant	mg Cl/l	1.44	
W1301POUT	Moyola PPP Final Water Outlet	4933388	24/06/2024 07:21	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4933388	24/06/2024 07:21	Total - Residual disinfectant	mg Cl/l	1.58	
W1301POUT	Moyola PPP Final Water Outlet	4933388	24/06/2024 07:21	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4933388	24/06/2024 07:21	Turbidity	NTU	<0.09	1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	2,4-D	ug/l	<0.011	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	2,4-DB	ug/l	<0.016	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Asulam	ug/l	<0.015	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Bentazone	ug/l	<0.0044	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Bromoxynil	ug/l	<0.0079	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Chlorotoluron	ug/l	<0.0031	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Chlorpyrifos	ug/l	<0.0070	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Clopyralid	ug/l	<0.0097	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Colony Counts 22	CFU/1 ml	0	
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Colour	mg/l Pt/Co	<4.56	20
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Conductivity	uS/cm 20 C	360	2500
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Cyanide	ug/l CN	<5.5	50
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Dicamba	ug/l	<0.028	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Dichlorprop	ug/l	<0.011	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Diflufenican	ug/l	<0.0072	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Dimethenamid	ug/l	<0.0063	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Diuron	ug/l	<0.0055	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	E. coli	CFU/100 ml	0	0
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Epoxiconazole	ug/l	<0.0049	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Fenpropimorph	ug/l	<0.0083	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Flufenacet	ug/l	<0.0052	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Fluroxypyr	ug/l	<0.0063	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Free - Residual disinfectant	mg Cl/l	0.4	
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Glyphosate	ug/l	<0.0077	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Gross Alpha Activity	Bq/l	<0.04	
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Gross Beta Activity	Bq/l	0.06	
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Hydrogen Ion	pH value	7.8	9.5
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Isoproturon	ug/l	<0.0025	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Linuron	ug/l	<0.0034	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	MCPA	ug/l	<0.0093	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	MCPB	ug/l	<0.015	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Mecoprop	ug/l	<0.011	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Metalaxyl	ug/l	<0.0097	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Metamitron	ug/l	<0.0074	0.1

W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Metazachlor	ug/l	<0.015	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Metoxuron	ug/l	<0.0080	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Metribuzin	ug/l	<0.0060	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Nitrite	mg/l	<0.03	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Oxamyl	ug/l	<0.0023	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Pendimethalin	ug/l	<0.0064	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Pesticides - Total Substances	ug/l	0	0.5
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Phorate	ug/l	<0.0092	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Pirimicarb	ug/l	<0.0063	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Propachlor	ug/l	<0.0096	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Propiconazole	ug/l	<0.0029	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Propyzamide	ug/l	<0.012	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Prothioconazole	ug/l	<0.0019	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Tebuconazole	ug/l	<0.0039	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Total - Residual disinfectant	mg Cl/l	0.53	
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Total Coliforms	CFU/100 ml	0	0
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Total Indicative Dose	mSv/year	<0.1	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Triclopyr	ug/l	<0.012	0.1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Tritium	Bq/l	<10	100
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Turbidity	NTU	<0.09	1
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Aluminium	ug Al/l	26	200
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Iron	ug Fe/l	17	200
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Manganese	ug Mn/l	0.98	50
W1316OUT	Money more Borewell Final Water Outlet	4933402	24/06/2024 08:07	Total Organic Carbon	mg C/l	1.7	
W1302OUT	Lough Fea Final Water Outlet	4933363	24/06/2024 09:01	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4933363	24/06/2024 09:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4933363	24/06/2024 09:01	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4933363	24/06/2024 09:01	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4933363	24/06/2024 09:01	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4933363	24/06/2024 09:01	Free - Residual disinfectant	mg Cl/l	0.71	
W1302OUT	Lough Fea Final Water Outlet	4933363	24/06/2024 09:01	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4933363	24/06/2024 09:01	Total - Residual disinfectant	mg Cl/l	0.79	
W1302OUT	Lough Fea Final Water Outlet	4933363	24/06/2024 09:01	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4933363	24/06/2024 09:01	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4933368	24/06/2024 09:57	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4933368	24/06/2024 09:57	Colony Counts 37 (48hrs)	CFU/1 ml	1	
W2514OUT	Seagahan Final Water Outlet	4933368	24/06/2024 09:57	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4933368	24/06/2024 09:57	Conductivity	uS/cm 20 C	370	2500
W2514OUT	Seagahan Final Water Outlet	4933368	24/06/2024 09:57	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4933368	24/06/2024 09:57	Free - Residual disinfectant	mg Cl/l	1.31	
W2514OUT	Seagahan Final Water Outlet	4933368	24/06/2024 09:57	Hydrogen Ion	pH value	7.6	9.5
W2514OUT	Seagahan Final Water Outlet	4933368	24/06/2024 09:57	Total - Residual disinfectant	mg Cl/l	1.42	

W2514OUT	Seagahan Final Water Outlet	4933368	24/06/2024 09:57	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4933368	24/06/2024 09:57	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4933387	24/06/2024 10:43	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4933387	24/06/2024 10:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4933387	24/06/2024 10:43	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4933387	24/06/2024 10:43	Conductivity	uS/cm 20 C	400	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4933387	24/06/2024 10:43	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4933387	24/06/2024 10:43	Free - Residual disinfectant	mg Cl/l	1.65	
W2308POUT	Castor Bay PPP Final Water Outlet	4933387	24/06/2024 10:43	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4933387	24/06/2024 10:43	Total - Residual disinfectant	mg Cl/l	1.71	
W2308POUT	Castor Bay PPP Final Water Outlet	4933387	24/06/2024 10:43	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4933387	24/06/2024 10:43	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4933387	24/06/2024 10:43	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4933387	24/06/2024 10:43	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4933387	24/06/2024 10:43	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4933387	24/06/2024 10:43	Taste - Nature		No taste	
W4523OUT	Lough Macrory Final Water Outlet	4933364	24/06/2024 10:44	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4933364	24/06/2024 10:44	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4933364	24/06/2024 10:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4933364	24/06/2024 10:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4933364	24/06/2024 10:44	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4933364	24/06/2024 10:44	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4933364	24/06/2024 10:44	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4933364	24/06/2024 10:44	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4933364	24/06/2024 10:44	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4933364	24/06/2024 10:44	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4933364	24/06/2024 10:44	Free - Residual disinfectant	mg Cl/l	0.91	
W4523OUT	Lough Macrory Final Water Outlet	4933364	24/06/2024 10:44	Free - Residual disinfectant	mg Cl/l	0.91	
W4523OUT	Lough Macrory Final Water Outlet	4933364	24/06/2024 10:44	Hydrogen Ion	pH value	7.1	9.5
W4523OUT	Lough Macrory Final Water Outlet	4933364	24/06/2024 10:44	Hydrogen Ion	pH value	7.1	9.5
W4523OUT	Lough Macrory Final Water Outlet	4933364	24/06/2024 10:44	Total - Residual disinfectant	mg Cl/l	1.02	
W4523OUT	Lough Macrory Final Water Outlet	4933364	24/06/2024 10:44	Total - Residual disinfectant	mg Cl/l	1.02	
W4523OUT	Lough Macrory Final Water Outlet	4933364	24/06/2024 10:44	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4933364	24/06/2024 10:44	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4933364	24/06/2024 10:44	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4933364	24/06/2024 10:44	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Conductivity	uS/cm 20 C	450	2500
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Free - Residual disinfectant	mg Cl/l	1.75	

W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Hydrogen Ion	pH value	7.6	9.5
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Total - Residual disinfectant	mg Cl/l	1.82	
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	2,4-D	ug/l	<0.011	0.1
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	2,4-DB	ug/l	<0.016	0.1
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Algae Blue Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Algae Diatom Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Algae Flagellate Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Algae Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Algae Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Aluminium	ug Al/l	27	200
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Asulam	ug/l	<0.015	0.1
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Bentazone	ug/l	<0.0044	0.1
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Bromoxynil	ug/l	<0.0079	0.1
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Clopyralid	ug/l	<0.0097	0.1
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Dichlorprop	ug/l	<0.011	0.1
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Iron	ug Fe/l	<14	200
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Manganese	ug Mn/l	5.1	50
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	MCPA	ug/l	0.018	0.1
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	MCPB	ug/l	<0.015	0.1
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Mecoprop	ug/l	<0.011	0.1
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Odour	Diln No	0	0
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Odour - Nature		No odour	
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Propyzamide	ug/l	<0.012	0.1
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Second most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Taste	Diln No	0	0
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Taste - Nature		No taste	
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Third most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Total Organic Carbon	mg C/l	2.2	
W4701OUT	Killyhevlin Final Water Outlet	4933379	24/06/2024 11:44	Triclopyr	ug/l	<0.012	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	2,4-D	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	2,4-DB	ug/l	<0.016	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Asulam	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Bentazone	ug/l	<0.0044	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Bromoxynil	ug/l	<0.0079	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Chlorotoluron	ug/l	<0.0031	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Chlorpyrifos	ug/l	<0.0070	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Clopyralid	ug/l	<0.0097	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Colony Counts 22	CFU/1 ml	0	

W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Cyanide	ug/l CN	<5.5	50
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Dicamba	ug/l	<0.028	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Dichlorprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Diflufenican	ug/l	<0.0072	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Dimethenamid	ug/l	<0.0063	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Diuron	ug/l	<0.0055	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Epoconazole	ug/l	<0.0049	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Fenpropimorph	ug/l	<0.0083	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Flufenacet	ug/l	<0.0052	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Fluroxypyr	ug/l	<0.0063	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Free - Residual disinfectant	mg Cl/l	1.47	
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Glyphosate	ug/l	<0.0077	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Isoproturon	ug/l	<0.0025	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Linuron	ug/l	<0.0034	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	MCPA	ug/l	<0.0093	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	MCPB	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Mecoprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Metalaxyl	ug/l	<0.0097	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Metamitron	ug/l	<0.0074	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Metazachlor	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Metoxuron	ug/l	<0.0080	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Metribuzin	ug/l	<0.0060	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Nitrite	mg/l	<0.03	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Oxamyl	ug/l	<0.0023	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Pendimethalin	ug/l	<0.0064	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Pesticides - Total Substances	ug/l	0	0.5
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Phorate	ug/l	<0.0092	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Pirimicarb	ug/l	<0.0063	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Propachlor	ug/l	<0.0096	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Propiconazole	ug/l	<0.0029	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Propyzamide	ug/l	<0.012	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Prothioconazole	ug/l	<0.0019	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Tebuconazole	ug/l	<0.0039	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Total - Residual disinfectant	mg Cl/l	1.62	
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Triclopyr	ug/l	<0.012	0.1
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Turbidity	NTU	<0.09	1

W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Algae Blue Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Algae Diatom Total	per ml	40	
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Algae Flagellate Total	per ml	40	
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Algae Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Algae Total	per ml	80	
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Aluminium	ug Al/l	44	200
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Bromodichloromethane	ug/l	5.3	
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Bromoform	ug/l	<3.5	
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Chloroform	ug/l	7.9	
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Dibromochloromethane	ug/l	5	
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Geosmin	ng/l	<1.1	
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Iron	ug Fe/l	<14	200
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Manganese	ug Mn/l	<0.8	50
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	MIB	ng/l	<1.9	
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Microcystin-LR	ug/l	<0.024	
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Most numerous Algae		Centric diatom	
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Second most numerous Algae		Gymnodinium	
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Taste - Nature		No taste	
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Third most numerous Algae		---	
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Total Organic Carbon	mg C/l	2.4	
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	Total Trihalomethanes	ug/l	19	100
W1301POUT	Moyola PPP Final Water Outlet	4933607	25/06/2024 06:50	WHO Index		0.17	1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	2,4-D	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	2,4-DB	ug/l	<0.016	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Asulam	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Bentazone	ug/l	<0.0044	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Bromoxynil	ug/l	<0.0079	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Chlorotoluron	ug/l	<0.0031	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Chlorpyrifos	ug/l	<0.0070	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Clopyralid	ug/l	<0.0097	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Conductivity	uS/cm 20 C	400	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Cyanide	ug/l CN	<5.5	50
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Dicamba	ug/l	<0.028	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Dichlorprop	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Diffenican	ug/l	<0.0072	0.1

W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Dimethenamid	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Diuron	ug/l	<0.0055	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Epoxiconazole	ug/l	<0.0049	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Fenpropimorph	ug/l	<0.0083	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Flufenacet	ug/l	<0.0052	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Fluroxypyr	ug/l	0.0077	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Free - Residual disinfectant	mg Cl/l	1.27	
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Glyphosate	ug/l	<0.0077	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Hydrogen Ion	pH value	7.4	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Isoproturon	ug/l	<0.0025	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Linuron	ug/l	<0.0034	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	MCPA	ug/l	0.013	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	MCPB	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Mecoprop	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Metalaxyl	ug/l	<0.0097	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Metamitron	ug/l	<0.0074	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Metazachlor	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Metoxuron	ug/l	<0.0080	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Metribuzin	ug/l	<0.0060	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Nitrite	mg/l	<0.03	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Oxamyl	ug/l	<0.0023	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Pendimethalin	ug/l	<0.0064	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Pesticides - Total Substances	ug/l	0.0207	0.5
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Phorate	ug/l	<0.0092	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Pirimicarb	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Propachlor	ug/l	<0.0096	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Propiconazole	ug/l	<0.0029	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Propyzamide	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Prothioconazole	ug/l	<0.0019	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Tebuconazole	ug/l	<0.0039	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Total - Residual disinfectant	mg Cl/l	1.36	
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Triclopyr	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Algae Diatom Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Algae Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Aluminium	ug Al/l	36	200
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Bromodichloromethane	ug/l	5.7	

W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Chloroform	ug/l	8.2	
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Dibromochloromethane	ug/l	5.7	
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Iron	ug Fe/l	<14	200
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Manganese	ug Mn/l	<0.8	50
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	MIB	ng/l	<1.9	
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Microcystin-LR	ug/l	<0.024	
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Most numerous Algae		---	
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Second most numerous Algae		---	
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Third most numerous Algae		---	
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Total Organic Carbon	mg C/l	2.3	
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	Total Trihalomethanes	ug/l	21	100
W2308POUT	Castor Bay PPP Final Water Outlet	4933602	25/06/2024 08:12	WHO Index		0.19	1
W1302OUT	Lough Fea Final Water Outlet	4933591	25/06/2024 08:46	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4933591	25/06/2024 08:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4933591	25/06/2024 08:46	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4933591	25/06/2024 08:46	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4933591	25/06/2024 08:46	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4933591	25/06/2024 08:46	Free - Residual disinfectant	mg Cl/l	0.72	
W1302OUT	Lough Fea Final Water Outlet	4933591	25/06/2024 08:46	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4933591	25/06/2024 08:46	Total - Residual disinfectant	mg Cl/l	0.81	
W1302OUT	Lough Fea Final Water Outlet	4933591	25/06/2024 08:46	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4933591	25/06/2024 08:46	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4933591	25/06/2024 08:46	2,4-D	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4933591	25/06/2024 08:46	2,4-DB	ug/l	<0.016	0.1
W1302OUT	Lough Fea Final Water Outlet	4933591	25/06/2024 08:46	Asulam	ug/l	<0.015	0.1
W1302OUT	Lough Fea Final Water Outlet	4933591	25/06/2024 08:46	Bentazone	ug/l	<0.0044	0.1
W1302OUT	Lough Fea Final Water Outlet	4933591	25/06/2024 08:46	Bromoxynil	ug/l	<0.0079	0.1
W1302OUT	Lough Fea Final Water Outlet	4933591	25/06/2024 08:46	Clopyralid	ug/l	<0.0097	0.1
W1302OUT	Lough Fea Final Water Outlet	4933591	25/06/2024 08:46	Dichlorprop	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4933591	25/06/2024 08:46	MCPA	ug/l	<0.0093	0.1
W1302OUT	Lough Fea Final Water Outlet	4933591	25/06/2024 08:46	MCPB	ug/l	<0.015	0.1
W1302OUT	Lough Fea Final Water Outlet	4933591	25/06/2024 08:46	Mecoprop	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4933591	25/06/2024 08:46	Propyzamide	ug/l	<0.012	0.1
W1302OUT	Lough Fea Final Water Outlet	4933591	25/06/2024 08:46	Triclopyr	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933592	25/06/2024 09:26	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4933592	25/06/2024 09:26	Colony Counts 22	CFU/1 ml	0	

W4523OUT	Lough Macrory Final Water Outlet	4933592	25/06/2024 09:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4933592	25/06/2024 09:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4933592	25/06/2024 09:26	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4933592	25/06/2024 09:26	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4933592	25/06/2024 09:26	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4933592	25/06/2024 09:26	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4933592	25/06/2024 09:26	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4933592	25/06/2024 09:26	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4933592	25/06/2024 09:26	Free - Residual disinfectant	mg Cl/l	0.96	
W4523OUT	Lough Macrory Final Water Outlet	4933592	25/06/2024 09:26	Free - Residual disinfectant	mg Cl/l	0.96	
W4523OUT	Lough Macrory Final Water Outlet	4933592	25/06/2024 09:26	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4933592	25/06/2024 09:26	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4933592	25/06/2024 09:26	Total - Residual disinfectant	mg Cl/l	1.21	
W4523OUT	Lough Macrory Final Water Outlet	4933592	25/06/2024 09:26	Total - Residual disinfectant	mg Cl/l	1.21	
W4523OUT	Lough Macrory Final Water Outlet	4933592	25/06/2024 09:26	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4933592	25/06/2024 09:26	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4933592	25/06/2024 09:26	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4933592	25/06/2024 09:26	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4933598	25/06/2024 10:28	Colony Counts 22	CFU/1 ml	1	
W4701OUT	Killyhevlin Final Water Outlet	4933598	25/06/2024 10:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4933598	25/06/2024 10:28	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4933598	25/06/2024 10:28	Conductivity	uS/cm 20 C	440	2500
W4701OUT	Killyhevlin Final Water Outlet	4933598	25/06/2024 10:28	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4933598	25/06/2024 10:28	Free - Residual disinfectant	mg Cl/l	1.56	
W4701OUT	Killyhevlin Final Water Outlet	4933598	25/06/2024 10:28	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4933598	25/06/2024 10:28	Total - Residual disinfectant	mg Cl/l	1.65	
W4701OUT	Killyhevlin Final Water Outlet	4933598	25/06/2024 10:28	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4933598	25/06/2024 10:28	Turbidity	NTU	0.099	1
W2514OUT	Seagahan Final Water Outlet	4933595	25/06/2024 11:25	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4933595	25/06/2024 11:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4933595	25/06/2024 11:25	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4933595	25/06/2024 11:25	Conductivity	uS/cm 20 C	370	2500
W2514OUT	Seagahan Final Water Outlet	4933595	25/06/2024 11:25	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4933595	25/06/2024 11:25	Free - Residual disinfectant	mg Cl/l	1.19	
W2514OUT	Seagahan Final Water Outlet	4933595	25/06/2024 11:25	Hydrogen Ion	pH value	7.6	9.5
W2514OUT	Seagahan Final Water Outlet	4933595	25/06/2024 11:25	Total - Residual disinfectant	mg Cl/l	1.37	
W2514OUT	Seagahan Final Water Outlet	4933595	25/06/2024 11:25	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4933595	25/06/2024 11:25	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4933595	25/06/2024 11:25	Algae Blue Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4933595	25/06/2024 11:25	Algae Diatom Total	per ml	40	
W2514OUT	Seagahan Final Water Outlet	4933595	25/06/2024 11:25	Algae Flagellate Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4933595	25/06/2024 11:25	Algae Green Total	per ml	0	

W2514OUT	Seagahan Final Water Outlet	4933595	25/06/2024 11:25	Algae Total	per ml	40	
W2514OUT	Seagahan Final Water Outlet	4933595	25/06/2024 11:25	Aluminium	ug Al/l	4.3	200
W2514OUT	Seagahan Final Water Outlet	4933595	25/06/2024 11:25	Iron	ug Fe/l	<14	200
W2514OUT	Seagahan Final Water Outlet	4933595	25/06/2024 11:25	Manganese	ug Mn/l	<0.8	50
W2514OUT	Seagahan Final Water Outlet	4933595	25/06/2024 11:25	Most numerous Algae		Diatoma	
W2514OUT	Seagahan Final Water Outlet	4933595	25/06/2024 11:25	Second most numerous Algae		---	
W2514OUT	Seagahan Final Water Outlet	4933595	25/06/2024 11:25	Third most numerous Algae		---	
W2514OUT	Seagahan Final Water Outlet	4933595	25/06/2024 11:25	Total Organic Carbon	mg C/l	2.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4933808	26/06/2024 08:04	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4933808	26/06/2024 08:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4933808	26/06/2024 08:04	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4933808	26/06/2024 08:04	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4933808	26/06/2024 08:04	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4933808	26/06/2024 08:04	Free - Residual disinfectant	mg Cl/l	1.45	
W2308POUT	Castor Bay PPP Final Water Outlet	4933808	26/06/2024 08:04	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4933808	26/06/2024 08:04	Total - Residual disinfectant	mg Cl/l	1.55	
W2308POUT	Castor Bay PPP Final Water Outlet	4933808	26/06/2024 08:04	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4933808	26/06/2024 08:04	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4933808	26/06/2024 08:04	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4933808	26/06/2024 08:04	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4933808	26/06/2024 08:04	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4933808	26/06/2024 08:04	Taste - Nature		No taste	
W1301POUT	Moyola PPP Final Water Outlet	4933809	26/06/2024 08:39	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4933809	26/06/2024 08:39	Colony Counts 37 (48hrs)	CFU/1 ml	8	
W1301POUT	Moyola PPP Final Water Outlet	4933809	26/06/2024 08:39	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4933809	26/06/2024 08:39	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4933809	26/06/2024 08:39	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4933809	26/06/2024 08:39	Free - Residual disinfectant	mg Cl/l	1.64	
W1301POUT	Moyola PPP Final Water Outlet	4933809	26/06/2024 08:39	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4933809	26/06/2024 08:39	Total - Residual disinfectant	mg Cl/l	1.74	
W1301POUT	Moyola PPP Final Water Outlet	4933809	26/06/2024 08:39	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4933809	26/06/2024 08:39	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4933798	26/06/2024 09:27	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4933798	26/06/2024 09:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4933798	26/06/2024 09:27	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4933798	26/06/2024 09:27	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4933798	26/06/2024 09:27	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4933798	26/06/2024 09:27	Free - Residual disinfectant	mg Cl/l	0.64	
W1302OUT	Lough Fea Final Water Outlet	4933798	26/06/2024 09:27	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4933798	26/06/2024 09:27	Total - Residual disinfectant	mg Cl/l	0.72	
W1302OUT	Lough Fea Final Water Outlet	4933798	26/06/2024 09:27	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4933798	26/06/2024 09:27	Turbidity	NTU	<0.09	1

W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.92	
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.92	
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Hydrogen Ion	pH value	7.7	9.5
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Hydrogen Ion	pH value	7.7	9.5
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Total - Residual disinfectant	mg Cl/l	1	
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Total - Residual disinfectant	mg Cl/l	1	
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	2,4-D	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	2,4-D	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	2,4-DB	ug/l	<0.016	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	2,4-DB	ug/l	<0.016	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Aluminium	ug Al/l	<3	200
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Aluminium	ug Al/l	<3	200
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Asulam	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Asulam	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Bentazone	ug/l	<0.0044	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Bentazone	ug/l	<0.0044	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Bromoxynil	ug/l	<0.0079	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Bromoxynil	ug/l	<0.0079	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Clopyralid	ug/l	<0.0097	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Clopyralid	ug/l	<0.0097	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Dichlorprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Dichlorprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Iron	ug Fe/l	<14	200
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Iron	ug Fe/l	<14	200
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Manganese	ug Mn/l	<0.8	50
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Manganese	ug Mn/l	<0.8	50
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	MCPA	ug/l	<0.0093	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	MCPA	ug/l	<0.0093	0.1

W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	MCPB	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	MCPB	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Mecoprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Mecoprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Propyzamide	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Propyzamide	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Total Organic Carbon	mg C/l	1.4	
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Total Organic Carbon	mg C/l	1.4	
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Triclopyr	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4933799	26/06/2024 10:15	Triclopyr	ug/l	<0.012	0.1
W4701OUT	Killyhevlin Final Water Outlet	4933804	26/06/2024 10:22	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4933804	26/06/2024 10:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4933804	26/06/2024 10:22	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4933804	26/06/2024 10:22	Conductivity	uS/cm 20 C	440	2500
W4701OUT	Killyhevlin Final Water Outlet	4933804	26/06/2024 10:22	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4933804	26/06/2024 10:22	Free - Residual disinfectant	mg Cl/l	1.73	
W4701OUT	Killyhevlin Final Water Outlet	4933804	26/06/2024 10:22	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4933804	26/06/2024 10:22	Total - Residual disinfectant	mg Cl/l	1.82	
W4701OUT	Killyhevlin Final Water Outlet	4933804	26/06/2024 10:22	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4933804	26/06/2024 10:22	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4933801	26/06/2024 11:10	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4933801	26/06/2024 11:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4933801	26/06/2024 11:10	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4933801	26/06/2024 11:10	Conductivity	uS/cm 20 C	370	2500
W2514OUT	Seagahan Final Water Outlet	4933801	26/06/2024 11:10	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4933801	26/06/2024 11:10	Free - Residual disinfectant	mg Cl/l	1.18	
W2514OUT	Seagahan Final Water Outlet	4933801	26/06/2024 11:10	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4933801	26/06/2024 11:10	Total - Residual disinfectant	mg Cl/l	1.34	
W2514OUT	Seagahan Final Water Outlet	4933801	26/06/2024 11:10	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4933801	26/06/2024 11:10	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4933966	27/06/2024 07:35	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4933966	27/06/2024 07:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4933966	27/06/2024 07:35	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4933966	27/06/2024 07:35	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4933966	27/06/2024 07:35	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4933966	27/06/2024 07:35	Free - Residual disinfectant	mg Cl/l	1.25	
W1301POUT	Moyola PPP Final Water Outlet	4933966	27/06/2024 07:35	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4933966	27/06/2024 07:35	Total - Residual disinfectant	mg Cl/l	1.55	
W1301POUT	Moyola PPP Final Water Outlet	4933966	27/06/2024 07:35	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4933966	27/06/2024 07:35	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4933964	27/06/2024 07:54	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4933964	27/06/2024 07:54	Colony Counts 37 (48hrs)	CFU/1 ml	0	

W2308POUT	Castor Bay PPP Final Water Outlet	4933964	27/06/2024 07:54	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4933964	27/06/2024 07:54	Conductivity	uS/cm 20 C	390	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4933964	27/06/2024 07:54	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4933964	27/06/2024 07:54	Free - Residual disinfectant	mg Cl/l	1.27	
W2308POUT	Castor Bay PPP Final Water Outlet	4933964	27/06/2024 07:54	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4933964	27/06/2024 07:54	Total - Residual disinfectant	mg Cl/l	1.35	
W2308POUT	Castor Bay PPP Final Water Outlet	4933964	27/06/2024 07:54	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4933964	27/06/2024 07:54	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4933953	27/06/2024 08:28	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4933953	27/06/2024 08:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4933953	27/06/2024 08:28	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4933953	27/06/2024 08:28	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4933953	27/06/2024 08:28	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4933953	27/06/2024 08:28	Free - Residual disinfectant	mg Cl/l	0.71	
W1302OUT	Lough Fea Final Water Outlet	4933953	27/06/2024 08:28	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4933953	27/06/2024 08:28	Total - Residual disinfectant	mg Cl/l	0.83	
W1302OUT	Lough Fea Final Water Outlet	4933953	27/06/2024 08:28	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4933953	27/06/2024 08:28	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4933953	27/06/2024 08:28	Aluminium	ug Al/l	26	200
W1302OUT	Lough Fea Final Water Outlet	4933953	27/06/2024 08:28	Bromodichloromethane	ug/l	9.4	
W1302OUT	Lough Fea Final Water Outlet	4933953	27/06/2024 08:28	Bromoform	ug/l	<3.5	
W1302OUT	Lough Fea Final Water Outlet	4933953	27/06/2024 08:28	Chloroform	ug/l	41	
W1302OUT	Lough Fea Final Water Outlet	4933953	27/06/2024 08:28	Dibromochloromethane	ug/l	<1.6	
W1302OUT	Lough Fea Final Water Outlet	4933953	27/06/2024 08:28	Iron	ug Fe/l	<14	200
W1302OUT	Lough Fea Final Water Outlet	4933953	27/06/2024 08:28	Manganese	ug Mn/l	<0.8	50
W1302OUT	Lough Fea Final Water Outlet	4933953	27/06/2024 08:28	Total Organic Carbon	mg C/l	1.6	
W1302OUT	Lough Fea Final Water Outlet	4933953	27/06/2024 08:28	Total Trihalomethanes	ug/l	52	100
W1302OUT	Lough Fea Final Water Outlet	4933953	27/06/2024 08:28	WHO Index		0.31	1
W2514OUT	Seagahan Final Water Outlet	4933957	27/06/2024 10:25	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4933957	27/06/2024 10:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4933957	27/06/2024 10:25	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4933957	27/06/2024 10:25	Conductivity	uS/cm 20 C	380	2500
W2514OUT	Seagahan Final Water Outlet	4933957	27/06/2024 10:25	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4933957	27/06/2024 10:25	Free - Residual disinfectant	mg Cl/l	1.22	
W2514OUT	Seagahan Final Water Outlet	4933957	27/06/2024 10:25	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4933957	27/06/2024 10:25	Total - Residual disinfectant	mg Cl/l	1.38	
W2514OUT	Seagahan Final Water Outlet	4933957	27/06/2024 10:25	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4933957	27/06/2024 10:25	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4933960	27/06/2024 10:35	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4933960	27/06/2024 10:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4933960	27/06/2024 10:35	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4933960	27/06/2024 10:35	Conductivity	uS/cm 20 C	430	2500

W4701OUT	Killyhevlin Final Water Outlet	4933960	27/06/2024 10:35	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4933960	27/06/2024 10:35	Free - Residual disinfectant	mg Cl/l	1.72	
W4701OUT	Killyhevlin Final Water Outlet	4933960	27/06/2024 10:35	Hydrogen Ion	pH value	7.5	9.5
W4701OUT	Killyhevlin Final Water Outlet	4933960	27/06/2024 10:35	Total - Residual disinfectant	mg Cl/l	1.83	
W4701OUT	Killyhevlin Final Water Outlet	4933960	27/06/2024 10:35	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4933960	27/06/2024 10:35	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4948094	27/06/2024 10:40	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4948094	27/06/2024 10:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4948094	27/06/2024 10:40	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4948094	27/06/2024 10:40	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4948094	27/06/2024 10:40	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4948094	27/06/2024 10:40	Free - Residual disinfectant	mg Cl/l	0.68	
W1302OUT	Lough Fea Final Water Outlet	4948094	27/06/2024 10:40	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4948094	27/06/2024 10:40	Total - Residual disinfectant	mg Cl/l	0.78	
W1302OUT	Lough Fea Final Water Outlet	4948094	27/06/2024 10:40	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4948094	27/06/2024 10:40	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4948064	27/06/2024 11:00	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4948064	27/06/2024 11:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4948064	27/06/2024 11:00	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4948064	27/06/2024 11:00	Conductivity	uS/cm 20 C	400	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4948064	27/06/2024 11:00	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4948064	27/06/2024 11:00	Free - Residual disinfectant	mg Cl/l	1.48	
W2308POUT	Castor Bay PPP Final Water Outlet	4948064	27/06/2024 11:00	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4948064	27/06/2024 11:00	Total - Residual disinfectant	mg Cl/l	1.6	
W2308POUT	Castor Bay PPP Final Water Outlet	4948064	27/06/2024 11:00	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4948064	27/06/2024 11:00	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4933954	27/06/2024 11:42	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4933954	27/06/2024 11:42	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4933954	27/06/2024 11:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4933954	27/06/2024 11:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4933954	27/06/2024 11:42	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4933954	27/06/2024 11:42	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4933954	27/06/2024 11:42	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4933954	27/06/2024 11:42	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4933954	27/06/2024 11:42	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4933954	27/06/2024 11:42	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4933954	27/06/2024 11:42	Free - Residual disinfectant	mg Cl/l	0.89	
W4523OUT	Lough Macrory Final Water Outlet	4933954	27/06/2024 11:42	Free - Residual disinfectant	mg Cl/l	0.89	
W4523OUT	Lough Macrory Final Water Outlet	4933954	27/06/2024 11:42	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4933954	27/06/2024 11:42	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4933954	27/06/2024 11:42	Total - Residual disinfectant	mg Cl/l	1	
W4523OUT	Lough Macrory Final Water Outlet	4933954	27/06/2024 11:42	Total - Residual disinfectant	mg Cl/l	1	

W4523OUT	Lough Macrory Final Water Outlet	4933954	27/06/2024 11:42	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4933954	27/06/2024 11:42	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4933954	27/06/2024 11:42	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4933954	27/06/2024 11:42	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4934095	28/06/2024 07:14	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4934095	28/06/2024 07:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4934095	28/06/2024 07:14	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4934095	28/06/2024 07:14	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4934095	28/06/2024 07:14	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4934095	28/06/2024 07:14	Free - Residual disinfectant	mg Cl/l	1.39	
W1301POUT	Moyola PPP Final Water Outlet	4934095	28/06/2024 07:14	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4934095	28/06/2024 07:14	Total - Residual disinfectant	mg Cl/l	1.43	
W1301POUT	Moyola PPP Final Water Outlet	4934095	28/06/2024 07:14	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4934095	28/06/2024 07:14	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4934094	28/06/2024 08:05	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4934094	28/06/2024 08:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4934094	28/06/2024 08:05	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4934094	28/06/2024 08:05	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4934094	28/06/2024 08:05	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4934094	28/06/2024 08:05	Free - Residual disinfectant	mg Cl/l	1.51	
W2308POUT	Castor Bay PPP Final Water Outlet	4934094	28/06/2024 08:05	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4934094	28/06/2024 08:05	Total - Residual disinfectant	mg Cl/l	1.68	
W2308POUT	Castor Bay PPP Final Water Outlet	4934094	28/06/2024 08:05	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4934094	28/06/2024 08:05	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4934088	28/06/2024 09:41	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4934088	28/06/2024 09:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4934088	28/06/2024 09:41	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4934088	28/06/2024 09:41	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4934088	28/06/2024 09:41	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4934088	28/06/2024 09:41	Free - Residual disinfectant	mg Cl/l	0.88	
W1302OUT	Lough Fea Final Water Outlet	4934088	28/06/2024 09:41	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4934088	28/06/2024 09:41	Total - Residual disinfectant	mg Cl/l	0.93	
W1302OUT	Lough Fea Final Water Outlet	4934088	28/06/2024 09:41	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4934088	28/06/2024 09:41	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4948404	28/06/2024 11:12	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4948404	28/06/2024 11:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4948404	28/06/2024 11:12	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4948404	28/06/2024 11:12	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4948404	28/06/2024 11:12	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4948404	28/06/2024 11:12	Free - Residual disinfectant	mg Cl/l	1.4	
W1301POUT	Moyola PPP Final Water Outlet	4948404	28/06/2024 11:12	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4948404	28/06/2024 11:12	Total - Residual disinfectant	mg Cl/l	1.42	

W1301POUT	Moyola PPP Final Water Outlet	4948404	28/06/2024 11:12	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4948404	28/06/2024 11:12	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4934090	28/06/2024 11:53	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4934090	28/06/2024 11:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4934090	28/06/2024 11:53	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4934090	28/06/2024 11:53	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4934090	28/06/2024 11:53	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4934090	28/06/2024 11:53	Free - Residual disinfectant	mg Cl/l	1.16	
W4701OUT	Killyhevlin Final Water Outlet	4934090	28/06/2024 11:53	Hydrogen Ion	pH value	7.6	9.5
W4701OUT	Killyhevlin Final Water Outlet	4934090	28/06/2024 11:53	Total - Residual disinfectant	mg Cl/l	1.21	
W4701OUT	Killyhevlin Final Water Outlet	4934090	28/06/2024 11:53	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4934090	28/06/2024 11:53	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4934153	29/06/2024 08:57	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4934153	29/06/2024 08:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4934153	29/06/2024 08:57	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4934153	29/06/2024 08:57	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4934153	29/06/2024 08:57	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4934153	29/06/2024 08:57	Free - Residual disinfectant	mg Cl/l	1.26	
W4701OUT	Killyhevlin Final Water Outlet	4934153	29/06/2024 08:57	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4934153	29/06/2024 08:57	Total - Residual disinfectant	mg Cl/l	1.39	
W4701OUT	Killyhevlin Final Water Outlet	4934153	29/06/2024 08:57	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4934153	29/06/2024 08:57	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4934157	29/06/2024 09:34	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4934157	29/06/2024 09:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4934157	29/06/2024 09:34	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4934157	29/06/2024 09:34	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4934157	29/06/2024 09:34	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4934157	29/06/2024 09:34	Free - Residual disinfectant	mg Cl/l	1.31	
W1301POUT	Moyola PPP Final Water Outlet	4934157	29/06/2024 09:34	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4934157	29/06/2024 09:34	Total - Residual disinfectant	mg Cl/l	1.5	
W1301POUT	Moyola PPP Final Water Outlet	4934157	29/06/2024 09:34	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4934157	29/06/2024 09:34	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4934152	29/06/2024 10:08	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4934152	29/06/2024 10:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4934152	29/06/2024 10:08	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4934152	29/06/2024 10:08	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4934152	29/06/2024 10:08	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4934152	29/06/2024 10:08	Free - Residual disinfectant	mg Cl/l	0.92	
W1302OUT	Lough Fea Final Water Outlet	4934152	29/06/2024 10:08	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4934152	29/06/2024 10:08	Total - Residual disinfectant	mg Cl/l	1.18	
W1302OUT	Lough Fea Final Water Outlet	4934152	29/06/2024 10:08	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4934152	29/06/2024 10:08	Turbidity	NTU	<0.09	1

W2308POUT	Castor Bay PPP Final Water Outlet	4934156	29/06/2024 10:21	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4934156	29/06/2024 10:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4934156	29/06/2024 10:21	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4934156	29/06/2024 10:21	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4934156	29/06/2024 10:21	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4934156	29/06/2024 10:21	Free - Residual disinfectant	mg Cl/l	1.53	
W2308POUT	Castor Bay PPP Final Water Outlet	4934156	29/06/2024 10:21	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4934156	29/06/2024 10:21	Total - Residual disinfectant	mg Cl/l	1.65	
W2308POUT	Castor Bay PPP Final Water Outlet	4934156	29/06/2024 10:21	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4934156	29/06/2024 10:21	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4934171	30/06/2024 00:00	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4934171	30/06/2024 00:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4934171	30/06/2024 00:00	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4934171	30/06/2024 00:00	Conductivity	uS/cm 20 C	440	2500
W4701OUT	Killyhevlin Final Water Outlet	4934171	30/06/2024 00:00	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4934171	30/06/2024 00:00	Free - Residual disinfectant	mg Cl/l	1.23	
W4701OUT	Killyhevlin Final Water Outlet	4934171	30/06/2024 00:00	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4934171	30/06/2024 00:00	Total - Residual disinfectant	mg Cl/l	1.39	
W4701OUT	Killyhevlin Final Water Outlet	4934171	30/06/2024 00:00	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4934171	30/06/2024 00:00	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4934174	30/06/2024 10:17	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4934174	30/06/2024 10:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4934174	30/06/2024 10:17	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4934174	30/06/2024 10:17	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4934174	30/06/2024 10:17	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4934174	30/06/2024 10:17	Free - Residual disinfectant	mg Cl/l	1.4	
W2308POUT	Castor Bay PPP Final Water Outlet	4934174	30/06/2024 10:17	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4934174	30/06/2024 10:17	Total - Residual disinfectant	mg Cl/l	1.45	
W2308POUT	Castor Bay PPP Final Water Outlet	4934174	30/06/2024 10:17	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4934174	30/06/2024 10:17	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4934175	30/06/2024 10:25	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4934175	30/06/2024 10:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4934175	30/06/2024 10:25	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4934175	30/06/2024 10:25	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4934175	30/06/2024 10:25	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4934175	30/06/2024 10:25	Free - Residual disinfectant	mg Cl/l	1.45	
W1301POUT	Moyola PPP Final Water Outlet	4934175	30/06/2024 10:25	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4934175	30/06/2024 10:25	Total - Residual disinfectant	mg Cl/l	1.95	
W1301POUT	Moyola PPP Final Water Outlet	4934175	30/06/2024 10:25	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4934175	30/06/2024 10:25	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4934170	30/06/2024 10:57	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4934170	30/06/2024 10:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	

W1302OUT	Lough Fea Final Water Outlet	4934170	30/06/2024 10:57	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4934170	30/06/2024 10:57	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4934170	30/06/2024 10:57	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4934170	30/06/2024 10:57	Free - Residual disinfectant	mg Cl/l	0.84	
W1302OUT	Lough Fea Final Water Outlet	4934170	30/06/2024 10:57	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4934170	30/06/2024 10:57	Total - Residual disinfectant	mg Cl/l	0.98	
W1302OUT	Lough Fea Final Water Outlet	4934170	30/06/2024 10:57	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4934170	30/06/2024 10:57	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4936272	01/07/2024 07:42	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4936272	01/07/2024 07:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4936272	01/07/2024 07:42	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4936272	01/07/2024 07:42	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4936272	01/07/2024 07:42	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4936272	01/07/2024 07:42	Free - Residual disinfectant	mg Cl/l	1.32	
W1301POUT	Moyola PPP Final Water Outlet	4936272	01/07/2024 07:42	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4936272	01/07/2024 07:42	Total - Residual disinfectant	mg Cl/l	1.41	
W1301POUT	Moyola PPP Final Water Outlet	4936272	01/07/2024 07:42	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4936272	01/07/2024 07:42	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4936270	01/07/2024 08:06	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4936270	01/07/2024 08:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4936270	01/07/2024 08:06	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4936270	01/07/2024 08:06	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4936270	01/07/2024 08:06	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4936270	01/07/2024 08:06	Free - Residual disinfectant	mg Cl/l	1.39	
W2308POUT	Castor Bay PPP Final Water Outlet	4936270	01/07/2024 08:06	Hydrogen Ion	pH value	7.7	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4936270	01/07/2024 08:06	Total - Residual disinfectant	mg Cl/l	1.52	
W2308POUT	Castor Bay PPP Final Water Outlet	4936270	01/07/2024 08:06	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4936270	01/07/2024 08:06	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4936270	01/07/2024 08:06	Aluminium	ug Al/l	29	200
W2308POUT	Castor Bay PPP Final Water Outlet	4936270	01/07/2024 08:06	Iron	ug Fe/l	<14	200
W2308POUT	Castor Bay PPP Final Water Outlet	4936270	01/07/2024 08:06	Manganese	ug Mn/l	<0.8	50
W2308POUT	Castor Bay PPP Final Water Outlet	4936270	01/07/2024 08:06	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4936270	01/07/2024 08:06	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4936270	01/07/2024 08:06	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4936270	01/07/2024 08:06	Taste - Nature		No taste	
W1316OUT	Moneymore Borewell Final Water Outlet	4936281	01/07/2024 08:39	Colony Counts 22	CFU/1 ml	0	
W1316OUT	Moneymore Borewell Final Water Outlet	4936281	01/07/2024 08:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1316OUT	Moneymore Borewell Final Water Outlet	4936281	01/07/2024 08:39	Colour	mg/l Pt/Co	<4.56	20
W1316OUT	Moneymore Borewell Final Water Outlet	4936281	01/07/2024 08:39	Conductivity	uS/cm 20 C	350	2500
W1316OUT	Moneymore Borewell Final Water Outlet	4936281	01/07/2024 08:39	E. coli	CFU/100 ml	0	0
W1316OUT	Moneymore Borewell Final Water Outlet	4936281	01/07/2024 08:39	Free - Residual disinfectant	mg Cl/l	0.39	
W1316OUT	Moneymore Borewell Final Water Outlet	4936281	01/07/2024 08:39	Hydrogen Ion	pH value	7.7	9.5

W1316OUT	Money more Borewell Final Water Outlet	4936281	01/07/2024 08:39	Total - Residual disinfectant	mg Cl/l	0.53	
W1316OUT	Money more Borewell Final Water Outlet	4936281	01/07/2024 08:39	Total Coliforms	CFU/100 ml	0	0
W1316OUT	Money more Borewell Final Water Outlet	4936281	01/07/2024 08:39	Turbidity	NTU	<0.09	1
W1316OUT	Money more Borewell Final Water Outlet	4936281	01/07/2024 08:39	Aluminium	ug Al/l	23	200
W1316OUT	Money more Borewell Final Water Outlet	4936281	01/07/2024 08:39	Iron	ug Fe/l	<14	200
W1316OUT	Money more Borewell Final Water Outlet	4936281	01/07/2024 08:39	Manganese	ug Mn/l	<0.8	50
W1316OUT	Money more Borewell Final Water Outlet	4936281	01/07/2024 08:39	Total Organic Carbon	mg C/l	1.8	
W1302OUT	Lough Fea Final Water Outlet	4936246	01/07/2024 09:26	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4936246	01/07/2024 09:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4936246	01/07/2024 09:26	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4936246	01/07/2024 09:26	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4936246	01/07/2024 09:26	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4936246	01/07/2024 09:26	Free - Residual disinfectant	mg Cl/l	0.93	
W1302OUT	Lough Fea Final Water Outlet	4936246	01/07/2024 09:26	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4936246	01/07/2024 09:26	Total - Residual disinfectant	mg Cl/l	1.06	
W1302OUT	Lough Fea Final Water Outlet	4936246	01/07/2024 09:26	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4936246	01/07/2024 09:26	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4936246	01/07/2024 09:26	Aluminium	ug Al/l	24	200
W1302OUT	Lough Fea Final Water Outlet	4936246	01/07/2024 09:26	Bromodichloromethane	ug/l	9.2	
W1302OUT	Lough Fea Final Water Outlet	4936246	01/07/2024 09:26	Bromoform	ug/l	<3.5	
W1302OUT	Lough Fea Final Water Outlet	4936246	01/07/2024 09:26	Chloroform	ug/l	37	
W1302OUT	Lough Fea Final Water Outlet	4936246	01/07/2024 09:26	Dibromochloromethane	ug/l	1.6	
W1302OUT	Lough Fea Final Water Outlet	4936246	01/07/2024 09:26	Iron	ug Fe/l	<14	200
W1302OUT	Lough Fea Final Water Outlet	4936246	01/07/2024 09:26	Manganese	ug Mn/l	<0.8	50
W1302OUT	Lough Fea Final Water Outlet	4936246	01/07/2024 09:26	Total Organic Carbon	mg C/l	1.6	
W1302OUT	Lough Fea Final Water Outlet	4936246	01/07/2024 09:26	Total Trihalomethanes	ug/l	48	100
W1302OUT	Lough Fea Final Water Outlet	4936246	01/07/2024 09:26	WHO Index		0.3	1
W4523OUT	Lough Macrory Final Water Outlet	4936247	01/07/2024 09:35	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4936247	01/07/2024 09:35	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4936247	01/07/2024 09:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4936247	01/07/2024 09:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4936247	01/07/2024 09:35	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4936247	01/07/2024 09:35	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4936247	01/07/2024 09:35	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4936247	01/07/2024 09:35	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4936247	01/07/2024 09:35	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4936247	01/07/2024 09:35	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4936247	01/07/2024 09:35	Free - Residual disinfectant	mg Cl/l	0.82	
W4523OUT	Lough Macrory Final Water Outlet	4936247	01/07/2024 09:35	Free - Residual disinfectant	mg Cl/l	0.82	
W4523OUT	Lough Macrory Final Water Outlet	4936247	01/07/2024 09:35	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4936247	01/07/2024 09:35	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4936247	01/07/2024 09:35	Total - Residual disinfectant	mg Cl/l	0.9	

W4523OUT	Lough Macrory Final Water Outlet	4936247	01/07/2024 09:35	Total - Residual disinfectant	mg Cl/l	0.9	
W4523OUT	Lough Macrory Final Water Outlet	4936247	01/07/2024 09:35	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4936247	01/07/2024 09:35	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4936247	01/07/2024 09:35	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4936247	01/07/2024 09:35	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4936260	01/07/2024 11:23	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4936260	01/07/2024 11:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4936260	01/07/2024 11:23	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4936260	01/07/2024 11:23	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4936260	01/07/2024 11:23	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4936260	01/07/2024 11:23	Free - Residual disinfectant	mg Cl/l	1.72	
W4701OUT	Killyhevlin Final Water Outlet	4936260	01/07/2024 11:23	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4936260	01/07/2024 11:23	Total - Residual disinfectant	mg Cl/l	1.82	
W4701OUT	Killyhevlin Final Water Outlet	4936260	01/07/2024 11:23	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4936260	01/07/2024 11:23	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4936252	01/07/2024 11:42	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4936252	01/07/2024 11:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4936252	01/07/2024 11:42	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4936252	01/07/2024 11:42	Conductivity	uS/cm 20 C	380	2500
W2514OUT	Seagahan Final Water Outlet	4936252	01/07/2024 11:42	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4936252	01/07/2024 11:42	Free - Residual disinfectant	mg Cl/l	1.18	
W2514OUT	Seagahan Final Water Outlet	4936252	01/07/2024 11:42	Hydrogen Ion	pH value	7.4	9.5
W2514OUT	Seagahan Final Water Outlet	4936252	01/07/2024 11:42	Total - Residual disinfectant	mg Cl/l	1.28	
W2514OUT	Seagahan Final Water Outlet	4936252	01/07/2024 11:42	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4936252	01/07/2024 11:42	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Free - Residual disinfectant	mg Cl/l	1.4	
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Total - Residual disinfectant	mg Cl/l	1.57	
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Algae Diatom Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Algae Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Aluminium	ug Al/l	23	200
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Bromodichloromethane	ug/l	6.7	

W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Chloroform	ug/l	11	
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Dibromochloromethane	ug/l	4.4	
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Iron	ug Fe/l	<14	200
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Manganese	ug Mn/l	<0.8	50
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	MIB	ng/l	3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Microcystin-LR	ug/l	<0.024	
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Most numerous Algae		---	
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Second most numerous Algae		---	
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Third most numerous Algae		---	
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Total Organic Carbon	mg C/l	2.6	
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	Total Trihalomethanes	ug/l	23	100
W2308POUT	Castor Bay PPP Final Water Outlet	4936659	02/07/2024 08:08	WHO Index		0.2	1
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Free - Residual disinfectant	mg Cl/l	1.31	
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Total - Residual disinfectant	mg Cl/l	1.41	
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	2,4-D	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	2,4-DB	ug/l	<0.016	0.1
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Algae Blue Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Algae Diatom Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Algae Flagellate Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Algae Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Algae Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Aluminium	ug Al/l	34	200
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Asulam	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Bentazone	ug/l	<0.0044	0.1
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Bromoxynil	ug/l	<0.0079	0.1
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Clopyralid	ug/l	<0.0097	0.1
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Dichlorprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Geosmin	ng/l	<1.1	

W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Iron	ug Fe/l	<14	200
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Manganese	ug Mn/l	<0.8	50
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	MCPA	ug/l	<0.0093	0.1
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	MCPB	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Mecoprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	MIB	ng/l	4.6	
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Microcystin-LR	ug/l	<0.024	
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Most numerous Algae		---	
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Propyzamide	ug/l	<0.012	0.1
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Second most numerous Algae		---	
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Third most numerous Algae		---	
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Total Organic Carbon	mg C/l	2.5	
W1301POUT	Moyola PPP Final Water Outlet	4936663	02/07/2024 08:14	Triclopyr	ug/l	<0.012	0.1
W4701OUT	Killyhevlin Final Water Outlet	4936654	02/07/2024 09:06	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4936654	02/07/2024 09:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4936654	02/07/2024 09:06	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4936654	02/07/2024 09:06	Conductivity	uS/cm 20 C	440	2500
W4701OUT	Killyhevlin Final Water Outlet	4936654	02/07/2024 09:06	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4936654	02/07/2024 09:06	Free - Residual disinfectant	mg Cl/l	1.7	
W4701OUT	Killyhevlin Final Water Outlet	4936654	02/07/2024 09:06	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4936654	02/07/2024 09:06	Total - Residual disinfectant	mg Cl/l	1.82	
W4701OUT	Killyhevlin Final Water Outlet	4936654	02/07/2024 09:06	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4936654	02/07/2024 09:06	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4936654	02/07/2024 09:06	Algae Blue Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4936654	02/07/2024 09:06	Algae Diatom Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4936654	02/07/2024 09:06	Algae Flagellate Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4936654	02/07/2024 09:06	Algae Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4936654	02/07/2024 09:06	Algae Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4936654	02/07/2024 09:06	Aluminium	ug Al/l	25	200
W4701OUT	Killyhevlin Final Water Outlet	4936654	02/07/2024 09:06	Iron	ug Fe/l	<14	200
W4701OUT	Killyhevlin Final Water Outlet	4936654	02/07/2024 09:06	Manganese	ug Mn/l	4.1	50
W4701OUT	Killyhevlin Final Water Outlet	4936654	02/07/2024 09:06	Most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4936654	02/07/2024 09:06	Second most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4936654	02/07/2024 09:06	Third most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4936654	02/07/2024 09:06	Total Organic Carbon	mg C/l	2.4	
W2514OUT	Seagahan Final Water Outlet	4936648	02/07/2024 09:19	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4936648	02/07/2024 09:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4936648	02/07/2024 09:19	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4936648	02/07/2024 09:19	Conductivity	uS/cm 20 C	380	2500
W2514OUT	Seagahan Final Water Outlet	4936648	02/07/2024 09:19	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4936648	02/07/2024 09:19	Free - Residual disinfectant	mg Cl/l	1.1	
W2514OUT	Seagahan Final Water Outlet	4936648	02/07/2024 09:19	Hydrogen Ion	pH value	7.5	9.5

W2514OUT	Seagahan Final Water Outlet	4936648	02/07/2024 09:19	Total - Residual disinfectant	mg Cl/l	1.24	
W2514OUT	Seagahan Final Water Outlet	4936648	02/07/2024 09:19	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4936648	02/07/2024 09:19	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4936643	02/07/2024 10:18	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4936643	02/07/2024 10:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4936643	02/07/2024 10:18	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4936643	02/07/2024 10:18	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4936643	02/07/2024 10:18	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4936643	02/07/2024 10:18	Free - Residual disinfectant	mg Cl/l	0.79	
W1302OUT	Lough Fea Final Water Outlet	4936643	02/07/2024 10:18	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4936643	02/07/2024 10:18	Total - Residual disinfectant	mg Cl/l	0.86	
W1302OUT	Lough Fea Final Water Outlet	4936643	02/07/2024 10:18	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4936643	02/07/2024 10:18	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4936644	02/07/2024 10:34	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4936644	02/07/2024 10:34	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4936644	02/07/2024 10:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4936644	02/07/2024 10:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4936644	02/07/2024 10:34	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4936644	02/07/2024 10:34	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4936644	02/07/2024 10:34	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4936644	02/07/2024 10:34	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4936644	02/07/2024 10:34	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4936644	02/07/2024 10:34	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4936644	02/07/2024 10:34	Free - Residual disinfectant	mg Cl/l	0.93	
W4523OUT	Lough Macrory Final Water Outlet	4936644	02/07/2024 10:34	Free - Residual disinfectant	mg Cl/l	0.93	
W4523OUT	Lough Macrory Final Water Outlet	4936644	02/07/2024 10:34	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4936644	02/07/2024 10:34	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4936644	02/07/2024 10:34	Total - Residual disinfectant	mg Cl/l	1.04	
W4523OUT	Lough Macrory Final Water Outlet	4936644	02/07/2024 10:34	Total - Residual disinfectant	mg Cl/l	1.04	
W4523OUT	Lough Macrory Final Water Outlet	4936644	02/07/2024 10:34	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4936644	02/07/2024 10:34	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4936644	02/07/2024 10:34	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4936644	02/07/2024 10:34	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4936842	03/07/2024 07:35	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4936842	03/07/2024 07:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4936842	03/07/2024 07:35	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4936842	03/07/2024 07:35	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4936842	03/07/2024 07:35	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4936842	03/07/2024 07:35	Free - Residual disinfectant	mg Cl/l	1.31	
W2308POUT	Castor Bay PPP Final Water Outlet	4936842	03/07/2024 07:35	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4936842	03/07/2024 07:35	Total - Residual disinfectant	mg Cl/l	1.51	
W2308POUT	Castor Bay PPP Final Water Outlet	4936842	03/07/2024 07:35	Total Coliforms	CFU/100 ml	0	0

W2308POUT	Castor Bay PPP Final Water Outlet	4936842	03/07/2024 07:35	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4936842	03/07/2024 07:35	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4936842	03/07/2024 07:35	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4936842	03/07/2024 07:35	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4936842	03/07/2024 07:35	Taste - Nature		No taste	
W1301POUT	Moyola PPP Final Water Outlet	4936844	03/07/2024 07:48	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4936844	03/07/2024 07:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4936844	03/07/2024 07:48	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4936844	03/07/2024 07:48	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4936844	03/07/2024 07:48	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4936844	03/07/2024 07:48	Free - Residual disinfectant	mg Cl/l	1.5	
W1301POUT	Moyola PPP Final Water Outlet	4936844	03/07/2024 07:48	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4936844	03/07/2024 07:48	Total - Residual disinfectant	mg Cl/l	1.81	
W1301POUT	Moyola PPP Final Water Outlet	4936844	03/07/2024 07:48	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4936844	03/07/2024 07:48	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4936837	03/07/2024 08:58	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4936837	03/07/2024 08:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4936837	03/07/2024 08:58	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4936837	03/07/2024 08:58	Conductivity	uS/cm 20 C	440	2500
W4701OUT	Killyhevlin Final Water Outlet	4936837	03/07/2024 08:58	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4936837	03/07/2024 08:58	Free - Residual disinfectant	mg Cl/l	1.91	
W4701OUT	Killyhevlin Final Water Outlet	4936837	03/07/2024 08:58	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4936837	03/07/2024 08:58	Total - Residual disinfectant	mg Cl/l	1.95	
W4701OUT	Killyhevlin Final Water Outlet	4936837	03/07/2024 08:58	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4936837	03/07/2024 08:58	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4936830	03/07/2024 10:15	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4936830	03/07/2024 10:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4936830	03/07/2024 10:15	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4936830	03/07/2024 10:15	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4936830	03/07/2024 10:15	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4936830	03/07/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.77	
W1302OUT	Lough Fea Final Water Outlet	4936830	03/07/2024 10:15	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4936830	03/07/2024 10:15	Total - Residual disinfectant	mg Cl/l	0.88	
W1302OUT	Lough Fea Final Water Outlet	4936830	03/07/2024 10:15	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4936830	03/07/2024 10:15	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4936831	03/07/2024 10:17	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4936831	03/07/2024 10:17	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4936831	03/07/2024 10:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4936831	03/07/2024 10:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4936831	03/07/2024 10:17	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4936831	03/07/2024 10:17	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4936831	03/07/2024 10:17	Conductivity	uS/cm 20 C	120	2500

W4523OUT	Lough Macrory Final Water Outlet	4936831	03/07/2024 10:17	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4936831	03/07/2024 10:17	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4936831	03/07/2024 10:17	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4936831	03/07/2024 10:17	Free - Residual disinfectant	mg Cl/l	0.89	
W4523OUT	Lough Macrory Final Water Outlet	4936831	03/07/2024 10:17	Free - Residual disinfectant	mg Cl/l	0.89	
W4523OUT	Lough Macrory Final Water Outlet	4936831	03/07/2024 10:17	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4936831	03/07/2024 10:17	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4936831	03/07/2024 10:17	Total - Residual disinfectant	mg Cl/l	0.99	
W4523OUT	Lough Macrory Final Water Outlet	4936831	03/07/2024 10:17	Total - Residual disinfectant	mg Cl/l	0.99	
W4523OUT	Lough Macrory Final Water Outlet	4936831	03/07/2024 10:17	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4936831	03/07/2024 10:17	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4936831	03/07/2024 10:17	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4936831	03/07/2024 10:17	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4936834	03/07/2024 11:47	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4936834	03/07/2024 11:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4936834	03/07/2024 11:47	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4936834	03/07/2024 11:47	Conductivity	uS/cm 20 C	370	2500
W2514OUT	Seagahan Final Water Outlet	4936834	03/07/2024 11:47	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4936834	03/07/2024 11:47	Free - Residual disinfectant	mg Cl/l	1.1	
W2514OUT	Seagahan Final Water Outlet	4936834	03/07/2024 11:47	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4936834	03/07/2024 11:47	Total - Residual disinfectant	mg Cl/l	1.27	
W2514OUT	Seagahan Final Water Outlet	4936834	03/07/2024 11:47	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4936834	03/07/2024 11:47	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4936834	03/07/2024 11:47	Algae Blue Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4936834	03/07/2024 11:47	Algae Diatom Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4936834	03/07/2024 11:47	Algae Flagellate Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4936834	03/07/2024 11:47	Algae Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4936834	03/07/2024 11:47	Algae Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4936834	03/07/2024 11:47	Aluminium	ug Al/l	460	200
W2514OUT	Seagahan Final Water Outlet	4936834	03/07/2024 11:47	Iron	ug/l Fe	2.2	200
W2514OUT	Seagahan Final Water Outlet	4936834	03/07/2024 11:47	Manganese	ug Mn/l	<0.642	50
W2514OUT	Seagahan Final Water Outlet	4936834	03/07/2024 11:47	Most numerous Algae		---	
W2514OUT	Seagahan Final Water Outlet	4936834	03/07/2024 11:47	Second most numerous Algae		---	
W2514OUT	Seagahan Final Water Outlet	4936834	03/07/2024 11:47	Third most numerous Algae		---	
W2514OUT	Seagahan Final Water Outlet	4936834	03/07/2024 11:47	Total Organic Carbon	mg C/l	2.3	
W1301POUT	Moyola PPP Final Water Outlet	4937007	04/07/2024 07:20	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4937007	04/07/2024 07:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4937007	04/07/2024 07:20	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4937007	04/07/2024 07:20	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4937007	04/07/2024 07:20	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4937007	04/07/2024 07:20	Free - Residual disinfectant	mg Cl/l	1.3	
W1301POUT	Moyola PPP Final Water Outlet	4937007	04/07/2024 07:20	Hydrogen Ion	pH value	7.7	9.5

W1301POUT	Moyola PPP Final Water Outlet	4937007	04/07/2024 07:20	Total - Residual disinfectant	mg Cl/l	1.46	
W1301POUT	Moyola PPP Final Water Outlet	4937007	04/07/2024 07:20	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4937007	04/07/2024 07:20	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4936996	04/07/2024 08:11	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4936996	04/07/2024 08:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4936996	04/07/2024 08:11	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4936996	04/07/2024 08:11	Conductivity	uS/cm 20 C	370	2500
W2514OUT	Seagahan Final Water Outlet	4936996	04/07/2024 08:11	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4936996	04/07/2024 08:11	Free - Residual disinfectant	mg Cl/l	1.02	
W2514OUT	Seagahan Final Water Outlet	4936996	04/07/2024 08:11	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4936996	04/07/2024 08:11	Total - Residual disinfectant	mg Cl/l	1.16	
W2514OUT	Seagahan Final Water Outlet	4936996	04/07/2024 08:11	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4936996	04/07/2024 08:11	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4936993	04/07/2024 08:20	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4936993	04/07/2024 08:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4936993	04/07/2024 08:20	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4936993	04/07/2024 08:20	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4936993	04/07/2024 08:20	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4936993	04/07/2024 08:20	Free - Residual disinfectant	mg Cl/l	0.74	
W1302OUT	Lough Fea Final Water Outlet	4936993	04/07/2024 08:20	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4936993	04/07/2024 08:20	Total - Residual disinfectant	mg Cl/l	0.8	
W1302OUT	Lough Fea Final Water Outlet	4936993	04/07/2024 08:20	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4936993	04/07/2024 08:20	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Free - Residual disinfectant	mg Cl/l	0.88	
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Free - Residual disinfectant	mg Cl/l	0.88	
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Total - Residual disinfectant	mg Cl/l	0.97	
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Total - Residual disinfectant	mg Cl/l	0.97	
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Turbidity	NTU	<0.09	1

W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Aluminium	ug Al/l	<3.089	200
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Aluminium	ug Al/l	<3.089	200
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Iron	ug/l Fe	<1.538	200
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Iron	ug/l Fe	<1.538	200
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Manganese	ug Mn/l	<0.642	50
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Manganese	ug Mn/l	<0.642	50
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Total Organic Carbon	mg C/l	1.6	
W4523OUT	Lough Macrory Final Water Outlet	4936994	04/07/2024 10:58	Total Organic Carbon	mg C/l	1.6	
W4701OUT	Killyhevlin Final Water Outlet	4937001	04/07/2024 11:01	Colony Counts 22	CFU/1 ml	1	
W4701OUT	Killyhevlin Final Water Outlet	4937001	04/07/2024 11:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4937001	04/07/2024 11:01	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4937001	04/07/2024 11:01	Conductivity	uS/cm 20 C	450	2500
W4701OUT	Killyhevlin Final Water Outlet	4937001	04/07/2024 11:01	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4937001	04/07/2024 11:01	Free - Residual disinfectant	mg Cl/l	1.22	
W4701OUT	Killyhevlin Final Water Outlet	4937001	04/07/2024 11:01	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4937001	04/07/2024 11:01	Total - Residual disinfectant	mg Cl/l	1.42	
W4701OUT	Killyhevlin Final Water Outlet	4937001	04/07/2024 11:01	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4937001	04/07/2024 11:01	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4937006	04/07/2024 11:15	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4937006	04/07/2024 11:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4937006	04/07/2024 11:15	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4937006	04/07/2024 11:15	Conductivity	uS/cm 20 C	390	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4937006	04/07/2024 11:15	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4937006	04/07/2024 11:15	Free - Residual disinfectant	mg Cl/l	1.45	
W2308POUT	Castor Bay PPP Final Water Outlet	4937006	04/07/2024 11:15	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4937006	04/07/2024 11:15	Total - Residual disinfectant	mg Cl/l	1.61	
W2308POUT	Castor Bay PPP Final Water Outlet	4937006	04/07/2024 11:15	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4937006	04/07/2024 11:15	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4937158	05/07/2024 07:30	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4937158	05/07/2024 07:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4937158	05/07/2024 07:30	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4937158	05/07/2024 07:30	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4937158	05/07/2024 07:30	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4937158	05/07/2024 07:30	Free - Residual disinfectant	mg Cl/l	1.46	
W1301POUT	Moyola PPP Final Water Outlet	4937158	05/07/2024 07:30	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4937158	05/07/2024 07:30	Total - Residual disinfectant	mg Cl/l	1.62	
W1301POUT	Moyola PPP Final Water Outlet	4937158	05/07/2024 07:30	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4937158	05/07/2024 07:30	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4937151	05/07/2024 08:19	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4937151	05/07/2024 08:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4937151	05/07/2024 08:19	Colour	mg/l Pt/Co	<4.56	20

W1302OUT	Lough Fea Final Water Outlet	4937151	05/07/2024 08:19	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4937151	05/07/2024 08:19	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4937151	05/07/2024 08:19	Free - Residual disinfectant	mg Cl/l	0.82	
W1302OUT	Lough Fea Final Water Outlet	4937151	05/07/2024 08:19	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4937151	05/07/2024 08:19	Total - Residual disinfectant	mg Cl/l	0.86	
W1302OUT	Lough Fea Final Water Outlet	4937151	05/07/2024 08:19	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4937151	05/07/2024 08:19	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4937157	05/07/2024 09:44	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4937157	05/07/2024 09:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4937157	05/07/2024 09:44	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4937157	05/07/2024 09:44	Conductivity	uS/cm 20 C	390	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4937157	05/07/2024 09:44	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4937157	05/07/2024 09:44	Free - Residual disinfectant	mg Cl/l	1.48	
W2308POUT	Castor Bay PPP Final Water Outlet	4937157	05/07/2024 09:44	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4937157	05/07/2024 09:44	Total - Residual disinfectant	mg Cl/l	1.62	
W2308POUT	Castor Bay PPP Final Water Outlet	4937157	05/07/2024 09:44	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4937157	05/07/2024 09:44	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4937153	05/07/2024 10:23	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4937153	05/07/2024 10:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4937153	05/07/2024 10:23	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4937153	05/07/2024 10:23	Conductivity	uS/cm 20 C	440	2500
W4701OUT	Killyhevlin Final Water Outlet	4937153	05/07/2024 10:23	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4937153	05/07/2024 10:23	Free - Residual disinfectant	mg Cl/l	1.81	
W4701OUT	Killyhevlin Final Water Outlet	4937153	05/07/2024 10:23	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4937153	05/07/2024 10:23	Total - Residual disinfectant	mg Cl/l	2.46	
W4701OUT	Killyhevlin Final Water Outlet	4937153	05/07/2024 10:23	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4937153	05/07/2024 10:23	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4937213	06/07/2024 06:26	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4937213	06/07/2024 06:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4937213	06/07/2024 06:26	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4937213	06/07/2024 06:26	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4937213	06/07/2024 06:26	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4937213	06/07/2024 06:26	Free - Residual disinfectant	mg Cl/l	1.17	
W2308POUT	Castor Bay PPP Final Water Outlet	4937213	06/07/2024 06:26	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4937213	06/07/2024 06:26	Total - Residual disinfectant	mg Cl/l	1.38	
W2308POUT	Castor Bay PPP Final Water Outlet	4937213	06/07/2024 06:26	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4937213	06/07/2024 06:26	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4937214	06/07/2024 08:51	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4937214	06/07/2024 08:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4937214	06/07/2024 08:51	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4937214	06/07/2024 08:51	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4937214	06/07/2024 08:51	E. coli	CFU/100 ml	0	0

W1301POUT	Moyola PPP Final Water Outlet	4937214	06/07/2024 08:51	Free - Residual disinfectant	mg Cl/l	1.46	
W1301POUT	Moyola PPP Final Water Outlet	4937214	06/07/2024 08:51	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4937214	06/07/2024 08:51	Total - Residual disinfectant	mg Cl/l	1.62	
W1301POUT	Moyola PPP Final Water Outlet	4937214	06/07/2024 08:51	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4937214	06/07/2024 08:51	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4937210	06/07/2024 09:20	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4937210	06/07/2024 09:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4937210	06/07/2024 09:20	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4937210	06/07/2024 09:20	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4937210	06/07/2024 09:20	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4937210	06/07/2024 09:20	Free - Residual disinfectant	mg Cl/l	1.64	
W4701OUT	Killyhevlin Final Water Outlet	4937210	06/07/2024 09:20	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4937210	06/07/2024 09:20	Total - Residual disinfectant	mg Cl/l	2.26	
W4701OUT	Killyhevlin Final Water Outlet	4937210	06/07/2024 09:20	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4937210	06/07/2024 09:20	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4937209	06/07/2024 09:26	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4937209	06/07/2024 09:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4937209	06/07/2024 09:26	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4937209	06/07/2024 09:26	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4937209	06/07/2024 09:26	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4937209	06/07/2024 09:26	Free - Residual disinfectant	mg Cl/l	0.87	
W1302OUT	Lough Fea Final Water Outlet	4937209	06/07/2024 09:26	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4937209	06/07/2024 09:26	Total - Residual disinfectant	mg Cl/l	1.02	
W1302OUT	Lough Fea Final Water Outlet	4937209	06/07/2024 09:26	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4937209	06/07/2024 09:26	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4937240	07/07/2024 06:37	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4937240	07/07/2024 06:37	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4937240	07/07/2024 06:37	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4937240	07/07/2024 06:37	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4937240	07/07/2024 06:37	Free - Residual disinfectant	mg Cl/l	1.51	
W2308POUT	Castor Bay PPP Final Water Outlet	4937240	07/07/2024 06:37	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4937240	07/07/2024 06:37	Total - Residual disinfectant	mg Cl/l	1.65	
W2308POUT	Castor Bay PPP Final Water Outlet	4937240	07/07/2024 06:37	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4937240	07/07/2024 06:37	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4937241	07/07/2024 08:45	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4937241	07/07/2024 08:45	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4937241	07/07/2024 08:45	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4937241	07/07/2024 08:45	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4937241	07/07/2024 08:45	Free - Residual disinfectant	mg Cl/l	1.49	
W1301POUT	Moyola PPP Final Water Outlet	4937241	07/07/2024 08:45	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4937241	07/07/2024 08:45	Total - Residual disinfectant	mg Cl/l	1.64	
W1301POUT	Moyola PPP Final Water Outlet	4937241	07/07/2024 08:45	Total Coliforms	CFU/100 ml	0	0

W1301POUT	Moyola PPP Final Water Outlet	4937241	07/07/2024 08:45	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4937236	07/07/2024 09:15	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4937236	07/07/2024 09:15	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4937236	07/07/2024 09:15	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4937236	07/07/2024 09:15	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4937236	07/07/2024 09:15	Free - Residual disinfectant	mg Cl/l	0.65	
W1302OUT	Lough Fea Final Water Outlet	4937236	07/07/2024 09:15	Hydrogen Ion	pH value	7.5	9.5
W1302OUT	Lough Fea Final Water Outlet	4937236	07/07/2024 09:15	Total - Residual disinfectant	mg Cl/l	0.7	
W1302OUT	Lough Fea Final Water Outlet	4937236	07/07/2024 09:15	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4937236	07/07/2024 09:15	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4937237	07/07/2024 09:21	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4937237	07/07/2024 09:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4937237	07/07/2024 09:21	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4937237	07/07/2024 09:21	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4937237	07/07/2024 09:21	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4937237	07/07/2024 09:21	Free - Residual disinfectant	mg Cl/l	1.66	
W4701OUT	Killyhevlin Final Water Outlet	4937237	07/07/2024 09:21	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4937237	07/07/2024 09:21	Total - Residual disinfectant	mg Cl/l	1.79	
W4701OUT	Killyhevlin Final Water Outlet	4937237	07/07/2024 09:21	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4937237	07/07/2024 09:21	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4939452	08/07/2024 08:52	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4939452	08/07/2024 08:52	Colony Counts 37 (48hrs)	CFU/1 ml	1	
W2514OUT	Seagahan Final Water Outlet	4939452	08/07/2024 08:52	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4939452	08/07/2024 08:52	Conductivity	uS/cm 20 C	360	2500
W2514OUT	Seagahan Final Water Outlet	4939452	08/07/2024 08:52	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4939452	08/07/2024 08:52	Free - Residual disinfectant	mg Cl/l	1.11	
W2514OUT	Seagahan Final Water Outlet	4939452	08/07/2024 08:52	Hydrogen Ion	pH value	7.6	9.5
W2514OUT	Seagahan Final Water Outlet	4939452	08/07/2024 08:52	Total - Residual disinfectant	mg Cl/l	1.25	
W2514OUT	Seagahan Final Water Outlet	4939452	08/07/2024 08:52	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4939452	08/07/2024 08:52	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4939471	08/07/2024 09:37	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4939471	08/07/2024 09:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4939471	08/07/2024 09:37	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4939471	08/07/2024 09:37	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4939471	08/07/2024 09:37	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4939471	08/07/2024 09:37	Free - Residual disinfectant	mg Cl/l	1.34	
W2308POUT	Castor Bay PPP Final Water Outlet	4939471	08/07/2024 09:37	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4939471	08/07/2024 09:37	Total - Residual disinfectant	mg Cl/l	1.51	
W2308POUT	Castor Bay PPP Final Water Outlet	4939471	08/07/2024 09:37	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4939471	08/07/2024 09:37	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4939471	08/07/2024 09:37	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4939471	08/07/2024 09:37	Odour - Nature		No odour	

W2308POUT	Castor Bay PPP Final Water Outlet	4939471	08/07/2024 09:37	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4939471	08/07/2024 09:37	Taste - Nature		No taste	
W4701OUT	Killyhevlin Final Water Outlet	4939461	08/07/2024 10:09	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4939461	08/07/2024 10:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4939461	08/07/2024 10:09	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4939461	08/07/2024 10:09	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4939461	08/07/2024 10:09	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4939461	08/07/2024 10:09	Free - Residual disinfectant	mg Cl/l	1.74	
W4701OUT	Killyhevlin Final Water Outlet	4939461	08/07/2024 10:09	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4939461	08/07/2024 10:09	Total - Residual disinfectant	mg Cl/l	1.82	
W4701OUT	Killyhevlin Final Water Outlet	4939461	08/07/2024 10:09	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4939461	08/07/2024 10:09	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4939449	08/07/2024 10:12	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4939449	08/07/2024 10:12	Colony Counts 37 (48hrs)	CFU/1 ml	1	
W1302OUT	Lough Fea Final Water Outlet	4939449	08/07/2024 10:12	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4939449	08/07/2024 10:12	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4939449	08/07/2024 10:12	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4939449	08/07/2024 10:12	Free - Residual disinfectant	mg Cl/l	0.8	
W1302OUT	Lough Fea Final Water Outlet	4939449	08/07/2024 10:12	Hydrogen Ion	pH value	7.5	9.5
W1302OUT	Lough Fea Final Water Outlet	4939449	08/07/2024 10:12	Total - Residual disinfectant	mg Cl/l	0.87	
W1302OUT	Lough Fea Final Water Outlet	4939449	08/07/2024 10:12	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4939449	08/07/2024 10:12	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Free - Residual disinfectant	mg Cl/l	1.19	
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Free - Residual disinfectant	mg Cl/l	1.19	
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Hydrogen Ion	pH value	7.4	9.5
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Hydrogen Ion	pH value	7.4	9.5
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Total - Residual disinfectant	mg Cl/l	1.31	
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Total - Residual disinfectant	mg Cl/l	1.31	
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Turbidity	NTU	<0.09	1

W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Aluminium	ug Al/l	<3.089	200
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Aluminium	ug Al/l	<3.089	200
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Iron	ug/l Fe	<1.538	200
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Iron	ug/l Fe	<1.538	200
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Manganese	ug Mn/l	<0.642	50
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Manganese	ug Mn/l	<0.642	50
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Total Organic Carbon	mg C/l	1.7	
W4523OUT	Lough Macrory Final Water Outlet	4939450	08/07/2024 10:41	Total Organic Carbon	mg C/l	1.7	
W1301POUT	Moyola PPP Final Water Outlet	4939472	08/07/2024 10:48	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4939472	08/07/2024 10:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4939472	08/07/2024 10:48	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4939472	08/07/2024 10:48	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4939472	08/07/2024 10:48	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4939472	08/07/2024 10:48	Free - Residual disinfectant	mg Cl/l	1.7	
W1301POUT	Moyola PPP Final Water Outlet	4939472	08/07/2024 10:48	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4939472	08/07/2024 10:48	Total - Residual disinfectant	mg Cl/l	1.77	
W1301POUT	Moyola PPP Final Water Outlet	4939472	08/07/2024 10:48	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4939472	08/07/2024 10:48	Turbidity	NTU	1.4	1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	2,4-D	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	2,4-DB	ug/l	<0.016	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Asulam	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Bentazone	ug/l	<0.0044	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Bromoxynil	ug/l	<0.0079	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Chlorotoluron	ug/l	<0.0031	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Chlorpyrifos	ug/l	<0.0070	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Clopyralid	ug/l	<0.0097	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Colony Counts 37 (48hrs)	CFU/1 ml	1	
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Cyanide	ug/l CN	<5.5	50
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Dicamba	ug/l	<0.028	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Dichlorprop	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Diflufenican	ug/l	<0.0072	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Dimethenamid	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Diuron	ug/l	<0.0055	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Epoxiconazole	ug/l	<0.0049	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Fenpropimorph	ug/l	<0.0083	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Flufenacet	ug/l	<0.0052	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Fluroxypyr	ug/l	0.0083	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Free - Residual disinfectant	mg Cl/l	1.29	

W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Glyphosate	ug/l	<0.0077	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Isoproturon	ug/l	<0.0025	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Linuron	ug/l	<0.0034	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	MCPA	ug/l	0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	MCPB	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Mecoprop	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Metalaxyl	ug/l	<0.0097	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Metamitron	ug/l	<0.0074	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Metazachlor	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Metoxuron	ug/l	<0.0080	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Metribuzin	ug/l	<0.0060	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Oxamyl	ug/l	<0.0023	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Pendimethalin	ug/l	<0.0064	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Pesticides - Total Substances	ug/l	0.0233	0.5
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Phorate	ug/l	<0.0092	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Pirimicarb	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Propachlor	ug/l	<0.0096	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Propiconazole	ug/l	<0.0029	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Propyzamide	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Prothioconazole	ug/l	<0.0019	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Tebuconazole	ug/l	<0.0039	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Total - Residual disinfectant	mg Cl/l	1.35	
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Triclopyr	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Algae Diatom Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Algae Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Aluminium	ug Al/l	28	200
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Bromodichloromethane	ug/l	6.4	
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Chloroform	ug/l	9.6	
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Dibromochloromethane	ug/l	5.2	
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Iron	ug/l Fe	1.8	200
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Manganese	ug Mn/l	<0.642	50
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	MIB	ng/l	4	
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Microcystin-LR	ug/l	<0.024	
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Most numerous Algae	-	-	

W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Second most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Third most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Total Organic Carbon	mg C/l	2.6	
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	Total Trihalomethanes	ug/l	22	100
W2308POUT	Castor Bay PPP Final Water Outlet	4939856	09/07/2024 08:30	WHO Index		0.2	1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	2,4-D	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	2,4-DB	ug/l	<0.016	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Asulam	ug/l	<0.015	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Bentazone	ug/l	<0.0044	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Bromoxynil	ug/l	<0.0079	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Chlorotoluron	ug/l	<0.0031	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Chlorpyrifos	ug/l	<0.0070	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Clopyralid	ug/l	<0.0097	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Cyanide	ug/l CN	<5.5	50
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Dicamba	ug/l	<0.028	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Dichlorprop	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Di flufenican	ug/l	<0.0072	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Dimethenamid	ug/l	<0.0063	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Diuron	ug/l	<0.0055	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Epoconazole	ug/l	<0.0049	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Fenpropimorph	ug/l	<0.0083	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Flufenacet	ug/l	<0.0052	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Fluroxypyr	ug/l	<0.0063	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Free - Residual disinfectant	mg Cl/l	0.8	
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Glyphosate	ug/l	<0.0077	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Isoproturon	ug/l	<0.0025	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Linuron	ug/l	<0.0034	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	MCPA	ug/l	<0.0093	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	MCPB	ug/l	<0.015	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Mecoprop	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Metalaxyl	ug/l	<0.0097	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Metamitron	ug/l	<0.0074	0.1

W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Metazachlor	ug/l	<0.015	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Metoxuron	ug/l	<0.0080	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Metribuzin	ug/l	<0.0060	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Oxamyl	ug/l	<0.0023	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Pendimethalin	ug/l	<0.0064	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Pesticides - Total Substances	ug/l	0	0.5
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Phorate	ug/l	<0.0092	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Pirimicarb	ug/l	<0.0063	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Propachlor	ug/l	<0.0096	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Propiconazole	ug/l	<0.0029	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Propyzamide	ug/l	<0.012	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Prothioconazole	ug/l	<0.0019	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Tebuconazole	ug/l	<0.0039	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Total - Residual disinfectant	mg Cl/l	0.85	
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Triclopyr	ug/l	<0.012	0.1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Aluminium	ug Al/l	23	200
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Bromodichloromethane	ug/l	8.9	
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Bromoform	ug/l	<3.5	
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Chloroform	ug/l	39	
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Dibromochloromethane	ug/l	<1.6	
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Iron	ug/l Fe	3.4	200
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Manganese	ug Mn/l	<0.642	50
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Total Organic Carbon	mg C/l	1.8	
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	Total Trihalomethanes	ug/l	50	100
W1302OUT	Lough Fea Final Water Outlet	4939843	09/07/2024 08:51	WHO Index		0.3	1
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Free - Residual disinfectant	mg Cl/l	1.98	
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Total - Residual disinfectant	mg Cl/l	2.06	
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Algae Blue Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Algae Diatom Total	per ml	40	
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Algae Flagellate Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Algae Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Algae Total	per ml	40	

W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Aluminium	ug Al/l	29	200
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Bromodichloromethane	ug/l	12	
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Bromoform	ug/l	<3.5	
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Chloroform	ug/l	35	
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Dibromochloromethane	ug/l	3.9	
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Geosmin	ng/l	<1.1	
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Iron	ug/l Fe	4.2	200
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Manganese	ug Mn/l	3.3	50
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	MIB	ng/l	2.2	
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Microcystin-LR	ug/l	<0.024	
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Most numerous Algae		Fragilaria	
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Second most numerous Algae		-	
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Third most numerous Algae		-	
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Total Organic Carbon	mg C/l	2.3	
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	Total Trihalomethanes	ug/l	52	100
W4701OUT	Killyhevlin Final Water Outlet	4939869	09/07/2024 09:17	WHO Index		0.36	1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	2,4-D	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	2,4-D	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	2,4-DB	ug/l	<0.016	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	2,4-DB	ug/l	<0.016	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Asulam	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Asulam	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Bentazone	ug/l	<0.0044	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Bentazone	ug/l	<0.0044	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Bromoxynil	ug/l	<0.0079	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Bromoxynil	ug/l	<0.0079	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Chlorotoluron	ug/l	<0.0031	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Chlorotoluron	ug/l	<0.0031	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Chlorpyrifos	ug/l	<0.0070	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Chlorpyrifos	ug/l	<0.0070	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Clopyralid	ug/l	<0.0097	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Clopyralid	ug/l	<0.0097	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Colony Counts 22	CFU/1 ml	1	
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Colony Counts 22	CFU/1 ml	1	
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Cyanide	ug/l CN	<5.5	50
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Cyanide	ug/l CN	<5.5	50

W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Dicamba	ug/l	<0.028	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Dicamba	ug/l	<0.028	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Dichlorprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Dichlorprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Diflufenican	ug/l	<0.0072	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Diflufenican	ug/l	<0.0072	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Dimethenamid	ug/l	<0.0063	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Dimethenamid	ug/l	<0.0063	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Diuron	ug/l	<0.0055	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Diuron	ug/l	<0.0055	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Epoxiconazole	ug/l	<0.0049	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Epoxiconazole	ug/l	<0.0049	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Fenpropimorph	ug/l	<0.0083	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Fenpropimorph	ug/l	<0.0083	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Flufenacet	ug/l	<0.0052	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Flufenacet	ug/l	<0.0052	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Fluroxypyr	ug/l	<0.0063	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Fluroxypyr	ug/l	<0.0063	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Free - Residual disinfectant	mg Cl/l	1.21	
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Free - Residual disinfectant	mg Cl/l	1.21	
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Glyphosate	ug/l	<0.0077	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Glyphosate	ug/l	<0.0077	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Isoproturon	ug/l	<0.0025	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Isoproturon	ug/l	<0.0025	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Linuron	ug/l	<0.0034	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Linuron	ug/l	<0.0034	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	MCPA	ug/l	<0.0093	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	MCPA	ug/l	<0.0093	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	MCPB	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	MCPB	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Mecoprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Mecoprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Metalaxyl	ug/l	<0.0097	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Metalaxyl	ug/l	<0.0097	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Metamitron	ug/l	<0.0074	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Metamitron	ug/l	<0.0074	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Metazachlor	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Metazachlor	ug/l	<0.015	0.1

W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Metoxuron	ug/l	<0.0080	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Metoxuron	ug/l	<0.0080	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Metribuzin	ug/l	<0.0060	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Metribuzin	ug/l	<0.0060	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Oxamyl	ug/l	<0.0023	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Oxamyl	ug/l	<0.0023	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Pendimethalin	ug/l	<0.0064	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Pendimethalin	ug/l	<0.0064	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Pesticides - Total Substances	ug/l	0	0.5
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Pesticides - Total Substances	ug/l	0	0.5
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Phorate	ug/l	<0.0092	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Phorate	ug/l	<0.0092	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Pirimicarb	ug/l	<0.0063	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Pirimicarb	ug/l	<0.0063	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Propachlor	ug/l	<0.0096	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Propachlor	ug/l	<0.0096	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Propiconazole	ug/l	<0.0029	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Propiconazole	ug/l	<0.0029	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Propyzamide	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Propyzamide	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Prothioconazole	ug/l	<0.0019	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Prothioconazole	ug/l	<0.0019	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Tebuconazole	ug/l	<0.0039	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Tebuconazole	ug/l	<0.0039	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Total - Residual disinfectant	mg Cl/l	1.39	
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Total - Residual disinfectant	mg Cl/l	1.39	
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Triclopyr	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Triclopyr	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4939844	09/07/2024 10:16	Turbidity	NTU	<0.09	1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	2,4-D	ug/l	<0.011	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	2,4-DB	ug/l	<0.016	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Asulam	ug/l	<0.015	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Bentazone	ug/l	<0.0044	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Bromoxynil	ug/l	<0.0079	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Chlorotoluron	ug/l	<0.0031	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Chlorpyrifos	ug/l	<0.0070	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Clopyralid	ug/l	<0.0097	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Colony Counts 22	CFU/1 ml	0	
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	

W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Colour	mg/l Pt/Co	<4.56	20
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Conductivity	uS/cm 20 C	360	2500
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Cyanide	ug/l CN	<5.5	50
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Dicamba	ug/l	<0.028	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Dichlorprop	ug/l	<0.011	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Diflufenican	ug/l	<0.0072	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Dimethenamid	ug/l	<0.0063	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Diuron	ug/l	<0.0055	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	E. coli	CFU/100 ml	0	0
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Epoxiconazole	ug/l	<0.0049	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Fenpropimorph	ug/l	<0.0083	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Flufenacet	ug/l	<0.0052	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Fluroxypyr	ug/l	<0.0063	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Free - Residual disinfectant	mg Cl/l	0.4	
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Glyphosate	ug/l	<0.0077	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Hydrogen Ion	pH value	7.7	9.5
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Isoproturon	ug/l	<0.0025	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Linuron	ug/l	<0.0034	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	MCPA	ug/l	<0.0093	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	MCPB	ug/l	<0.015	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Mecoprop	ug/l	<0.011	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Metalaxyl	ug/l	<0.0097	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Metamitron	ug/l	<0.0074	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Metazachlor	ug/l	<0.015	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Metoxuron	ug/l	<0.0080	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Metribuzin	ug/l	<0.0060	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Oxamyl	ug/l	<0.0023	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Pendimethalin	ug/l	<0.0064	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Pesticides - Total Substances	ug/l	0	0.5
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Phorate	ug/l	<0.0092	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Pirimicarb	ug/l	<0.0063	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Propachlor	ug/l	<0.0096	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Propiconazole	ug/l	<0.0029	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Propyzamide	ug/l	<0.012	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Prothioconazole	ug/l	<0.0019	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Tebuconazole	ug/l	<0.0039	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Total - Residual disinfectant	mg Cl/l	0.54	
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Total Coliforms	CFU/100 ml	0	0
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Triclopyr	ug/l	<0.012	0.1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Turbidity	NTU	<0.09	1
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Aluminium	ug Al/l	23	200
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Antimony	ug/l Sb	0.078	5

W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Arsenic	ug/l As	1.2	10
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Boron	mg/l B	<0.0586	1000
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Bromodichloromethane	ug/l	10	
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Bromoform	ug/l	<3.5	
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Cadmium	ug/l Cd	<0.042	5
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Chloroform	ug/l	19	
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Chromium	ug/l Cr	1.4	50
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Dibromochloromethane	ug/l	6.4	
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Iron	ug/l Fe	17	200
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Manganese	ug Mn/l	<0.642	50
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Selenium	ug/l Se	<0.057	10
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	Total Trihalomethanes	ug/l	37	100
W1316OUT	Money more Borewell Final Water Outlet	4939875	09/07/2024 10:16	WHO Index		0.31	1
W2514OUT	Seagahan Final Water Outlet	4939849	09/07/2024 11:34	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4939849	09/07/2024 11:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4939849	09/07/2024 11:34	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4939849	09/07/2024 11:34	Conductivity	uS/cm 20 C	370	2500
W2514OUT	Seagahan Final Water Outlet	4939849	09/07/2024 11:34	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4939849	09/07/2024 11:34	Free - Residual disinfectant	mg Cl/l	1.11	
W2514OUT	Seagahan Final Water Outlet	4939849	09/07/2024 11:34	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4939849	09/07/2024 11:34	Total - Residual disinfectant	mg Cl/l	1.34	
W2514OUT	Seagahan Final Water Outlet	4939849	09/07/2024 11:34	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4939849	09/07/2024 11:34	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	Free - Residual disinfectant	mg Cl/l	1.02	
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	Total - Residual disinfectant	mg Cl/l	1.14	
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	Algae Blue Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	Algae Diatom Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	Algae Flagellate Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	Algae Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	Algae Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	Aluminium	ug Al/l	41	200
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	Geosmin	ng/l	<1.1	
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	Iron	ug/l Fe	6.4	200
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	Manganese	ug Mn/l	<0.642	50

W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	MIB	ng/l	<1.9	
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	Most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	Second most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	Third most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4939862	09/07/2024 11:42	Total Organic Carbon	mg C/l	2.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4940063	10/07/2024 08:04	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4940063	10/07/2024 08:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4940063	10/07/2024 08:04	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4940063	10/07/2024 08:04	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4940063	10/07/2024 08:04	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4940063	10/07/2024 08:04	Free - Residual disinfectant	mg Cl/l	1.59	
W2308POUT	Castor Bay PPP Final Water Outlet	4940063	10/07/2024 08:04	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4940063	10/07/2024 08:04	Total - Residual disinfectant	mg Cl/l	1.69	
W2308POUT	Castor Bay PPP Final Water Outlet	4940063	10/07/2024 08:04	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4940063	10/07/2024 08:04	Turbidity	NTU	0.19	1
W2308POUT	Castor Bay PPP Final Water Outlet	4940063	10/07/2024 08:04	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4940063	10/07/2024 08:04	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4940063	10/07/2024 08:04	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4940063	10/07/2024 08:04	Taste - Nature		No taste	
W4701OUT	Killyhevlin Final Water Outlet	4940069	10/07/2024 08:53	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4940069	10/07/2024 08:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4940069	10/07/2024 08:53	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4940069	10/07/2024 08:53	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4940069	10/07/2024 08:53	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4940069	10/07/2024 08:53	Free - Residual disinfectant	mg Cl/l	1.34	
W4701OUT	Killyhevlin Final Water Outlet	4940069	10/07/2024 08:53	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4940069	10/07/2024 08:53	Total - Residual disinfectant	mg Cl/l	1.42	
W4701OUT	Killyhevlin Final Water Outlet	4940069	10/07/2024 08:53	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4940069	10/07/2024 08:53	Turbidity	NTU	0.13	1
W1301POUT	Moyola PPP Final Water Outlet	4940064	10/07/2024 08:56	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4940064	10/07/2024 08:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4940064	10/07/2024 08:56	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4940064	10/07/2024 08:56	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4940064	10/07/2024 08:56	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4940064	10/07/2024 08:56	Free - Residual disinfectant	mg Cl/l	1.5	
W1301POUT	Moyola PPP Final Water Outlet	4940064	10/07/2024 08:56	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4940064	10/07/2024 08:56	Total - Residual disinfectant	mg Cl/l	1.6	
W1301POUT	Moyola PPP Final Water Outlet	4940064	10/07/2024 08:56	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4940064	10/07/2024 08:56	Turbidity	NTU	0.1	1
W1302OUT	Lough Fea Final Water Outlet	4940049	10/07/2024 09:38	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4940049	10/07/2024 09:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4940049	10/07/2024 09:38	Colour	mg/l Pt/Co	<4.56	20

W1302OUT	Lough Fea Final Water Outlet	4940049	10/07/2024 09:38	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4940049	10/07/2024 09:38	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4940049	10/07/2024 09:38	Free - Residual disinfectant	mg Cl/l	0.79	
W1302OUT	Lough Fea Final Water Outlet	4940049	10/07/2024 09:38	Hydrogen Ion	pH value	7.5	9.5
W1302OUT	Lough Fea Final Water Outlet	4940049	10/07/2024 09:38	Total - Residual disinfectant	mg Cl/l	0.85	
W1302OUT	Lough Fea Final Water Outlet	4940049	10/07/2024 09:38	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4940049	10/07/2024 09:38	Turbidity	NTU	0.097	1
W4523OUT	Lough Macrory Final Water Outlet	4940050	10/07/2024 09:41	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4940050	10/07/2024 09:41	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4940050	10/07/2024 09:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4940050	10/07/2024 09:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4940050	10/07/2024 09:41	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4940050	10/07/2024 09:41	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4940050	10/07/2024 09:41	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4940050	10/07/2024 09:41	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4940050	10/07/2024 09:41	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4940050	10/07/2024 09:41	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4940050	10/07/2024 09:41	Free - Residual disinfectant	mg Cl/l	1.13	
W4523OUT	Lough Macrory Final Water Outlet	4940050	10/07/2024 09:41	Free - Residual disinfectant	mg Cl/l	1.13	
W4523OUT	Lough Macrory Final Water Outlet	4940050	10/07/2024 09:41	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4940050	10/07/2024 09:41	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4940050	10/07/2024 09:41	Total - Residual disinfectant	mg Cl/l	1.23	
W4523OUT	Lough Macrory Final Water Outlet	4940050	10/07/2024 09:41	Total - Residual disinfectant	mg Cl/l	1.23	
W4523OUT	Lough Macrory Final Water Outlet	4940050	10/07/2024 09:41	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4940050	10/07/2024 09:41	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4940050	10/07/2024 09:41	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4940050	10/07/2024 09:41	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4940054	10/07/2024 10:08	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4940054	10/07/2024 10:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4940054	10/07/2024 10:08	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4940054	10/07/2024 10:08	Conductivity	uS/cm 20 C	380	2500
W2514OUT	Seagahan Final Water Outlet	4940054	10/07/2024 10:08	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4940054	10/07/2024 10:08	Free - Residual disinfectant	mg Cl/l	1.22	
W2514OUT	Seagahan Final Water Outlet	4940054	10/07/2024 10:08	Hydrogen Ion	pH value	7.6	9.5
W2514OUT	Seagahan Final Water Outlet	4940054	10/07/2024 10:08	Total - Residual disinfectant	mg Cl/l	1.68	
W2514OUT	Seagahan Final Water Outlet	4940054	10/07/2024 10:08	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4940054	10/07/2024 10:08	Turbidity	NTU	0.11	1
W2308POUT	Castor Bay PPP Final Water Outlet	4940246	11/07/2024 08:11	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4940246	11/07/2024 08:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4940246	11/07/2024 08:11	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4940246	11/07/2024 08:11	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4940246	11/07/2024 08:11	E. coli	CFU/100 ml	0	0

W2308POUT	Castor Bay PPP Final Water Outlet	4940246	11/07/2024 08:11	Free - Residual disinfectant	mg Cl/l	1.43	
W2308POUT	Castor Bay PPP Final Water Outlet	4940246	11/07/2024 08:11	Hydrogen Ion	pH value	7.7	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4940246	11/07/2024 08:11	Total - Residual disinfectant	mg Cl/l	1.49	
W2308POUT	Castor Bay PPP Final Water Outlet	4940246	11/07/2024 08:11	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4940246	11/07/2024 08:11	Turbidity	NTU	0.12	1
W1301POUT	Moyola PPP Final Water Outlet	4940248	11/07/2024 08:31	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4940248	11/07/2024 08:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4940248	11/07/2024 08:31	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4940248	11/07/2024 08:31	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4940248	11/07/2024 08:31	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4940248	11/07/2024 08:31	Free - Residual disinfectant	mg Cl/l	1.42	
W1301POUT	Moyola PPP Final Water Outlet	4940248	11/07/2024 08:31	Hydrogen Ion	pH value	7.8	9.5
W1301POUT	Moyola PPP Final Water Outlet	4940248	11/07/2024 08:31	Total - Residual disinfectant	mg Cl/l	1.52	
W1301POUT	Moyola PPP Final Water Outlet	4940248	11/07/2024 08:31	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4940248	11/07/2024 08:31	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4940241	11/07/2024 09:14	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4940241	11/07/2024 09:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4940241	11/07/2024 09:14	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4940241	11/07/2024 09:14	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4940241	11/07/2024 09:14	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4940241	11/07/2024 09:14	Free - Residual disinfectant	mg Cl/l	1.46	
W4701OUT	Killyhevlin Final Water Outlet	4940241	11/07/2024 09:14	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4940241	11/07/2024 09:14	Total - Residual disinfectant	mg Cl/l	1.58	
W4701OUT	Killyhevlin Final Water Outlet	4940241	11/07/2024 09:14	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4940241	11/07/2024 09:14	Turbidity	NTU	0.15	1
W1302OUT	Lough Fea Final Water Outlet	4940234	11/07/2024 09:58	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4940234	11/07/2024 09:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4940234	11/07/2024 09:58	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4940234	11/07/2024 09:58	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4940234	11/07/2024 09:58	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4940234	11/07/2024 09:58	Free - Residual disinfectant	mg Cl/l	0.83	
W1302OUT	Lough Fea Final Water Outlet	4940234	11/07/2024 09:58	Hydrogen Ion	pH value	7.5	9.5
W1302OUT	Lough Fea Final Water Outlet	4940234	11/07/2024 09:58	Total - Residual disinfectant	mg Cl/l	0.91	
W1302OUT	Lough Fea Final Water Outlet	4940234	11/07/2024 09:58	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4940234	11/07/2024 09:58	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4940235	11/07/2024 10:31	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4940235	11/07/2024 10:31	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4940235	11/07/2024 10:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4940235	11/07/2024 10:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4940235	11/07/2024 10:31	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4940235	11/07/2024 10:31	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4940235	11/07/2024 10:31	Conductivity	uS/cm 20 C	120	2500

W4523OUT	Lough Macrory Final Water Outlet	4940235	11/07/2024 10:31	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4940235	11/07/2024 10:31	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4940235	11/07/2024 10:31	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4940235	11/07/2024 10:31	Free - Residual disinfectant	mg Cl/l	1.06	
W4523OUT	Lough Macrory Final Water Outlet	4940235	11/07/2024 10:31	Free - Residual disinfectant	mg Cl/l	1.06	
W4523OUT	Lough Macrory Final Water Outlet	4940235	11/07/2024 10:31	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4940235	11/07/2024 10:31	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4940235	11/07/2024 10:31	Total - Residual disinfectant	mg Cl/l	1.17	
W4523OUT	Lough Macrory Final Water Outlet	4940235	11/07/2024 10:31	Total - Residual disinfectant	mg Cl/l	1.17	
W4523OUT	Lough Macrory Final Water Outlet	4940235	11/07/2024 10:31	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4940235	11/07/2024 10:31	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4940235	11/07/2024 10:31	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4940235	11/07/2024 10:31	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Conductivity	uS/cm 20 C	380	2500
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Free - Residual disinfectant	mg Cl/l	0.92	
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Total - Residual disinfectant	mg Cl/l	1.17	
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Turbidity	NTU	0.1	1
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	2,4-D	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	2,4-DB	ug/l	<0.016	0.1
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Algae Blue Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Algae Diatom Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Algae Flagellate Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Algae Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Algae Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Aluminium	ug Al/l	4.4	200
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Asulam	ug/l	<0.015	0.1
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Bentazone	ug/l	<0.0044	0.1
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Bromodichloromethane	ug/l	13	
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Bromoform	ug/l	<3.5	
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Bromoxynil	ug/l	<0.0079	0.1
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Chloroform	ug/l	28	
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Clopyralid	ug/l	<0.0097	0.1
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Dibromochloromethane	ug/l	5	
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Dichlorprop	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Geosmin	ng/l	<1.1	
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Iron	ug/l Fe	<1.538	200

W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Manganese	ug Mn/l	<0.642	50
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	MCPA	ug/l	0.01	0.1
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	MCPB	ug/l	<0.015	0.1
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Mecoprop	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	MIB	ng/l	<1.9	
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Microcystin-LR	ug/l	<0.024	
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Propyzamide	ug/l	<0.012	0.1
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Second most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Third most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Total Organic Carbon	mg C/l	2.6	
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Total Trihalomethanes	ug/l	47	100
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	Triclopyr	ug/l	<0.012	0.1
W2514OUT	Seagahan Final Water Outlet	4940238	11/07/2024 11:21	WHO Index		0.37	1
W1301POUT	Moyola PPP Final Water Outlet	4940350	12/07/2024 09:55	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4940350	12/07/2024 09:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4940350	12/07/2024 09:55	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4940350	12/07/2024 09:55	Conductivity	uS/cm 20 C	340	2500
W1301POUT	Moyola PPP Final Water Outlet	4940350	12/07/2024 09:55	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4940350	12/07/2024 09:55	Free - Residual disinfectant	mg Cl/l	1.26	
W1301POUT	Moyola PPP Final Water Outlet	4940350	12/07/2024 09:55	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4940350	12/07/2024 09:55	Total - Residual disinfectant	mg Cl/l	1.38	
W1301POUT	Moyola PPP Final Water Outlet	4940350	12/07/2024 09:55	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4940350	12/07/2024 09:55	Turbidity	NTU	0.27	1
W4701OUT	Killyhevlin Final Water Outlet	4940346	12/07/2024 10:03	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4940346	12/07/2024 10:03	Colony Counts 37 (48hrs)	CFU/1 ml	1	
W4701OUT	Killyhevlin Final Water Outlet	4940346	12/07/2024 10:03	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4940346	12/07/2024 10:03	Conductivity	uS/cm 20 C	410	2500
W4701OUT	Killyhevlin Final Water Outlet	4940346	12/07/2024 10:03	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4940346	12/07/2024 10:03	Free - Residual disinfectant	mg Cl/l	1.36	
W4701OUT	Killyhevlin Final Water Outlet	4940346	12/07/2024 10:03	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4940346	12/07/2024 10:03	Total - Residual disinfectant	mg Cl/l	1.44	
W4701OUT	Killyhevlin Final Water Outlet	4940346	12/07/2024 10:03	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4940346	12/07/2024 10:03	Turbidity	NTU	0.12	1
W2308POUT	Castor Bay PPP Final Water Outlet	4940349	12/07/2024 10:22	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4940349	12/07/2024 10:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4940349	12/07/2024 10:22	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4940349	12/07/2024 10:22	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4940349	12/07/2024 10:22	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4940349	12/07/2024 10:22	Free - Residual disinfectant	mg Cl/l	1.52	
W2308POUT	Castor Bay PPP Final Water Outlet	4940349	12/07/2024 10:22	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4940349	12/07/2024 10:22	Total - Residual disinfectant	mg Cl/l	1.68	

W2308POUT	Castor Bay PPP Final Water Outlet	4940349	12/07/2024 10:22	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4940349	12/07/2024 10:22	Turbidity	NTU	0.16	1
W1302OUT	Lough Fea Final Water Outlet	4940345	12/07/2024 10:50	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4940345	12/07/2024 10:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4940345	12/07/2024 10:50	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4940345	12/07/2024 10:50	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4940345	12/07/2024 10:50	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4940345	12/07/2024 10:50	Free - Residual disinfectant	mg Cl/l	0.86	
W1302OUT	Lough Fea Final Water Outlet	4940345	12/07/2024 10:50	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4940345	12/07/2024 10:50	Total - Residual disinfectant	mg Cl/l	0.89	
W1302OUT	Lough Fea Final Water Outlet	4940345	12/07/2024 10:50	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4940345	12/07/2024 10:50	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4940369	13/07/2024 07:27	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4940369	13/07/2024 07:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4940369	13/07/2024 07:27	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4940369	13/07/2024 07:27	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4940369	13/07/2024 07:27	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4940369	13/07/2024 07:27	Free - Residual disinfectant	mg Cl/l	1.11	
W2308POUT	Castor Bay PPP Final Water Outlet	4940369	13/07/2024 07:27	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4940369	13/07/2024 07:27	Total - Residual disinfectant	mg Cl/l	1.28	
W2308POUT	Castor Bay PPP Final Water Outlet	4940369	13/07/2024 07:27	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4940369	13/07/2024 07:27	Turbidity	NTU	0.1	1
W1301POUT	Moyola PPP Final Water Outlet	4940370	13/07/2024 09:23	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4940370	13/07/2024 09:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4940370	13/07/2024 09:23	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4940370	13/07/2024 09:23	Conductivity	uS/cm 20 C	340	2500
W1301POUT	Moyola PPP Final Water Outlet	4940370	13/07/2024 09:23	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4940370	13/07/2024 09:23	Free - Residual disinfectant	mg Cl/l	0.97	
W1301POUT	Moyola PPP Final Water Outlet	4940370	13/07/2024 09:23	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4940370	13/07/2024 09:23	Total - Residual disinfectant	mg Cl/l	1.03	
W1301POUT	Moyola PPP Final Water Outlet	4940370	13/07/2024 09:23	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4940370	13/07/2024 09:23	Turbidity	NTU	0.15	1
W1302OUT	Lough Fea Final Water Outlet	4940365	13/07/2024 10:07	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4940365	13/07/2024 10:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4940365	13/07/2024 10:07	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4940365	13/07/2024 10:07	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4940365	13/07/2024 10:07	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4940365	13/07/2024 10:07	Free - Residual disinfectant	mg Cl/l	0.92	
W1302OUT	Lough Fea Final Water Outlet	4940365	13/07/2024 10:07	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4940365	13/07/2024 10:07	Total - Residual disinfectant	mg Cl/l	0.94	
W1302OUT	Lough Fea Final Water Outlet	4940365	13/07/2024 10:07	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4940365	13/07/2024 10:07	Turbidity	NTU	<0.09	1

W4701OUT	Killyhevlin Final Water Outlet	4940366	13/07/2024 10:10	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4940366	13/07/2024 10:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4940366	13/07/2024 10:10	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4940366	13/07/2024 10:10	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4940366	13/07/2024 10:10	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4940366	13/07/2024 10:10	Free - Residual disinfectant	mg Cl/l	1.42	
W4701OUT	Killyhevlin Final Water Outlet	4940366	13/07/2024 10:10	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4940366	13/07/2024 10:10	Total - Residual disinfectant	mg Cl/l	1.53	
W4701OUT	Killyhevlin Final Water Outlet	4940366	13/07/2024 10:10	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4940366	13/07/2024 10:10	Turbidity	NTU	0.14	1
W2308POUT	Castor Bay PPP Final Water Outlet	4940387	14/07/2024 06:39	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4940387	14/07/2024 06:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4940387	14/07/2024 06:39	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4940387	14/07/2024 06:39	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4940387	14/07/2024 06:39	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4940387	14/07/2024 06:39	Free - Residual disinfectant	mg Cl/l	1.24	
W2308POUT	Castor Bay PPP Final Water Outlet	4940387	14/07/2024 06:39	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4940387	14/07/2024 06:39	Total - Residual disinfectant	mg Cl/l	1.6	
W2308POUT	Castor Bay PPP Final Water Outlet	4940387	14/07/2024 06:39	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4940387	14/07/2024 06:39	Turbidity	NTU	0.13	1
W1301POUT	Moyola PPP Final Water Outlet	4940388	14/07/2024 08:51	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4940388	14/07/2024 08:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4940388	14/07/2024 08:51	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4940388	14/07/2024 08:51	Conductivity	uS/cm 20 C	350	2500
W1301POUT	Moyola PPP Final Water Outlet	4940388	14/07/2024 08:51	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4940388	14/07/2024 08:51	Free - Residual disinfectant	mg Cl/l	1.53	
W1301POUT	Moyola PPP Final Water Outlet	4940388	14/07/2024 08:51	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4940388	14/07/2024 08:51	Total - Residual disinfectant	mg Cl/l	1.64	
W1301POUT	Moyola PPP Final Water Outlet	4940388	14/07/2024 08:51	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4940388	14/07/2024 08:51	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4940383	14/07/2024 09:25	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4940383	14/07/2024 09:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4940383	14/07/2024 09:25	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4940383	14/07/2024 09:25	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4940383	14/07/2024 09:25	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4940383	14/07/2024 09:25	Free - Residual disinfectant	mg Cl/l	0.79	
W1302OUT	Lough Fea Final Water Outlet	4940383	14/07/2024 09:25	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4940383	14/07/2024 09:25	Total - Residual disinfectant	mg Cl/l	0.81	
W1302OUT	Lough Fea Final Water Outlet	4940383	14/07/2024 09:25	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4940383	14/07/2024 09:25	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4940384	14/07/2024 10:09	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4940384	14/07/2024 10:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	

W4701OUT	Killyhevlin Final Water Outlet	4940384	14/07/2024 10:09	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4940384	14/07/2024 10:09	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4940384	14/07/2024 10:09	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4940384	14/07/2024 10:09	Free - Residual disinfectant	mg Cl/l	1.34	
W4701OUT	Killyhevlin Final Water Outlet	4940384	14/07/2024 10:09	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4940384	14/07/2024 10:09	Total - Residual disinfectant	mg Cl/l	1.45	
W4701OUT	Killyhevlin Final Water Outlet	4940384	14/07/2024 10:09	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4940384	14/07/2024 10:09	Turbidity	NTU	0.12	1
W1301POUT	Moyola PPP Final Water Outlet	4942766	15/07/2024 09:05	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4942766	15/07/2024 09:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4942766	15/07/2024 09:05	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4942766	15/07/2024 09:05	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4942766	15/07/2024 09:05	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4942766	15/07/2024 09:05	Free - Residual disinfectant	mg Cl/l	1.4	
W1301POUT	Moyola PPP Final Water Outlet	4942766	15/07/2024 09:05	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4942766	15/07/2024 09:05	Total - Residual disinfectant	mg Cl/l	1.42	
W1301POUT	Moyola PPP Final Water Outlet	4942766	15/07/2024 09:05	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4942766	15/07/2024 09:05	Turbidity	NTU	0.17	1
W1302OUT	Lough Fea Final Water Outlet	4942761	15/07/2024 09:51	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4942761	15/07/2024 09:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4942761	15/07/2024 09:51	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4942761	15/07/2024 09:51	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4942761	15/07/2024 09:51	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4942761	15/07/2024 09:51	Free - Residual disinfectant	mg Cl/l	0.79	
W1302OUT	Lough Fea Final Water Outlet	4942761	15/07/2024 09:51	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4942761	15/07/2024 09:51	Total - Residual disinfectant	mg Cl/l	0.84	
W1302OUT	Lough Fea Final Water Outlet	4942761	15/07/2024 09:51	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4942761	15/07/2024 09:51	Turbidity	NTU	0.11	1
W2308POUT	Castor Bay PPP Final Water Outlet	4942765	15/07/2024 09:58	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4942765	15/07/2024 09:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4942765	15/07/2024 09:58	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4942765	15/07/2024 09:58	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4942765	15/07/2024 09:58	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4942765	15/07/2024 09:58	Free - Residual disinfectant	mg Cl/l	1.68	
W2308POUT	Castor Bay PPP Final Water Outlet	4942765	15/07/2024 09:58	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4942765	15/07/2024 09:58	Total - Residual disinfectant	mg Cl/l	1.78	
W2308POUT	Castor Bay PPP Final Water Outlet	4942765	15/07/2024 09:58	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4942765	15/07/2024 09:58	Turbidity	NTU	0.11	1
W4701OUT	Killyhevlin Final Water Outlet	4942762	15/07/2024 10:01	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4942762	15/07/2024 10:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4942762	15/07/2024 10:01	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4942762	15/07/2024 10:01	Conductivity	uS/cm 20 C	430	2500

W4701OUT	Killyhevlin Final Water Outlet	4942762	15/07/2024 10:01	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4942762	15/07/2024 10:01	Free - Residual disinfectant	mg Cl/l	1.31	
W4701OUT	Killyhevlin Final Water Outlet	4942762	15/07/2024 10:01	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4942762	15/07/2024 10:01	Total - Residual disinfectant	mg Cl/l	1.45	
W4701OUT	Killyhevlin Final Water Outlet	4942762	15/07/2024 10:01	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4942762	15/07/2024 10:01	Turbidity	NTU	0.13	1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Free - Residual disinfectant	mg Cl/l	0.78	
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Free - Residual disinfectant	mg Cl/l	0.78	
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Total - Residual disinfectant	mg Cl/l	0.95	
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Total - Residual disinfectant	mg Cl/l	0.95	
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Turbidity	NTU	0.097	1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Turbidity	NTU	0.097	1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	2,4-D	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	2,4-D	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	2,4-DB	ug/l	<0.016	0.1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	2,4-DB	ug/l	<0.016	0.1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Aluminium	ug Al/l	6	200
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Aluminium	ug Al/l	6	200
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Asulam	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Asulam	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Bentazone	ug/l	<0.0044	0.1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Bentazone	ug/l	<0.0044	0.1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Bromoxynil	ug/l	<0.0079	0.1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Bromoxynil	ug/l	<0.0079	0.1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Clopyralid	ug/l	<0.0097	0.1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Clopyralid	ug/l	<0.0097	0.1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Dichlorprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Dichlorprop	ug/l	<0.011	0.1

W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Iron	ug/l Fe	<1.538	200
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Iron	ug/l Fe	<1.538	200
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Manganese	ug Mn/l	<0.642	50
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Manganese	ug Mn/l	<0.642	50
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	MCPA	ug/l	<0.0093	0.1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	MCPA	ug/l	<0.0093	0.1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	MCPB	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	MCPB	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Mecoprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Mecoprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Propyzamide	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Propyzamide	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Total Organic Carbon	mg C/l	1.8	
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Total Organic Carbon	mg C/l	1.8	
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Triclopyr	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4942924	16/07/2024 08:50	Triclopyr	ug/l	<0.012	0.1
W4701OUT	Killyhevlin Final Water Outlet	4942931	16/07/2024 09:00	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4942931	16/07/2024 09:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4942931	16/07/2024 09:00	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4942931	16/07/2024 09:00	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4942931	16/07/2024 09:00	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4942931	16/07/2024 09:00	Free - Residual disinfectant	mg Cl/l	1.36	
W4701OUT	Killyhevlin Final Water Outlet	4942931	16/07/2024 09:00	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4942931	16/07/2024 09:00	Total - Residual disinfectant	mg Cl/l	1.44	
W4701OUT	Killyhevlin Final Water Outlet	4942931	16/07/2024 09:00	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4942931	16/07/2024 09:00	Turbidity	NTU	0.14	1
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Colony Counts 22	CFU/1 ml	1	
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Free - Residual disinfectant	mg Cl/l	1.37	
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Hydrogen Ion	pH value	7.7	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Nitrite	mg/l	<0.03	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Total - Residual disinfectant	mg Cl/l	1.52	
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Turbidity	NTU	0.095	1
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Algae Diatom Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Algae Green Total	per ml	0	

W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Aluminium	ug Al/l	20	200
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Bromodichloromethane	ug/l	5.2	
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Chloroform	ug/l	10	
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Iron	ug/l Fe	<1.538	200
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Manganese	ug Mn/l	<0.642	50
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	MIB	ng/l	<1.9	
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Second most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Third most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4942937	16/07/2024 09:38	Total Organic Carbon	mg C/l	2.6	
W1302OUT	Lough Fea Final Water Outlet	4942922	16/07/2024 10:12	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4942922	16/07/2024 10:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4942922	16/07/2024 10:12	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4942922	16/07/2024 10:12	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4942922	16/07/2024 10:12	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4942922	16/07/2024 10:12	Free - Residual disinfectant	mg Cl/l	0.68	
W1302OUT	Lough Fea Final Water Outlet	4942922	16/07/2024 10:12	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4942922	16/07/2024 10:12	Total - Residual disinfectant	mg Cl/l	0.76	
W1302OUT	Lough Fea Final Water Outlet	4942922	16/07/2024 10:12	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4942922	16/07/2024 10:12	Turbidity	NTU	0.16	1
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Free - Residual disinfectant	mg Cl/l	1.31	
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Total - Residual disinfectant	mg Cl/l	1.55	
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Turbidity	NTU	0.25	1
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	2,4-D	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	2,4-DB	ug/l	<0.016	0.1
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Algae Blue Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Algae Diatom Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Algae Flagellate Total	per ml	0	

W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Algae Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Algae Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Aluminium	ug Al/l	39	200
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Asulam	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Bentazone	ug/l	<0.0044	0.1
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Bromoxynil	ug/l	<0.0079	0.1
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Clopyralid	ug/l	<0.0097	0.1
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Dichlorprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Geosmin	ng/l	<1.1	
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Iron	ug/l Fe	30	200
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Manganese	ug Mn/l	<0.642	50
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	MCPA	ug/l	<0.0093	0.1
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	MCPB	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Mecoprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	MIB	ng/l	<1.9	
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Propyzamide	ug/l	<0.012	0.1
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Second most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Taste - Nature		No taste	
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Third most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Total Organic Carbon	mg C/l	2.7	
W1301POUT	Moyola PPP Final Water Outlet	4942943	16/07/2024 11:31	Triclopyr	ug/l	<0.012	0.1
W2514OUT	Seagahan Final Water Outlet	4942953	16/07/2024 12:18	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4942953	16/07/2024 12:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4942953	16/07/2024 12:18	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4942953	16/07/2024 12:18	Conductivity	uS/cm 20 C	380	2500
W2514OUT	Seagahan Final Water Outlet	4942953	16/07/2024 12:18	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4942953	16/07/2024 12:18	Free - Residual disinfectant	mg Cl/l	1.11	
W2514OUT	Seagahan Final Water Outlet	4942953	16/07/2024 12:18	Hydrogen Ion	pH value	7.6	9.5
W2514OUT	Seagahan Final Water Outlet	4942953	16/07/2024 12:18	Total - Residual disinfectant	mg Cl/l	1.25	
W2514OUT	Seagahan Final Water Outlet	4942953	16/07/2024 12:18	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4942953	16/07/2024 12:18	Turbidity	NTU	0.12	1
W2514OUT	Seagahan Final Water Outlet	4942953	16/07/2024 12:18	Algae Blue Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4942953	16/07/2024 12:18	Algae Diatom Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4942953	16/07/2024 12:18	Algae Flagellate Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4942953	16/07/2024 12:18	Algae Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4942953	16/07/2024 12:18	Algae Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4942953	16/07/2024 12:18	Aluminium	ug Al/l	6.4	200
W2514OUT	Seagahan Final Water Outlet	4942953	16/07/2024 12:18	Iron	ug/l Fe	<1.538	200

W2514OUT	Seagahan Final Water Outlet	4942953	16/07/2024 12:18	Manganese	ug Mn/l	<0.642	50
W2514OUT	Seagahan Final Water Outlet	4942953	16/07/2024 12:18	Most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4942953	16/07/2024 12:18	Second most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4942953	16/07/2024 12:18	Third most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4942953	16/07/2024 12:18	Total Organic Carbon	mg C/l	2.6	
W1301POUT	Moyola PPP Final Water Outlet	4943199	17/07/2024 07:08	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4943199	17/07/2024 07:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4943199	17/07/2024 07:08	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4943199	17/07/2024 07:08	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4943199	17/07/2024 07:08	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4943199	17/07/2024 07:08	Free - Residual disinfectant	mg Cl/l	1.55	
W1301POUT	Moyola PPP Final Water Outlet	4943199	17/07/2024 07:08	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4943199	17/07/2024 07:08	Total - Residual disinfectant	mg Cl/l	1.94	
W1301POUT	Moyola PPP Final Water Outlet	4943199	17/07/2024 07:08	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4943199	17/07/2024 07:08	Turbidity	NTU	0.096	1
W2308POUT	Castor Bay PPP Final Water Outlet	4943193	17/07/2024 07:36	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4943193	17/07/2024 07:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4943193	17/07/2024 07:36	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4943193	17/07/2024 07:36	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4943193	17/07/2024 07:36	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4943193	17/07/2024 07:36	Free - Residual disinfectant	mg Cl/l	1.38	
W2308POUT	Castor Bay PPP Final Water Outlet	4943193	17/07/2024 07:36	Hydrogen Ion	pH value	7.8	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4943193	17/07/2024 07:36	Total - Residual disinfectant	mg Cl/l	1.46	
W2308POUT	Castor Bay PPP Final Water Outlet	4943193	17/07/2024 07:36	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4943193	17/07/2024 07:36	Turbidity	NTU	0.15	1
W2308POUT	Castor Bay PPP Final Water Outlet	4943193	17/07/2024 07:36	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4943193	17/07/2024 07:36	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4943193	17/07/2024 07:36	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4943193	17/07/2024 07:36	Taste - Nature		No taste	
W1316OUT	Moneymore Borewell Final Water Outlet	4943205	17/07/2024 07:50	Colony Counts 22	CFU/1 ml	0	
W1316OUT	Moneymore Borewell Final Water Outlet	4943205	17/07/2024 07:50	Colony Counts 37 (48hrs)	CFU/1 ml	1	
W1316OUT	Moneymore Borewell Final Water Outlet	4943205	17/07/2024 07:50	Colour	mg/l Pt/Co	<4.56	20
W1316OUT	Moneymore Borewell Final Water Outlet	4943205	17/07/2024 07:50	Conductivity	uS/cm 20 C	350	2500
W1316OUT	Moneymore Borewell Final Water Outlet	4943205	17/07/2024 07:50	E. coli	CFU/100 ml	0	0
W1316OUT	Moneymore Borewell Final Water Outlet	4943205	17/07/2024 07:50	Free - Residual disinfectant	mg Cl/l	0.41	
W1316OUT	Moneymore Borewell Final Water Outlet	4943205	17/07/2024 07:50	Hydrogen Ion	pH value	7.8	9.5
W1316OUT	Moneymore Borewell Final Water Outlet	4943205	17/07/2024 07:50	Total - Residual disinfectant	mg Cl/l	0.52	
W1316OUT	Moneymore Borewell Final Water Outlet	4943205	17/07/2024 07:50	Total Coliforms	CFU/100 ml	0	0
W1316OUT	Moneymore Borewell Final Water Outlet	4943205	17/07/2024 07:50	Turbidity	NTU	0.1	1
W1316OUT	Moneymore Borewell Final Water Outlet	4943205	17/07/2024 07:50	Aluminium	ug Al/l	23	200
W1316OUT	Moneymore Borewell Final Water Outlet	4943205	17/07/2024 07:50	Antimony	ug/l Sb	0.083	5
W1316OUT	Moneymore Borewell Final Water Outlet	4943205	17/07/2024 07:50	Arsenic	ug/l As	1.1	10

W1316OUT	Money more Borewell Final Water Outlet	4943205	17/07/2024 07:50	Boron	mg/l B	<0.0586	1000
W1316OUT	Money more Borewell Final Water Outlet	4943205	17/07/2024 07:50	Cadmium	ug/l Cd	<0.042	5
W1316OUT	Money more Borewell Final Water Outlet	4943205	17/07/2024 07:50	Chromium	ug/l Cr	1.3	50
W1316OUT	Money more Borewell Final Water Outlet	4943205	17/07/2024 07:50	Iron	ug/l Fe	13	200
W1316OUT	Money more Borewell Final Water Outlet	4943205	17/07/2024 07:50	Manganese	ug Mn/l	<0.642	50
W1316OUT	Money more Borewell Final Water Outlet	4943205	17/07/2024 07:50	Selenium	ug/l Se	0.074	10
W1316OUT	Money more Borewell Final Water Outlet	4943205	17/07/2024 07:50	Total Organic Carbon	mg C/l	1.8	
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	Colony Counts 37 (48hrs)	CFU/1 ml	1	
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	Free - Residual disinfectant	mg Cl/l	0.64	
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	Total - Residual disinfectant	mg Cl/l	0.75	
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	2,4-D	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	2,4-DB	ug/l	<0.016	0.1
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	Aluminium	ug Al/l	25	200
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	Asulam	ug/l	<0.015	0.1
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	Bentazone	ug/l	<0.0044	0.1
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	Bromoxynil	ug/l	<0.0079	0.1
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	Clopyralid	ug/l	<0.0097	0.1
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	Dichlorprop	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	Iron	ug/l Fe	2	200
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	Manganese	ug Mn/l	<0.642	50
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	MCPA	ug/l	<0.0093	0.1
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	MCPB	ug/l	<0.015	0.1
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	Mecoprop	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	Propyzamide	ug/l	<0.012	0.1
W1302OUT	Lough Fea Final Water Outlet	4943175	17/07/2024 08:23	Triclopyr	ug/l	<0.012	0.1
W4701OUT	Killyhevlin Final Water Outlet	4943186	17/07/2024 10:39	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4943186	17/07/2024 10:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4943186	17/07/2024 10:39	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4943186	17/07/2024 10:39	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4943186	17/07/2024 10:39	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4943186	17/07/2024 10:39	Free - Residual disinfectant	mg Cl/l	1.39	
W4701OUT	Killyhevlin Final Water Outlet	4943186	17/07/2024 10:39	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4943186	17/07/2024 10:39	Total - Residual disinfectant	mg Cl/l	1.47	
W4701OUT	Killyhevlin Final Water Outlet	4943186	17/07/2024 10:39	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4943186	17/07/2024 10:39	Turbidity	NTU	0.15	1

W4523OUT	Lough Macrory Final Water Outlet	4943176	17/07/2024 11:18	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4943176	17/07/2024 11:18	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4943176	17/07/2024 11:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4943176	17/07/2024 11:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4943176	17/07/2024 11:18	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4943176	17/07/2024 11:18	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4943176	17/07/2024 11:18	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4943176	17/07/2024 11:18	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4943176	17/07/2024 11:18	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4943176	17/07/2024 11:18	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4943176	17/07/2024 11:18	Free - Residual disinfectant	mg Cl/l	0.74	
W4523OUT	Lough Macrory Final Water Outlet	4943176	17/07/2024 11:18	Free - Residual disinfectant	mg Cl/l	0.74	
W4523OUT	Lough Macrory Final Water Outlet	4943176	17/07/2024 11:18	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4943176	17/07/2024 11:18	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4943176	17/07/2024 11:18	Total - Residual disinfectant	mg Cl/l	0.88	
W4523OUT	Lough Macrory Final Water Outlet	4943176	17/07/2024 11:18	Total - Residual disinfectant	mg Cl/l	0.88	
W4523OUT	Lough Macrory Final Water Outlet	4943176	17/07/2024 11:18	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4943176	17/07/2024 11:18	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4943176	17/07/2024 11:18	Turbidity	NTU	0.14	1
W4523OUT	Lough Macrory Final Water Outlet	4943176	17/07/2024 11:18	Turbidity	NTU	0.14	1
W2514OUT	Seagahan Final Water Outlet	4943183	17/07/2024 12:27	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4943183	17/07/2024 12:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4943183	17/07/2024 12:27	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4943183	17/07/2024 12:27	Conductivity	uS/cm 20 C	380	2500
W2514OUT	Seagahan Final Water Outlet	4943183	17/07/2024 12:27	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4943183	17/07/2024 12:27	Free - Residual disinfectant	mg Cl/l	1.01	
W2514OUT	Seagahan Final Water Outlet	4943183	17/07/2024 12:27	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4943183	17/07/2024 12:27	Total - Residual disinfectant	mg Cl/l	1.22	
W2514OUT	Seagahan Final Water Outlet	4943183	17/07/2024 12:27	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4943183	17/07/2024 12:27	Turbidity	NTU	0.12	1
W2308POUT	Castor Bay PPP Final Water Outlet	4943384	18/07/2024 08:25	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4943384	18/07/2024 08:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4943384	18/07/2024 08:25	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4943384	18/07/2024 08:25	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4943384	18/07/2024 08:25	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4943384	18/07/2024 08:25	Free - Residual disinfectant	mg Cl/l	1.54	
W2308POUT	Castor Bay PPP Final Water Outlet	4943384	18/07/2024 08:25	Hydrogen Ion	pH value	7.9	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4943384	18/07/2024 08:25	Total - Residual disinfectant	mg Cl/l	1.73	
W2308POUT	Castor Bay PPP Final Water Outlet	4943384	18/07/2024 08:25	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4943384	18/07/2024 08:25	Turbidity	NTU	0.27	1
W2308POUT	Castor Bay PPP Final Water Outlet	4943384	18/07/2024 08:25	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4943384	18/07/2024 08:25	Odour - Nature		No odour	

W2308POUT	Castor Bay PPP Final Water Outlet	4943384	18/07/2024 08:25	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4943384	18/07/2024 08:25	Taste - Nature		No taste	
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Free - Residual disinfectant	mg Cl/l	1.34	
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Total - Residual disinfectant	mg Cl/l	1.4	
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Turbidity	NTU	0.13	1
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	2,4-D	ug/l	<0.011	0.1
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	2,4-DB	ug/l	<0.016	0.1
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Algae Blue Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Algae Diatom Total	per ml	40	
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Algae Flagellate Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Algae Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Algae Total	per ml	40	
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Aluminium	ug Al/l	28	200
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Asulam	ug/l	<0.015	0.1
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Bentazone	ug/l	<0.0044	0.1
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Bromoxynil	ug/l	<0.0079	0.1
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Clopyralid	ug/l	<0.0097	0.1
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Dichlorprop	ug/l	<0.011	0.1
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Iron	ug/l Fe	3.2	200
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Manganese	ug Mn/l	1.5	50
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	MCPA	ug/l	0.02	0.1
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	MCPB	ug/l	<0.015	0.1
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Mecoprop	ug/l	<0.011	0.1
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Most numerous Algae		Centric diatom	
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Odour	Diln No	0	0
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Odour - Nature		No odour	
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Propyzamide	ug/l	<0.012	0.1
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Second most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Taste	Diln No	0	0
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Taste - Nature		No taste	
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Third most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Total Organic Carbon	mg C/l	2.5	
W4701OUT	Killyhevlin Final Water Outlet	4943379	18/07/2024 09:04	Triclopyr	ug/l	<0.012	0.1
W1302OUT	Lough Fea Final Water Outlet	4943366	18/07/2024 09:57	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4943366	18/07/2024 09:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	

W1302OUT	Lough Fea Final Water Outlet	4943366	18/07/2024 09:57	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4943366	18/07/2024 09:57	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4943366	18/07/2024 09:57	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4943366	18/07/2024 09:57	Free - Residual disinfectant	mg Cl/l	0.65	
W1302OUT	Lough Fea Final Water Outlet	4943366	18/07/2024 09:57	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4943366	18/07/2024 09:57	Total - Residual disinfectant	mg Cl/l	0.74	
W1302OUT	Lough Fea Final Water Outlet	4943366	18/07/2024 09:57	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4943366	18/07/2024 09:57	Turbidity	NTU	0.1	1
W1301POUT	Moyola PPP Final Water Outlet	4943386	18/07/2024 10:37	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4943386	18/07/2024 10:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4943386	18/07/2024 10:37	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4943386	18/07/2024 10:37	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4943386	18/07/2024 10:37	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4943386	18/07/2024 10:37	Free - Residual disinfectant	mg Cl/l	1.48	
W1301POUT	Moyola PPP Final Water Outlet	4943386	18/07/2024 10:37	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4943386	18/07/2024 10:37	Total - Residual disinfectant	mg Cl/l	1.56	
W1301POUT	Moyola PPP Final Water Outlet	4943386	18/07/2024 10:37	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4943386	18/07/2024 10:37	Turbidity	NTU	0.1	1
W2514OUT	Seagahan Final Water Outlet	4943372	18/07/2024 10:47	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4943372	18/07/2024 10:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4943372	18/07/2024 10:47	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4943372	18/07/2024 10:47	Conductivity	uS/cm 20 C	390	2500
W2514OUT	Seagahan Final Water Outlet	4943372	18/07/2024 10:47	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4943372	18/07/2024 10:47	Free - Residual disinfectant	mg Cl/l	1.11	
W2514OUT	Seagahan Final Water Outlet	4943372	18/07/2024 10:47	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4943372	18/07/2024 10:47	Total - Residual disinfectant	mg Cl/l	1.31	
W2514OUT	Seagahan Final Water Outlet	4943372	18/07/2024 10:47	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4943372	18/07/2024 10:47	Turbidity	NTU	0.15	1
W4523OUT	Lough Macrory Final Water Outlet	4943367	18/07/2024 10:58	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4943367	18/07/2024 10:58	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4943367	18/07/2024 10:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4943367	18/07/2024 10:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4943367	18/07/2024 10:58	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4943367	18/07/2024 10:58	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4943367	18/07/2024 10:58	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4943367	18/07/2024 10:58	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4943367	18/07/2024 10:58	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4943367	18/07/2024 10:58	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4943367	18/07/2024 10:58	Free - Residual disinfectant	mg Cl/l	1.16	
W4523OUT	Lough Macrory Final Water Outlet	4943367	18/07/2024 10:58	Free - Residual disinfectant	mg Cl/l	1.16	
W4523OUT	Lough Macrory Final Water Outlet	4943367	18/07/2024 10:58	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4943367	18/07/2024 10:58	Hydrogen Ion	pH value	7.6	9.5

W4523OUT	Lough Macrory Final Water Outlet	4943367	18/07/2024 10:58	Total - Residual disinfectant	mg Cl/l	1.21	
W4523OUT	Lough Macrory Final Water Outlet	4943367	18/07/2024 10:58	Total - Residual disinfectant	mg Cl/l	1.21	
W4523OUT	Lough Macrory Final Water Outlet	4943367	18/07/2024 10:58	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4943367	18/07/2024 10:58	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4943367	18/07/2024 10:58	Turbidity	NTU	0.14	1
W4523OUT	Lough Macrory Final Water Outlet	4943367	18/07/2024 10:58	Turbidity	NTU	0.14	1
W2308POUT	Castor Bay PPP Final Water Outlet	4943566	19/07/2024 08:01	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4943566	19/07/2024 08:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4943566	19/07/2024 08:01	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4943566	19/07/2024 08:01	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4943566	19/07/2024 08:01	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4943566	19/07/2024 08:01	Free - Residual disinfectant	mg Cl/l	1.48	
W2308POUT	Castor Bay PPP Final Water Outlet	4943566	19/07/2024 08:01	Hydrogen Ion	pH value	7.8	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4943566	19/07/2024 08:01	Total - Residual disinfectant	mg Cl/l	1.65	
W2308POUT	Castor Bay PPP Final Water Outlet	4943566	19/07/2024 08:01	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4943566	19/07/2024 08:01	Turbidity	NTU	0.15	1
W1301POUT	Moyola PPP Final Water Outlet	4943568	19/07/2024 08:03	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4943568	19/07/2024 08:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4943568	19/07/2024 08:03	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4943568	19/07/2024 08:03	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4943568	19/07/2024 08:03	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4943568	19/07/2024 08:03	Free - Residual disinfectant	mg Cl/l	1.49	
W1301POUT	Moyola PPP Final Water Outlet	4943568	19/07/2024 08:03	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4943568	19/07/2024 08:03	Total - Residual disinfectant	mg Cl/l	1.56	
W1301POUT	Moyola PPP Final Water Outlet	4943568	19/07/2024 08:03	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4943568	19/07/2024 08:03	Turbidity	NTU	0.11	1
W1302OUT	Lough Fea Final Water Outlet	4943561	19/07/2024 09:57	Colony Counts 22	CFU/1 ml	2	
W1302OUT	Lough Fea Final Water Outlet	4943561	19/07/2024 09:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4943561	19/07/2024 09:57	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4943561	19/07/2024 09:57	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4943561	19/07/2024 09:57	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4943561	19/07/2024 09:57	Free - Residual disinfectant	mg Cl/l	0.53	
W1302OUT	Lough Fea Final Water Outlet	4943561	19/07/2024 09:57	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4943561	19/07/2024 09:57	Total - Residual disinfectant	mg Cl/l	0.61	
W1302OUT	Lough Fea Final Water Outlet	4943561	19/07/2024 09:57	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4943561	19/07/2024 09:57	Turbidity	NTU	0.096	1
W2514OUT	Seagahan Final Water Outlet	4943576	19/07/2024 10:10	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4943576	19/07/2024 10:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4943576	19/07/2024 10:10	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4943576	19/07/2024 10:10	Conductivity	uS/cm 20 C	390	2500
W2514OUT	Seagahan Final Water Outlet	4943576	19/07/2024 10:10	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4943576	19/07/2024 10:10	Free - Residual disinfectant	mg Cl/l	1.05	

W2514OUT	Seagahan Final Water Outlet	4943576	19/07/2024 10:10	Hydrogen Ion	pH value	7.4	9.5
W2514OUT	Seagahan Final Water Outlet	4943576	19/07/2024 10:10	Total - Residual disinfectant	mg Cl/l	1.19	
W2514OUT	Seagahan Final Water Outlet	4943576	19/07/2024 10:10	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4943576	19/07/2024 10:10	Turbidity	NTU	0.12	1
W4523OUT	Lough Macrory Final Water Outlet	4943579	19/07/2024 10:23	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4943579	19/07/2024 10:23	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4943579	19/07/2024 10:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4943579	19/07/2024 10:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4943579	19/07/2024 10:23	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4943579	19/07/2024 10:23	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4943579	19/07/2024 10:23	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4943579	19/07/2024 10:23	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4943579	19/07/2024 10:23	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4943579	19/07/2024 10:23	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4943579	19/07/2024 10:23	Free - Residual disinfectant	mg Cl/l	1.11	
W4523OUT	Lough Macrory Final Water Outlet	4943579	19/07/2024 10:23	Free - Residual disinfectant	mg Cl/l	1.11	
W4523OUT	Lough Macrory Final Water Outlet	4943579	19/07/2024 10:23	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4943579	19/07/2024 10:23	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4943579	19/07/2024 10:23	Total - Residual disinfectant	mg Cl/l	1.16	
W4523OUT	Lough Macrory Final Water Outlet	4943579	19/07/2024 10:23	Total - Residual disinfectant	mg Cl/l	1.16	
W4523OUT	Lough Macrory Final Water Outlet	4943579	19/07/2024 10:23	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4943579	19/07/2024 10:23	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4943579	19/07/2024 10:23	Turbidity	NTU	0.13	1
W4523OUT	Lough Macrory Final Water Outlet	4943579	19/07/2024 10:23	Turbidity	NTU	0.13	1
W4701OUT	Killyhevlin Final Water Outlet	4943563	19/07/2024 11:05	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4943563	19/07/2024 11:05	Colony Counts 37 (48hrs)	CFU/1 ml	1	
W4701OUT	Killyhevlin Final Water Outlet	4943563	19/07/2024 11:05	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4943563	19/07/2024 11:05	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4943563	19/07/2024 11:05	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4943563	19/07/2024 11:05	Free - Residual disinfectant	mg Cl/l	1.24	
W4701OUT	Killyhevlin Final Water Outlet	4943563	19/07/2024 11:05	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4943563	19/07/2024 11:05	Total - Residual disinfectant	mg Cl/l	1.33	
W4701OUT	Killyhevlin Final Water Outlet	4943563	19/07/2024 11:05	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4943563	19/07/2024 11:05	Turbidity	NTU	0.15	1
W1301POUT	Moyola PPP Final Water Outlet	4943683	20/07/2024 07:27	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4943683	20/07/2024 07:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4943683	20/07/2024 07:27	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4943683	20/07/2024 07:27	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4943683	20/07/2024 07:27	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4943683	20/07/2024 07:27	Free - Residual disinfectant	mg Cl/l	1.47	
W1301POUT	Moyola PPP Final Water Outlet	4943683	20/07/2024 07:27	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4943683	20/07/2024 07:27	Total - Residual disinfectant	mg Cl/l	1.6	

W1301POUT	Moyola PPP Final Water Outlet	4943683	20/07/2024 07:27	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4943683	20/07/2024 07:27	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4943678	20/07/2024 08:10	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4943678	20/07/2024 08:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4943678	20/07/2024 08:10	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4943678	20/07/2024 08:10	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4943678	20/07/2024 08:10	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4943678	20/07/2024 08:10	Free - Residual disinfectant	mg Cl/l	0.73	
W1302OUT	Lough Fea Final Water Outlet	4943678	20/07/2024 08:10	Hydrogen Ion	pH value	7.5	9.5
W1302OUT	Lough Fea Final Water Outlet	4943678	20/07/2024 08:10	Total - Residual disinfectant	mg Cl/l	0.78	
W1302OUT	Lough Fea Final Water Outlet	4943678	20/07/2024 08:10	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4943678	20/07/2024 08:10	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4943679	20/07/2024 08:50	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4943679	20/07/2024 08:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4943679	20/07/2024 08:50	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4943679	20/07/2024 08:50	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4943679	20/07/2024 08:50	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4943679	20/07/2024 08:50	Free - Residual disinfectant	mg Cl/l	1.29	
W4701OUT	Killyhevlin Final Water Outlet	4943679	20/07/2024 08:50	Hydrogen Ion	pH value	7.6	9.5
W4701OUT	Killyhevlin Final Water Outlet	4943679	20/07/2024 08:50	Total - Residual disinfectant	mg Cl/l	1.58	
W4701OUT	Killyhevlin Final Water Outlet	4943679	20/07/2024 08:50	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4943679	20/07/2024 08:50	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4943682	20/07/2024 09:51	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4943682	20/07/2024 09:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4943682	20/07/2024 09:51	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4943682	20/07/2024 09:51	Conductivity	uS/cm 20 C	390	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4943682	20/07/2024 09:51	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4943682	20/07/2024 09:51	Free - Residual disinfectant	mg Cl/l	1.7	
W2308POUT	Castor Bay PPP Final Water Outlet	4943682	20/07/2024 09:51	Hydrogen Ion	pH value	7.8	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4943682	20/07/2024 09:51	Total - Residual disinfectant	mg Cl/l	1.83	
W2308POUT	Castor Bay PPP Final Water Outlet	4943682	20/07/2024 09:51	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4943682	20/07/2024 09:51	Turbidity	NTU	0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4943701	21/07/2024 08:40	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4943701	21/07/2024 08:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4943701	21/07/2024 08:40	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4943701	21/07/2024 08:40	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4943701	21/07/2024 08:40	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4943701	21/07/2024 08:40	Free - Residual disinfectant	mg Cl/l	1.46	
W1301POUT	Moyola PPP Final Water Outlet	4943701	21/07/2024 08:40	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4943701	21/07/2024 08:40	Total - Residual disinfectant	mg Cl/l	1.61	
W1301POUT	Moyola PPP Final Water Outlet	4943701	21/07/2024 08:40	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4943701	21/07/2024 08:40	Turbidity	NTU	<0.09	1

W1302OUT	Lough Fea Final Water Outlet	4943696	21/07/2024 09:22	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4943696	21/07/2024 09:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4943696	21/07/2024 09:22	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4943696	21/07/2024 09:22	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4943696	21/07/2024 09:22	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4943696	21/07/2024 09:22	Free - Residual disinfectant	mg Cl/l	0.75	
W1302OUT	Lough Fea Final Water Outlet	4943696	21/07/2024 09:22	Hydrogen Ion	pH value	7.5	9.5
W1302OUT	Lough Fea Final Water Outlet	4943696	21/07/2024 09:22	Total - Residual disinfectant	mg Cl/l	0.9	
W1302OUT	Lough Fea Final Water Outlet	4943696	21/07/2024 09:22	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4943696	21/07/2024 09:22	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4943697	21/07/2024 09:32	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4943697	21/07/2024 09:32	Colony Counts 37 (48hrs)	CFU/1 ml	1	
W4701OUT	Killyhevlin Final Water Outlet	4943697	21/07/2024 09:32	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4943697	21/07/2024 09:32	Conductivity	uS/cm 20 C	440	2500
W4701OUT	Killyhevlin Final Water Outlet	4943697	21/07/2024 09:32	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4943697	21/07/2024 09:32	Free - Residual disinfectant	mg Cl/l	1.27	
W4701OUT	Killyhevlin Final Water Outlet	4943697	21/07/2024 09:32	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4943697	21/07/2024 09:32	Total - Residual disinfectant	mg Cl/l	1.44	
W4701OUT	Killyhevlin Final Water Outlet	4943697	21/07/2024 09:32	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4943697	21/07/2024 09:32	Turbidity	NTU	0.12	1
W2308POUT	Castor Bay PPP Final Water Outlet	4943700	21/07/2024 10:25	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4943700	21/07/2024 10:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4943700	21/07/2024 10:25	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4943700	21/07/2024 10:25	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4943700	21/07/2024 10:25	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4943700	21/07/2024 10:25	Free - Residual disinfectant	mg Cl/l	1.61	
W2308POUT	Castor Bay PPP Final Water Outlet	4943700	21/07/2024 10:25	Hydrogen Ion	pH value	7.7	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4943700	21/07/2024 10:25	Total - Residual disinfectant	mg Cl/l	1.79	
W2308POUT	Castor Bay PPP Final Water Outlet	4943700	21/07/2024 10:25	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4943700	21/07/2024 10:25	Turbidity	NTU	0.093	1
W1301POUT	Moyola PPP Final Water Outlet	4946183	22/07/2024 07:28	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4946183	22/07/2024 07:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4946183	22/07/2024 07:28	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4946183	22/07/2024 07:28	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4946183	22/07/2024 07:28	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4946183	22/07/2024 07:28	Free - Residual disinfectant	mg Cl/l	1.48	
W1301POUT	Moyola PPP Final Water Outlet	4946183	22/07/2024 07:28	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4946183	22/07/2024 07:28	Total - Residual disinfectant	mg Cl/l	1.71	
W1301POUT	Moyola PPP Final Water Outlet	4946183	22/07/2024 07:28	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4946183	22/07/2024 07:28	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4946182	22/07/2024 08:44	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4946182	22/07/2024 08:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	

W2308POUT	Castor Bay PPP Final Water Outlet	4946182	22/07/2024 08:44	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4946182	22/07/2024 08:44	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4946182	22/07/2024 08:44	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4946182	22/07/2024 08:44	Free - Residual disinfectant	mg Cl/l	1.37	
W2308POUT	Castor Bay PPP Final Water Outlet	4946182	22/07/2024 08:44	Hydrogen Ion	pH value	7.7	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4946182	22/07/2024 08:44	Total - Residual disinfectant	mg Cl/l	1.54	
W2308POUT	Castor Bay PPP Final Water Outlet	4946182	22/07/2024 08:44	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4946182	22/07/2024 08:44	Turbidity	NTU	0.1	1
W2308POUT	Castor Bay PPP Final Water Outlet	4946182	22/07/2024 08:44	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4946182	22/07/2024 08:44	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4946182	22/07/2024 08:44	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4946182	22/07/2024 08:44	Taste - Nature		No taste	
W1302OUT	Lough Fea Final Water Outlet	4946155	22/07/2024 08:54	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4946155	22/07/2024 08:54	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4946155	22/07/2024 08:54	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4946155	22/07/2024 08:54	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4946155	22/07/2024 08:54	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4946155	22/07/2024 08:54	Free - Residual disinfectant	mg Cl/l	0.7	
W1302OUT	Lough Fea Final Water Outlet	4946155	22/07/2024 08:54	Hydrogen Ion	pH value	7.5	9.5
W1302OUT	Lough Fea Final Water Outlet	4946155	22/07/2024 08:54	Total - Residual disinfectant	mg Cl/l	0.82	
W1302OUT	Lough Fea Final Water Outlet	4946155	22/07/2024 08:54	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4946155	22/07/2024 08:54	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4946156	22/07/2024 10:00	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4946156	22/07/2024 10:00	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4946156	22/07/2024 10:00	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4946156	22/07/2024 10:00	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4946156	22/07/2024 10:00	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4946156	22/07/2024 10:00	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4946156	22/07/2024 10:00	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4946156	22/07/2024 10:00	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4946156	22/07/2024 10:00	Free - Residual disinfectant	mg Cl/l	1.06	
W4523OUT	Lough Macrory Final Water Outlet	4946156	22/07/2024 10:00	Free - Residual disinfectant	mg Cl/l	1.06	
W4523OUT	Lough Macrory Final Water Outlet	4946156	22/07/2024 10:00	Hydrogen Ion	pH value	7.4	9.5
W4523OUT	Lough Macrory Final Water Outlet	4946156	22/07/2024 10:00	Hydrogen Ion	pH value	7.4	9.5
W4523OUT	Lough Macrory Final Water Outlet	4946156	22/07/2024 10:00	Total - Residual disinfectant	mg Cl/l	1.13	
W4523OUT	Lough Macrory Final Water Outlet	4946156	22/07/2024 10:00	Total - Residual disinfectant	mg Cl/l	1.13	
W4523OUT	Lough Macrory Final Water Outlet	4946156	22/07/2024 10:00	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4946156	22/07/2024 10:00	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4946156	22/07/2024 10:00	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4946156	22/07/2024 10:00	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	2,4-D	ug/l	<0.011	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	2,4-DB	ug/l	<0.016	0.1

W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Asulam	ug/l	<0.015	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Bentazone	ug/l	<0.0044	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Bromoxynil	ug/l	<0.0079	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Chlorotoluron	ug/l	<0.0031	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Chlorpyrifos	ug/l	<0.0070	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Clopyralid	ug/l	<0.0097	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Cyanide	ug/l CN	<5.5	50
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Dicamba	ug/l	<0.028	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Dichlorprop	ug/l	<0.011	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Diffenican	ug/l	<0.0072	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Dimethenamid	ug/l	<0.0063	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Diuron	ug/l	<0.0055	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Epoconazole	ug/l	<0.0049	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Fenpropimorph	ug/l	<0.0083	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Flufenacet	ug/l	<0.0052	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Fluroxypyr	ug/l	<0.0063	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Free - Residual disinfectant	mg Cl/l	1.37	
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Glyphosate	ug/l	<0.0077	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Isoproturon	ug/l	<0.0025	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Linuron	ug/l	<0.0034	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	MCPA	ug/l	0.02	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	MCPB	ug/l	<0.015	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Mecoprop	ug/l	<0.011	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Metalaxyl	ug/l	<0.0097	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Metamitron	ug/l	<0.0074	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Metazachlor	ug/l	<0.015	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Metoxuron	ug/l	<0.0080	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Metribuzin	ug/l	<0.0060	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Nitrite	mg/l	<0.03	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Oxamyl	ug/l	<0.0023	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Pendimethalin	ug/l	<0.0064	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Pesticides - Total Substances	ug/l	0.02	0.5
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Phorate	ug/l	<0.0092	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Pirimicarb	ug/l	<0.0063	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Propachlor	ug/l	<0.0096	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Propiconazole	ug/l	<0.0029	0.1

W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Propyzamide	ug/l	<0.012	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Prothioconazole	ug/l	<0.0019	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Tebuconazole	ug/l	<0.0039	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Total - Residual disinfectant	mg Cl/l	1.46	
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Triclopyr	ug/l	<0.012	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Algae Blue Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Algae Diatom Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Algae Flagellate Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Algae Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Algae Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Aluminium	ug Al/l	28	200
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Bromodichloromethane	ug/l	13	
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Bromoform	ug/l	<3.5	
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Chloroform	ug/l	40	
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Diazinon	ug/l	<0.0074	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Dibromochloromethane	ug/l	4.6	
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Geosmin	ng/l	<1.1	
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Iron	ug/l Fe	3.9	200
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Manganese	ug Mn/l	1.9	50
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	MIB	ng/l	<1.9	
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Microcystin-LR	ug/l	<0.024	
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Most numerous Algae		-	
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Second most numerous Algae		-	
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	Third most numerous Algae		-	
W4701OUT	Killyhevlin Final Water Outlet	4946172	22/07/2024 10:52	WHO Index		0.4	1
W2514OUT	Seagahan Final Water Outlet	4946160	22/07/2024 11:01	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4946160	22/07/2024 11:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4946160	22/07/2024 11:01	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4946160	22/07/2024 11:01	Conductivity	uS/cm 20 C	400	2500
W2514OUT	Seagahan Final Water Outlet	4946160	22/07/2024 11:01	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4946160	22/07/2024 11:01	Free - Residual disinfectant	mg Cl/l	0.97	
W2514OUT	Seagahan Final Water Outlet	4946160	22/07/2024 11:01	Hydrogen Ion	pH value	7.6	9.5
W2514OUT	Seagahan Final Water Outlet	4946160	22/07/2024 11:01	Total - Residual disinfectant	mg Cl/l	1.17	
W2514OUT	Seagahan Final Water Outlet	4946160	22/07/2024 11:01	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4946160	22/07/2024 11:01	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	2,4-D	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	2,4-DB	ug/l	<0.016	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Asulam	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Bentazone	ug/l	<0.0044	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Bromoxynil	ug/l	<0.0079	0.1

W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Chlorotoluron	ug/l	<0.0031	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Chlorpyrifos	ug/l	<0.0070	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Clopyralid	ug/l	<0.0097	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Cyanide	ug/l CN	<5.5	50
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Dicamba	ug/l	<0.028	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Dichlorprop	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Diflufenican	ug/l	<0.0072	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Dimethenamid	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Diuron	ug/l	<0.0055	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Epoxiconazole	ug/l	<0.0049	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Fenpropimorph	ug/l	<0.0083	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Flufenacet	ug/l	<0.0052	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Fluroxypyr	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Free - Residual disinfectant	mg Cl/l	1.29	
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Glyphosate	ug/l	<0.0077	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Hydrogen Ion	pH value	7.9	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Isoproturon	ug/l	<0.0025	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Linuron	ug/l	<0.0034	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	MCPA	ug/l	0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	MCPB	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Mecoprop	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Metalaxyl	ug/l	<0.0097	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Metamitron	ug/l	<0.0074	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Metazachlor	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Metoxuron	ug/l	<0.0080	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Metribuzin	ug/l	<0.0060	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Oxamyl	ug/l	<0.0023	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Pendimethalin	ug/l	<0.0064	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Pesticides - Total Substances	ug/l	0.012	0.5
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Phorate	ug/l	<0.0092	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Pirimicarb	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Propachlor	ug/l	<0.0096	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Propiconazole	ug/l	<0.0029	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Propyzamide	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Prothioconazole	ug/l	<0.0019	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Tebuconazole	ug/l	<0.0039	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Total - Residual disinfectant	mg Cl/l	1.35	

W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Triclopyr	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Turbidity	NTU	0.13	1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Algae Diatom Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Algae Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Aluminium	ug Al/l	49	200
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Bromodichloromethane	ug/l	8.4	
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Chloroform	ug/l	14	
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Diazinon	ug/l	<0.0074	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Dibromochloromethane	ug/l	5.3	
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Iron	ug/l Fe	3.3	200
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Manganese	ug Mn/l	<0.642	50
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	MIB	ng/l	<1.9	
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Microcystin-LR	ug/l	<0.024	
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Second most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Third most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Total Organic Carbon	mg C/l	2.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	Total Trihalomethanes	ug/l	28	100
W2308POUT	Castor Bay PPP Final Water Outlet	4946407	23/07/2024 08:18	WHO Index		0.25	1
W1302OUT	Lough Fea Final Water Outlet	4946394	23/07/2024 08:42	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4946394	23/07/2024 08:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4946394	23/07/2024 08:42	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4946394	23/07/2024 08:42	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4946394	23/07/2024 08:42	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4946394	23/07/2024 08:42	Free - Residual disinfectant	mg Cl/l	0.81	
W1302OUT	Lough Fea Final Water Outlet	4946394	23/07/2024 08:42	Hydrogen Ion	pH value	7.1	9.5
W1302OUT	Lough Fea Final Water Outlet	4946394	23/07/2024 08:42	Total - Residual disinfectant	mg Cl/l	0.9	
W1302OUT	Lough Fea Final Water Outlet	4946394	23/07/2024 08:42	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4946394	23/07/2024 08:42	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Colour	mg/l Pt/Co	<4.56	20

W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Free - Residual disinfectant	mg Cl/l	1.48	
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Hydrogen Ion	pH value	7.8	9.5
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Total - Residual disinfectant	mg Cl/l	1.54	
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	2,4-D	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	2,4-DB	ug/l	<0.016	0.1
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Algae Blue Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Algae Diatom Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Algae Flagellate Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Algae Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Algae Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Aluminium	ug Al/l	36	200
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Asulam	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Bentazone	ug/l	<0.0044	0.1
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Bromoxynil	ug/l	<0.0079	0.1
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Clopyralid	ug/l	<0.0097	0.1
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Dichlorprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Geosmin	ng/l	<1.1	
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Iron	ug/l Fe	2.5	200
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Manganese	ug Mn/l	<0.642	50
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	MCPA	ug/l	0.014	0.1
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	MCPB	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Mecoprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	MIB	ng/l	<1.9	
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Microcystin-LR	ug/l	<0.024	
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Propyzamide	ug/l	<0.012	0.1
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Second most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Third most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Total Organic Carbon	mg C/l	2.5	
W1301POUT	Moyola PPP Final Water Outlet	4946412	23/07/2024 09:24	Triclopyr	ug/l	<0.012	0.1
W4701OUT	Killyhevlin Final Water Outlet	4946401	23/07/2024 09:25	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4946401	23/07/2024 09:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4946401	23/07/2024 09:25	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4946401	23/07/2024 09:25	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4946401	23/07/2024 09:25	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4946401	23/07/2024 09:25	Free - Residual disinfectant	mg Cl/l	1.39	
W4701OUT	Killyhevlin Final Water Outlet	4946401	23/07/2024 09:25	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4946401	23/07/2024 09:25	Total - Residual disinfectant	mg Cl/l	1.46	

W4701OUT	Killyhevlin Final Water Outlet	4946401	23/07/2024 09:25	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4946401	23/07/2024 09:25	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4946395	23/07/2024 11:02	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4946395	23/07/2024 11:02	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4946395	23/07/2024 11:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4946395	23/07/2024 11:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4946395	23/07/2024 11:02	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4946395	23/07/2024 11:02	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4946395	23/07/2024 11:02	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4946395	23/07/2024 11:02	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4946395	23/07/2024 11:02	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4946395	23/07/2024 11:02	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4946395	23/07/2024 11:02	Free - Residual disinfectant	mg Cl/l	1	
W4523OUT	Lough Macrory Final Water Outlet	4946395	23/07/2024 11:02	Free - Residual disinfectant	mg Cl/l	1	
W4523OUT	Lough Macrory Final Water Outlet	4946395	23/07/2024 11:02	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4946395	23/07/2024 11:02	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4946395	23/07/2024 11:02	Total - Residual disinfectant	mg Cl/l	1.08	
W4523OUT	Lough Macrory Final Water Outlet	4946395	23/07/2024 11:02	Total - Residual disinfectant	mg Cl/l	1.08	
W4523OUT	Lough Macrory Final Water Outlet	4946395	23/07/2024 11:02	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4946395	23/07/2024 11:02	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4946395	23/07/2024 11:02	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4946395	23/07/2024 11:02	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	2,4-D	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	2,4-DB	ug/l	<0.016	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Asulam	ug/l	<0.015	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Bentazone	ug/l	<0.0044	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Bromoxynil	ug/l	<0.0079	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Chlorotoluron	ug/l	<0.0031	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Chlorpyrifos	ug/l	<0.0070	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Clopyralid	ug/l	<0.0097	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Conductivity	uS/cm 20 C	400	2500
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Cyanide	ug/l CN	<5.5	50
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Dicamba	ug/l	<0.028	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Dichlorprop	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Di flufenican	ug/l	<0.0072	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Dimethenamid	ug/l	<0.0063	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Diuron	ug/l	<0.0055	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	E. coli	CFU/100 ml	0	0

W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Epoxiconazole	ug/l	<0.0049	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Fenpropimorph	ug/l	<0.0083	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Flufenacet	ug/l	<0.0052	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Fluroxypyr	ug/l	<0.0063	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Free - Residual disinfectant	mg Cl/l	0.8	
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Glyphosate	ug/l	<0.0077	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Hydrogen Ion	pH value	7.6	9.5
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Isoproturon	ug/l	<0.0025	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Linuron	ug/l	<0.0034	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	MCPA	ug/l	0.012	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	MCPB	ug/l	<0.015	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Mecoprop	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Metalaxyl	ug/l	<0.0097	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Metamitron	ug/l	<0.0074	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Metazachlor	ug/l	<0.015	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Metoxuron	ug/l	<0.0080	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Metribuzin	ug/l	<0.0060	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Oxamyl	ug/l	<0.0023	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Pendimethalin	ug/l	<0.0064	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Pesticides - Total Substances	ug/l	0.012	0.5
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Phorate	ug/l	<0.0092	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Pirimicarb	ug/l	<0.0063	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Propachlor	ug/l	<0.0096	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Propiconazole	ug/l	<0.0029	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Propyzamide	ug/l	<0.012	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Prothioconazole	ug/l	<0.0019	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Tebuconazole	ug/l	<0.0039	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Total - Residual disinfectant	mg Cl/l	0.98	
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Triclopyr	ug/l	<0.012	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Algae Blue Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Algae Diatom Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Algae Flagellate Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Algae Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Algae Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Aluminium	ug Al/l	4.4	200
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Bromodichloromethane	ug/l	15	
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Bromoform	ug/l	<3.5	
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Chloroform	ug/l	30	
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Diazinon	ug/l	<0.0074	0.1
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Dibromochloromethane	ug/l	4.5	

W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Geosmin	ng/l	<1.1	
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Iron	ug/l Fe	2.5	200
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Manganese	ug Mn/l	1.3	50
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	MIB	ng/l	<1.9	
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Microcystin-LR	ug/l	<0.024	
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Second most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Third most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	Total Organic Carbon	mg C/l	2.5	
W2514OUT	Seagahan Final Water Outlet	4946398	23/07/2024 11:59	WHO Index		0.4	1
W1301POUT	Moyola PPP Final Water Outlet	4946596	24/07/2024 07:44	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4946596	24/07/2024 07:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4946596	24/07/2024 07:44	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4946596	24/07/2024 07:44	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4946596	24/07/2024 07:44	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4946596	24/07/2024 07:44	Free - Residual disinfectant	mg Cl/l	1.54	
W1301POUT	Moyola PPP Final Water Outlet	4946596	24/07/2024 07:44	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4946596	24/07/2024 07:44	Total - Residual disinfectant	mg Cl/l	1.69	
W1301POUT	Moyola PPP Final Water Outlet	4946596	24/07/2024 07:44	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4946596	24/07/2024 07:44	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4946583	24/07/2024 08:32	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4946583	24/07/2024 08:32	Colony Counts 37 (48hrs)	CFU/1 ml	2	
W1302OUT	Lough Fea Final Water Outlet	4946583	24/07/2024 08:32	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4946583	24/07/2024 08:32	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4946583	24/07/2024 08:32	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4946583	24/07/2024 08:32	Free - Residual disinfectant	mg Cl/l	0.74	
W1302OUT	Lough Fea Final Water Outlet	4946583	24/07/2024 08:32	Hydrogen Ion	pH value	7.5	9.5
W1302OUT	Lough Fea Final Water Outlet	4946583	24/07/2024 08:32	Total - Residual disinfectant	mg Cl/l	0.78	
W1302OUT	Lough Fea Final Water Outlet	4946583	24/07/2024 08:32	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4946583	24/07/2024 08:32	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4946595	24/07/2024 08:58	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4946595	24/07/2024 08:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4946595	24/07/2024 08:58	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4946595	24/07/2024 08:58	Conductivity	uS/cm 20 C	390	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4946595	24/07/2024 08:58	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4946595	24/07/2024 08:58	Free - Residual disinfectant	mg Cl/l	1.92	
W2308POUT	Castor Bay PPP Final Water Outlet	4946595	24/07/2024 08:58	Hydrogen Ion	pH value	8.1	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4946595	24/07/2024 08:58	Total - Residual disinfectant	mg Cl/l	2	
W2308POUT	Castor Bay PPP Final Water Outlet	4946595	24/07/2024 08:58	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4946595	24/07/2024 08:58	Turbidity	NTU	0.15	1
W2308POUT	Castor Bay PPP Final Water Outlet	4946595	24/07/2024 08:58	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4946595	24/07/2024 08:58	Odour - Nature		No odour	

W2308POUT	Castor Bay PPP Final Water Outlet	4946595	24/07/2024 08:58	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4946595	24/07/2024 08:58	Taste - Nature		No taste	
W4701OUT	Killyhevlin Final Water Outlet	4946590	24/07/2024 09:30	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4946590	24/07/2024 09:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4946590	24/07/2024 09:30	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4946590	24/07/2024 09:30	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4946590	24/07/2024 09:30	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4946590	24/07/2024 09:30	Free - Residual disinfectant	mg Cl/l	1.68	
W4701OUT	Killyhevlin Final Water Outlet	4946590	24/07/2024 09:30	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4946590	24/07/2024 09:30	Total - Residual disinfectant	mg Cl/l	1.79	
W4701OUT	Killyhevlin Final Water Outlet	4946590	24/07/2024 09:30	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4946590	24/07/2024 09:30	Turbidity	NTU	0.091	1
W2514OUT	Seagahan Final Water Outlet	4946586	24/07/2024 10:31	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4946586	24/07/2024 10:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4946586	24/07/2024 10:31	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4946586	24/07/2024 10:31	Conductivity	uS/cm 20 C	380	2500
W2514OUT	Seagahan Final Water Outlet	4946586	24/07/2024 10:31	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4946586	24/07/2024 10:31	Free - Residual disinfectant	mg Cl/l	1.06	
W2514OUT	Seagahan Final Water Outlet	4946586	24/07/2024 10:31	Hydrogen Ion	pH value	7.6	9.5
W2514OUT	Seagahan Final Water Outlet	4946586	24/07/2024 10:31	Total - Residual disinfectant	mg Cl/l	1.24	
W2514OUT	Seagahan Final Water Outlet	4946586	24/07/2024 10:31	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4946586	24/07/2024 10:31	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Free - Residual disinfectant	mg Cl/l	0.96	
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Free - Residual disinfectant	mg Cl/l	0.96	
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Total - Residual disinfectant	mg Cl/l	1.08	
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Total - Residual disinfectant	mg Cl/l	1.08	
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Total Coliforms	CFU/100 ml	0	0

W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Turbidity	NTU	0.11	1
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Turbidity	NTU	0.11	1
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Aluminium	ug Al/l	3.8	200
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Aluminium	ug Al/l	3.8	200
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Iron	ug/l Fe	4.6	200
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Iron	ug/l Fe	4.6	200
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Manganese	ug Mn/l	<0.642	50
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Manganese	ug Mn/l	<0.642	50
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Total Organic Carbon	mg C/l	1.7	
W4523OUT	Lough Macrory Final Water Outlet	4946584	24/07/2024 11:41	Total Organic Carbon	mg C/l	1.7	
W2308POUT	Castor Bay PPP Final Water Outlet	4946787	25/07/2024 08:30	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4946787	25/07/2024 08:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4946787	25/07/2024 08:30	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4946787	25/07/2024 08:30	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4946787	25/07/2024 08:30	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4946787	25/07/2024 08:30	Free - Residual disinfectant	mg Cl/l	1.23	
W2308POUT	Castor Bay PPP Final Water Outlet	4946787	25/07/2024 08:30	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4946787	25/07/2024 08:30	Total - Residual disinfectant	mg Cl/l	1.38	
W2308POUT	Castor Bay PPP Final Water Outlet	4946787	25/07/2024 08:30	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4946787	25/07/2024 08:30	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4946782	25/07/2024 09:14	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4946782	25/07/2024 09:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4946782	25/07/2024 09:14	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4946782	25/07/2024 09:14	Conductivity	uS/cm 20 C	410	2500
W4701OUT	Killyhevlin Final Water Outlet	4946782	25/07/2024 09:14	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4946782	25/07/2024 09:14	Free - Residual disinfectant	mg Cl/l	1.46	
W4701OUT	Killyhevlin Final Water Outlet	4946782	25/07/2024 09:14	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4946782	25/07/2024 09:14	Total - Residual disinfectant	mg Cl/l	1.58	
W4701OUT	Killyhevlin Final Water Outlet	4946782	25/07/2024 09:14	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4946782	25/07/2024 09:14	Turbidity	NTU	0.1	1
W1302OUT	Lough Fea Final Water Outlet	4946773	25/07/2024 09:38	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4946773	25/07/2024 09:38	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4946773	25/07/2024 09:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4946773	25/07/2024 09:38	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4946773	25/07/2024 09:38	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4946773	25/07/2024 09:38	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4946773	25/07/2024 09:38	Free - Residual disinfectant	mg Cl/l	0.75	
W1302OUT	Lough Fea Final Water Outlet	4946773	25/07/2024 09:38	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4946773	25/07/2024 09:38	Total - Residual disinfectant	mg Cl/l	0.83	
W1302OUT	Lough Fea Final Water Outlet	4946773	25/07/2024 09:38	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4946773	25/07/2024 09:38	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4946773	25/07/2024 09:38	Aluminium	ug Al/l	38	200

W1302OUT	Lough Fea Final Water Outlet	4946773	25/07/2024 09:38	Iron	ug/l Fe	4.5	200
W1302OUT	Lough Fea Final Water Outlet	4946773	25/07/2024 09:38	Manganese	ug Mn/l	1.1	50
W1302OUT	Lough Fea Final Water Outlet	4946773	25/07/2024 09:38	Total Organic Carbon	mg C/l	2.1	
W4523OUT	Lough Macrory Final Water Outlet	4946774	25/07/2024 09:46	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4946774	25/07/2024 09:46	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4946774	25/07/2024 09:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4946774	25/07/2024 09:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4946774	25/07/2024 09:46	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4946774	25/07/2024 09:46	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4946774	25/07/2024 09:46	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4946774	25/07/2024 09:46	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4946774	25/07/2024 09:46	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4946774	25/07/2024 09:46	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4946774	25/07/2024 09:46	Free - Residual disinfectant	mg Cl/l	0.98	
W4523OUT	Lough Macrory Final Water Outlet	4946774	25/07/2024 09:46	Free - Residual disinfectant	mg Cl/l	0.98	
W4523OUT	Lough Macrory Final Water Outlet	4946774	25/07/2024 09:46	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4946774	25/07/2024 09:46	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4946774	25/07/2024 09:46	Total - Residual disinfectant	mg Cl/l	1.07	
W4523OUT	Lough Macrory Final Water Outlet	4946774	25/07/2024 09:46	Total - Residual disinfectant	mg Cl/l	1.07	
W4523OUT	Lough Macrory Final Water Outlet	4946774	25/07/2024 09:46	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4946774	25/07/2024 09:46	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4946774	25/07/2024 09:46	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4946774	25/07/2024 09:46	Turbidity	NTU	<0.09	1
W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	Colony Counts 22	CFU/1 ml	0	
W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	Colour	mg/l Pt/Co	<4.56	20
W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	Conductivity	uS/cm 20 C	360	2500
W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	E. coli	CFU/100 ml	0	0
W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	Free - Residual disinfectant	mg Cl/l	0.39	
W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	Hydrogen Ion	pH value	7.8	9.5
W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	Nitrite	mg/l	<0.03	0.1
W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	Total - Residual disinfectant	mg Cl/l	0.46	
W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	Total Coliforms	CFU/100 ml	0	0
W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	Turbidity	NTU	<0.09	1
W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	Aluminium	ug Al/l	27	200
W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	Antimony	ug/l Sb	0.23	5
W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	Arsenic	ug/l As	1.2	10
W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	Boron	mg/l B	<0.0586	1000
W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	Cadmium	ug/l Cd	0.15	5
W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	Chromium	ug/l Cr	1.6	50
W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	Iron	ug/l Fe	17	200

W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	Manganese	ug Mn/l	1.1	50
W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	Radon	Bq/l	<10	
W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	Selenium	ug/l Se	0.29	10
W1316OUT	Money more Borewell Final Water Outlet	4946798	25/07/2024 10:23	Total Organic Carbon	mg C/l	2	
W2514OUT	Seagahan Final Water Outlet	4946779	25/07/2024 10:41	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4946779	25/07/2024 10:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4946779	25/07/2024 10:41	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4946779	25/07/2024 10:41	Conductivity	uS/cm 20 C	230	2500
W2514OUT	Seagahan Final Water Outlet	4946779	25/07/2024 10:41	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4946779	25/07/2024 10:41	Free - Residual disinfectant	mg Cl/l	1.04	
W2514OUT	Seagahan Final Water Outlet	4946779	25/07/2024 10:41	Hydrogen Ion	pH value	7.3	9.5
W2514OUT	Seagahan Final Water Outlet	4946779	25/07/2024 10:41	Total - Residual disinfectant	mg Cl/l	1.24	
W2514OUT	Seagahan Final Water Outlet	4946779	25/07/2024 10:41	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4946779	25/07/2024 10:41	Turbidity	NTU	0.12	1
W1301POUT	Moyola PPP Final Water Outlet	4946789	25/07/2024 10:57	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4946789	25/07/2024 10:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4946789	25/07/2024 10:57	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4946789	25/07/2024 10:57	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4946789	25/07/2024 10:57	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4946789	25/07/2024 10:57	Free - Residual disinfectant	mg Cl/l	1.44	
W1301POUT	Moyola PPP Final Water Outlet	4946789	25/07/2024 10:57	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4946789	25/07/2024 10:57	Total - Residual disinfectant	mg Cl/l	1.69	
W1301POUT	Moyola PPP Final Water Outlet	4946789	25/07/2024 10:57	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4946789	25/07/2024 10:57	Turbidity	NTU	0.1	1
W2308POUT	Castor Bay PPP Final Water Outlet	4946941	26/07/2024 07:59	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4946941	26/07/2024 07:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4946941	26/07/2024 07:59	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4946941	26/07/2024 07:59	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4946941	26/07/2024 07:59	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4946941	26/07/2024 07:59	Free - Residual disinfectant	mg Cl/l	1.46	
W2308POUT	Castor Bay PPP Final Water Outlet	4946941	26/07/2024 07:59	Hydrogen Ion	pH value	7.8	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4946941	26/07/2024 07:59	Total - Residual disinfectant	mg Cl/l	1.62	
W2308POUT	Castor Bay PPP Final Water Outlet	4946941	26/07/2024 07:59	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4946941	26/07/2024 07:59	Turbidity	NTU	0.12	1
W1302OUT	Lough Fea Final Water Outlet	4946935	26/07/2024 09:35	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4946935	26/07/2024 09:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4946935	26/07/2024 09:35	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4946935	26/07/2024 09:35	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4946935	26/07/2024 09:35	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4946935	26/07/2024 09:35	Free - Residual disinfectant	mg Cl/l	0.82	
W1302OUT	Lough Fea Final Water Outlet	4946935	26/07/2024 09:35	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4946935	26/07/2024 09:35	Total - Residual disinfectant	mg Cl/l	0.89	

W1302OUT	Lough Fea Final Water Outlet	4946935	26/07/2024 09:35	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4946935	26/07/2024 09:35	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4946942	26/07/2024 10:17	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4946942	26/07/2024 10:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4946942	26/07/2024 10:17	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4946942	26/07/2024 10:17	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4946942	26/07/2024 10:17	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4946942	26/07/2024 10:17	Free - Residual disinfectant	mg Cl/l	1.49	
W1301POUT	Moyola PPP Final Water Outlet	4946942	26/07/2024 10:17	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4946942	26/07/2024 10:17	Total - Residual disinfectant	mg Cl/l	1.56	
W1301POUT	Moyola PPP Final Water Outlet	4946942	26/07/2024 10:17	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4946942	26/07/2024 10:17	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4946937	26/07/2024 11:49	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4946937	26/07/2024 11:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4946937	26/07/2024 11:49	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4946937	26/07/2024 11:49	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4946937	26/07/2024 11:49	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4946937	26/07/2024 11:49	Free - Residual disinfectant	mg Cl/l	1.57	
W4701OUT	Killyhevlin Final Water Outlet	4946937	26/07/2024 11:49	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4946937	26/07/2024 11:49	Total - Residual disinfectant	mg Cl/l	1.66	
W4701OUT	Killyhevlin Final Water Outlet	4946937	26/07/2024 11:49	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4946937	26/07/2024 11:49	Turbidity	NTU	0.19	1
W4701OUT	Killyhevlin Final Water Outlet	4947022	27/07/2024 08:33	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4947022	27/07/2024 08:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4947022	27/07/2024 08:33	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4947022	27/07/2024 08:33	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4947022	27/07/2024 08:33	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4947022	27/07/2024 08:33	Free - Residual disinfectant	mg Cl/l	1.06	
W4701OUT	Killyhevlin Final Water Outlet	4947022	27/07/2024 08:33	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4947022	27/07/2024 08:33	Total - Residual disinfectant	mg Cl/l	1.18	
W4701OUT	Killyhevlin Final Water Outlet	4947022	27/07/2024 08:33	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4947022	27/07/2024 08:33	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4947026	27/07/2024 09:18	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4947026	27/07/2024 09:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4947026	27/07/2024 09:18	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4947026	27/07/2024 09:18	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4947026	27/07/2024 09:18	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4947026	27/07/2024 09:18	Free - Residual disinfectant	mg Cl/l	1.22	
W1301POUT	Moyola PPP Final Water Outlet	4947026	27/07/2024 09:18	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4947026	27/07/2024 09:18	Total - Residual disinfectant	mg Cl/l	1.24	
W1301POUT	Moyola PPP Final Water Outlet	4947026	27/07/2024 09:18	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4947026	27/07/2024 09:18	Turbidity	NTU	<0.09	1

W1302OUT	Lough Fea Final Water Outlet	4947021	27/07/2024 09:50	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4947021	27/07/2024 09:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4947021	27/07/2024 09:50	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4947021	27/07/2024 09:50	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4947021	27/07/2024 09:50	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4947021	27/07/2024 09:50	Free - Residual disinfectant	mg Cl/l	0.72	
W1302OUT	Lough Fea Final Water Outlet	4947021	27/07/2024 09:50	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4947021	27/07/2024 09:50	Total - Residual disinfectant	mg Cl/l	0.79	
W1302OUT	Lough Fea Final Water Outlet	4947021	27/07/2024 09:50	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4947021	27/07/2024 09:50	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4947025	27/07/2024 12:02	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4947025	27/07/2024 12:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4947025	27/07/2024 12:02	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4947025	27/07/2024 12:02	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4947025	27/07/2024 12:02	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4947025	27/07/2024 12:02	Free - Residual disinfectant	mg Cl/l	1.58	
W2308POUT	Castor Bay PPP Final Water Outlet	4947025	27/07/2024 12:02	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4947025	27/07/2024 12:02	Total - Residual disinfectant	mg Cl/l	1.73	
W2308POUT	Castor Bay PPP Final Water Outlet	4947025	27/07/2024 12:02	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4947025	27/07/2024 12:02	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4947040	28/07/2024 08:27	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4947040	28/07/2024 08:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4947040	28/07/2024 08:27	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4947040	28/07/2024 08:27	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4947040	28/07/2024 08:27	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4947040	28/07/2024 08:27	Free - Residual disinfectant	mg Cl/l	1.38	
W4701OUT	Killyhevlin Final Water Outlet	4947040	28/07/2024 08:27	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4947040	28/07/2024 08:27	Total - Residual disinfectant	mg Cl/l	1.51	
W4701OUT	Killyhevlin Final Water Outlet	4947040	28/07/2024 08:27	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4947040	28/07/2024 08:27	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4947044	28/07/2024 10:07	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4947044	28/07/2024 10:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4947044	28/07/2024 10:07	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4947044	28/07/2024 10:07	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4947044	28/07/2024 10:07	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4947044	28/07/2024 10:07	Free - Residual disinfectant	mg Cl/l	1.25	
W1301POUT	Moyola PPP Final Water Outlet	4947044	28/07/2024 10:07	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4947044	28/07/2024 10:07	Total - Residual disinfectant	mg Cl/l	1.54	
W1301POUT	Moyola PPP Final Water Outlet	4947044	28/07/2024 10:07	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4947044	28/07/2024 10:07	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4947039	28/07/2024 10:39	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4947039	28/07/2024 10:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	

W1302OUT	Lough Fea Final Water Outlet	4947039	28/07/2024 10:39	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4947039	28/07/2024 10:39	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4947039	28/07/2024 10:39	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4947039	28/07/2024 10:39	Free - Residual disinfectant	mg Cl/l	0.68	
W1302OUT	Lough Fea Final Water Outlet	4947039	28/07/2024 10:39	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4947039	28/07/2024 10:39	Total - Residual disinfectant	mg Cl/l	0.76	
W1302OUT	Lough Fea Final Water Outlet	4947039	28/07/2024 10:39	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4947039	28/07/2024 10:39	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4947043	28/07/2024 11:51	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4947043	28/07/2024 11:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4947043	28/07/2024 11:51	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4947043	28/07/2024 11:51	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4947043	28/07/2024 11:51	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4947043	28/07/2024 11:51	Free - Residual disinfectant	mg Cl/l	1.52	
W2308POUT	Castor Bay PPP Final Water Outlet	4947043	28/07/2024 11:51	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4947043	28/07/2024 11:51	Total - Residual disinfectant	mg Cl/l	1.68	
W2308POUT	Castor Bay PPP Final Water Outlet	4947043	28/07/2024 11:51	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4947043	28/07/2024 11:51	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4949330	29/07/2024 08:20	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4949330	29/07/2024 08:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4949330	29/07/2024 08:20	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4949330	29/07/2024 08:20	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4949330	29/07/2024 08:20	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4949330	29/07/2024 08:20	Free - Residual disinfectant	mg Cl/l	1.27	
W2308POUT	Castor Bay PPP Final Water Outlet	4949330	29/07/2024 08:20	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4949330	29/07/2024 08:20	Total - Residual disinfectant	mg Cl/l	1.32	
W2308POUT	Castor Bay PPP Final Water Outlet	4949330	29/07/2024 08:20	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4949330	29/07/2024 08:20	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4949330	29/07/2024 08:20	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4949330	29/07/2024 08:20	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4949330	29/07/2024 08:20	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4949330	29/07/2024 08:20	Taste - Nature		No taste	
W1302OUT	Lough Fea Final Water Outlet	4949305	29/07/2024 09:53	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4949305	29/07/2024 09:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4949305	29/07/2024 09:53	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4949305	29/07/2024 09:53	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4949305	29/07/2024 09:53	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4949305	29/07/2024 09:53	Free - Residual disinfectant	mg Cl/l	0.8	
W1302OUT	Lough Fea Final Water Outlet	4949305	29/07/2024 09:53	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4949305	29/07/2024 09:53	Total - Residual disinfectant	mg Cl/l	0.88	
W1302OUT	Lough Fea Final Water Outlet	4949305	29/07/2024 09:53	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4949305	29/07/2024 09:53	Turbidity	NTU	<0.09	1

W1302OUT	Lough Fea Final Water Outlet	4949305	29/07/2024 09:53	Aluminium	ug Al/l	43	200
W1302OUT	Lough Fea Final Water Outlet	4949305	29/07/2024 09:53	Bromodichloromethane	ug/l	9.6	
W1302OUT	Lough Fea Final Water Outlet	4949305	29/07/2024 09:53	Bromoform	ug/l	<3.5	
W1302OUT	Lough Fea Final Water Outlet	4949305	29/07/2024 09:53	Chloroform	ug/l	51	
W1302OUT	Lough Fea Final Water Outlet	4949305	29/07/2024 09:53	Dibromochloromethane	ug/l	<1.6	
W1302OUT	Lough Fea Final Water Outlet	4949305	29/07/2024 09:53	Iron	ug/l Fe	5.3	200
W1302OUT	Lough Fea Final Water Outlet	4949305	29/07/2024 09:53	Manganese	ug Mn/l	1.2	50
W1302OUT	Lough Fea Final Water Outlet	4949305	29/07/2024 09:53	Total Organic Carbon	mg C/l	1.9	
W1302OUT	Lough Fea Final Water Outlet	4949305	29/07/2024 09:53	Total Trihalomethanes	ug/l	62	100
W1302OUT	Lough Fea Final Water Outlet	4949305	29/07/2024 09:53	WHO Index		0.35	1
W4523OUT	Lough Macrory Final Water Outlet	4949306	29/07/2024 10:29	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4949306	29/07/2024 10:29	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4949306	29/07/2024 10:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4949306	29/07/2024 10:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4949306	29/07/2024 10:29	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4949306	29/07/2024 10:29	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4949306	29/07/2024 10:29	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4949306	29/07/2024 10:29	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4949306	29/07/2024 10:29	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4949306	29/07/2024 10:29	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4949306	29/07/2024 10:29	Free - Residual disinfectant	mg Cl/l	0.88	
W4523OUT	Lough Macrory Final Water Outlet	4949306	29/07/2024 10:29	Free - Residual disinfectant	mg Cl/l	0.88	
W4523OUT	Lough Macrory Final Water Outlet	4949306	29/07/2024 10:29	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4949306	29/07/2024 10:29	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4949306	29/07/2024 10:29	Total - Residual disinfectant	mg Cl/l	0.95	
W4523OUT	Lough Macrory Final Water Outlet	4949306	29/07/2024 10:29	Total - Residual disinfectant	mg Cl/l	0.95	
W4523OUT	Lough Macrory Final Water Outlet	4949306	29/07/2024 10:29	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4949306	29/07/2024 10:29	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4949306	29/07/2024 10:29	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4949306	29/07/2024 10:29	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4949312	29/07/2024 10:39	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4949312	29/07/2024 10:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4949312	29/07/2024 10:39	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4949312	29/07/2024 10:39	Conductivity	uS/cm 20 C	400	2500
W2514OUT	Seagahan Final Water Outlet	4949312	29/07/2024 10:39	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4949312	29/07/2024 10:39	Free - Residual disinfectant	mg Cl/l	1.11	
W2514OUT	Seagahan Final Water Outlet	4949312	29/07/2024 10:39	Hydrogen Ion	pH value	7.6	9.5
W2514OUT	Seagahan Final Water Outlet	4949312	29/07/2024 10:39	Total - Residual disinfectant	mg Cl/l	1.31	
W2514OUT	Seagahan Final Water Outlet	4949312	29/07/2024 10:39	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4949312	29/07/2024 10:39	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4949332	29/07/2024 10:45	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4949332	29/07/2024 10:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	

W1301POUT	Moyola PPP Final Water Outlet	4949332	29/07/2024 10:45	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4949332	29/07/2024 10:45	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4949332	29/07/2024 10:45	E. coli	CFU/100 ml	1	0
W1301POUT	Moyola PPP Final Water Outlet	4949332	29/07/2024 10:45	Free - Residual disinfectant	mg Cl/l	1.53	
W1301POUT	Moyola PPP Final Water Outlet	4949332	29/07/2024 10:45	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4949332	29/07/2024 10:45	Total - Residual disinfectant	mg Cl/l	1.7	
W1301POUT	Moyola PPP Final Water Outlet	4949332	29/07/2024 10:45	Total Coliforms	CFU/100 ml	1	0
W1301POUT	Moyola PPP Final Water Outlet	4949332	29/07/2024 10:45	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4949320	29/07/2024 11:38	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4949320	29/07/2024 11:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4949320	29/07/2024 11:38	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4949320	29/07/2024 11:38	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4949320	29/07/2024 11:38	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4949320	29/07/2024 11:38	Free - Residual disinfectant	mg Cl/l	1.67	
W4701OUT	Killyhevlin Final Water Outlet	4949320	29/07/2024 11:38	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4949320	29/07/2024 11:38	Total - Residual disinfectant	mg Cl/l	1.73	
W4701OUT	Killyhevlin Final Water Outlet	4949320	29/07/2024 11:38	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4949320	29/07/2024 11:38	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Free - Residual disinfectant	mg Cl/l	1.44	
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Total - Residual disinfectant	mg Cl/l	1.56	
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Algae Diatom Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Algae Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Aluminium	ug Al/l	26	200
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Bromodichloromethane	ug/l	7.9	
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Chloroform	ug/l	13	
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Dibromochloromethane	ug/l	4.6	
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Iron	ug/l Fe	<1.538	200
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Manganese	ug Mn/l	<0.642	50

W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	MIB	ng/l	<1.9	
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Microcystin-LR	ug/l	<0.024	
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Second most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Third most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Total Organic Carbon	mg C/l	2.8	
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	Total Trihalomethanes	ug/l	26	100
W2308POUT	Castor Bay PPP Final Water Outlet	4949621	30/07/2024 08:11	WHO Index		0.23	1
W4701OUT	Killyhevlin Final Water Outlet	4949615	30/07/2024 09:02	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4949615	30/07/2024 09:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4949615	30/07/2024 09:02	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4949615	30/07/2024 09:02	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4949615	30/07/2024 09:02	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4949615	30/07/2024 09:02	Free - Residual disinfectant	mg Cl/l	1.48	
W4701OUT	Killyhevlin Final Water Outlet	4949615	30/07/2024 09:02	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4949615	30/07/2024 09:02	Total - Residual disinfectant	mg Cl/l	1.59	
W4701OUT	Killyhevlin Final Water Outlet	4949615	30/07/2024 09:02	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4949615	30/07/2024 09:02	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4949615	30/07/2024 09:02	Algae Blue Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4949615	30/07/2024 09:02	Algae Diatom Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4949615	30/07/2024 09:02	Algae Flagellate Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4949615	30/07/2024 09:02	Algae Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4949615	30/07/2024 09:02	Algae Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4949615	30/07/2024 09:02	Aluminium	ug Al/l	30	200
W4701OUT	Killyhevlin Final Water Outlet	4949615	30/07/2024 09:02	Iron	ug/l Fe	3.2	200
W4701OUT	Killyhevlin Final Water Outlet	4949615	30/07/2024 09:02	Manganese	ug Mn/l	3.1	50
W4701OUT	Killyhevlin Final Water Outlet	4949615	30/07/2024 09:02	Most numerous Algae		-	
W4701OUT	Killyhevlin Final Water Outlet	4949615	30/07/2024 09:02	Second most numerous Algae		-	
W4701OUT	Killyhevlin Final Water Outlet	4949615	30/07/2024 09:02	Third most numerous Algae		-	
W4701OUT	Killyhevlin Final Water Outlet	4949615	30/07/2024 09:02	Total Organic Carbon	mg C/l	2.7	
W1302OUT	Lough Fea Final Water Outlet	4949605	30/07/2024 09:55	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4949605	30/07/2024 09:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4949605	30/07/2024 09:55	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4949605	30/07/2024 09:55	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4949605	30/07/2024 09:55	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4949605	30/07/2024 09:55	Free - Residual disinfectant	mg Cl/l	0.78	
W1302OUT	Lough Fea Final Water Outlet	4949605	30/07/2024 09:55	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4949605	30/07/2024 09:55	Total - Residual disinfectant	mg Cl/l	0.88	

W1302OUT	Lough Fea Final Water Outlet	4949605	30/07/2024 09:55	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4949605	30/07/2024 09:55	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4949606	30/07/2024 10:37	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4949606	30/07/2024 10:37	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4949606	30/07/2024 10:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4949606	30/07/2024 10:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4949606	30/07/2024 10:37	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4949606	30/07/2024 10:37	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4949606	30/07/2024 10:37	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4949606	30/07/2024 10:37	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4949606	30/07/2024 10:37	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4949606	30/07/2024 10:37	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4949606	30/07/2024 10:37	Free - Residual disinfectant	mg Cl/l	0.91	
W4523OUT	Lough Macrory Final Water Outlet	4949606	30/07/2024 10:37	Free - Residual disinfectant	mg Cl/l	0.91	
W4523OUT	Lough Macrory Final Water Outlet	4949606	30/07/2024 10:37	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4949606	30/07/2024 10:37	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4949606	30/07/2024 10:37	Total - Residual disinfectant	mg Cl/l	0.99	
W4523OUT	Lough Macrory Final Water Outlet	4949606	30/07/2024 10:37	Total - Residual disinfectant	mg Cl/l	0.99	
W4523OUT	Lough Macrory Final Water Outlet	4949606	30/07/2024 10:37	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4949606	30/07/2024 10:37	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4949606	30/07/2024 10:37	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4949606	30/07/2024 10:37	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4949609	30/07/2024 10:52	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4949609	30/07/2024 10:52	Colony Counts 37 (48hrs)	CFU/1 ml	1	
W2514OUT	Seagahan Final Water Outlet	4949609	30/07/2024 10:52	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4949609	30/07/2024 10:52	Conductivity	uS/cm 20 C	410	2500
W2514OUT	Seagahan Final Water Outlet	4949609	30/07/2024 10:52	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4949609	30/07/2024 10:52	Free - Residual disinfectant	mg Cl/l	1.13	
W2514OUT	Seagahan Final Water Outlet	4949609	30/07/2024 10:52	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4949609	30/07/2024 10:52	Total - Residual disinfectant	mg Cl/l	1.35	
W2514OUT	Seagahan Final Water Outlet	4949609	30/07/2024 10:52	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4949609	30/07/2024 10:52	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Free - Residual disinfectant	mg Cl/l	1.58	
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Total - Residual disinfectant	mg Cl/l	1.62	
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Turbidity	NTU	<0.09	1

W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	2,4-D	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	2,4-DB	ug/l	<0.016	0.1
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Algae Blue Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Algae Diatom Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Algae Flagellate Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Algae Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Algae Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Aluminium	ug Al/l	37	200
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Asulam	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Bentazone	ug/l	<0.0044	0.1
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Bromoxynil	ug/l	<0.0079	0.1
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Clopyralid	ug/l	<0.0097	0.1
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Dichlorprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Geosmin	ng/l	<1.1	
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Iron	ug/l Fe	<1.538	200
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Manganese	ug Mn/l	<0.642	50
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	MCPA	ug/l	0.0098	0.1
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	MCPB	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Mecoprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	MIB	ng/l	<1.9	
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Microcystin-LR	ug/l	<0.024	
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Propyzamide	ug/l	<0.012	0.1
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Second most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Taste - Nature		No taste	
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Third most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Total Organic Carbon	mg C/l	2.7	
W1301POUT	Moyola PPP Final Water Outlet	4949625	30/07/2024 11:02	Triclopyr	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4949794	31/07/2024 07:03	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4949794	31/07/2024 07:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4949794	31/07/2024 07:03	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4949794	31/07/2024 07:03	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4949794	31/07/2024 07:03	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4949794	31/07/2024 07:03	Free - Residual disinfectant	mg Cl/l	1.42	
W2308POUT	Castor Bay PPP Final Water Outlet	4949794	31/07/2024 07:03	Hydrogen Ion	pH value	7.7	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4949794	31/07/2024 07:03	Total - Residual disinfectant	mg Cl/l	1.49	
W2308POUT	Castor Bay PPP Final Water Outlet	4949794	31/07/2024 07:03	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4949794	31/07/2024 07:03	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4949794	31/07/2024 07:03	Odour	Diln No	0	0

W2308POUT	Castor Bay PPP Final Water Outlet	4949794	31/07/2024 07:03	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4949794	31/07/2024 07:03	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4949794	31/07/2024 07:03	Taste - Nature		No taste	
W4701OUT	Killyhevlin Final Water Outlet	4949789	31/07/2024 09:37	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4949789	31/07/2024 09:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4949789	31/07/2024 09:37	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4949789	31/07/2024 09:37	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4949789	31/07/2024 09:37	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4949789	31/07/2024 09:37	Free - Residual disinfectant	mg Cl/l	1.49	
W4701OUT	Killyhevlin Final Water Outlet	4949789	31/07/2024 09:37	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4949789	31/07/2024 09:37	Total - Residual disinfectant	mg Cl/l	1.61	
W4701OUT	Killyhevlin Final Water Outlet	4949789	31/07/2024 09:37	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4949789	31/07/2024 09:37	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4949782	31/07/2024 09:53	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4949782	31/07/2024 09:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4949782	31/07/2024 09:53	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4949782	31/07/2024 09:53	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4949782	31/07/2024 09:53	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4949782	31/07/2024 09:53	Free - Residual disinfectant	mg Cl/l	0.75	
W1302OUT	Lough Fea Final Water Outlet	4949782	31/07/2024 09:53	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4949782	31/07/2024 09:53	Total - Residual disinfectant	mg Cl/l	0.86	
W1302OUT	Lough Fea Final Water Outlet	4949782	31/07/2024 09:53	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4949782	31/07/2024 09:53	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4949796	31/07/2024 10:36	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4949796	31/07/2024 10:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4949796	31/07/2024 10:36	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4949796	31/07/2024 10:36	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4949796	31/07/2024 10:36	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4949796	31/07/2024 10:36	Free - Residual disinfectant	mg Cl/l	1.41	
W1301POUT	Moyola PPP Final Water Outlet	4949796	31/07/2024 10:36	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4949796	31/07/2024 10:36	Total - Residual disinfectant	mg Cl/l	1.55	
W1301POUT	Moyola PPP Final Water Outlet	4949796	31/07/2024 10:36	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4949796	31/07/2024 10:36	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4949783	31/07/2024 10:51	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4949783	31/07/2024 10:51	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4949783	31/07/2024 10:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4949783	31/07/2024 10:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4949783	31/07/2024 10:51	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4949783	31/07/2024 10:51	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4949783	31/07/2024 10:51	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4949783	31/07/2024 10:51	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4949783	31/07/2024 10:51	E. coli	CFU/100 ml	0	0

W4523OUT	Lough Macrory Final Water Outlet	4949783	31/07/2024 10:51	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4949783	31/07/2024 10:51	Free - Residual disinfectant	mg Cl/l	0.81	
W4523OUT	Lough Macrory Final Water Outlet	4949783	31/07/2024 10:51	Free - Residual disinfectant	mg Cl/l	0.81	
W4523OUT	Lough Macrory Final Water Outlet	4949783	31/07/2024 10:51	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4949783	31/07/2024 10:51	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4949783	31/07/2024 10:51	Total - Residual disinfectant	mg Cl/l	0.87	
W4523OUT	Lough Macrory Final Water Outlet	4949783	31/07/2024 10:51	Total - Residual disinfectant	mg Cl/l	0.87	
W4523OUT	Lough Macrory Final Water Outlet	4949783	31/07/2024 10:51	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4949783	31/07/2024 10:51	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4949783	31/07/2024 10:51	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4949783	31/07/2024 10:51	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4949786	31/07/2024 11:22	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4949786	31/07/2024 11:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4949786	31/07/2024 11:22	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4949786	31/07/2024 11:22	Conductivity	uS/cm 20 C	410	2500
W2514OUT	Seagahan Final Water Outlet	4949786	31/07/2024 11:22	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4949786	31/07/2024 11:22	Free - Residual disinfectant	mg Cl/l	1.29	
W2514OUT	Seagahan Final Water Outlet	4949786	31/07/2024 11:22	Hydrogen Ion	pH value	7.6	9.5
W2514OUT	Seagahan Final Water Outlet	4949786	31/07/2024 11:22	Total - Residual disinfectant	mg Cl/l	1.5	
W2514OUT	Seagahan Final Water Outlet	4949786	31/07/2024 11:22	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4949786	31/07/2024 11:22	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4949786	31/07/2024 11:22	Algae Blue Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4949786	31/07/2024 11:22	Algae Diatom Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4949786	31/07/2024 11:22	Algae Flagellate Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4949786	31/07/2024 11:22	Algae Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4949786	31/07/2024 11:22	Algae Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4949786	31/07/2024 11:22	Aluminium	ug Al/l	<3.089	200
W2514OUT	Seagahan Final Water Outlet	4949786	31/07/2024 11:22	Iron	ug/l Fe	<1.538	200
W2514OUT	Seagahan Final Water Outlet	4949786	31/07/2024 11:22	Manganese	ug Mn/l	<0.642	50
W2514OUT	Seagahan Final Water Outlet	4949786	31/07/2024 11:22	Most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4949786	31/07/2024 11:22	Second most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4949786	31/07/2024 11:22	Third most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4949786	31/07/2024 11:22	Total Organic Carbon	mg C/l	2.6	
W4701OUT	Killyhevlin Final Water Outlet	4949956	01/08/2024 09:07	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4949956	01/08/2024 09:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4949956	01/08/2024 09:07	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4949956	01/08/2024 09:07	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4949956	01/08/2024 09:07	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4949956	01/08/2024 09:07	Free - Residual disinfectant	mg Cl/l	1.32	
W4701OUT	Killyhevlin Final Water Outlet	4949956	01/08/2024 09:07	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4949956	01/08/2024 09:07	Total - Residual disinfectant	mg Cl/l	1.44	
W4701OUT	Killyhevlin Final Water Outlet	4949956	01/08/2024 09:07	Total Coliforms	CFU/100 ml	0	0

W4701OUT	Killyhevlin Final Water Outlet	4949956	01/08/2024 09:07	Turbidity	NTU	0.092	1
W1302OUT	Lough Fea Final Water Outlet	4949948	01/08/2024 09:48	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4949948	01/08/2024 09:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4949948	01/08/2024 09:48	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4949948	01/08/2024 09:48	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4949948	01/08/2024 09:48	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4949948	01/08/2024 09:48	Free - Residual disinfectant	mg Cl/l	0.8	
W1302OUT	Lough Fea Final Water Outlet	4949948	01/08/2024 09:48	Hydrogen Ion	pH value	7.1	9.5
W1302OUT	Lough Fea Final Water Outlet	4949948	01/08/2024 09:48	Total - Residual disinfectant	mg Cl/l	0.92	
W1302OUT	Lough Fea Final Water Outlet	4949948	01/08/2024 09:48	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4949948	01/08/2024 09:48	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4949961	01/08/2024 09:56	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4949961	01/08/2024 09:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4949961	01/08/2024 09:56	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4949961	01/08/2024 09:56	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4949961	01/08/2024 09:56	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4949961	01/08/2024 09:56	Free - Residual disinfectant	mg Cl/l	1.53	
W2308POUT	Castor Bay PPP Final Water Outlet	4949961	01/08/2024 09:56	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4949961	01/08/2024 09:56	Total - Residual disinfectant	mg Cl/l	1.7	
W2308POUT	Castor Bay PPP Final Water Outlet	4949961	01/08/2024 09:56	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4949961	01/08/2024 09:56	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4949962	01/08/2024 10:55	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4949962	01/08/2024 10:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4949962	01/08/2024 10:55	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4949962	01/08/2024 10:55	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4949962	01/08/2024 10:55	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4949962	01/08/2024 10:55	Free - Residual disinfectant	mg Cl/l	1.3	
W1301POUT	Moyola PPP Final Water Outlet	4949962	01/08/2024 10:55	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4949962	01/08/2024 10:55	Total - Residual disinfectant	mg Cl/l	1.46	
W1301POUT	Moyola PPP Final Water Outlet	4949962	01/08/2024 10:55	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4949962	01/08/2024 10:55	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4949951	01/08/2024 10:58	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4949951	01/08/2024 10:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4949951	01/08/2024 10:58	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4949951	01/08/2024 10:58	Conductivity	uS/cm 20 C	390	2500
W2514OUT	Seagahan Final Water Outlet	4949951	01/08/2024 10:58	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4949951	01/08/2024 10:58	Free - Residual disinfectant	mg Cl/l	1	
W2514OUT	Seagahan Final Water Outlet	4949951	01/08/2024 10:58	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4949951	01/08/2024 10:58	Total - Residual disinfectant	mg Cl/l	1.18	
W2514OUT	Seagahan Final Water Outlet	4949951	01/08/2024 10:58	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4949951	01/08/2024 10:58	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Colony Counts 22	CFU/1 ml	0	

W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Free - Residual disinfectant	mg Cl/l	0.95	
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Free - Residual disinfectant	mg Cl/l	0.95	
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Hydrogen Ion	pH value	7.4	9.5
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Hydrogen Ion	pH value	7.4	9.5
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Total - Residual disinfectant	mg Cl/l	1.07	
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Total - Residual disinfectant	mg Cl/l	1.07	
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Aluminium	ug Al/l	4.8	200
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Aluminium	ug Al/l	4.8	200
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Iron	ug/l Fe	<1.538	200
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Iron	ug/l Fe	<1.538	200
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Manganese	ug Mn/l	<0.642	50
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Manganese	ug Mn/l	<0.642	50
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Total Organic Carbon	mg C/l	1.8	
W4523OUT	Lough Macrory Final Water Outlet	4949949	01/08/2024 11:18	Total Organic Carbon	mg C/l	1.8	
W2308POUT	Castor Bay PPP Final Water Outlet	4950097	02/08/2024 08:07	Colony Counts 22	CFU/1 ml	1	
W2308POUT	Castor Bay PPP Final Water Outlet	4950097	02/08/2024 08:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4950097	02/08/2024 08:07	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4950097	02/08/2024 08:07	Conductivity	uS/cm 20 C	360	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4950097	02/08/2024 08:07	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4950097	02/08/2024 08:07	Free - Residual disinfectant	mg Cl/l	1.46	
W2308POUT	Castor Bay PPP Final Water Outlet	4950097	02/08/2024 08:07	Hydrogen Ion	pH value	7.7	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4950097	02/08/2024 08:07	Total - Residual disinfectant	mg Cl/l	1.63	
W2308POUT	Castor Bay PPP Final Water Outlet	4950097	02/08/2024 08:07	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4950097	02/08/2024 08:07	Turbidity	NTU	0.11	1
W1302OUT	Lough Fea Final Water Outlet	4950091	02/08/2024 08:32	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4950091	02/08/2024 08:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4950091	02/08/2024 08:32	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4950091	02/08/2024 08:32	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4950091	02/08/2024 08:32	E. coli	CFU/100 ml	0	0

W1302OUT	Lough Fea Final Water Outlet	4950091	02/08/2024 08:32	Free - Residual disinfectant	mg Cl/l	0.8	
W1302OUT	Lough Fea Final Water Outlet	4950091	02/08/2024 08:32	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4950091	02/08/2024 08:32	Total - Residual disinfectant	mg Cl/l	0.87	
W1302OUT	Lough Fea Final Water Outlet	4950091	02/08/2024 08:32	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4950091	02/08/2024 08:32	Turbidity	NTU	<0.09	1
W1316OUT	Money more Borewell Final Water Outlet	4950103	02/08/2024 09:13	Colony Counts 22	CFU/1 ml	0	
W1316OUT	Money more Borewell Final Water Outlet	4950103	02/08/2024 09:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1316OUT	Money more Borewell Final Water Outlet	4950103	02/08/2024 09:13	Colour	mg/l Pt/Co	<4.56	20
W1316OUT	Money more Borewell Final Water Outlet	4950103	02/08/2024 09:13	Conductivity	uS/cm 20 C	360	2500
W1316OUT	Money more Borewell Final Water Outlet	4950103	02/08/2024 09:13	E. coli	CFU/100 ml	0	0
W1316OUT	Money more Borewell Final Water Outlet	4950103	02/08/2024 09:13	Free - Residual disinfectant	mg Cl/l	0.4	
W1316OUT	Money more Borewell Final Water Outlet	4950103	02/08/2024 09:13	Hydrogen Ion	pH value	7.8	9.5
W1316OUT	Money more Borewell Final Water Outlet	4950103	02/08/2024 09:13	Total - Residual disinfectant	mg Cl/l	0.42	
W1316OUT	Money more Borewell Final Water Outlet	4950103	02/08/2024 09:13	Total Coliforms	CFU/100 ml	0	0
W1316OUT	Money more Borewell Final Water Outlet	4950103	02/08/2024 09:13	Turbidity	NTU	<0.09	1
W1316OUT	Money more Borewell Final Water Outlet	4950103	02/08/2024 09:13	Aluminium	ug Al/l	24	200
W1316OUT	Money more Borewell Final Water Outlet	4950103	02/08/2024 09:13	Antimony	ug/l Sb	0.11	5
W1316OUT	Money more Borewell Final Water Outlet	4950103	02/08/2024 09:13	Arsenic	ug/l As	1.2	10
W1316OUT	Money more Borewell Final Water Outlet	4950103	02/08/2024 09:13	Boron	mg/l B	<0.0586	1000
W1316OUT	Money more Borewell Final Water Outlet	4950103	02/08/2024 09:13	Cadmium	ug/l Cd	<0.042	5
W1316OUT	Money more Borewell Final Water Outlet	4950103	02/08/2024 09:13	Chromium	ug/l Cr	1.1	50
W1316OUT	Money more Borewell Final Water Outlet	4950103	02/08/2024 09:13	Iron	ug/l Fe	16	200
W1316OUT	Money more Borewell Final Water Outlet	4950103	02/08/2024 09:13	Manganese	ug Mn/l	<0.642	50
W1316OUT	Money more Borewell Final Water Outlet	4950103	02/08/2024 09:13	Selenium	ug/l Se	0.091	10
W1316OUT	Money more Borewell Final Water Outlet	4950103	02/08/2024 09:13	Total Organic Carbon	mg C/l	2	
W4701OUT	Killyhevlin Final Water Outlet	4950093	02/08/2024 09:19	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4950093	02/08/2024 09:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4950093	02/08/2024 09:19	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4950093	02/08/2024 09:19	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4950093	02/08/2024 09:19	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4950093	02/08/2024 09:19	Free - Residual disinfectant	mg Cl/l	1.75	
W4701OUT	Killyhevlin Final Water Outlet	4950093	02/08/2024 09:19	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4950093	02/08/2024 09:19	Total - Residual disinfectant	mg Cl/l	1.82	
W4701OUT	Killyhevlin Final Water Outlet	4950093	02/08/2024 09:19	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4950093	02/08/2024 09:19	Turbidity	NTU	0.12	1
W1301POUT	Moyola PPP Final Water Outlet	4950098	02/08/2024 10:08	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4950098	02/08/2024 10:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4950098	02/08/2024 10:08	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4950098	02/08/2024 10:08	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4950098	02/08/2024 10:08	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4950098	02/08/2024 10:08	Free - Residual disinfectant	mg Cl/l	1.45	
W1301POUT	Moyola PPP Final Water Outlet	4950098	02/08/2024 10:08	Hydrogen Ion	pH value	7.7	9.5

W1301POUT	Moyola PPP Final Water Outlet	4950098	02/08/2024 10:08	Total - Residual disinfectant	mg Cl/l	1.5	
W1301POUT	Moyola PPP Final Water Outlet	4950098	02/08/2024 10:08	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4950098	02/08/2024 10:08	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4950181	03/08/2024 06:55	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4950181	03/08/2024 06:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4950181	03/08/2024 06:55	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4950181	03/08/2024 06:55	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4950181	03/08/2024 06:55	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4950181	03/08/2024 06:55	Free - Residual disinfectant	mg Cl/l	1.48	
W2308POUT	Castor Bay PPP Final Water Outlet	4950181	03/08/2024 06:55	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4950181	03/08/2024 06:55	Total - Residual disinfectant	mg Cl/l	1.6	
W2308POUT	Castor Bay PPP Final Water Outlet	4950181	03/08/2024 06:55	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4950181	03/08/2024 06:55	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4950182	03/08/2024 08:44	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4950182	03/08/2024 08:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4950182	03/08/2024 08:44	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4950182	03/08/2024 08:44	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4950182	03/08/2024 08:44	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4950182	03/08/2024 08:44	Free - Residual disinfectant	mg Cl/l	1.07	
W1301POUT	Moyola PPP Final Water Outlet	4950182	03/08/2024 08:44	Hydrogen Ion	pH value	7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4950182	03/08/2024 08:44	Total - Residual disinfectant	mg Cl/l	1.17	
W1301POUT	Moyola PPP Final Water Outlet	4950182	03/08/2024 08:44	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4950182	03/08/2024 08:44	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4950177	03/08/2024 09:21	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4950177	03/08/2024 09:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4950177	03/08/2024 09:21	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4950177	03/08/2024 09:21	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4950177	03/08/2024 09:21	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4950177	03/08/2024 09:21	Free - Residual disinfectant	mg Cl/l	0.75	
W1302OUT	Lough Fea Final Water Outlet	4950177	03/08/2024 09:21	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4950177	03/08/2024 09:21	Total - Residual disinfectant	mg Cl/l	0.82	
W1302OUT	Lough Fea Final Water Outlet	4950177	03/08/2024 09:21	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4950177	03/08/2024 09:21	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4950178	03/08/2024 09:58	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4950178	03/08/2024 09:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4950178	03/08/2024 09:58	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4950178	03/08/2024 09:58	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4950178	03/08/2024 09:58	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4950178	03/08/2024 09:58	Free - Residual disinfectant	mg Cl/l	1.23	
W4701OUT	Killyhevlin Final Water Outlet	4950178	03/08/2024 09:58	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4950178	03/08/2024 09:58	Total - Residual disinfectant	mg Cl/l	1.31	
W4701OUT	Killyhevlin Final Water Outlet	4950178	03/08/2024 09:58	Total Coliforms	CFU/100 ml	0	0

W4701OUT	Killyhevlin Final Water Outlet	4950178	03/08/2024 09:58	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4950205	04/08/2024 07:50	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4950205	04/08/2024 07:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4950205	04/08/2024 07:50	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4950205	04/08/2024 07:50	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4950205	04/08/2024 07:50	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4950205	04/08/2024 07:50	Free - Residual disinfectant	mg Cl/l	1.39	
W2308POUT	Castor Bay PPP Final Water Outlet	4950205	04/08/2024 07:50	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4950205	04/08/2024 07:50	Total - Residual disinfectant	mg Cl/l	1.57	
W2308POUT	Castor Bay PPP Final Water Outlet	4950205	04/08/2024 07:50	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4950205	04/08/2024 07:50	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4950206	04/08/2024 08:29	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4950206	04/08/2024 08:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4950206	04/08/2024 08:29	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4950206	04/08/2024 08:29	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4950206	04/08/2024 08:29	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4950206	04/08/2024 08:29	Free - Residual disinfectant	mg Cl/l	1.56	
W1301POUT	Moyola PPP Final Water Outlet	4950206	04/08/2024 08:29	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4950206	04/08/2024 08:29	Total - Residual disinfectant	mg Cl/l	1.66	
W1301POUT	Moyola PPP Final Water Outlet	4950206	04/08/2024 08:29	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4950206	04/08/2024 08:29	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4950201	04/08/2024 09:04	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4950201	04/08/2024 09:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4950201	04/08/2024 09:04	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4950201	04/08/2024 09:04	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4950201	04/08/2024 09:04	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4950201	04/08/2024 09:04	Free - Residual disinfectant	mg Cl/l	0.9	
W1302OUT	Lough Fea Final Water Outlet	4950201	04/08/2024 09:04	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4950201	04/08/2024 09:04	Total - Residual disinfectant	mg Cl/l	0.95	
W1302OUT	Lough Fea Final Water Outlet	4950201	04/08/2024 09:04	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4950201	04/08/2024 09:04	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4950202	04/08/2024 10:21	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4950202	04/08/2024 10:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4950202	04/08/2024 10:21	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4950202	04/08/2024 10:21	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4950202	04/08/2024 10:21	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4950202	04/08/2024 10:21	Free - Residual disinfectant	mg Cl/l	1.42	
W4701OUT	Killyhevlin Final Water Outlet	4950202	04/08/2024 10:21	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4950202	04/08/2024 10:21	Total - Residual disinfectant	mg Cl/l	1.5	
W4701OUT	Killyhevlin Final Water Outlet	4950202	04/08/2024 10:21	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4950202	04/08/2024 10:21	Turbidity	NTU	0.12	1
W1301POUT	Moyola PPP Final Water Outlet	4952368	05/08/2024 07:15	Colony Counts 22	CFU/1 ml	0	

W1301POUT	Moyola PPP Final Water Outlet	4952368	05/08/2024 07:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4952368	05/08/2024 07:15	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4952368	05/08/2024 07:15	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4952368	05/08/2024 07:15	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4952368	05/08/2024 07:15	Free - Residual disinfectant	mg Cl/l	1.43	
W1301POUT	Moyola PPP Final Water Outlet	4952368	05/08/2024 07:15	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4952368	05/08/2024 07:15	Total - Residual disinfectant	mg Cl/l	1.55	
W1301POUT	Moyola PPP Final Water Outlet	4952368	05/08/2024 07:15	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4952368	05/08/2024 07:15	Turbidity	NTU	<0.09	1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	2,4-D	ug/l	<0.011	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	2,4-DB	ug/l	<0.016	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Asulam	ug/l	<0.015	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Bentazone	ug/l	<0.0044	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Bromoxynil	ug/l	<0.0079	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Chlorotoluron	ug/l	<0.0031	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Chlorpyrifos	ug/l	<0.0070	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Clopyralid	ug/l	<0.0097	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Colony Counts 22	CFU/1 ml	0	
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Colony Counts 37 (48hrs)	CFU/1 ml	8	
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Colour	mg/l Pt/Co	<4.56	20
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Conductivity	uS/cm 20 C	360	2500
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Cyanide	ug/l CN	<5.5	50
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Diazinon	ug/l	<0.0074	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Dicamba	ug/l	<0.028	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Dichlorprop	ug/l	<0.011	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Diflufenican	ug/l	<0.0072	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Dimethenamid	ug/l	<0.0063	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Diuron	ug/l	<0.0055	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	E. coli	CFU/100 ml	0	0
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Epoxiconazole	ug/l	<0.0049	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Fenpropimorph	ug/l	<0.0083	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Flufenacet	ug/l	<0.0052	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Fluroxypyr	ug/l	<0.0063	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Free - Residual disinfectant	mg Cl/l	0.32	
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Glyphosate	ug/l	<0.0077	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Hydrogen Ion	pH value	7.8	9.5
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Isoproturon	ug/l	<0.0025	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Linuron	ug/l	<0.0034	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	MCPA	ug/l	<0.0093	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	MCPB	ug/l	<0.015	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Mecoprop	ug/l	<0.011	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Metalaxyl	ug/l	<0.0097	0.1

W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Metamitron	ug/l	<0.0074	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Metazachlor	ug/l	<0.015	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Metoxuron	ug/l	<0.0080	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Metribuzin	ug/l	<0.0060	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Oxamyl	ug/l	<0.0023	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Pendimethalin	ug/l	<0.0064	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Pesticides - Total Substances	ug/l	0	0.5
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Phorate	ug/l	<0.0092	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Pirimicarb	ug/l	<0.0063	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Propachlor	ug/l	<0.0096	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Propiconazole	ug/l	<0.0029	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Propyzamide	ug/l	<0.012	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Prothioconazole	ug/l	<0.0019	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Tebuconazole	ug/l	<0.0039	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Total - Residual disinfectant	mg Cl/l	0.4	
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Total Coliforms	CFU/100 ml	0	0
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Triclopyr	ug/l	<0.012	0.1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Turbidity	NTU	<0.09	1
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Aluminium	ug Al/l	23	200
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Antimony	ug/l Sb	0.092	5
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Arsenic	ug/l As	1	10
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Boron	mg/l B	<0.0586	1000
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Bromodichloromethane	ug/l	15	
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Bromoform	ug/l	<3.5	
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Cadmium	ug/l Cd	<0.042	5
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Chloroform	ug/l	34	
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Chromium	ug/l Cr	1.2	50
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Dibromochloromethane	ug/l	6	
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Iron	ug/l Fe	18	200
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Manganese	ug Mn/l	<0.642	50
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Radon	Bq/l	<10	
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Selenium	ug/l Se	0.082	10
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Total Organic Carbon	mg C/l	2.3	
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	Total Trihalomethanes	ug/l	56	100
W1316OUT	Money more Borewell Final Water Outlet	4952379	05/08/2024 08:20	WHO Index		0.43	1
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Free - Residual disinfectant	mg Cl/l	1.66	
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Hydrogen Ion	pH value	7.8	9.5

W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Total - Residual disinfectant	mg Cl/l	1.71	
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952365	05/08/2024 08:27	Taste - Nature		No taste	
W1302OUT	Lough Fea Final Water Outlet	4952339	05/08/2024 09:14	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4952339	05/08/2024 09:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4952339	05/08/2024 09:14	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4952339	05/08/2024 09:14	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4952339	05/08/2024 09:14	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4952339	05/08/2024 09:14	Free - Residual disinfectant	mg Cl/l	0.66	
W1302OUT	Lough Fea Final Water Outlet	4952339	05/08/2024 09:14	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4952339	05/08/2024 09:14	Total - Residual disinfectant	mg Cl/l	0.73	
W1302OUT	Lough Fea Final Water Outlet	4952339	05/08/2024 09:14	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4952339	05/08/2024 09:14	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Free - Residual disinfectant	mg Cl/l	0.96	
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Free - Residual disinfectant	mg Cl/l	0.96	
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Total - Residual disinfectant	mg Cl/l	1.04	
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Total - Residual disinfectant	mg Cl/l	1.04	
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	2,4-D	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	2,4-D	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	2,4-DB	ug/l	<0.016	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	2,4-DB	ug/l	<0.016	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Aluminium	ug Al/l	6.6	200

W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Aluminium	ug Al/l	6.6	200
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Asulam	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Asulam	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Bentazone	ug/l	<0.0044	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Bentazone	ug/l	<0.0044	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Bromoxynil	ug/l	<0.0079	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Bromoxynil	ug/l	<0.0079	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Clopyralid	ug/l	<0.0097	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Clopyralid	ug/l	<0.0097	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Dichlorprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Dichlorprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Iron	ug/l Fe	<1.538	200
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Iron	ug/l Fe	<1.538	200
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Manganese	ug Mn/l	<0.80	50
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Manganese	ug Mn/l	<0.80	50
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	MCPA	ug/l	<0.0093	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	MCPA	ug/l	<0.0093	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	MCPB	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	MCPB	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Mecoprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Mecoprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Propyzamide	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Propyzamide	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Total Organic Carbon	mg C/l	1.9	
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Total Organic Carbon	mg C/l	1.9	
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Triclopyr	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4952340	05/08/2024 09:57	Triclopyr	ug/l	<0.012	0.1
W2514OUT	Seagahan Final Water Outlet	4952342	05/08/2024 11:18	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4952342	05/08/2024 11:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4952342	05/08/2024 11:18	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4952342	05/08/2024 11:18	Conductivity	uS/cm 20 C	400	2500
W2514OUT	Seagahan Final Water Outlet	4952342	05/08/2024 11:18	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4952342	05/08/2024 11:18	Free - Residual disinfectant	mg Cl/l	0.78	
W2514OUT	Seagahan Final Water Outlet	4952342	05/08/2024 11:18	Hydrogen Ion	pH value	7.6	9.5
W2514OUT	Seagahan Final Water Outlet	4952342	05/08/2024 11:18	Total - Residual disinfectant	mg Cl/l	0.99	
W2514OUT	Seagahan Final Water Outlet	4952342	05/08/2024 11:18	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4952342	05/08/2024 11:18	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4952353	05/08/2024 11:22	Colony Counts 22	CFU/1 ml	7	
W4701OUT	Killyhevlin Final Water Outlet	4952353	05/08/2024 11:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4952353	05/08/2024 11:22	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4952353	05/08/2024 11:22	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4952353	05/08/2024 11:22	E. coli	CFU/100 ml	0	0

W4701OUT	Killyhevlin Final Water Outlet	4952353	05/08/2024 11:22	Free - Residual disinfectant	mg Cl/l	1.39	
W4701OUT	Killyhevlin Final Water Outlet	4952353	05/08/2024 11:22	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4952353	05/08/2024 11:22	Total - Residual disinfectant	mg Cl/l	1.65	
W4701OUT	Killyhevlin Final Water Outlet	4952353	05/08/2024 11:22	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4952353	05/08/2024 11:22	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	2,4-D	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	2,4-DB	ug/l	<0.016	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Asulam	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Bentazone	ug/l	<0.0044	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Bromoxynil	ug/l	<0.0079	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Chlorotoluron	ug/l	<0.0031	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Chlorpyrifos	ug/l	<0.0070	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Clopyralid	ug/l	<0.0097	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Cyanide	ug/l CN	<5.5	50
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Diazinon	ug/l	<0.0074	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Dicamba	ug/l	<0.028	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Dichlorprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Di flufenican	ug/l	<0.0072	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Dimethenamid	ug/l	<0.0063	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Diuron	ug/l	<0.0055	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Epoxiconazole	ug/l	<0.0049	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Fenpropimorph	ug/l	<0.0083	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Flufenacet	ug/l	<0.0052	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Fluroxypyr	ug/l	<0.0063	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Free - Residual disinfectant	mg Cl/l	1.53	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Glyphosate	ug/l	<0.0077	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Hydrogen Ion	pH value	7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Isoproturon	ug/l	<0.0025	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Linuron	ug/l	<0.0034	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	MCPA	ug/l	<0.0093	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	MCPB	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Mecoprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Metalaxyl	ug/l	<0.0097	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Metamitron	ug/l	<0.0074	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Metazachlor	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Metoxuron	ug/l	<0.0080	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Metribuzin	ug/l	<0.0060	0.1

W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Oxamyl	ug/l	<0.0023	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Pendimethalin	ug/l	<0.0064	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Pesticides - Total Substances	ug/l	0	0.5
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Phorate	ug/l	<0.0092	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Pirimicarb	ug/l	<0.0063	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Propachlor	ug/l	<0.0096	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Propiconazole	ug/l	<0.0029	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Propyzamide	ug/l	<0.012	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Prothioconazole	ug/l	<0.0019	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Tebuconazole	ug/l	<0.0039	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Total - Residual disinfectant	mg Cl/l	1.88	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Triclopyr	ug/l	<0.012	0.1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Algae Blue Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Algae Diatom Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Algae Flagellate Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Algae Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Algae Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Aluminium	ug Al/l	31	200
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Geosmin	ng/l	<1.1	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Iron	ug/l Fe	3.3	200
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Manganese	ug Mn/l	<0.80	50
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	MIB	ng/l	<1.9	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Microcystin-LR	ug/l	<0.024	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Most numerous Algae		---	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Second most numerous Algae		---	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Third most numerous Algae		---	
W1301POUT	Moyola PPP Final Water Outlet	4952698	06/08/2024 07:56	Total Organic Carbon	mg C/l	2.8	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	2,4-D	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	2,4-DB	ug/l	<0.016	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Asulam	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Bentazone	ug/l	<0.0044	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Bromoxynil	ug/l	<0.0079	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Chlorotoluron	ug/l	<0.0031	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Chlorpyrifos	ug/l	<0.0070	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Clopyralid	ug/l	<0.0097	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Cyanide	ug/l CN	<5.5	50

W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Diazinon	ug/l	<0.0074	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Dicamba	ug/l	<0.028	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Dichlorprop	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Diflufenican	ug/l	<0.0072	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Dimethenamid	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Diuron	ug/l	<0.0055	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Epoxiconazole	ug/l	<0.0049	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Fenpropimorph	ug/l	<0.0083	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Flufenacet	ug/l	<0.0052	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Fluroxypyr	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Free - Residual disinfectant	mg Cl/l	1.53	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Glyphosate	ug/l	<0.0077	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Hydrogen Ion	pH value	7.8	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Isoproturon	ug/l	<0.0025	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Linuron	ug/l	<0.0034	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	MCPA	ug/l	0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	MCPB	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Mecoprop	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Metalaxyl	ug/l	<0.0097	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Metamitron	ug/l	<0.0074	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Metazachlor	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Metoxuron	ug/l	<0.0080	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Metribuzin	ug/l	<0.0060	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Oxamyl	ug/l	<0.0023	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Pendimethalin	ug/l	<0.0064	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Pesticides - Total Substances	ug/l	0.012	0.5
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Phorate	ug/l	<0.0092	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Pirimicarb	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Propachlor	ug/l	<0.0096	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Propiconazole	ug/l	<0.0029	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Propyzamide	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Prothioconazole	ug/l	<0.0019	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Tebuconazole	ug/l	<0.0039	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Total - Residual disinfectant	mg Cl/l	1.7	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Triclopyr	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Algae Diatom Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Algae Green Total	per ml	0	

W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Aluminium	ug Al/l	24	200
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Bromodichloromethane	ug/l	7.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Chloroform	ug/l	12	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Dibromochloromethane	ug/l	4.7	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Iron	ug/l Fe	<1.538	200
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Manganese	ug Mn/l	<0.80	50
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	MIB	ng/l	<1.9	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Microcystin-LR	ug/l	<0.024	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Most numerous Algae		---	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Second most numerous Algae		---	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Third most numerous Algae		---	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Total Organic Carbon	mg C/l	2.7	
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	Total Trihalomethanes	ug/l	24	100
W2308POUT	Castor Bay PPP Final Water Outlet	4952692	06/08/2024 08:08	WHO Index		0.21	1
W1316OUT	Moneymore Borewell Final Water Outlet	4963880	06/08/2024 08:37	Gross Alpha Activity	Bq/l	<0.04	
W1316OUT	Moneymore Borewell Final Water Outlet	4963880	06/08/2024 08:37	Gross Beta Activity	Bq/l	0.09	
W1316OUT	Moneymore Borewell Final Water Outlet	4963880	06/08/2024 08:37	Total Indicative Dose	mSv/year	<0.1	0.1
W1316OUT	Moneymore Borewell Final Water Outlet	4963880	06/08/2024 08:37	Tritium	Bq/l	<10	100
W2514OUT	Seagahan Final Water Outlet	4952683	06/08/2024 09:45	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4952683	06/08/2024 09:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4952683	06/08/2024 09:45	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4952683	06/08/2024 09:45	Conductivity	uS/cm 20 C	400	2500
W2514OUT	Seagahan Final Water Outlet	4952683	06/08/2024 09:45	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4952683	06/08/2024 09:45	Free - Residual disinfectant	mg Cl/l	1.06	
W2514OUT	Seagahan Final Water Outlet	4952683	06/08/2024 09:45	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4952683	06/08/2024 09:45	Total - Residual disinfectant	mg Cl/l	1.34	
W2514OUT	Seagahan Final Water Outlet	4952683	06/08/2024 09:45	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4952683	06/08/2024 09:45	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Free - Residual disinfectant	mg Cl/l	0.7	
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Hydrogen Ion	pH value	7.1	9.5

W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Total - Residual disinfectant	mg Cl/l	0.78	
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	2,4-D	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	2,4-DB	ug/l	<0.016	0.1
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Aluminium	ug Al/l	8.2	200
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Asulam	ug/l	<0.015	0.1
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Bentazone	ug/l	<0.0044	0.1
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Bromodichloromethane	ug/l	9.7	
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Bromoform	ug/l	<3.5	
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Bromoxynil	ug/l	<0.0079	0.1
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Chloroform	ug/l	48	
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Clopyralid	ug/l	<0.0097	0.1
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Dibromochloromethane	ug/l	<1.6	
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Dichlorprop	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Iron	ug/l Fe	<1.538	200
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Manganese	ug Mn/l	<0.80	50
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	MCPA	ug/l	<0.0093	0.1
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	MCPB	ug/l	<0.015	0.1
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Mecoprop	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Propyzamide	ug/l	<0.012	0.1
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Total Organic Carbon	mg C/l	1.8	
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Total Trihalomethanes	ug/l	60	100
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	Triclopyr	ug/l	<0.012	0.1
W1302OUT	Lough Fea Final Water Outlet	4952677	06/08/2024 09:46	WHO Index		0.34	1
W4523OUT	Lough Macrory Final Water Outlet	4952678	06/08/2024 10:23	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4952678	06/08/2024 10:23	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4952678	06/08/2024 10:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4952678	06/08/2024 10:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4952678	06/08/2024 10:23	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4952678	06/08/2024 10:23	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4952678	06/08/2024 10:23	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4952678	06/08/2024 10:23	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4952678	06/08/2024 10:23	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4952678	06/08/2024 10:23	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4952678	06/08/2024 10:23	Free - Residual disinfectant	mg Cl/l	0.98	
W4523OUT	Lough Macrory Final Water Outlet	4952678	06/08/2024 10:23	Free - Residual disinfectant	mg Cl/l	0.98	
W4523OUT	Lough Macrory Final Water Outlet	4952678	06/08/2024 10:23	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4952678	06/08/2024 10:23	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4952678	06/08/2024 10:23	Total - Residual disinfectant	mg Cl/l	1.08	
W4523OUT	Lough Macrory Final Water Outlet	4952678	06/08/2024 10:23	Total - Residual disinfectant	mg Cl/l	1.08	
W4523OUT	Lough Macrory Final Water Outlet	4952678	06/08/2024 10:23	Total Coliforms	CFU/100 ml	0	0

W4523OUT	Lough Macrory Final Water Outlet	4952678	06/08/2024 10:23	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4952678	06/08/2024 10:23	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4952678	06/08/2024 10:23	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4952686	06/08/2024 10:37	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4952686	06/08/2024 10:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4952686	06/08/2024 10:37	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4952686	06/08/2024 10:37	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4952686	06/08/2024 10:37	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4952686	06/08/2024 10:37	Free - Residual disinfectant	mg Cl/l	1.2	
W4701OUT	Killyhevlin Final Water Outlet	4952686	06/08/2024 10:37	Hydrogen Ion	pH value	8.1	9.5
W4701OUT	Killyhevlin Final Water Outlet	4952686	06/08/2024 10:37	Total - Residual disinfectant	mg Cl/l	1.44	
W4701OUT	Killyhevlin Final Water Outlet	4952686	06/08/2024 10:37	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4952686	06/08/2024 10:37	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4952889	07/08/2024 07:25	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4952889	07/08/2024 07:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4952889	07/08/2024 07:25	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4952889	07/08/2024 07:25	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4952889	07/08/2024 07:25	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4952889	07/08/2024 07:25	Free - Residual disinfectant	mg Cl/l	1.43	
W1301POUT	Moyola PPP Final Water Outlet	4952889	07/08/2024 07:25	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4952889	07/08/2024 07:25	Total - Residual disinfectant	mg Cl/l	1.62	
W1301POUT	Moyola PPP Final Water Outlet	4952889	07/08/2024 07:25	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4952889	07/08/2024 07:25	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Colony Counts 22	CFU/1 ml	1	
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Free - Residual disinfectant	mg Cl/l	1.66	
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Total - Residual disinfectant	mg Cl/l	1.78	
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4952887	07/08/2024 07:45	Taste - Nature		No taste	
W2514OUT	Seagahan Final Water Outlet	4952878	07/08/2024 08:12	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4952878	07/08/2024 08:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4952878	07/08/2024 08:12	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4952878	07/08/2024 08:12	Conductivity	uS/cm 20 C	400	2500
W2514OUT	Seagahan Final Water Outlet	4952878	07/08/2024 08:12	E. coli	CFU/100 ml	0	0

W2514OUT	Seagahan Final Water Outlet	4952878	07/08/2024 08:12	Free - Residual disinfectant	mg Cl/l	1.02	
W2514OUT	Seagahan Final Water Outlet	4952878	07/08/2024 08:12	Hydrogen Ion	pH value	7.6	9.5
W2514OUT	Seagahan Final Water Outlet	4952878	07/08/2024 08:12	Total - Residual disinfectant	mg Cl/l	1.22	
W2514OUT	Seagahan Final Water Outlet	4952878	07/08/2024 08:12	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4952878	07/08/2024 08:12	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Free - Residual disinfectant	mg Cl/l	1.14	
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Total - Residual disinfectant	mg Cl/l	1.21	
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Turbidity	NTU	0.093	1
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	2,4-D	ug/l	<0.011	0.1
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	2,4-DB	ug/l	<0.016	0.1
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Algae Blue Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Algae Diatom Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Algae Flagellate Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Algae Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Algae Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Aluminium	ug Al/l	25	200
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Asulam	ug/l	<0.015	0.1
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Bentazone	ug/l	<0.0044	0.1
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Bromodichloromethane	ug/l	15	
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Bromoform	ug/l	<3.5	
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Bromoxynil	ug/l	<0.0079	0.1
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Chloroform	ug/l	47	
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Clopyralid	ug/l	<0.0097	0.1
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Dibromochloromethane	ug/l	4.4	
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Dichlorprop	ug/l	<0.011	0.1
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Geosmin	ng/l	<1.1	
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Iron	ug/l Fe	5.1	200
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Manganese	ug Mn/l	3.5	50
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	MCPA	ug/l	0.023	0.1
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	MCPB	ug/l	<0.015	0.1
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Mecoprop	ug/l	<0.011	0.1
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	MIB	ng/l	<1.9	
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Odour	Diln No	0	0
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Odour - Nature		No odour	

W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Propyzamide	ug/l	<0.012	0.1
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Second most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Taste	Diln No	0	0
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Taste - Nature		No taste	
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Third most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Total Organic Carbon	mg C/l	2.8	
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Total Trihalomethanes	ug/l	67	100
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	Triclopyr	ug/l	<0.012	0.1
W4701OUT	Killyhevlin Final Water Outlet	4952882	07/08/2024 08:57	WHO Index		0.46	1
W1302OUT	Lough Fea Final Water Outlet	4952874	07/08/2024 09:42	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4952874	07/08/2024 09:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4952874	07/08/2024 09:42	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4952874	07/08/2024 09:42	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4952874	07/08/2024 09:42	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4952874	07/08/2024 09:42	Free - Residual disinfectant	mg Cl/l	0.69	
W1302OUT	Lough Fea Final Water Outlet	4952874	07/08/2024 09:42	Hydrogen Ion	pH value	7.1	9.5
W1302OUT	Lough Fea Final Water Outlet	4952874	07/08/2024 09:42	Total - Residual disinfectant	mg Cl/l	0.73	
W1302OUT	Lough Fea Final Water Outlet	4952874	07/08/2024 09:42	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4952874	07/08/2024 09:42	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4952875	07/08/2024 10:20	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4952875	07/08/2024 10:20	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4952875	07/08/2024 10:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4952875	07/08/2024 10:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4952875	07/08/2024 10:20	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4952875	07/08/2024 10:20	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4952875	07/08/2024 10:20	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4952875	07/08/2024 10:20	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4952875	07/08/2024 10:20	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4952875	07/08/2024 10:20	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4952875	07/08/2024 10:20	Free - Residual disinfectant	mg Cl/l	0.91	
W4523OUT	Lough Macrory Final Water Outlet	4952875	07/08/2024 10:20	Free - Residual disinfectant	mg Cl/l	0.91	
W4523OUT	Lough Macrory Final Water Outlet	4952875	07/08/2024 10:20	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4952875	07/08/2024 10:20	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4952875	07/08/2024 10:20	Total - Residual disinfectant	mg Cl/l	0.98	
W4523OUT	Lough Macrory Final Water Outlet	4952875	07/08/2024 10:20	Total - Residual disinfectant	mg Cl/l	0.98	
W4523OUT	Lough Macrory Final Water Outlet	4952875	07/08/2024 10:20	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4952875	07/08/2024 10:20	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4952875	07/08/2024 10:20	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4952875	07/08/2024 10:20	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4953028	08/08/2024 08:53	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4953028	08/08/2024 08:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4953028	08/08/2024 08:53	Colour	mg/l Pt/Co	<4.56	20

W1302OUT	Lough Fea Final Water Outlet	4953028	08/08/2024 08:53	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4953028	08/08/2024 08:53	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4953028	08/08/2024 08:53	Free - Residual disinfectant	mg Cl/l	0.74	
W1302OUT	Lough Fea Final Water Outlet	4953028	08/08/2024 08:53	Hydrogen Ion	pH value	7.1	9.5
W1302OUT	Lough Fea Final Water Outlet	4953028	08/08/2024 08:53	Total - Residual disinfectant	mg Cl/l	0.8	
W1302OUT	Lough Fea Final Water Outlet	4953028	08/08/2024 08:53	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4953028	08/08/2024 08:53	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4953043	08/08/2024 09:37	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4953043	08/08/2024 09:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4953043	08/08/2024 09:37	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4953043	08/08/2024 09:37	Conductivity	uS/cm 20 C	380	2500
W1301POUT	Moyola PPP Final Water Outlet	4953043	08/08/2024 09:37	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4953043	08/08/2024 09:37	Free - Residual disinfectant	mg Cl/l	1.41	
W1301POUT	Moyola PPP Final Water Outlet	4953043	08/08/2024 09:37	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4953043	08/08/2024 09:37	Total - Residual disinfectant	mg Cl/l	1.56	
W1301POUT	Moyola PPP Final Water Outlet	4953043	08/08/2024 09:37	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4953043	08/08/2024 09:37	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4953029	08/08/2024 09:48	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4953029	08/08/2024 09:48	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4953029	08/08/2024 09:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4953029	08/08/2024 09:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4953029	08/08/2024 09:48	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4953029	08/08/2024 09:48	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4953029	08/08/2024 09:48	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4953029	08/08/2024 09:48	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4953029	08/08/2024 09:48	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4953029	08/08/2024 09:48	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4953029	08/08/2024 09:48	Free - Residual disinfectant	mg Cl/l	0.89	
W4523OUT	Lough Macrory Final Water Outlet	4953029	08/08/2024 09:48	Free - Residual disinfectant	mg Cl/l	0.89	
W4523OUT	Lough Macrory Final Water Outlet	4953029	08/08/2024 09:48	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4953029	08/08/2024 09:48	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4953029	08/08/2024 09:48	Total - Residual disinfectant	mg Cl/l	0.97	
W4523OUT	Lough Macrory Final Water Outlet	4953029	08/08/2024 09:48	Total - Residual disinfectant	mg Cl/l	0.97	
W4523OUT	Lough Macrory Final Water Outlet	4953029	08/08/2024 09:48	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4953029	08/08/2024 09:48	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4953029	08/08/2024 09:48	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4953029	08/08/2024 09:48	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4953035	08/08/2024 09:56	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4953035	08/08/2024 09:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4953035	08/08/2024 09:56	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4953035	08/08/2024 09:56	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4953035	08/08/2024 09:56	E. coli	CFU/100 ml	0	0

W4701OUT	Killyhevlin Final Water Outlet	4953035	08/08/2024 09:56	Free - Residual disinfectant	mg Cl/l	1.52	
W4701OUT	Killyhevlin Final Water Outlet	4953035	08/08/2024 09:56	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4953035	08/08/2024 09:56	Total - Residual disinfectant	mg Cl/l	1.87	
W4701OUT	Killyhevlin Final Water Outlet	4953035	08/08/2024 09:56	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4953035	08/08/2024 09:56	Turbidity	NTU	0.095	1
W2308POUT	Castor Bay PPP Final Water Outlet	4953040	08/08/2024 10:04	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4953040	08/08/2024 10:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4953040	08/08/2024 10:04	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4953040	08/08/2024 10:04	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4953040	08/08/2024 10:04	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4953040	08/08/2024 10:04	Free - Residual disinfectant	mg Cl/l	1.52	
W2308POUT	Castor Bay PPP Final Water Outlet	4953040	08/08/2024 10:04	Hydrogen Ion	pH value	7.7	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4953040	08/08/2024 10:04	Total - Residual disinfectant	mg Cl/l	1.62	
W2308POUT	Castor Bay PPP Final Water Outlet	4953040	08/08/2024 10:04	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4953040	08/08/2024 10:04	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Conductivity	uS/cm 20 C	390	2500
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Free - Residual disinfectant	mg Cl/l	0.65	
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Total - Residual disinfectant	mg Cl/l	0.7	
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	2,4-D	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	2,4-DB	ug/l	<0.016	0.1
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Algae Blue Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Algae Diatom Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Algae Flagellate Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Algae Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Algae Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Aluminium	ug Al/l	4.6	200
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Asulam	ug/l	<0.015	0.1
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Bentazone	ug/l	<0.0044	0.1
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Bromodichloromethane	ug/l	13	
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Bromoform	ug/l	<3.5	
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Bromoxynil	ug/l	<0.0079	0.1
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Chloroform	ug/l	31	
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Clopyralid	ug/l	<0.0097	0.1
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Dibromochloromethane	ug/l	3.8	
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Dichlorprop	ug/l	<0.011	0.1

W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Geosmin	ng/l	<1.1	
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Iron	ug/l Fe	1.9	200
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Manganese	ug Mn/l	1	50
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	MCPA	ug/l	0.014	0.1
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	MCPB	ug/l	<0.015	0.1
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Mecoprop	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	MIB	ng/l	2.6	
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Microcystin-LR	ug/l	<0.024	
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Most numerous Algae		----	
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Propyzamide	ug/l	<0.012	0.1
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Second most numerous Algae		---	
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Third most numerous Algae		---	
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Total Organic Carbon	mg C/l	2.6	
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Total Trihalomethanes	ug/l	48	100
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	Triclopyr	ug/l	<0.012	0.1
W2514OUT	Seagahan Final Water Outlet	4953032	08/08/2024 11:30	WHO Index		0.36	1
W1301POUT	Moyola PPP Final Water Outlet	4953168	09/08/2024 07:12	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4953168	09/08/2024 07:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4953168	09/08/2024 07:12	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4953168	09/08/2024 07:12	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4953168	09/08/2024 07:12	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4953168	09/08/2024 07:12	Free - Residual disinfectant	mg Cl/l	1.53	
W1301POUT	Moyola PPP Final Water Outlet	4953168	09/08/2024 07:12	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4953168	09/08/2024 07:12	Total - Residual disinfectant	mg Cl/l	1.57	
W1301POUT	Moyola PPP Final Water Outlet	4953168	09/08/2024 07:12	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4953168	09/08/2024 07:12	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4953161	09/08/2024 07:51	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4953161	09/08/2024 07:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4953161	09/08/2024 07:51	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4953161	09/08/2024 07:51	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4953161	09/08/2024 07:51	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4953161	09/08/2024 07:51	Free - Residual disinfectant	mg Cl/l	0.76	
W1302OUT	Lough Fea Final Water Outlet	4953161	09/08/2024 07:51	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4953161	09/08/2024 07:51	Total - Residual disinfectant	mg Cl/l	0.86	
W1302OUT	Lough Fea Final Water Outlet	4953161	09/08/2024 07:51	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4953161	09/08/2024 07:51	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4953167	09/08/2024 09:53	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4953167	09/08/2024 09:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4953167	09/08/2024 09:53	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4953167	09/08/2024 09:53	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4953167	09/08/2024 09:53	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4953167	09/08/2024 09:53	Free - Residual disinfectant	mg Cl/l	1.37	

W2308POUT	Castor Bay PPP Final Water Outlet	4953167	09/08/2024 09:53	Hydrogen Ion	pH value	7.7	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4953167	09/08/2024 09:53	Total - Residual disinfectant	mg Cl/l	1.46	
W2308POUT	Castor Bay PPP Final Water Outlet	4953167	09/08/2024 09:53	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4953167	09/08/2024 09:53	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4953163	09/08/2024 11:04	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4953163	09/08/2024 11:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4953163	09/08/2024 11:04	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4953163	09/08/2024 11:04	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4953163	09/08/2024 11:04	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4953163	09/08/2024 11:04	Free - Residual disinfectant	mg Cl/l	1.08	
W4701OUT	Killyhevlin Final Water Outlet	4953163	09/08/2024 11:04	Hydrogen Ion	pH value	8.1	9.5
W4701OUT	Killyhevlin Final Water Outlet	4953163	09/08/2024 11:04	Total - Residual disinfectant	mg Cl/l	1.25	
W4701OUT	Killyhevlin Final Water Outlet	4953163	09/08/2024 11:04	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4953163	09/08/2024 11:04	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4953238	10/08/2024 09:16	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4953238	10/08/2024 09:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4953238	10/08/2024 09:16	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4953238	10/08/2024 09:16	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4953238	10/08/2024 09:16	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4953238	10/08/2024 09:16	Free - Residual disinfectant	mg Cl/l	1.43	
W1301POUT	Moyola PPP Final Water Outlet	4953238	10/08/2024 09:16	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4953238	10/08/2024 09:16	Total - Residual disinfectant	mg Cl/l	1.47	
W1301POUT	Moyola PPP Final Water Outlet	4953238	10/08/2024 09:16	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4953238	10/08/2024 09:16	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4953234	10/08/2024 09:17	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4953234	10/08/2024 09:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4953234	10/08/2024 09:17	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4953234	10/08/2024 09:17	Conductivity	uS/cm 20 C	410	2500
W4701OUT	Killyhevlin Final Water Outlet	4953234	10/08/2024 09:17	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4953234	10/08/2024 09:17	Free - Residual disinfectant	mg Cl/l	1.17	
W4701OUT	Killyhevlin Final Water Outlet	4953234	10/08/2024 09:17	Hydrogen Ion	pH value	8.1	9.5
W4701OUT	Killyhevlin Final Water Outlet	4953234	10/08/2024 09:17	Total - Residual disinfectant	mg Cl/l	1.4	
W4701OUT	Killyhevlin Final Water Outlet	4953234	10/08/2024 09:17	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4953234	10/08/2024 09:17	Turbidity	NTU	0.12	1
W2308POUT	Castor Bay PPP Final Water Outlet	4953237	10/08/2024 09:59	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4953237	10/08/2024 09:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4953237	10/08/2024 09:59	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4953237	10/08/2024 09:59	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4953237	10/08/2024 09:59	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4953237	10/08/2024 09:59	Free - Residual disinfectant	mg Cl/l	1.44	
W2308POUT	Castor Bay PPP Final Water Outlet	4953237	10/08/2024 09:59	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4953237	10/08/2024 09:59	Total - Residual disinfectant	mg Cl/l	1.54	

W2308POUT	Castor Bay PPP Final Water Outlet	4953237	10/08/2024 09:59	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4953237	10/08/2024 09:59	Turbidity	NTU	0.12	1
W1302OUT	Lough Fea Final Water Outlet	4953233	10/08/2024 10:03	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4953233	10/08/2024 10:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4953233	10/08/2024 10:03	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4953233	10/08/2024 10:03	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4953233	10/08/2024 10:03	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4953233	10/08/2024 10:03	Free - Residual disinfectant	mg Cl/l	0.76	
W1302OUT	Lough Fea Final Water Outlet	4953233	10/08/2024 10:03	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4953233	10/08/2024 10:03	Total - Residual disinfectant	mg Cl/l	0.81	
W1302OUT	Lough Fea Final Water Outlet	4953233	10/08/2024 10:03	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4953233	10/08/2024 10:03	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4953252	11/08/2024 09:21	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4953252	11/08/2024 09:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4953252	11/08/2024 09:21	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4953252	11/08/2024 09:21	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4953252	11/08/2024 09:21	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4953252	11/08/2024 09:21	Free - Residual disinfectant	mg Cl/l	1.58	
W4701OUT	Killyhevlin Final Water Outlet	4953252	11/08/2024 09:21	Hydrogen Ion	pH value	8.1	9.5
W4701OUT	Killyhevlin Final Water Outlet	4953252	11/08/2024 09:21	Total - Residual disinfectant	mg Cl/l	1.68	
W4701OUT	Killyhevlin Final Water Outlet	4953252	11/08/2024 09:21	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4953252	11/08/2024 09:21	Turbidity	NTU	0.093	1
W1301POUT	Moyola PPP Final Water Outlet	4953256	11/08/2024 09:32	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4953256	11/08/2024 09:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4953256	11/08/2024 09:32	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4953256	11/08/2024 09:32	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4953256	11/08/2024 09:32	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4953256	11/08/2024 09:32	Free - Residual disinfectant	mg Cl/l	1.45	
W1301POUT	Moyola PPP Final Water Outlet	4953256	11/08/2024 09:32	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4953256	11/08/2024 09:32	Total - Residual disinfectant	mg Cl/l	1.55	
W1301POUT	Moyola PPP Final Water Outlet	4953256	11/08/2024 09:32	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4953256	11/08/2024 09:32	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4953251	11/08/2024 10:13	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4953251	11/08/2024 10:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4953251	11/08/2024 10:13	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4953251	11/08/2024 10:13	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4953251	11/08/2024 10:13	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4953251	11/08/2024 10:13	Free - Residual disinfectant	mg Cl/l	0.71	
W1302OUT	Lough Fea Final Water Outlet	4953251	11/08/2024 10:13	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4953251	11/08/2024 10:13	Total - Residual disinfectant	mg Cl/l	0.79	
W1302OUT	Lough Fea Final Water Outlet	4953251	11/08/2024 10:13	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4953251	11/08/2024 10:13	Turbidity	NTU	<0.09	1

W2308POUT	Castor Bay PPP Final Water Outlet	4953255	11/08/2024 10:47	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4953255	11/08/2024 10:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4953255	11/08/2024 10:47	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4953255	11/08/2024 10:47	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4953255	11/08/2024 10:47	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4953255	11/08/2024 10:47	Free - Residual disinfectant	mg Cl/l	1.65	
W2308POUT	Castor Bay PPP Final Water Outlet	4953255	11/08/2024 10:47	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4953255	11/08/2024 10:47	Total - Residual disinfectant	mg Cl/l	1.78	
W2308POUT	Castor Bay PPP Final Water Outlet	4953255	11/08/2024 10:47	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4953255	11/08/2024 10:47	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4955086	12/08/2024 07:10	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4955086	12/08/2024 07:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4955086	12/08/2024 07:10	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4955086	12/08/2024 07:10	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4955086	12/08/2024 07:10	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4955086	12/08/2024 07:10	Free - Residual disinfectant	mg Cl/l	1.4	
W1301POUT	Moyola PPP Final Water Outlet	4955086	12/08/2024 07:10	Hydrogen Ion	pH value	7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4955086	12/08/2024 07:10	Total - Residual disinfectant	mg Cl/l	1.67	
W1301POUT	Moyola PPP Final Water Outlet	4955086	12/08/2024 07:10	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4955086	12/08/2024 07:10	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4955054	12/08/2024 07:52	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4955054	12/08/2024 07:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4955054	12/08/2024 07:52	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4955054	12/08/2024 07:52	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4955054	12/08/2024 07:52	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4955054	12/08/2024 07:52	Free - Residual disinfectant	mg Cl/l	0.65	
W1302OUT	Lough Fea Final Water Outlet	4955054	12/08/2024 07:52	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4955054	12/08/2024 07:52	Total - Residual disinfectant	mg Cl/l	0.84	
W1302OUT	Lough Fea Final Water Outlet	4955054	12/08/2024 07:52	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4955054	12/08/2024 07:52	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4955067	12/08/2024 09:21	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4955067	12/08/2024 09:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4955067	12/08/2024 09:21	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4955067	12/08/2024 09:21	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4955067	12/08/2024 09:21	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4955067	12/08/2024 09:21	Free - Residual disinfectant	mg Cl/l	1.38	
W4701OUT	Killyhevlin Final Water Outlet	4955067	12/08/2024 09:21	Hydrogen Ion	pH value	8.1	9.5
W4701OUT	Killyhevlin Final Water Outlet	4955067	12/08/2024 09:21	Total - Residual disinfectant	mg Cl/l	1.52	
W4701OUT	Killyhevlin Final Water Outlet	4955067	12/08/2024 09:21	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4955067	12/08/2024 09:21	Turbidity	NTU	0.1	1
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	

W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Free - Residual disinfectant	mg Cl/l	1.18	
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Total - Residual disinfectant	mg Cl/l	1.35	
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955081	12/08/2024 09:51	Taste - Nature		No taste	
W2514OUT	Seagahan Final Water Outlet	4955058	12/08/2024 11:16	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4955058	12/08/2024 11:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4955058	12/08/2024 11:16	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4955058	12/08/2024 11:16	Conductivity	uS/cm 20 C	400	2500
W2514OUT	Seagahan Final Water Outlet	4955058	12/08/2024 11:16	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4955058	12/08/2024 11:16	Free - Residual disinfectant	mg Cl/l	1.12	
W2514OUT	Seagahan Final Water Outlet	4955058	12/08/2024 11:16	Hydrogen Ion	pH value	7.6	9.5
W2514OUT	Seagahan Final Water Outlet	4955058	12/08/2024 11:16	Total - Residual disinfectant	mg Cl/l	1.4	
W2514OUT	Seagahan Final Water Outlet	4955058	12/08/2024 11:16	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4955058	12/08/2024 11:16	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4955058	12/08/2024 11:16	Algae Blue Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4955058	12/08/2024 11:16	Algae Diatom Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4955058	12/08/2024 11:16	Algae Flagellate Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4955058	12/08/2024 11:16	Algae Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4955058	12/08/2024 11:16	Algae Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4955058	12/08/2024 11:16	Aluminium	ug Al/l	3.2	200
W2514OUT	Seagahan Final Water Outlet	4955058	12/08/2024 11:16	Iron	ug/l Fe	<1.538	200
W2514OUT	Seagahan Final Water Outlet	4955058	12/08/2024 11:16	Manganese	ug Mn/l	<0.80	50
W2514OUT	Seagahan Final Water Outlet	4955058	12/08/2024 11:16	Most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4955058	12/08/2024 11:16	Second most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4955058	12/08/2024 11:16	Third most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4955058	12/08/2024 11:16	Total Organic Carbon	mg C/l	2.8	
W4523OUT	Lough Macrory Final Water Outlet	4955055	12/08/2024 11:40	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4955055	12/08/2024 11:40	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4955055	12/08/2024 11:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4955055	12/08/2024 11:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4955055	12/08/2024 11:40	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4955055	12/08/2024 11:40	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4955055	12/08/2024 11:40	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4955055	12/08/2024 11:40	Conductivity	uS/cm 20 C	120	2500

W4523OUT	Lough Macrory Final Water Outlet	4955055	12/08/2024 11:40	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4955055	12/08/2024 11:40	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4955055	12/08/2024 11:40	Free - Residual disinfectant	mg Cl/l	0.96	
W4523OUT	Lough Macrory Final Water Outlet	4955055	12/08/2024 11:40	Free - Residual disinfectant	mg Cl/l	0.96	
W4523OUT	Lough Macrory Final Water Outlet	4955055	12/08/2024 11:40	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4955055	12/08/2024 11:40	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4955055	12/08/2024 11:40	Total - Residual disinfectant	mg Cl/l	1.04	
W4523OUT	Lough Macrory Final Water Outlet	4955055	12/08/2024 11:40	Total - Residual disinfectant	mg Cl/l	1.04	
W4523OUT	Lough Macrory Final Water Outlet	4955055	12/08/2024 11:40	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4955055	12/08/2024 11:40	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4955055	12/08/2024 11:40	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4955055	12/08/2024 11:40	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Free - Residual disinfectant	mg Cl/l	1.44	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Total - Residual disinfectant	mg Cl/l	1.49	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	2,4-D	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	2,4-DB	ug/l	<0.016	0.1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Algae Blue Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Algae Diatom Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Algae Flagellate Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Algae Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Algae Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Aluminium	ug Al/l	35	200
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Asulam	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Bentazone	ug/l	<0.0044	0.1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Bromoxynil	ug/l	<0.0079	0.1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Clopyralid	ug/l	<0.0097	0.1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Dichlorprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Geosmin	ng/l	<1.1	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Iron	ug/l Fe	<1.538	200
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Manganese	ug Mn/l	<0.80	50
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	MCPA	ug/l	0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	MCPB	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Mecoprop	ug/l	<0.011	0.1

W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	MIB	ng/l	<1.9	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Microcystin-LR	ug/l	<0.024	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Propyzamide	ug/l	<0.012	0.1
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Second most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Taste - Nature		No taste	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Third most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Total Organic Carbon	mg C/l	2.9	
W1301POUT	Moyola PPP Final Water Outlet	4955374	13/08/2024 07:24	Triclopyr	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Free - Residual disinfectant	mg Cl/l	1.3	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Total - Residual disinfectant	mg Cl/l	1.47	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Algae Diatom Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Algae Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Aluminium	ug Al/l	36	200
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Bromodichloromethane	ug/l	7.4	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Chloroform	ug/l	13	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Dibromochloromethane	ug/l	3.7	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Iron	ug/l Fe	<1.538	200
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Manganese	ug Mn/l	<0.80	50
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	MIB	ng/l	<1.9	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Microcystin-LR	ug/l	<0.024	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Second most numerous Algae		-	

W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Third most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Total Organic Carbon	mg C/l	3	
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	Total Trihalomethanes	ug/l	25	100
W2308POUT	Castor Bay PPP Final Water Outlet	4955369	13/08/2024 08:10	WHO Index		0.21	1
W4701OUT	Killyhevlin Final Water Outlet	4955363	13/08/2024 09:01	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4955363	13/08/2024 09:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4955363	13/08/2024 09:01	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4955363	13/08/2024 09:01	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4955363	13/08/2024 09:01	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4955363	13/08/2024 09:01	Free - Residual disinfectant	mg Cl/l	1.31	
W4701OUT	Killyhevlin Final Water Outlet	4955363	13/08/2024 09:01	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4955363	13/08/2024 09:01	Total - Residual disinfectant	mg Cl/l	1.42	
W4701OUT	Killyhevlin Final Water Outlet	4955363	13/08/2024 09:01	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4955363	13/08/2024 09:01	Turbidity	NTU	0.11	1
W1302OUT	Lough Fea Final Water Outlet	4955354	13/08/2024 09:14	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4955354	13/08/2024 09:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4955354	13/08/2024 09:14	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4955354	13/08/2024 09:14	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4955354	13/08/2024 09:14	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4955354	13/08/2024 09:14	Free - Residual disinfectant	mg Cl/l	0.65	
W1302OUT	Lough Fea Final Water Outlet	4955354	13/08/2024 09:14	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4955354	13/08/2024 09:14	Total - Residual disinfectant	mg Cl/l	0.71	
W1302OUT	Lough Fea Final Water Outlet	4955354	13/08/2024 09:14	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4955354	13/08/2024 09:14	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Colony Counts 22	CFU/1 ml	1	
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Colony Counts 22	CFU/1 ml	1	
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Free - Residual disinfectant	mg Cl/l	0.99	
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Free - Residual disinfectant	mg Cl/l	0.99	
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Total - Residual disinfectant	mg Cl/l	1.06	
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Total - Residual disinfectant	mg Cl/l	1.06	

W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Aluminium	ug Al/l	9.8	200
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Aluminium	ug Al/l	9.8	200
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Bromodichloromethane	ug/l	7.1	
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Bromodichloromethane	ug/l	7.1	
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Bromoform	ug/l	<3.5	
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Bromoform	ug/l	<3.5	
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Chloroform	ug/l	29	
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Chloroform	ug/l	29	
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Dibromochloromethane	ug/l	<1.6	
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Dibromochloromethane	ug/l	<1.6	
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Iron	ug/l Fe	<1.538	200
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Iron	ug/l Fe	<1.538	200
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Manganese	ug Mn/l	<0.80	50
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Manganese	ug Mn/l	<0.80	50
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Total Organic Carbon	mg C/l	1.8	
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Total Organic Carbon	mg C/l	1.8	
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Total Trihalomethanes	ug/l	38	100
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	Total Trihalomethanes	ug/l	38	100
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	WHO Index		0.23	1
W4523OUT	Lough Macrory Final Water Outlet	4955355	13/08/2024 10:12	WHO Index		0.23	1
W2514OUT	Seagahan Final Water Outlet	4955358	13/08/2024 10:44	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4955358	13/08/2024 10:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4955358	13/08/2024 10:44	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4955358	13/08/2024 10:44	Conductivity	uS/cm 20 C	390	2500
W2514OUT	Seagahan Final Water Outlet	4955358	13/08/2024 10:44	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4955358	13/08/2024 10:44	Free - Residual disinfectant	mg Cl/l	1.07	
W2514OUT	Seagahan Final Water Outlet	4955358	13/08/2024 10:44	Hydrogen Ion	pH value	7.4	9.5
W2514OUT	Seagahan Final Water Outlet	4955358	13/08/2024 10:44	Total - Residual disinfectant	mg Cl/l	1.32	
W2514OUT	Seagahan Final Water Outlet	4955358	13/08/2024 10:44	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4955358	13/08/2024 10:44	Turbidity	NTU	0.097	1
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Free - Residual disinfectant	mg Cl/l	1.4	
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Total - Residual disinfectant	mg Cl/l	1.63	

W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955599	14/08/2024 08:10	Taste - Nature		No taste	
W1302OUT	Lough Fea Final Water Outlet	4955583	14/08/2024 09:32	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4955583	14/08/2024 09:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4955583	14/08/2024 09:32	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4955583	14/08/2024 09:32	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4955583	14/08/2024 09:32	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4955583	14/08/2024 09:32	Free - Residual disinfectant	mg Cl/l	0.66	
W1302OUT	Lough Fea Final Water Outlet	4955583	14/08/2024 09:32	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4955583	14/08/2024 09:32	Total - Residual disinfectant	mg Cl/l	0.73	
W1302OUT	Lough Fea Final Water Outlet	4955583	14/08/2024 09:32	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4955583	14/08/2024 09:32	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4955583	14/08/2024 09:32	Aluminium	ug Al/l	17	200
W1302OUT	Lough Fea Final Water Outlet	4955583	14/08/2024 09:32	Bromodichloromethane	ug/l	9.6	
W1302OUT	Lough Fea Final Water Outlet	4955583	14/08/2024 09:32	Bromoform	ug/l	<3.5	
W1302OUT	Lough Fea Final Water Outlet	4955583	14/08/2024 09:32	Chloroform	ug/l	51	
W1302OUT	Lough Fea Final Water Outlet	4955583	14/08/2024 09:32	Dibromochloromethane	ug/l	<1.6	
W1302OUT	Lough Fea Final Water Outlet	4955583	14/08/2024 09:32	Iron	ug/l Fe	1.7	200
W1302OUT	Lough Fea Final Water Outlet	4955583	14/08/2024 09:32	Manganese	ug Mn/l	<0.80	50
W1302OUT	Lough Fea Final Water Outlet	4955583	14/08/2024 09:32	Total Organic Carbon	mg C/l	2.2	
W1302OUT	Lough Fea Final Water Outlet	4955583	14/08/2024 09:32	Total Trihalomethanes	ug/l	63	100
W1302OUT	Lough Fea Final Water Outlet	4955583	14/08/2024 09:32	WHO Index		0.35	1
W2514OUT	Seagahan Final Water Outlet	4955591	14/08/2024 09:52	Colony Counts 22	CFU/1 ml	3	
W2514OUT	Seagahan Final Water Outlet	4955591	14/08/2024 09:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4955591	14/08/2024 09:52	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4955591	14/08/2024 09:52	Conductivity	uS/cm 20 C	400	2500
W2514OUT	Seagahan Final Water Outlet	4955591	14/08/2024 09:52	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4955591	14/08/2024 09:52	Free - Residual disinfectant	mg Cl/l	0.98	
W2514OUT	Seagahan Final Water Outlet	4955591	14/08/2024 09:52	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4955591	14/08/2024 09:52	Total - Residual disinfectant	mg Cl/l	1.19	
W2514OUT	Seagahan Final Water Outlet	4955591	14/08/2024 09:52	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4955591	14/08/2024 09:52	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4955602	14/08/2024 10:18	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4955602	14/08/2024 10:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4955602	14/08/2024 10:18	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4955602	14/08/2024 10:18	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4955602	14/08/2024 10:18	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4955602	14/08/2024 10:18	Free - Residual disinfectant	mg Cl/l	1.39	

W1301POUT	Moyola PPP Final Water Outlet	4955602	14/08/2024 10:18	Hydrogen Ion	pH value	7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4955602	14/08/2024 10:18	Total - Residual disinfectant	mg Cl/l	1.45	
W1301POUT	Moyola PPP Final Water Outlet	4955602	14/08/2024 10:18	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4955602	14/08/2024 10:18	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4955584	14/08/2024 10:28	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4955584	14/08/2024 10:28	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4955584	14/08/2024 10:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4955584	14/08/2024 10:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4955584	14/08/2024 10:28	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4955584	14/08/2024 10:28	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4955584	14/08/2024 10:28	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4955584	14/08/2024 10:28	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4955584	14/08/2024 10:28	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4955584	14/08/2024 10:28	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4955584	14/08/2024 10:28	Free - Residual disinfectant	mg Cl/l	0.94	
W4523OUT	Lough Macrory Final Water Outlet	4955584	14/08/2024 10:28	Free - Residual disinfectant	mg Cl/l	0.94	
W4523OUT	Lough Macrory Final Water Outlet	4955584	14/08/2024 10:28	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4955584	14/08/2024 10:28	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4955584	14/08/2024 10:28	Total - Residual disinfectant	mg Cl/l	1.01	
W4523OUT	Lough Macrory Final Water Outlet	4955584	14/08/2024 10:28	Total - Residual disinfectant	mg Cl/l	1.01	
W4523OUT	Lough Macrory Final Water Outlet	4955584	14/08/2024 10:28	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4955584	14/08/2024 10:28	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4955584	14/08/2024 10:28	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4955584	14/08/2024 10:28	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4955594	14/08/2024 11:52	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4955594	14/08/2024 11:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4955594	14/08/2024 11:52	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4955594	14/08/2024 11:52	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4955594	14/08/2024 11:52	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4955594	14/08/2024 11:52	Free - Residual disinfectant	mg Cl/l	1.29	
W4701OUT	Killyhevlin Final Water Outlet	4955594	14/08/2024 11:52	Hydrogen Ion	pH value	8.1	9.5
W4701OUT	Killyhevlin Final Water Outlet	4955594	14/08/2024 11:52	Total - Residual disinfectant	mg Cl/l	1.4	
W4701OUT	Killyhevlin Final Water Outlet	4955594	14/08/2024 11:52	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4955594	14/08/2024 11:52	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4955793	15/08/2024 07:39	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4955793	15/08/2024 07:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4955793	15/08/2024 07:39	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4955793	15/08/2024 07:39	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4955793	15/08/2024 07:39	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4955793	15/08/2024 07:39	Free - Residual disinfectant	mg Cl/l	1.33	
W1301POUT	Moyola PPP Final Water Outlet	4955793	15/08/2024 07:39	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4955793	15/08/2024 07:39	Total - Residual disinfectant	mg Cl/l	1.44	

W1301POUT	Moyola PPP Final Water Outlet	4955793	15/08/2024 07:39	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4955793	15/08/2024 07:39	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4955791	15/08/2024 08:01	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955791	15/08/2024 08:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955791	15/08/2024 08:01	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4955791	15/08/2024 08:01	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4955791	15/08/2024 08:01	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955791	15/08/2024 08:01	Free - Residual disinfectant	mg Cl/l	1.26	
W2308POUT	Castor Bay PPP Final Water Outlet	4955791	15/08/2024 08:01	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4955791	15/08/2024 08:01	Total - Residual disinfectant	mg Cl/l	1.36	
W2308POUT	Castor Bay PPP Final Water Outlet	4955791	15/08/2024 08:01	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955791	15/08/2024 08:01	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4955778	15/08/2024 09:04	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4955778	15/08/2024 09:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4955778	15/08/2024 09:04	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4955778	15/08/2024 09:04	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4955778	15/08/2024 09:04	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4955778	15/08/2024 09:04	Free - Residual disinfectant	mg Cl/l	0.68	
W1302OUT	Lough Fea Final Water Outlet	4955778	15/08/2024 09:04	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4955778	15/08/2024 09:04	Total - Residual disinfectant	mg Cl/l	0.76	
W1302OUT	Lough Fea Final Water Outlet	4955778	15/08/2024 09:04	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4955778	15/08/2024 09:04	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4955785	15/08/2024 10:03	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4955785	15/08/2024 10:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4955785	15/08/2024 10:03	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4955785	15/08/2024 10:03	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4955785	15/08/2024 10:03	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4955785	15/08/2024 10:03	Free - Residual disinfectant	mg Cl/l	1.38	
W4701OUT	Killyhevlin Final Water Outlet	4955785	15/08/2024 10:03	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4955785	15/08/2024 10:03	Total - Residual disinfectant	mg Cl/l	1.47	
W4701OUT	Killyhevlin Final Water Outlet	4955785	15/08/2024 10:03	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4955785	15/08/2024 10:03	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4955785	15/08/2024 10:03	Algae Blue Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4955785	15/08/2024 10:03	Algae Diatom Total	per ml	40	
W4701OUT	Killyhevlin Final Water Outlet	4955785	15/08/2024 10:03	Algae Flagellate Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4955785	15/08/2024 10:03	Algae Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4955785	15/08/2024 10:03	Algae Total	per ml	40	
W4701OUT	Killyhevlin Final Water Outlet	4955785	15/08/2024 10:03	Aluminium	ug Al/l	29	200
W4701OUT	Killyhevlin Final Water Outlet	4955785	15/08/2024 10:03	Iron	ug/l Fe	6.2	200
W4701OUT	Killyhevlin Final Water Outlet	4955785	15/08/2024 10:03	Manganese	ug Mn/l	3.8	50
W4701OUT	Killyhevlin Final Water Outlet	4955785	15/08/2024 10:03	Most numerous Algae		Centric diatom	
W4701OUT	Killyhevlin Final Water Outlet	4955785	15/08/2024 10:03	Second most numerous Algae		---	

W4701OUT	Killyhevlin Final Water Outlet	4955785	15/08/2024 10:03	Third most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4955785	15/08/2024 10:03	Total Organic Carbon	mg C/l	2.6	
W2514OUT	Seagahan Final Water Outlet	4955781	15/08/2024 10:05	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4955781	15/08/2024 10:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4955781	15/08/2024 10:05	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4955781	15/08/2024 10:05	Conductivity	uS/cm 20 C	410	2500
W2514OUT	Seagahan Final Water Outlet	4955781	15/08/2024 10:05	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4955781	15/08/2024 10:05	Free - Residual disinfectant	mg Cl/l	1.02	
W2514OUT	Seagahan Final Water Outlet	4955781	15/08/2024 10:05	Hydrogen Ion	pH value	7.6	9.5
W2514OUT	Seagahan Final Water Outlet	4955781	15/08/2024 10:05	Total - Residual disinfectant	mg Cl/l	1.24	
W2514OUT	Seagahan Final Water Outlet	4955781	15/08/2024 10:05	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4955781	15/08/2024 10:05	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4955779	15/08/2024 10:33	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4955779	15/08/2024 10:33	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4955779	15/08/2024 10:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4955779	15/08/2024 10:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4955779	15/08/2024 10:33	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4955779	15/08/2024 10:33	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4955779	15/08/2024 10:33	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4955779	15/08/2024 10:33	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4955779	15/08/2024 10:33	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4955779	15/08/2024 10:33	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4955779	15/08/2024 10:33	Free - Residual disinfectant	mg Cl/l	0.95	
W4523OUT	Lough Macrory Final Water Outlet	4955779	15/08/2024 10:33	Free - Residual disinfectant	mg Cl/l	0.95	
W4523OUT	Lough Macrory Final Water Outlet	4955779	15/08/2024 10:33	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4955779	15/08/2024 10:33	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4955779	15/08/2024 10:33	Total - Residual disinfectant	mg Cl/l	1.02	
W4523OUT	Lough Macrory Final Water Outlet	4955779	15/08/2024 10:33	Total - Residual disinfectant	mg Cl/l	1.02	
W4523OUT	Lough Macrory Final Water Outlet	4955779	15/08/2024 10:33	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4955779	15/08/2024 10:33	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4955779	15/08/2024 10:33	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4955779	15/08/2024 10:33	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4955964	16/08/2024 08:03	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955964	16/08/2024 08:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4955964	16/08/2024 08:03	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4955964	16/08/2024 08:03	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4955964	16/08/2024 08:03	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955964	16/08/2024 08:03	Free - Residual disinfectant	mg Cl/l	1.17	
W2308POUT	Castor Bay PPP Final Water Outlet	4955964	16/08/2024 08:03	Hydrogen Ion	pH value	7.7	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4955964	16/08/2024 08:03	Total - Residual disinfectant	mg Cl/l	1.29	
W2308POUT	Castor Bay PPP Final Water Outlet	4955964	16/08/2024 08:03	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4955964	16/08/2024 08:03	Turbidity	NTU	0.09	1

W4701OUT	Killyhevlin Final Water Outlet	4955960	16/08/2024 09:06	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4955960	16/08/2024 09:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4955960	16/08/2024 09:06	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4955960	16/08/2024 09:06	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4955960	16/08/2024 09:06	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4955960	16/08/2024 09:06	Free - Residual disinfectant	mg Cl/l	1.52	
W4701OUT	Killyhevlin Final Water Outlet	4955960	16/08/2024 09:06	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4955960	16/08/2024 09:06	Total - Residual disinfectant	mg Cl/l	1.63	
W4701OUT	Killyhevlin Final Water Outlet	4955960	16/08/2024 09:06	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4955960	16/08/2024 09:06	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4955958	16/08/2024 09:10	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4955958	16/08/2024 09:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4955958	16/08/2024 09:10	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4955958	16/08/2024 09:10	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4955958	16/08/2024 09:10	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4955958	16/08/2024 09:10	Free - Residual disinfectant	mg Cl/l	0.63	
W1302OUT	Lough Fea Final Water Outlet	4955958	16/08/2024 09:10	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4955958	16/08/2024 09:10	Total - Residual disinfectant	mg Cl/l	0.82	
W1302OUT	Lough Fea Final Water Outlet	4955958	16/08/2024 09:10	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4955958	16/08/2024 09:10	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4955965	16/08/2024 10:15	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4955965	16/08/2024 10:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4955965	16/08/2024 10:15	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4955965	16/08/2024 10:15	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4955965	16/08/2024 10:15	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4955965	16/08/2024 10:15	Free - Residual disinfectant	mg Cl/l	1.38	
W1301POUT	Moyola PPP Final Water Outlet	4955965	16/08/2024 10:15	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4955965	16/08/2024 10:15	Total - Residual disinfectant	mg Cl/l	1.42	
W1301POUT	Moyola PPP Final Water Outlet	4955965	16/08/2024 10:15	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4955965	16/08/2024 10:15	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4956049	17/08/2024 06:55	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4956049	17/08/2024 06:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4956049	17/08/2024 06:55	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4956049	17/08/2024 06:55	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4956049	17/08/2024 06:55	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4956049	17/08/2024 06:55	Free - Residual disinfectant	mg Cl/l	1.32	
W2308POUT	Castor Bay PPP Final Water Outlet	4956049	17/08/2024 06:55	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4956049	17/08/2024 06:55	Total - Residual disinfectant	mg Cl/l	1.44	
W2308POUT	Castor Bay PPP Final Water Outlet	4956049	17/08/2024 06:55	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4956049	17/08/2024 06:55	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4956050	17/08/2024 09:04	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4956050	17/08/2024 09:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	

W1301POUT	Moyola PPP Final Water Outlet	4956050	17/08/2024 09:04	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4956050	17/08/2024 09:04	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4956050	17/08/2024 09:04	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4956050	17/08/2024 09:04	Free - Residual disinfectant	mg Cl/l	1.53	
W1301POUT	Moyola PPP Final Water Outlet	4956050	17/08/2024 09:04	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4956050	17/08/2024 09:04	Total - Residual disinfectant	mg Cl/l	1.63	
W1301POUT	Moyola PPP Final Water Outlet	4956050	17/08/2024 09:04	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4956050	17/08/2024 09:04	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4956046	17/08/2024 09:07	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4956046	17/08/2024 09:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4956046	17/08/2024 09:07	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4956046	17/08/2024 09:07	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4956046	17/08/2024 09:07	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4956046	17/08/2024 09:07	Free - Residual disinfectant	mg Cl/l	1.2	
W4701OUT	Killyhevlin Final Water Outlet	4956046	17/08/2024 09:07	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4956046	17/08/2024 09:07	Total - Residual disinfectant	mg Cl/l	1.5	
W4701OUT	Killyhevlin Final Water Outlet	4956046	17/08/2024 09:07	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4956046	17/08/2024 09:07	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4956045	17/08/2024 09:48	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4956045	17/08/2024 09:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4956045	17/08/2024 09:48	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4956045	17/08/2024 09:48	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4956045	17/08/2024 09:48	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4956045	17/08/2024 09:48	Free - Residual disinfectant	mg Cl/l	0.7	
W1302OUT	Lough Fea Final Water Outlet	4956045	17/08/2024 09:48	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4956045	17/08/2024 09:48	Total - Residual disinfectant	mg Cl/l	0.76	
W1302OUT	Lough Fea Final Water Outlet	4956045	17/08/2024 09:48	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4956045	17/08/2024 09:48	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4956072	18/08/2024 07:11	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4956072	18/08/2024 07:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4956072	18/08/2024 07:11	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4956072	18/08/2024 07:11	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4956072	18/08/2024 07:11	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4956072	18/08/2024 07:11	Free - Residual disinfectant	mg Cl/l	1.21	
W2308POUT	Castor Bay PPP Final Water Outlet	4956072	18/08/2024 07:11	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4956072	18/08/2024 07:11	Total - Residual disinfectant	mg Cl/l	1.39	
W2308POUT	Castor Bay PPP Final Water Outlet	4956072	18/08/2024 07:11	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4956072	18/08/2024 07:11	Turbidity	NTU	0.12	1
W1301POUT	Moyola PPP Final Water Outlet	4956073	18/08/2024 08:47	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4956073	18/08/2024 08:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4956073	18/08/2024 08:47	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4956073	18/08/2024 08:47	Conductivity	uS/cm 20 C	360	2500

W1301POUT	Moyola PPP Final Water Outlet	4956073	18/08/2024 08:47	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4956073	18/08/2024 08:47	Free - Residual disinfectant	mg Cl/l	1.46	
W1301POUT	Moyola PPP Final Water Outlet	4956073	18/08/2024 08:47	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4956073	18/08/2024 08:47	Total - Residual disinfectant	mg Cl/l	1.55	
W1301POUT	Moyola PPP Final Water Outlet	4956073	18/08/2024 08:47	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4956073	18/08/2024 08:47	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4956069	18/08/2024 09:08	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4956069	18/08/2024 09:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4956069	18/08/2024 09:08	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4956069	18/08/2024 09:08	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4956069	18/08/2024 09:08	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4956069	18/08/2024 09:08	Free - Residual disinfectant	mg Cl/l	1.44	
W4701OUT	Killyhevlin Final Water Outlet	4956069	18/08/2024 09:08	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4956069	18/08/2024 09:08	Total - Residual disinfectant	mg Cl/l	1.75	
W4701OUT	Killyhevlin Final Water Outlet	4956069	18/08/2024 09:08	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4956069	18/08/2024 09:08	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4956068	18/08/2024 09:36	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4956068	18/08/2024 09:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4956068	18/08/2024 09:36	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4956068	18/08/2024 09:36	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4956068	18/08/2024 09:36	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4956068	18/08/2024 09:36	Free - Residual disinfectant	mg Cl/l	0.67	
W1302OUT	Lough Fea Final Water Outlet	4956068	18/08/2024 09:36	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4956068	18/08/2024 09:36	Total - Residual disinfectant	mg Cl/l	0.69	
W1302OUT	Lough Fea Final Water Outlet	4956068	18/08/2024 09:36	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4956068	18/08/2024 09:36	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Free - Residual disinfectant	mg Cl/l	1.51	
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Hydrogen Ion	pH value	7.8	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Total - Residual disinfectant	mg Cl/l	1.66	
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Turbidity	NTU	0.092	1
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958182	19/08/2024 08:10	Taste - Nature		No taste	
W1302OUT	Lough Fea Final Water Outlet	4958158	19/08/2024 10:19	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4958158	19/08/2024 10:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	

W1302OUT	Lough Fea Final Water Outlet	4958158	19/08/2024 10:19	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4958158	19/08/2024 10:19	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4958158	19/08/2024 10:19	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4958158	19/08/2024 10:19	Free - Residual disinfectant	mg Cl/l	0.64	
W1302OUT	Lough Fea Final Water Outlet	4958158	19/08/2024 10:19	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4958158	19/08/2024 10:19	Total - Residual disinfectant	mg Cl/l	0.72	
W1302OUT	Lough Fea Final Water Outlet	4958158	19/08/2024 10:19	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4958158	19/08/2024 10:19	Turbidity	NTU	0.093	1
W2514OUT	Seagahan Final Water Outlet	4958162	19/08/2024 10:45	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4958162	19/08/2024 10:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4958162	19/08/2024 10:45	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4958162	19/08/2024 10:45	Conductivity	uS/cm 20 C	410	2500
W2514OUT	Seagahan Final Water Outlet	4958162	19/08/2024 10:45	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4958162	19/08/2024 10:45	Free - Residual disinfectant	mg Cl/l	1.07	
W2514OUT	Seagahan Final Water Outlet	4958162	19/08/2024 10:45	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4958162	19/08/2024 10:45	Total - Residual disinfectant	mg Cl/l	1.33	
W2514OUT	Seagahan Final Water Outlet	4958162	19/08/2024 10:45	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4958162	19/08/2024 10:45	Turbidity	NTU	0.12	1
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Free - Residual disinfectant	mg Cl/l	1.66	
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Total - Residual disinfectant	mg Cl/l	1.78	
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Turbidity	NTU	0.2	1
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Algae Blue Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Algae Diatom Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Algae Flagellate Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Algae Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Algae Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Aluminium	ug Al/l	29	200
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Bromodichloromethane	ug/l	12	
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Bromoform	ug/l	<3.5	
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Chloroform	ug/l	38	
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Dibromochloromethane	ug/l	3.4	
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Geosmin	ng/l	<1.1	
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Iron	ug/l Fe	11	200
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Manganese	ug Mn/l	4.9	50
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	MIB	ng/l	<1.9	

W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Microcystin-LR	ug/l	<0.024	
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Most numerous Algae		-	
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Second most numerous Algae		-	
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Third most numerous Algae		-	
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Total Organic Carbon	mg C/l	2.6	
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	Total Trihalomethanes	ug/l	54	100
W4701OUT	Killyhevlin Final Water Outlet	4958173	19/08/2024 11:24	WHO Index		0.37	1
W4523OUT	Lough Macrory Final Water Outlet	4958159	19/08/2024 11:25	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4958159	19/08/2024 11:25	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4958159	19/08/2024 11:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4958159	19/08/2024 11:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4958159	19/08/2024 11:25	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4958159	19/08/2024 11:25	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4958159	19/08/2024 11:25	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4958159	19/08/2024 11:25	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4958159	19/08/2024 11:25	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4958159	19/08/2024 11:25	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4958159	19/08/2024 11:25	Free - Residual disinfectant	mg Cl/l	0.86	
W4523OUT	Lough Macrory Final Water Outlet	4958159	19/08/2024 11:25	Free - Residual disinfectant	mg Cl/l	0.86	
W4523OUT	Lough Macrory Final Water Outlet	4958159	19/08/2024 11:25	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4958159	19/08/2024 11:25	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4958159	19/08/2024 11:25	Total - Residual disinfectant	mg Cl/l	0.98	
W4523OUT	Lough Macrory Final Water Outlet	4958159	19/08/2024 11:25	Total - Residual disinfectant	mg Cl/l	0.98	
W4523OUT	Lough Macrory Final Water Outlet	4958159	19/08/2024 11:25	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4958159	19/08/2024 11:25	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4958159	19/08/2024 11:25	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4958159	19/08/2024 11:25	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4958185	19/08/2024 12:23	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4958185	19/08/2024 12:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4958185	19/08/2024 12:23	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4958185	19/08/2024 12:23	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4958185	19/08/2024 12:23	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4958185	19/08/2024 12:23	Free - Residual disinfectant	mg Cl/l	1.38	
W1301POUT	Moyola PPP Final Water Outlet	4958185	19/08/2024 12:23	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4958185	19/08/2024 12:23	Total - Residual disinfectant	mg Cl/l	1.42	
W1301POUT	Moyola PPP Final Water Outlet	4958185	19/08/2024 12:23	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4958185	19/08/2024 12:23	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	E. coli	CFU/100 ml	0	0

W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Free - Residual disinfectant	mg Cl/l	1.79	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Total - Residual disinfectant	mg Cl/l	1.86	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	2,4-D	ug/l	0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	2,4-DB	ug/l	<0.016	0.1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Algae Blue Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Algae Diatom Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Algae Flagellate Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Algae Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Algae Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Aluminium	ug Al/l	29	200
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Asulam	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Bentazone	ug/l	<0.0044	0.1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Bromoxynil	ug/l	<0.0079	0.1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Clopyralid	ug/l	<0.0097	0.1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Dichlorprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Geosmin	ng/l	<1.1	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Iron	ug/l Fe	<1.538	200
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Manganese	ug Mn/l	<0.80	50
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	MCPA	ug/l	<0.0093	0.1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	MCPB	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Mecoprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	MIB	ng/l	<1.9	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Propyzamide	ug/l	<0.012	0.1
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Second most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Third most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Total Organic Carbon	mg C/l	2.5	
W1301POUT	Moyola PPP Final Water Outlet	4958456	20/08/2024 07:23	Triclopyr	ug/l	<0.012	0.1
W1302OUT	Lough Fea Final Water Outlet	4958438	20/08/2024 08:18	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4958438	20/08/2024 08:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4958438	20/08/2024 08:18	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4958438	20/08/2024 08:18	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4958438	20/08/2024 08:18	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4958438	20/08/2024 08:18	Free - Residual disinfectant	mg Cl/l	0.61	
W1302OUT	Lough Fea Final Water Outlet	4958438	20/08/2024 08:18	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4958438	20/08/2024 08:18	Total - Residual disinfectant	mg Cl/l	0.7	
W1302OUT	Lough Fea Final Water Outlet	4958438	20/08/2024 08:18	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4958438	20/08/2024 08:18	Turbidity	NTU	0.12	1
W4701OUT	Killyhevlin Final Water Outlet	4958445	20/08/2024 09:01	Colony Counts 22	CFU/1 ml	0	

W4701OUT	Killyhevlin Final Water Outlet	4958445	20/08/2024 09:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4958445	20/08/2024 09:01	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4958445	20/08/2024 09:01	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4958445	20/08/2024 09:01	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4958445	20/08/2024 09:01	Free - Residual disinfectant	mg Cl/l	1.62	
W4701OUT	Killyhevlin Final Water Outlet	4958445	20/08/2024 09:01	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4958445	20/08/2024 09:01	Total - Residual disinfectant	mg Cl/l	1.7	
W4701OUT	Killyhevlin Final Water Outlet	4958445	20/08/2024 09:01	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4958445	20/08/2024 09:01	Turbidity	NTU	0.11	1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	2,4-D	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	2,4-DB	ug/l	<0.016	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Asulam	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Bentazone	ug/l	<0.0044	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Bromoxynil	ug/l	<0.0079	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Chlorotoluron	ug/l	<0.0031	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Chlorpyrifos	ug/l	<0.0070	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Clopyralid	ug/l	<0.0097	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Cyanide	ug/l CN	<5.5	50
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Dicamba	ug/l	<0.028	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Dichlorprop	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Diffenican	ug/l	<0.0072	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Dimethenamid	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Diuron	ug/l	<0.0055	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Epoconazole	ug/l	<0.0049	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Fenpropimorph	ug/l	<0.0083	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Flufenacet	ug/l	<0.0052	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Fluroxypyr	ug/l	0.0073	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Free - Residual disinfectant	mg Cl/l	1.52	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Glyphosate	ug/l	<0.0077	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Isoproturon	ug/l	<0.0025	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Linuron	ug/l	<0.0034	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	MCPA	ug/l	0.016	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	MCPB	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Mecoprop	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Metaxyl	ug/l	<0.0097	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Metamitron	ug/l	<0.0074	0.1

W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Metazachlor	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Metoxuron	ug/l	<0.0080	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Metribuzin	ug/l	<0.0060	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Oxamyl	ug/l	<0.0023	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Pendimethalin	ug/l	<0.0064	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Pesticides - Total Substances	ug/l	0.0233	0.5
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Phorate	ug/l	<0.0092	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Pirimicarb	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Propachlor	ug/l	<0.0096	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Propiconazole	ug/l	<0.0029	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Propyzamide	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Prothioconazole	ug/l	<0.0019	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Tebuconazole	ug/l	<0.0039	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Total - Residual disinfectant	mg Cl/l	1.66	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Triclopyr	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Algae Diatom Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Algae Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Aluminium	ug Al/l	22	200
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Bromodichloromethane	ug/l	11	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Chloroform	ug/l	23	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Diazinon	ug/l	<0.0074	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Dibromochloromethane	ug/l	2.6	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Iron	ug/l Fe	<1.538	200
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Manganese	ug Mn/l	<0.80	50
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	MIB	ng/l	<1.9	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Microcystin-LR	ug/l	<0.024	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Second most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Third most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Total Organic Carbon	mg C/l	3	
W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	Total Trihalomethanes	ug/l	37	100

W2308POUT	Castor Bay PPP Final Water Outlet	4958450	20/08/2024 09:06	WHO Index		0.29	1
W4523OUT	Lough Macrory Final Water Outlet	4958439	20/08/2024 09:37	Colony Counts 22	CFU/1 ml	1	
W4523OUT	Lough Macrory Final Water Outlet	4958439	20/08/2024 09:37	Colony Counts 22	CFU/1 ml	1	
W4523OUT	Lough Macrory Final Water Outlet	4958439	20/08/2024 09:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4958439	20/08/2024 09:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4958439	20/08/2024 09:37	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4958439	20/08/2024 09:37	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4958439	20/08/2024 09:37	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4958439	20/08/2024 09:37	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4958439	20/08/2024 09:37	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4958439	20/08/2024 09:37	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4958439	20/08/2024 09:37	Free - Residual disinfectant	mg Cl/l	0.78	
W4523OUT	Lough Macrory Final Water Outlet	4958439	20/08/2024 09:37	Free - Residual disinfectant	mg Cl/l	0.78	
W4523OUT	Lough Macrory Final Water Outlet	4958439	20/08/2024 09:37	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4958439	20/08/2024 09:37	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4958439	20/08/2024 09:37	Total - Residual disinfectant	mg Cl/l	0.94	
W4523OUT	Lough Macrory Final Water Outlet	4958439	20/08/2024 09:37	Total - Residual disinfectant	mg Cl/l	0.94	
W4523OUT	Lough Macrory Final Water Outlet	4958439	20/08/2024 09:37	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4958439	20/08/2024 09:37	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4958439	20/08/2024 09:37	Turbidity	NTU	0.14	1
W4523OUT	Lough Macrory Final Water Outlet	4958439	20/08/2024 09:37	Turbidity	NTU	0.14	1
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Conductivity	uS/cm 20 C	400	2500
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Free - Residual disinfectant	mg Cl/l	1	
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Total - Residual disinfectant	mg Cl/l	1.35	
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Turbidity	NTU	0.095	1
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	2,4-D	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	2,4-DB	ug/l	<0.016	0.1
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Algae Blue Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Algae Diatom Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Algae Flagellate Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Algae Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Algae Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Aluminium	ug Al/l	5	200
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Asulam	ug/l	<0.015	0.1
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Bentazone	ug/l	<0.0044	0.1
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Bromodichloromethane	ug/l	15	

W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Bromoform	ug/l	<3.5	
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Bromoxynil	ug/l	<0.0079	0.1
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Chloroform	ug/l	36	
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Clopyralid	ug/l	<0.0097	0.1
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Dibromochloromethane	ug/l	4.8	
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Dichlorprop	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Geosmin	ng/l	<1.1	
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Iron	ug/l Fe	<1.538	200
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Manganese	ug Mn/l	<0.80	50
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	MCPA	ug/l	0.014	0.1
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	MCPB	ug/l	<0.015	0.1
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Mecoprop	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	MIB	ng/l	<1.9	
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Microcystin-LR	ug/l	<0.024	
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Propyzamide	ug/l	<0.012	0.1
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Second most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Third most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Total Organic Carbon	mg C/l	2.9	
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Total Trihalomethanes	ug/l	56	100
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	Triclopyr	ug/l	<0.012	0.1
W2514OUT	Seagahan Final Water Outlet	4958442	20/08/2024 11:13	WHO Index		0.42	1
W1301POUT	Moyola PPP Final Water Outlet	4958622	21/08/2024 07:28	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4958622	21/08/2024 07:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4958622	21/08/2024 07:28	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4958622	21/08/2024 07:28	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4958622	21/08/2024 07:28	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4958622	21/08/2024 07:28	Free - Residual disinfectant	mg Cl/l	1.77	
W1301POUT	Moyola PPP Final Water Outlet	4958622	21/08/2024 07:28	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4958622	21/08/2024 07:28	Total - Residual disinfectant	mg Cl/l	1.86	
W1301POUT	Moyola PPP Final Water Outlet	4958622	21/08/2024 07:28	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4958622	21/08/2024 07:28	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Free - Residual disinfectant	mg Cl/l	1.43	
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Total - Residual disinfectant	mg Cl/l	1.49	
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Turbidity	NTU	0.12	1

W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958620	21/08/2024 08:09	Taste - Nature		No taste	
W1302OUT	Lough Fea Final Water Outlet	4958609	21/08/2024 09:24	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4958609	21/08/2024 09:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4958609	21/08/2024 09:24	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4958609	21/08/2024 09:24	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4958609	21/08/2024 09:24	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4958609	21/08/2024 09:24	Free - Residual disinfectant	mg Cl/l	0.75	
W1302OUT	Lough Fea Final Water Outlet	4958609	21/08/2024 09:24	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4958609	21/08/2024 09:24	Total - Residual disinfectant	mg Cl/l	0.77	
W1302OUT	Lough Fea Final Water Outlet	4958609	21/08/2024 09:24	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4958609	21/08/2024 09:24	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Free - Residual disinfectant	mg Cl/l	0.91	
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Free - Residual disinfectant	mg Cl/l	0.91	
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Total - Residual disinfectant	mg Cl/l	0.97	
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Total - Residual disinfectant	mg Cl/l	0.97	
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Aluminium	ug Al/l	16	200
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Aluminium	ug Al/l	16	200
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Iron	ug/l Fe	4.1	200
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Iron	ug/l Fe	4.1	200
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Manganese	ug Mn/l	<0.80	50
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Manganese	ug Mn/l	<0.80	50
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Total Organic Carbon	mg C/l	2.1	
W4523OUT	Lough Macrory Final Water Outlet	4958610	21/08/2024 10:40	Total Organic Carbon	mg C/l	2.1	

W4701OUT	Killyhevlin Final Water Outlet	4958616	21/08/2024 10:41	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4958616	21/08/2024 10:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4958616	21/08/2024 10:41	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4958616	21/08/2024 10:41	Conductivity	uS/cm 20 C	410	2500
W4701OUT	Killyhevlin Final Water Outlet	4958616	21/08/2024 10:41	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4958616	21/08/2024 10:41	Free - Residual disinfectant	mg Cl/l	1.56	
W4701OUT	Killyhevlin Final Water Outlet	4958616	21/08/2024 10:41	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4958616	21/08/2024 10:41	Total - Residual disinfectant	mg Cl/l	1.68	
W4701OUT	Killyhevlin Final Water Outlet	4958616	21/08/2024 10:41	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4958616	21/08/2024 10:41	Turbidity	NTU	0.11	1
W2514OUT	Seagahan Final Water Outlet	4958612	21/08/2024 11:16	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4958612	21/08/2024 11:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4958612	21/08/2024 11:16	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4958612	21/08/2024 11:16	Conductivity	uS/cm 20 C	400	2500
W2514OUT	Seagahan Final Water Outlet	4958612	21/08/2024 11:16	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4958612	21/08/2024 11:16	Free - Residual disinfectant	mg Cl/l	0.84	
W2514OUT	Seagahan Final Water Outlet	4958612	21/08/2024 11:16	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4958612	21/08/2024 11:16	Total - Residual disinfectant	mg Cl/l	1.07	
W2514OUT	Seagahan Final Water Outlet	4958612	21/08/2024 11:16	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4958612	21/08/2024 11:16	Turbidity	NTU	0.098	1
W2308POUT	Castor Bay PPP Final Water Outlet	4958821	22/08/2024 08:15	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958821	22/08/2024 08:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958821	22/08/2024 08:15	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4958821	22/08/2024 08:15	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4958821	22/08/2024 08:15	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958821	22/08/2024 08:15	Free - Residual disinfectant	mg Cl/l	1.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4958821	22/08/2024 08:15	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4958821	22/08/2024 08:15	Total - Residual disinfectant	mg Cl/l	1.64	
W2308POUT	Castor Bay PPP Final Water Outlet	4958821	22/08/2024 08:15	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958821	22/08/2024 08:15	Turbidity	NTU	0.14	1
W1302OUT	Lough Fea Final Water Outlet	4958808	22/08/2024 08:52	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4958808	22/08/2024 08:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4958808	22/08/2024 08:52	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4958808	22/08/2024 08:52	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4958808	22/08/2024 08:52	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4958808	22/08/2024 08:52	Free - Residual disinfectant	mg Cl/l	0.76	
W1302OUT	Lough Fea Final Water Outlet	4958808	22/08/2024 08:52	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4958808	22/08/2024 08:52	Total - Residual disinfectant	mg Cl/l	0.85	
W1302OUT	Lough Fea Final Water Outlet	4958808	22/08/2024 08:52	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4958808	22/08/2024 08:52	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4958808	22/08/2024 08:52	Aluminium	ug Al/l	13	200
W1302OUT	Lough Fea Final Water Outlet	4958808	22/08/2024 08:52	Bromodichloromethane	ug/l	8.6	

W1302OUT	Lough Fea Final Water Outlet	4958808	22/08/2024 08:52	Bromoform	ug/l	<3.5	
W1302OUT	Lough Fea Final Water Outlet	4958808	22/08/2024 08:52	Chloroform	ug/l	49	
W1302OUT	Lough Fea Final Water Outlet	4958808	22/08/2024 08:52	Dibromochloromethane	ug/l	<1.6	
W1302OUT	Lough Fea Final Water Outlet	4958808	22/08/2024 08:52	Iron	ug/l Fe	3.8	200
W1302OUT	Lough Fea Final Water Outlet	4958808	22/08/2024 08:52	Manganese	ug Mn/l	<0.80	50
W1302OUT	Lough Fea Final Water Outlet	4958808	22/08/2024 08:52	Total Organic Carbon	mg C/l	2.2	
W1302OUT	Lough Fea Final Water Outlet	4958808	22/08/2024 08:52	Total Trihalomethanes	ug/l	59	100
W1302OUT	Lough Fea Final Water Outlet	4958808	22/08/2024 08:52	WHO Index		0.32	1
W4701OUT	Killyhevlin Final Water Outlet	4958817	22/08/2024 09:03	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4958817	22/08/2024 09:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4958817	22/08/2024 09:03	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4958817	22/08/2024 09:03	Conductivity	uS/cm 20 C	410	2500
W4701OUT	Killyhevlin Final Water Outlet	4958817	22/08/2024 09:03	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4958817	22/08/2024 09:03	Free - Residual disinfectant	mg Cl/l	1.46	
W4701OUT	Killyhevlin Final Water Outlet	4958817	22/08/2024 09:03	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4958817	22/08/2024 09:03	Total - Residual disinfectant	mg Cl/l	1.52	
W4701OUT	Killyhevlin Final Water Outlet	4958817	22/08/2024 09:03	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4958817	22/08/2024 09:03	Turbidity	NTU	0.11	1
W1301POUT	Moyola PPP Final Water Outlet	4958824	22/08/2024 09:31	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4958824	22/08/2024 09:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4958824	22/08/2024 09:31	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4958824	22/08/2024 09:31	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4958824	22/08/2024 09:31	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4958824	22/08/2024 09:31	Free - Residual disinfectant	mg Cl/l	1.47	
W1301POUT	Moyola PPP Final Water Outlet	4958824	22/08/2024 09:31	Hydrogen Ion	pH value	7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4958824	22/08/2024 09:31	Total - Residual disinfectant	mg Cl/l	1.52	
W1301POUT	Moyola PPP Final Water Outlet	4958824	22/08/2024 09:31	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4958824	22/08/2024 09:31	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4958814	22/08/2024 09:42	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4958814	22/08/2024 09:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4958814	22/08/2024 09:42	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4958814	22/08/2024 09:42	Conductivity	uS/cm 20 C	400	2500
W2514OUT	Seagahan Final Water Outlet	4958814	22/08/2024 09:42	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4958814	22/08/2024 09:42	Free - Residual disinfectant	mg Cl/l	1.04	
W2514OUT	Seagahan Final Water Outlet	4958814	22/08/2024 09:42	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4958814	22/08/2024 09:42	Total - Residual disinfectant	mg Cl/l	1.31	
W2514OUT	Seagahan Final Water Outlet	4958814	22/08/2024 09:42	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4958814	22/08/2024 09:42	Turbidity	NTU	0.098	1
W4523OUT	Lough Macrory Final Water Outlet	4958809	22/08/2024 09:53	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4958809	22/08/2024 09:53	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4958809	22/08/2024 09:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4958809	22/08/2024 09:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	

W4523OUT	Lough Macrory Final Water Outlet	4958809	22/08/2024 09:53	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4958809	22/08/2024 09:53	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4958809	22/08/2024 09:53	Free - Residual disinfectant	mg Cl/l	0.8	
W4523OUT	Lough Macrory Final Water Outlet	4958809	22/08/2024 09:53	Free - Residual disinfectant	mg Cl/l	0.8	
W4523OUT	Lough Macrory Final Water Outlet	4958809	22/08/2024 09:53	Total - Residual disinfectant	mg Cl/l	0.93	
W4523OUT	Lough Macrory Final Water Outlet	4958809	22/08/2024 09:53	Total - Residual disinfectant	mg Cl/l	0.93	
W4523OUT	Lough Macrory Final Water Outlet	4958809	22/08/2024 09:53	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4958809	22/08/2024 09:53	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4958981	23/08/2024 07:51	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4958981	23/08/2024 07:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4958981	23/08/2024 07:51	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4958981	23/08/2024 07:51	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4958981	23/08/2024 07:51	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4958981	23/08/2024 07:51	Free - Residual disinfectant	mg Cl/l	1.53	
W1301POUT	Moyola PPP Final Water Outlet	4958981	23/08/2024 07:51	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4958981	23/08/2024 07:51	Total - Residual disinfectant	mg Cl/l	1.6	
W1301POUT	Moyola PPP Final Water Outlet	4958981	23/08/2024 07:51	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4958981	23/08/2024 07:51	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4958980	23/08/2024 08:40	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958980	23/08/2024 08:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4958980	23/08/2024 08:40	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4958980	23/08/2024 08:40	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4958980	23/08/2024 08:40	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958980	23/08/2024 08:40	Free - Residual disinfectant	mg Cl/l	1.57	
W2308POUT	Castor Bay PPP Final Water Outlet	4958980	23/08/2024 08:40	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4958980	23/08/2024 08:40	Total - Residual disinfectant	mg Cl/l	1.66	
W2308POUT	Castor Bay PPP Final Water Outlet	4958980	23/08/2024 08:40	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4958980	23/08/2024 08:40	Turbidity	NTU	0.13	1
W4701OUT	Killyhevlin Final Water Outlet	4958976	23/08/2024 08:57	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4958976	23/08/2024 08:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4958976	23/08/2024 08:57	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4958976	23/08/2024 08:57	Conductivity	uS/cm 20 C	230	2500
W4701OUT	Killyhevlin Final Water Outlet	4958976	23/08/2024 08:57	Free - Residual disinfectant	mg Cl/l	1.69	
W4701OUT	Killyhevlin Final Water Outlet	4958976	23/08/2024 08:57	Hydrogen Ion	pH value	7.7	9.5
W4701OUT	Killyhevlin Final Water Outlet	4958976	23/08/2024 08:57	Total - Residual disinfectant	mg Cl/l	1.78	
W4701OUT	Killyhevlin Final Water Outlet	4958976	23/08/2024 08:57	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4958974	23/08/2024 09:15	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4958974	23/08/2024 09:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4958974	23/08/2024 09:15	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4958974	23/08/2024 09:15	Conductivity	uS/cm 20 C	120	2500
W1302OUT	Lough Fea Final Water Outlet	4958974	23/08/2024 09:15	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4958974	23/08/2024 09:15	Free - Residual disinfectant	mg Cl/l	0.78	

W1302OUT	Lough Fea Final Water Outlet	4958974	23/08/2024 09:15	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4958974	23/08/2024 09:15	Total - Residual disinfectant	mg Cl/l	0.91	
W1302OUT	Lough Fea Final Water Outlet	4958974	23/08/2024 09:15	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4958974	23/08/2024 09:15	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4961127	23/08/2024 09:20	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4961127	23/08/2024 09:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4961127	23/08/2024 09:20	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4961127	23/08/2024 09:20	Conductivity	uS/cm 20 C	390	2500
W2514OUT	Seagahan Final Water Outlet	4961127	23/08/2024 09:20	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4961127	23/08/2024 09:20	Free - Residual disinfectant	mg Cl/l	1.05	
W2514OUT	Seagahan Final Water Outlet	4961127	23/08/2024 09:20	Hydrogen Ion	pH value	7.6	9.5
W2514OUT	Seagahan Final Water Outlet	4961127	23/08/2024 09:20	Total - Residual disinfectant	mg Cl/l	1.27	
W2514OUT	Seagahan Final Water Outlet	4961127	23/08/2024 09:20	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4961127	23/08/2024 09:20	Turbidity	NTU	0.1	1
W4523OUT	Lough Macrory Final Water Outlet	4961123	23/08/2024 10:49	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4961123	23/08/2024 10:49	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4961123	23/08/2024 10:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4961123	23/08/2024 10:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4961123	23/08/2024 10:49	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4961123	23/08/2024 10:49	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4961123	23/08/2024 10:49	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4961123	23/08/2024 10:49	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4961123	23/08/2024 10:49	Free - Residual disinfectant	mg Cl/l	0.78	
W4523OUT	Lough Macrory Final Water Outlet	4961123	23/08/2024 10:49	Free - Residual disinfectant	mg Cl/l	0.78	
W4523OUT	Lough Macrory Final Water Outlet	4961123	23/08/2024 10:49	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4961123	23/08/2024 10:49	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4961123	23/08/2024 10:49	Total - Residual disinfectant	mg Cl/l	0.92	
W4523OUT	Lough Macrory Final Water Outlet	4961123	23/08/2024 10:49	Total - Residual disinfectant	mg Cl/l	0.92	
W4523OUT	Lough Macrory Final Water Outlet	4961123	23/08/2024 10:49	Turbidity	NTU	0.095	1
W4523OUT	Lough Macrory Final Water Outlet	4961123	23/08/2024 10:49	Turbidity	NTU	0.095	1
W2308POUT	Castor Bay PPP Final Water Outlet	4959085	24/08/2024 08:02	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4959085	24/08/2024 08:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4959085	24/08/2024 08:02	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4959085	24/08/2024 08:02	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4959085	24/08/2024 08:02	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4959085	24/08/2024 08:02	Free - Residual disinfectant	mg Cl/l	1.07	
W2308POUT	Castor Bay PPP Final Water Outlet	4959085	24/08/2024 08:02	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4959085	24/08/2024 08:02	Total - Residual disinfectant	mg Cl/l	1.18	
W2308POUT	Castor Bay PPP Final Water Outlet	4959085	24/08/2024 08:02	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4959085	24/08/2024 08:02	Turbidity	NTU	0.35	1
W1302OUT	Lough Fea Final Water Outlet	4959081	24/08/2024 08:33	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4959081	24/08/2024 08:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	

W1302OUT	Lough Fea Final Water Outlet	4959081	24/08/2024 08:33	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4959081	24/08/2024 08:33	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4959081	24/08/2024 08:33	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4959081	24/08/2024 08:33	Free - Residual disinfectant	mg Cl/l	0.8	
W1302OUT	Lough Fea Final Water Outlet	4959081	24/08/2024 08:33	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4959081	24/08/2024 08:33	Total - Residual disinfectant	mg Cl/l	0.88	
W1302OUT	Lough Fea Final Water Outlet	4959081	24/08/2024 08:33	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4959081	24/08/2024 08:33	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4959086	24/08/2024 09:11	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4959086	24/08/2024 09:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4959086	24/08/2024 09:11	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4959086	24/08/2024 09:11	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4959086	24/08/2024 09:11	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4959086	24/08/2024 09:11	Free - Residual disinfectant	mg Cl/l	1.48	
W1301POUT	Moyola PPP Final Water Outlet	4959086	24/08/2024 09:11	Hydrogen Ion	pH value	7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4959086	24/08/2024 09:11	Total - Residual disinfectant	mg Cl/l	1.62	
W1301POUT	Moyola PPP Final Water Outlet	4959086	24/08/2024 09:11	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4959086	24/08/2024 09:11	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4959082	24/08/2024 09:14	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4959082	24/08/2024 09:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4959082	24/08/2024 09:14	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4959082	24/08/2024 09:14	Conductivity	uS/cm 20 C	400	2500
W4701OUT	Killyhevlin Final Water Outlet	4959082	24/08/2024 09:14	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4959082	24/08/2024 09:14	Free - Residual disinfectant	mg Cl/l	1.48	
W4701OUT	Killyhevlin Final Water Outlet	4959082	24/08/2024 09:14	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4959082	24/08/2024 09:14	Total - Residual disinfectant	mg Cl/l	1.59	
W4701OUT	Killyhevlin Final Water Outlet	4959082	24/08/2024 09:14	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4959082	24/08/2024 09:14	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4959099	25/08/2024 07:32	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4959099	25/08/2024 07:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4959099	25/08/2024 07:32	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4959099	25/08/2024 07:32	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4959099	25/08/2024 07:32	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4959099	25/08/2024 07:32	Free - Residual disinfectant	mg Cl/l	0.8	
W1302OUT	Lough Fea Final Water Outlet	4959099	25/08/2024 07:32	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4959099	25/08/2024 07:32	Total - Residual disinfectant	mg Cl/l	0.89	
W1302OUT	Lough Fea Final Water Outlet	4959099	25/08/2024 07:32	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4959099	25/08/2024 07:32	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4959103	25/08/2024 07:34	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4959103	25/08/2024 07:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4959103	25/08/2024 07:34	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4959103	25/08/2024 07:34	Conductivity	uS/cm 20 C	380	2500

W2308POUT	Castor Bay PPP Final Water Outlet	4959103	25/08/2024 07:34	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4959103	25/08/2024 07:34	Free - Residual disinfectant	mg Cl/l	1.48	
W2308POUT	Castor Bay PPP Final Water Outlet	4959103	25/08/2024 07:34	Hydrogen Ion	pH value	7.7	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4959103	25/08/2024 07:34	Total - Residual disinfectant	mg Cl/l	1.7	
W2308POUT	Castor Bay PPP Final Water Outlet	4959103	25/08/2024 07:34	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4959103	25/08/2024 07:34	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4959104	25/08/2024 08:08	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4959104	25/08/2024 08:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4959104	25/08/2024 08:08	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4959104	25/08/2024 08:08	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4959104	25/08/2024 08:08	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4959104	25/08/2024 08:08	Free - Residual disinfectant	mg Cl/l	1.39	
W1301POUT	Moyola PPP Final Water Outlet	4959104	25/08/2024 08:08	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4959104	25/08/2024 08:08	Total - Residual disinfectant	mg Cl/l	1.47	
W1301POUT	Moyola PPP Final Water Outlet	4959104	25/08/2024 08:08	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4959104	25/08/2024 08:08	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4959100	25/08/2024 10:21	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4959100	25/08/2024 10:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4959100	25/08/2024 10:21	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4959100	25/08/2024 10:21	Conductivity	uS/cm 20 C	410	2500
W4701OUT	Killyhevlin Final Water Outlet	4959100	25/08/2024 10:21	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4959100	25/08/2024 10:21	Free - Residual disinfectant	mg Cl/l	1.56	
W4701OUT	Killyhevlin Final Water Outlet	4959100	25/08/2024 10:21	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4959100	25/08/2024 10:21	Total - Residual disinfectant	mg Cl/l	1.64	
W4701OUT	Killyhevlin Final Water Outlet	4959100	25/08/2024 10:21	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4959100	25/08/2024 10:21	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4961122	26/08/2024 08:14	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4961122	26/08/2024 08:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4961122	26/08/2024 08:14	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4961122	26/08/2024 08:14	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4961122	26/08/2024 08:14	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4961122	26/08/2024 08:14	Free - Residual disinfectant	mg Cl/l	0.85	
W1302OUT	Lough Fea Final Water Outlet	4961122	26/08/2024 08:14	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4961122	26/08/2024 08:14	Total - Residual disinfectant	mg Cl/l	1.02	
W1302OUT	Lough Fea Final Water Outlet	4961122	26/08/2024 08:14	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4961122	26/08/2024 08:14	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4961137	26/08/2024 08:55	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4961137	26/08/2024 08:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4961137	26/08/2024 08:55	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4961137	26/08/2024 08:55	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4961137	26/08/2024 08:55	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4961137	26/08/2024 08:55	Free - Residual disinfectant	mg Cl/l	1.5	

W1301POUT	Moyola PPP Final Water Outlet	4961137	26/08/2024 08:55	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4961137	26/08/2024 08:55	Total - Residual disinfectant	mg Cl/l	1.57	
W1301POUT	Moyola PPP Final Water Outlet	4961137	26/08/2024 08:55	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4961137	26/08/2024 08:55	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4961134	26/08/2024 09:31	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961134	26/08/2024 09:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961134	26/08/2024 09:31	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4961134	26/08/2024 09:31	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4961134	26/08/2024 09:31	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961134	26/08/2024 09:31	Free - Residual disinfectant	mg Cl/l	1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4961134	26/08/2024 09:31	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4961134	26/08/2024 09:31	Total - Residual disinfectant	mg Cl/l	1.28	
W2308POUT	Castor Bay PPP Final Water Outlet	4961134	26/08/2024 09:31	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961134	26/08/2024 09:31	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4961130	26/08/2024 10:21	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4961130	26/08/2024 10:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4961130	26/08/2024 10:21	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4961130	26/08/2024 10:21	Conductivity	uS/cm 20 C	400	2500
W4701OUT	Killyhevlin Final Water Outlet	4961130	26/08/2024 10:21	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4961130	26/08/2024 10:21	Free - Residual disinfectant	mg Cl/l	1.53	
W4701OUT	Killyhevlin Final Water Outlet	4961130	26/08/2024 10:21	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4961130	26/08/2024 10:21	Total - Residual disinfectant	mg Cl/l	1.62	
W4701OUT	Killyhevlin Final Water Outlet	4961130	26/08/2024 10:21	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4961130	26/08/2024 10:21	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Colony Counts 37 (48hrs)	CFU/1 ml	1	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Free - Residual disinfectant	mg Cl/l	1.39	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Total - Residual disinfectant	mg Cl/l	1.47	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	2,4-D	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	2,4-DB	ug/l	<0.016	0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Algae Blue Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Algae Diatom Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Algae Flagellate Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Algae Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Algae Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Aluminium	ug Al/l	27	200

W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Asulam	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Bentazone	ug/l	<0.0044	0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Bromodichloromethane	ug/l	4.6	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Bromoform	ug/l	<3.5	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Bromoxynil	ug/l	<0.0079	0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Chloroform	ug/l	9.2	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Clopyralid	ug/l	<0.0097	0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Dibromochloromethane	ug/l	2.9	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Dichlorprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Geosmin	ng/l	<1.1	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Iron	ug/l Fe	1.8	200
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Manganese	ug Mn/l	<0.80	50
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	MCPA	ug/l	0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	MCPB	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Mecoprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	MIB	ng/l	9.5	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Microcystin-LR	ug/l	<0.024	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Propyzamide	ug/l	<0.012	0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Second most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Taste - Nature		No taste	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Third most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Total Organic Carbon	mg C/l	2.9	
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Total Trihalomethanes	ug/l	17	100
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	Triclopyr	ug/l	<0.012	0.1
W1301POUT	Moyola PPP Final Water Outlet	4961312	27/08/2024 07:05	WHO Index		0.14	1
W2514OUT	Seagahan Final Water Outlet	4961294	27/08/2024 08:19	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4961294	27/08/2024 08:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4961294	27/08/2024 08:19	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4961294	27/08/2024 08:19	Conductivity	uS/cm 20 C	400	2500
W2514OUT	Seagahan Final Water Outlet	4961294	27/08/2024 08:19	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4961294	27/08/2024 08:19	Free - Residual disinfectant	mg Cl/l	0.99	
W2514OUT	Seagahan Final Water Outlet	4961294	27/08/2024 08:19	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4961294	27/08/2024 08:19	Total - Residual disinfectant	mg Cl/l	1.09	
W2514OUT	Seagahan Final Water Outlet	4961294	27/08/2024 08:19	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4961294	27/08/2024 08:19	Turbidity	NTU	0.1	1
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Colour	mg/l Pt/Co	<4.56	20

W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Free - Residual disinfectant	mg Cl/l	0.73	
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Total - Residual disinfectant	mg Cl/l	0.83	
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	2,4-D	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	2,4-DB	ug/l	<0.016	0.1
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Aluminium	ug Al/l	12	200
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Asulam	ug/l	<0.015	0.1
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Bentazone	ug/l	<0.0044	0.1
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Bromodichloromethane	ug/l	9.1	
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Bromoform	ug/l	<3.5	
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Bromoxynil	ug/l	<0.0079	0.1
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Chloroform	ug/l	49	
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Clopyralid	ug/l	<0.0097	0.1
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Dibromochloromethane	ug/l	<1.6	
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Dichlorprop	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Iron	ug/l Fe	3.9	200
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Manganese	ug Mn/l	<0.80	50
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	MCPA	ug/l	<0.0093	0.1
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	MCPB	ug/l	<0.015	0.1
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Mecoprop	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Propyzamide	ug/l	<0.012	0.1
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Total Organic Carbon	mg C/l	2.2	
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Total Trihalomethanes	ug/l	60	100
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	Triclopyr	ug/l	<0.012	0.1
W1302OUT	Lough Fea Final Water Outlet	4961290	27/08/2024 08:53	WHO Index		0.33	1
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Conductivity	uS/cm 20 C	400	2500
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Free - Residual disinfectant	mg Cl/l	1.38	
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Total - Residual disinfectant	mg Cl/l	1.46	
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	2,4-D	ug/l	<0.011	0.1
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	2,4-DB	ug/l	<0.016	0.1
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Algae Blue Green Total	per ml	0	

W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Algae Diatom Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Algae Flagellate Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Algae Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Algae Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Aluminium	ug Al/l	25	200
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Asulam	ug/l	<0.015	0.1
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Bentazone	ug/l	<0.0044	0.1
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Bromoxynil	ug/l	<0.0079	0.1
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Clopyralid	ug/l	<0.0097	0.1
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Dichlorprop	ug/l	<0.011	0.1
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Iron	ug/l Fe	5.4	200
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Manganese	ug Mn/l	1.3	50
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	MCPA	ug/l	0.02	0.1
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	MCPB	ug/l	<0.015	0.1
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Mecoprop	ug/l	<0.011	0.1
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Most numerous Algae		-	
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Odour	Diln No	0	0
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Odour - Nature		No odour	
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Propyzamide	ug/l	<0.012	0.1
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Second most numerous Algae		-	
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Taste	Diln No	0	0
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Taste - Nature		No taste	
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Third most numerous Algae		-	
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Total Organic Carbon	mg C/l	2.4	
W4701OUT	Killyhevlin Final Water Outlet	4961300	27/08/2024 09:57	Triclopyr	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961291	27/08/2024 11:02	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4961291	27/08/2024 11:02	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4961291	27/08/2024 11:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4961291	27/08/2024 11:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4961291	27/08/2024 11:02	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4961291	27/08/2024 11:02	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4961291	27/08/2024 11:02	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4961291	27/08/2024 11:02	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4961291	27/08/2024 11:02	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4961291	27/08/2024 11:02	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4961291	27/08/2024 11:02	Free - Residual disinfectant	mg Cl/l	0.69	
W4523OUT	Lough Macrory Final Water Outlet	4961291	27/08/2024 11:02	Free - Residual disinfectant	mg Cl/l	0.69	
W4523OUT	Lough Macrory Final Water Outlet	4961291	27/08/2024 11:02	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4961291	27/08/2024 11:02	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4961291	27/08/2024 11:02	Total - Residual disinfectant	mg Cl/l	0.74	
W4523OUT	Lough Macrory Final Water Outlet	4961291	27/08/2024 11:02	Total - Residual disinfectant	mg Cl/l	0.74	
W4523OUT	Lough Macrory Final Water Outlet	4961291	27/08/2024 11:02	Total Coliforms	CFU/100 ml	0	0

W4523OUT	Lough Macrory Final Water Outlet	4961291	27/08/2024 11:02	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4961291	27/08/2024 11:02	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4961291	27/08/2024 11:02	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Free - Residual disinfectant	mg Cl/l	1.45	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Nitrite	mg/l	<0.03	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Total - Residual disinfectant	mg Cl/l	1.62	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Algae Diatom Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Algae Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Aluminium	ug Al/l	16	200
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Bromodichloromethane	ug/l	6	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Dibromochloromethane	ug/l	4.2	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Iron	ug/l Fe	2.2	200
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Manganese	ug Mn/l	<0.80	50
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	MIB	ng/l	<1.9	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Microcystin-LR	ug/l	<0.024	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Second most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Third most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Total Organic Carbon	mg C/l	2.7	
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	Total Trihalomethanes	ug/l	21	100
W2308POUT	Castor Bay PPP Final Water Outlet	4961306	27/08/2024 11:31	WHO Index		0.18	1
W2514OUT	Seagahan Final Water Outlet	4961572	28/08/2024 08:14	Colony Counts 22	CFU/1 ml	2	
W2514OUT	Seagahan Final Water Outlet	4961572	28/08/2024 08:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4961572	28/08/2024 08:14	Colour	mg/l Pt/Co	<4.56	20

W2514OUT	Seagahan Final Water Outlet	4961572	28/08/2024 08:14	Conductivity	uS/cm 20 C	400	2500
W2514OUT	Seagahan Final Water Outlet	4961572	28/08/2024 08:14	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4961572	28/08/2024 08:14	Free - Residual disinfectant	mg Cl/l	1.02	
W2514OUT	Seagahan Final Water Outlet	4961572	28/08/2024 08:14	Hydrogen Ion	pH value	7.4	9.5
W2514OUT	Seagahan Final Water Outlet	4961572	28/08/2024 08:14	Total - Residual disinfectant	mg Cl/l	1.07	
W2514OUT	Seagahan Final Water Outlet	4961572	28/08/2024 08:14	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4961572	28/08/2024 08:14	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4961572	28/08/2024 08:14	Algae Blue Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4961572	28/08/2024 08:14	Algae Diatom Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4961572	28/08/2024 08:14	Algae Flagellate Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4961572	28/08/2024 08:14	Algae Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4961572	28/08/2024 08:14	Algae Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4961572	28/08/2024 08:14	Aluminium	ug Al/l	5.3	200
W2514OUT	Seagahan Final Water Outlet	4961572	28/08/2024 08:14	Iron	ug/l Fe	<1.538	200
W2514OUT	Seagahan Final Water Outlet	4961572	28/08/2024 08:14	Manganese	ug Mn/l	1.3	50
W2514OUT	Seagahan Final Water Outlet	4961572	28/08/2024 08:14	Most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4961572	28/08/2024 08:14	Second most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4961572	28/08/2024 08:14	Third most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4961572	28/08/2024 08:14	Total Organic Carbon	mg C/l	3.2	
W1302OUT	Lough Fea Final Water Outlet	4961566	28/08/2024 09:43	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4961566	28/08/2024 09:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4961566	28/08/2024 09:43	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4961566	28/08/2024 09:43	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4961566	28/08/2024 09:43	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4961566	28/08/2024 09:43	Free - Residual disinfectant	mg Cl/l	0.71	
W1302OUT	Lough Fea Final Water Outlet	4961566	28/08/2024 09:43	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4961566	28/08/2024 09:43	Total - Residual disinfectant	mg Cl/l	0.76	
W1302OUT	Lough Fea Final Water Outlet	4961566	28/08/2024 09:43	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4961566	28/08/2024 09:43	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Free - Residual disinfectant	mg Cl/l	1.77	
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Total - Residual disinfectant	mg Cl/l	1.92	
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Taste	Diln No	0	0

W2308POUT	Castor Bay PPP Final Water Outlet	4961581	28/08/2024 10:03	Taste - Nature		No taste	
W4701OUT	Killyhevlin Final Water Outlet	4961575	28/08/2024 10:49	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4961575	28/08/2024 10:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4961575	28/08/2024 10:49	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4961575	28/08/2024 10:49	Conductivity	uS/cm 20 C	400	2500
W4701OUT	Killyhevlin Final Water Outlet	4961575	28/08/2024 10:49	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4961575	28/08/2024 10:49	Free - Residual disinfectant	mg Cl/l	1.26	
W4701OUT	Killyhevlin Final Water Outlet	4961575	28/08/2024 10:49	Hydrogen Ion	pH value	8.1	9.5
W4701OUT	Killyhevlin Final Water Outlet	4961575	28/08/2024 10:49	Total - Residual disinfectant	mg Cl/l	1.37	
W4701OUT	Killyhevlin Final Water Outlet	4961575	28/08/2024 10:49	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4961575	28/08/2024 10:49	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4961584	28/08/2024 10:50	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4961584	28/08/2024 10:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4961584	28/08/2024 10:50	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4961584	28/08/2024 10:50	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4961584	28/08/2024 10:50	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4961584	28/08/2024 10:50	Free - Residual disinfectant	mg Cl/l	1.25	
W1301POUT	Moyola PPP Final Water Outlet	4961584	28/08/2024 10:50	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4961584	28/08/2024 10:50	Total - Residual disinfectant	mg Cl/l	1.58	
W1301POUT	Moyola PPP Final Water Outlet	4961584	28/08/2024 10:50	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4961584	28/08/2024 10:50	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4961567	28/08/2024 11:13	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4961567	28/08/2024 11:13	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4961567	28/08/2024 11:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4961567	28/08/2024 11:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4961567	28/08/2024 11:13	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4961567	28/08/2024 11:13	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4961567	28/08/2024 11:13	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4961567	28/08/2024 11:13	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4961567	28/08/2024 11:13	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4961567	28/08/2024 11:13	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4961567	28/08/2024 11:13	Free - Residual disinfectant	mg Cl/l	0.69	
W4523OUT	Lough Macrory Final Water Outlet	4961567	28/08/2024 11:13	Free - Residual disinfectant	mg Cl/l	0.69	
W4523OUT	Lough Macrory Final Water Outlet	4961567	28/08/2024 11:13	Hydrogen Ion	pH value	7.4	9.5
W4523OUT	Lough Macrory Final Water Outlet	4961567	28/08/2024 11:13	Hydrogen Ion	pH value	7.4	9.5
W4523OUT	Lough Macrory Final Water Outlet	4961567	28/08/2024 11:13	Total - Residual disinfectant	mg Cl/l	0.75	
W4523OUT	Lough Macrory Final Water Outlet	4961567	28/08/2024 11:13	Total - Residual disinfectant	mg Cl/l	0.75	
W4523OUT	Lough Macrory Final Water Outlet	4961567	28/08/2024 11:13	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4961567	28/08/2024 11:13	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4961567	28/08/2024 11:13	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4961567	28/08/2024 11:13	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4961755	29/08/2024 08:17	Colony Counts 22	CFU/1 ml	0	

W2514OUT	Seagahan Final Water Outlet	4961755	29/08/2024 08:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4961755	29/08/2024 08:17	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4961755	29/08/2024 08:17	Conductivity	uS/cm 20 C	400	2500
W2514OUT	Seagahan Final Water Outlet	4961755	29/08/2024 08:17	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4961755	29/08/2024 08:17	Free - Residual disinfectant	mg Cl/l	0.94	
W2514OUT	Seagahan Final Water Outlet	4961755	29/08/2024 08:17	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4961755	29/08/2024 08:17	Total - Residual disinfectant	mg Cl/l	1.03	
W2514OUT	Seagahan Final Water Outlet	4961755	29/08/2024 08:17	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4961755	29/08/2024 08:17	Turbidity	NTU	0.12	1
W1302OUT	Lough Fea Final Water Outlet	4961752	29/08/2024 08:48	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4961752	29/08/2024 08:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4961752	29/08/2024 08:48	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4961752	29/08/2024 08:48	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4961752	29/08/2024 08:48	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4961752	29/08/2024 08:48	Free - Residual disinfectant	mg Cl/l	0.76	
W1302OUT	Lough Fea Final Water Outlet	4961752	29/08/2024 08:48	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4961752	29/08/2024 08:48	Total - Residual disinfectant	mg Cl/l	0.8	
W1302OUT	Lough Fea Final Water Outlet	4961752	29/08/2024 08:48	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4961752	29/08/2024 08:48	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Free - Residual disinfectant	mg Cl/l	0.77	
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Free - Residual disinfectant	mg Cl/l	0.77	
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Total - Residual disinfectant	mg Cl/l	0.84	
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Total - Residual disinfectant	mg Cl/l	0.84	
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	2,4-D	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	2,4-D	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	2,4-DB	ug/l	<0.016	0.1

W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	2,4-DB	ug/l	<0.016	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Aluminium	ug Al/l	16	200
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Aluminium	ug Al/l	16	200
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Asulam	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Asulam	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Bentazone	ug/l	<0.0044	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Bentazone	ug/l	<0.0044	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Bromoxynil	ug/l	<0.0079	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Bromoxynil	ug/l	<0.0079	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Clopyralid	ug/l	<0.0097	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Clopyralid	ug/l	<0.0097	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Dichlorprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Dichlorprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Iron	ug/l Fe	4.9	200
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Iron	ug/l Fe	4.9	200
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Manganese	ug Mn/l	<0.80	50
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Manganese	ug Mn/l	<0.80	50
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	MCPA	ug/l	<0.0093	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	MCPA	ug/l	<0.0093	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	MCPB	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	MCPB	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Mecoprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Mecoprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Propyzamide	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Propyzamide	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Total Organic Carbon	mg C/l	2.1	
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Total Organic Carbon	mg C/l	2.1	
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Triclopyr	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4961753	29/08/2024 09:49	Triclopyr	ug/l	<0.012	0.1
W4701OUT	Killyhevlin Final Water Outlet	4961760	29/08/2024 11:07	Colony Counts 22	CFU/1 ml	44	
W4701OUT	Killyhevlin Final Water Outlet	4961760	29/08/2024 11:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4961760	29/08/2024 11:07	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4961760	29/08/2024 11:07	Conductivity	uS/cm 20 C	390	2500
W4701OUT	Killyhevlin Final Water Outlet	4961760	29/08/2024 11:07	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4961760	29/08/2024 11:07	Free - Residual disinfectant	mg Cl/l	1.36	
W4701OUT	Killyhevlin Final Water Outlet	4961760	29/08/2024 11:07	Hydrogen Ion	pH value	8.1	9.5
W4701OUT	Killyhevlin Final Water Outlet	4961760	29/08/2024 11:07	Total - Residual disinfectant	mg Cl/l	1.49	
W4701OUT	Killyhevlin Final Water Outlet	4961760	29/08/2024 11:07	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4961760	29/08/2024 11:07	Turbidity	NTU	0.11	1
W1301POUT	Moyola PPP Final Water Outlet	4961766	29/08/2024 11:23	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4961766	29/08/2024 11:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4961766	29/08/2024 11:23	Colour	mg/l Pt/Co	<4.56	20

W1301POUT	Moyola PPP Final Water Outlet	4961766	29/08/2024 11:23	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4961766	29/08/2024 11:23	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4961766	29/08/2024 11:23	Free - Residual disinfectant	mg Cl/l	1.4	
W1301POUT	Moyola PPP Final Water Outlet	4961766	29/08/2024 11:23	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4961766	29/08/2024 11:23	Total - Residual disinfectant	mg Cl/l	1.56	
W1301POUT	Moyola PPP Final Water Outlet	4961766	29/08/2024 11:23	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4961766	29/08/2024 11:23	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	Free - Residual disinfectant	mg Cl/l	1.61	
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	Total - Residual disinfectant	mg Cl/l	1.79	
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961764	29/08/2024 12:20	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4961905	30/08/2024 08:28	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4961905	30/08/2024 08:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4961905	30/08/2024 08:28	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4961905	30/08/2024 08:28	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4961905	30/08/2024 08:28	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4961905	30/08/2024 08:28	Free - Residual disinfectant	mg Cl/l	0.84	
W1302OUT	Lough Fea Final Water Outlet	4961905	30/08/2024 08:28	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4961905	30/08/2024 08:28	Total - Residual disinfectant	mg Cl/l	0.94	
W1302OUT	Lough Fea Final Water Outlet	4961905	30/08/2024 08:28	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4961905	30/08/2024 08:28	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4961912	30/08/2024 09:28	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4961912	30/08/2024 09:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4961912	30/08/2024 09:28	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4961912	30/08/2024 09:28	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4961912	30/08/2024 09:28	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4961912	30/08/2024 09:28	Free - Residual disinfectant	mg Cl/l	1.47	
W1301POUT	Moyola PPP Final Water Outlet	4961912	30/08/2024 09:28	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4961912	30/08/2024 09:28	Total - Residual disinfectant	mg Cl/l	1.52	
W1301POUT	Moyola PPP Final Water Outlet	4961912	30/08/2024 09:28	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4961912	30/08/2024 09:28	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4961907	30/08/2024 11:13	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4961907	30/08/2024 11:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4961907	30/08/2024 11:13	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4961907	30/08/2024 11:13	Conductivity	uS/cm 20 C	380	2500
W4701OUT	Killyhevlin Final Water Outlet	4961907	30/08/2024 11:13	E. coli	CFU/100 ml	0	0

W4701OUT	Killyhevlin Final Water Outlet	4961907	30/08/2024 11:13	Free - Residual disinfectant	mg Cl/l	1.4	
W4701OUT	Killyhevlin Final Water Outlet	4961907	30/08/2024 11:13	Hydrogen Ion	pH value	8.1	9.5
W4701OUT	Killyhevlin Final Water Outlet	4961907	30/08/2024 11:13	Total - Residual disinfectant	mg Cl/l	1.53	
W4701OUT	Killyhevlin Final Water Outlet	4961907	30/08/2024 11:13	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4961907	30/08/2024 11:13	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4961911	30/08/2024 11:27	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961911	30/08/2024 11:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961911	30/08/2024 11:27	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4961911	30/08/2024 11:27	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4961911	30/08/2024 11:27	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961911	30/08/2024 11:27	Free - Residual disinfectant	mg Cl/l	1.4	
W2308POUT	Castor Bay PPP Final Water Outlet	4961911	30/08/2024 11:27	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4961911	30/08/2024 11:27	Total - Residual disinfectant	mg Cl/l	1.61	
W2308POUT	Castor Bay PPP Final Water Outlet	4961911	30/08/2024 11:27	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961911	30/08/2024 11:27	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4961986	31/08/2024 08:38	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4961986	31/08/2024 08:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4961986	31/08/2024 08:38	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4961986	31/08/2024 08:38	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4961986	31/08/2024 08:38	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4961986	31/08/2024 08:38	Free - Residual disinfectant	mg Cl/l	1.31	
W1301POUT	Moyola PPP Final Water Outlet	4961986	31/08/2024 08:38	Hydrogen Ion	pH value	7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4961986	31/08/2024 08:38	Total - Residual disinfectant	mg Cl/l	1.62	
W1301POUT	Moyola PPP Final Water Outlet	4961986	31/08/2024 08:38	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4961986	31/08/2024 08:38	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4961980	31/08/2024 09:13	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4961980	31/08/2024 09:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4961980	31/08/2024 09:13	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4961980	31/08/2024 09:13	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4961980	31/08/2024 09:13	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4961980	31/08/2024 09:13	Free - Residual disinfectant	mg Cl/l	1.04	
W1302OUT	Lough Fea Final Water Outlet	4961980	31/08/2024 09:13	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4961980	31/08/2024 09:13	Total - Residual disinfectant	mg Cl/l	1.09	
W1302OUT	Lough Fea Final Water Outlet	4961980	31/08/2024 09:13	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4961980	31/08/2024 09:13	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4961981	31/08/2024 09:30	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4961981	31/08/2024 09:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4961981	31/08/2024 09:30	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4961981	31/08/2024 09:30	Conductivity	uS/cm 20 C	390	2500
W4701OUT	Killyhevlin Final Water Outlet	4961981	31/08/2024 09:30	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4961981	31/08/2024 09:30	Free - Residual disinfectant	mg Cl/l	1.15	
W4701OUT	Killyhevlin Final Water Outlet	4961981	31/08/2024 09:30	Hydrogen Ion	pH value	8	9.5

W4701OUT	Killyhevlin Final Water Outlet	4961981	31/08/2024 09:30	Total - Residual disinfectant	mg Cl/l	1.25	
W4701OUT	Killyhevlin Final Water Outlet	4961981	31/08/2024 09:30	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4961981	31/08/2024 09:30	Turbidity	NTU	0.14	1
W2308POUT	Castor Bay PPP Final Water Outlet	4961985	31/08/2024 10:59	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961985	31/08/2024 10:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4961985	31/08/2024 10:59	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4961985	31/08/2024 10:59	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4961985	31/08/2024 10:59	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961985	31/08/2024 10:59	Free - Residual disinfectant	mg Cl/l	1.66	
W2308POUT	Castor Bay PPP Final Water Outlet	4961985	31/08/2024 10:59	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4961985	31/08/2024 10:59	Total - Residual disinfectant	mg Cl/l	1.83	
W2308POUT	Castor Bay PPP Final Water Outlet	4961985	31/08/2024 10:59	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4961985	31/08/2024 10:59	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4962004	01/09/2024 08:55	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4962004	01/09/2024 08:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4962004	01/09/2024 08:55	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4962004	01/09/2024 08:55	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4962004	01/09/2024 08:55	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4962004	01/09/2024 08:55	Free - Residual disinfectant	mg Cl/l	1.18	
W1301POUT	Moyola PPP Final Water Outlet	4962004	01/09/2024 08:55	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4962004	01/09/2024 08:55	Total - Residual disinfectant	mg Cl/l	1.33	
W1301POUT	Moyola PPP Final Water Outlet	4962004	01/09/2024 08:55	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4962004	01/09/2024 08:55	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4961998	01/09/2024 09:30	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4961998	01/09/2024 09:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4961998	01/09/2024 09:30	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4961998	01/09/2024 09:30	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4961998	01/09/2024 09:30	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4961998	01/09/2024 09:30	Free - Residual disinfectant	mg Cl/l	0.78	
W1302OUT	Lough Fea Final Water Outlet	4961998	01/09/2024 09:30	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4961998	01/09/2024 09:30	Total - Residual disinfectant	mg Cl/l	0.84	
W1302OUT	Lough Fea Final Water Outlet	4961998	01/09/2024 09:30	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4961998	01/09/2024 09:30	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4961999	01/09/2024 09:37	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4961999	01/09/2024 09:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4961999	01/09/2024 09:37	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4961999	01/09/2024 09:37	Conductivity	uS/cm 20 C	400	2500
W4701OUT	Killyhevlin Final Water Outlet	4961999	01/09/2024 09:37	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4961999	01/09/2024 09:37	Free - Residual disinfectant	mg Cl/l	1.24	
W4701OUT	Killyhevlin Final Water Outlet	4961999	01/09/2024 09:37	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4961999	01/09/2024 09:37	Total - Residual disinfectant	mg Cl/l	1.31	
W4701OUT	Killyhevlin Final Water Outlet	4961999	01/09/2024 09:37	Total Coliforms	CFU/100 ml	0	0

W4701OUT	Killyhevlin Final Water Outlet	4961999	01/09/2024 09:37	Turbidity	NTU	0.2	1
W2308POUT	Castor Bay PPP Final Water Outlet	4962002	01/09/2024 09:59	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4962002	01/09/2024 09:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4962002	01/09/2024 09:59	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4962002	01/09/2024 09:59	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4962002	01/09/2024 09:59	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4962002	01/09/2024 09:59	Free - Residual disinfectant	mg Cl/l	0.98	
W2308POUT	Castor Bay PPP Final Water Outlet	4962002	01/09/2024 09:59	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4962002	01/09/2024 09:59	Total - Residual disinfectant	mg Cl/l	1.11	
W2308POUT	Castor Bay PPP Final Water Outlet	4962002	01/09/2024 09:59	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4962002	01/09/2024 09:59	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4964191	02/09/2024 08:12	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4964191	02/09/2024 08:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4964191	02/09/2024 08:12	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4964191	02/09/2024 08:12	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4964191	02/09/2024 08:12	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4964191	02/09/2024 08:12	Free - Residual disinfectant	mg Cl/l	1.45	
W1301POUT	Moyola PPP Final Water Outlet	4964191	02/09/2024 08:12	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4964191	02/09/2024 08:12	Total - Residual disinfectant	mg Cl/l	1.48	
W1301POUT	Moyola PPP Final Water Outlet	4964191	02/09/2024 08:12	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4964191	02/09/2024 08:12	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4964159	02/09/2024 10:31	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4964159	02/09/2024 10:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4964159	02/09/2024 10:31	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4964159	02/09/2024 10:31	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4964159	02/09/2024 10:31	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4964159	02/09/2024 10:31	Free - Residual disinfectant	mg Cl/l	0.8	
W1302OUT	Lough Fea Final Water Outlet	4964159	02/09/2024 10:31	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4964159	02/09/2024 10:31	Total - Residual disinfectant	mg Cl/l	0.84	
W1302OUT	Lough Fea Final Water Outlet	4964159	02/09/2024 10:31	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4964159	02/09/2024 10:31	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4964166	02/09/2024 10:36	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4964166	02/09/2024 10:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4964166	02/09/2024 10:36	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4964166	02/09/2024 10:36	Conductivity	uS/cm 20 C	400	2500
W2514OUT	Seagahan Final Water Outlet	4964166	02/09/2024 10:36	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4964166	02/09/2024 10:36	Free - Residual disinfectant	mg Cl/l	0.92	
W2514OUT	Seagahan Final Water Outlet	4964166	02/09/2024 10:36	Hydrogen Ion	pH value	7.4	9.5
W2514OUT	Seagahan Final Water Outlet	4964166	02/09/2024 10:36	Total - Residual disinfectant	mg Cl/l	1.17	
W2514OUT	Seagahan Final Water Outlet	4964166	02/09/2024 10:36	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4964166	02/09/2024 10:36	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	2,4-D	ug/l	<0.011	0.1

W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	2,4-D	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	2,4-DB	ug/l	<0.016	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	2,4-DB	ug/l	<0.016	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Asulam	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Asulam	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Bentazone	ug/l	<0.0044	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Bentazone	ug/l	<0.0044	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Bromoxynil	ug/l	<0.0079	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Bromoxynil	ug/l	<0.0079	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Chlorotoluron	ug/l	<0.0031	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Chlorotoluron	ug/l	<0.0031	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Chlorpyrifos	ug/l	<0.0070	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Chlorpyrifos	ug/l	<0.0070	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Clopyralid	ug/l	<0.0097	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Clopyralid	ug/l	<0.0097	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Cyanide	ug/l CN	<5.5	50
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Cyanide	ug/l CN	<5.5	50
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Diazinon	ug/l	<0.0074	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Diazinon	ug/l	<0.0074	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Dicamba	ug/l	<0.028	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Dicamba	ug/l	<0.028	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Dichlorprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Dichlorprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Diflufenican	ug/l	<0.0072	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Diflufenican	ug/l	<0.0072	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Dimethenamid	ug/l	<0.0063	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Dimethenamid	ug/l	<0.0063	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Diuron	ug/l	<0.0055	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Diuron	ug/l	<0.0055	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Epoxiconazole	ug/l	<0.0049	0.1

W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Epoxiconazole	ug/l	<0.0049	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Fenpropimorph	ug/l	<0.0083	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Fenpropimorph	ug/l	<0.0083	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Flufenacet	ug/l	<0.0052	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Flufenacet	ug/l	<0.0052	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Fluroxypyr	ug/l	<0.0063	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Fluroxypyr	ug/l	<0.0063	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Free - Residual disinfectant	mg Cl/l	0.74	
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Free - Residual disinfectant	mg Cl/l	0.74	
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Glyphosate	ug/l	<0.0077	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Glyphosate	ug/l	<0.0077	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Isoproturon	ug/l	<0.0025	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Isoproturon	ug/l	<0.0025	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Linuron	ug/l	<0.0034	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Linuron	ug/l	<0.0034	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	MCPA	ug/l	<0.0093	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	MCPA	ug/l	<0.0093	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	MCPB	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	MCPB	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Mecoprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Mecoprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Metalaxyl	ug/l	<0.0097	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Metalaxyl	ug/l	<0.0097	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Metamitron	ug/l	<0.0074	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Metamitron	ug/l	<0.0074	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Metazachlor	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Metazachlor	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Metoxuron	ug/l	<0.0080	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Metoxuron	ug/l	<0.0080	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Metribuzin	ug/l	<0.0060	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Metribuzin	ug/l	<0.0060	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Oxamyl	ug/l	<0.0023	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Oxamyl	ug/l	<0.0023	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Pendimethalin	ug/l	<0.0064	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Pendimethalin	ug/l	<0.0064	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Pesticides - Total Substances	ug/l	0	0.5
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Pesticides - Total Substances	ug/l	0	0.5
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Phorate	ug/l	<0.0092	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Phorate	ug/l	<0.0092	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Pirimicarb	ug/l	<0.0063	0.1

W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Pirimicarb	ug/l	<0.0063	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Propachlor	ug/l	<0.0096	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Propachlor	ug/l	<0.0096	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Propiconazole	ug/l	<0.0029	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Propiconazole	ug/l	<0.0029	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Propyzamide	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Propyzamide	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Prothioconazole	ug/l	<0.0019	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Prothioconazole	ug/l	<0.0019	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Tebuconazole	ug/l	<0.0039	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Tebuconazole	ug/l	<0.0039	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Total - Residual disinfectant	mg Cl/l	0.82	
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Total - Residual disinfectant	mg Cl/l	0.82	
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Triclopyr	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Triclopyr	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Aluminium	ug Al/l	25	200
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Aluminium	ug Al/l	25	200
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Iron	ug/l Fe	10	200
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Iron	ug/l Fe	10	200
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Manganese	ug Mn/l	1.1	50
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Manganese	ug Mn/l	1.1	50
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Total Organic Carbon	mg C/l	2.1	
W4523OUT	Lough Macrory Final Water Outlet	4964160	02/09/2024 11:03	Total Organic Carbon	mg C/l	2.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Free - Residual disinfectant	mg Cl/l	1.75	
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Total - Residual disinfectant	mg Cl/l	1.91	
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964186	02/09/2024 11:24	Taste - Nature		No taste	
W4701OUT	Killyhevlin Final Water Outlet	4964175	02/09/2024 11:28	Colony Counts 22	CFU/1 ml	0	

W4701OUT	Killyhevlin Final Water Outlet	4964175	02/09/2024 11:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4964175	02/09/2024 11:28	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4964175	02/09/2024 11:28	Conductivity	uS/cm 20 C	410	2500
W4701OUT	Killyhevlin Final Water Outlet	4964175	02/09/2024 11:28	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4964175	02/09/2024 11:28	Free - Residual disinfectant	mg Cl/l	1.11	
W4701OUT	Killyhevlin Final Water Outlet	4964175	02/09/2024 11:28	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4964175	02/09/2024 11:28	Total - Residual disinfectant	mg Cl/l	1.21	
W4701OUT	Killyhevlin Final Water Outlet	4964175	02/09/2024 11:28	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4964175	02/09/2024 11:28	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	2,4-D	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	2,4-DB	ug/l	<0.016	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Asulam	ug/l	<0.015	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Bentazone	ug/l	<0.0044	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Bromoxynil	ug/l	<0.0079	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Chlorotoluron	ug/l	<0.0031	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Chlorpyrifos	ug/l	<0.0070	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Clopyralid	ug/l	<0.0097	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Cyanide	ug/l CN	<5.5	50
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Diazinon	ug/l	<0.0074	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Dicamba	ug/l	<0.028	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Dichlorprop	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Diflufenican	ug/l	<0.0072	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Dimethenamid	ug/l	<0.0063	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Diuron	ug/l	<0.0055	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Epoxiconazole	ug/l	<0.0049	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Fenpropimorph	ug/l	<0.0083	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Flufenacet	ug/l	<0.0052	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Fluroxypyr	ug/l	<0.0063	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Free - Residual disinfectant	mg Cl/l	0.81	
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Glyphosate	ug/l	<0.0077	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Isoproturon	ug/l	<0.0025	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Linuron	ug/l	<0.0034	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	MCPA	ug/l	<0.0093	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	MCPB	ug/l	<0.015	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Mecoprop	ug/l	<0.011	0.1

W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Metaxyl	ug/l	<0.0097	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Metamitron	ug/l	<0.0074	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Metazachlor	ug/l	<0.015	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Metoxuron	ug/l	<0.0080	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Metribuzin	ug/l	<0.0060	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Oxamyl	ug/l	<0.0023	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Pendimethalin	ug/l	<0.0064	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Pesticides - Total Substances	ug/l	0	0.5
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Phorate	ug/l	<0.0092	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Pirimicarb	ug/l	<0.0063	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Propachlor	ug/l	<0.0096	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Propiconazole	ug/l	<0.0029	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Propyzamide	ug/l	<0.012	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Prothioconazole	ug/l	<0.0019	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Tebuconazole	ug/l	<0.0039	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Total - Residual disinfectant	mg Cl/l	0.92	
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Triclopyr	ug/l	<0.012	0.1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Aluminium	ug Al/l	15	200
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Bromodichloromethane	ug/l	8.8	
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Bromoform	ug/l	<3.5	
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Chloroform	ug/l	48	
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Dibromochloromethane	ug/l	<1.6	
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Iron	ug/l Fe	5.2	200
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Manganese	ug Mn/l	<0.80	50
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Total Organic Carbon	mg C/l	2	
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	Total Trihalomethanes	ug/l	58	100
W1302OUT	Lough Fea Final Water Outlet	4964615	03/09/2024 09:02	WHO Index		0.32	1
W4701OUT	Killyhevlin Final Water Outlet	4964626	03/09/2024 09:19	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4964626	03/09/2024 09:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4964626	03/09/2024 09:19	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4964626	03/09/2024 09:19	Conductivity	uS/cm 20 C	410	2500
W4701OUT	Killyhevlin Final Water Outlet	4964626	03/09/2024 09:19	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4964626	03/09/2024 09:19	Free - Residual disinfectant	mg Cl/l	1.41	
W4701OUT	Killyhevlin Final Water Outlet	4964626	03/09/2024 09:19	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4964626	03/09/2024 09:19	Total - Residual disinfectant	mg Cl/l	1.49	
W4701OUT	Killyhevlin Final Water Outlet	4964626	03/09/2024 09:19	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4964626	03/09/2024 09:19	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Colour	mg/l Pt/Co	<4.56	20

W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Free - Residual disinfectant	mg Cl/l	1.45	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Total - Residual disinfectant	mg Cl/l	1.53	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	2,4-D	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	2,4-DB	ug/l	<0.016	0.1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Algae Blue Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Algae Diatom Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Algae Flagellate Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Algae Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Algae Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Aluminium	ug Al/l	34	200
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Asulam	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Bentazone	ug/l	<0.0044	0.1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Bromoxynil	ug/l	<0.0079	0.1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Clopyralid	ug/l	<0.0097	0.1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Dichlorprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Geosmin	ng/l	<1.1	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Iron	ug/l Fe	2.6	200
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Manganese	ug Mn/l	<0.80	50
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	MCPA	ug/l	0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	MCPB	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Mecoprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	MIB	ng/l	17	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Microcystin-LR	ug/l	<0.024	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Most numerous Algae		---	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Propyzamide	ug/l	<0.012	0.1
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Second most numerous Algae		---	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Taste - Nature		No taste	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Third most numerous Algae		---	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Total Organic Carbon	mg C/l	2.7	
W1301POUT	Moyola PPP Final Water Outlet	4964640	03/09/2024 09:48	Triclopyr	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4964616	03/09/2024 10:29	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4964616	03/09/2024 10:29	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4964616	03/09/2024 10:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4964616	03/09/2024 10:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	

W4523OUT	Lough Macrory Final Water Outlet	4964616	03/09/2024 10:29	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4964616	03/09/2024 10:29	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4964616	03/09/2024 10:29	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4964616	03/09/2024 10:29	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4964616	03/09/2024 10:29	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4964616	03/09/2024 10:29	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4964616	03/09/2024 10:29	Free - Residual disinfectant	mg Cl/l	0.99	
W4523OUT	Lough Macrory Final Water Outlet	4964616	03/09/2024 10:29	Free - Residual disinfectant	mg Cl/l	0.99	
W4523OUT	Lough Macrory Final Water Outlet	4964616	03/09/2024 10:29	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4964616	03/09/2024 10:29	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4964616	03/09/2024 10:29	Total - Residual disinfectant	mg Cl/l	1.05	
W4523OUT	Lough Macrory Final Water Outlet	4964616	03/09/2024 10:29	Total - Residual disinfectant	mg Cl/l	1.05	
W4523OUT	Lough Macrory Final Water Outlet	4964616	03/09/2024 10:29	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4964616	03/09/2024 10:29	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4964616	03/09/2024 10:29	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4964616	03/09/2024 10:29	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4964623	03/09/2024 11:16	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4964623	03/09/2024 11:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4964623	03/09/2024 11:16	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4964623	03/09/2024 11:16	Conductivity	uS/cm 20 C	420	2500
W2514OUT	Seagahan Final Water Outlet	4964623	03/09/2024 11:16	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4964623	03/09/2024 11:16	Free - Residual disinfectant	mg Cl/l	1.02	
W2514OUT	Seagahan Final Water Outlet	4964623	03/09/2024 11:16	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4964623	03/09/2024 11:16	Total - Residual disinfectant	mg Cl/l	1.29	
W2514OUT	Seagahan Final Water Outlet	4964623	03/09/2024 11:16	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4964623	03/09/2024 11:16	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	2,4-D	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	2,4-DB	ug/l	<0.016	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Asulam	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Bentazone	ug/l	<0.0044	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Bromoxynil	ug/l	<0.0079	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Chlorotoluron	ug/l	<0.0031	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Chlorpyrifos	ug/l	<0.0070	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Clopyralid	ug/l	<0.0097	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Cyanide	ug/l CN	<5.5	50
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Diazinon	ug/l	<0.0074	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Dicamba	ug/l	<0.028	0.1

W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Dichlorprop	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Diflufenican	ug/l	<0.0072	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Dimethenamid	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Diuron	ug/l	<0.0055	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Epoxiconazole	ug/l	<0.0049	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Fenpropimorph	ug/l	<0.0083	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Flufenacet	ug/l	<0.0052	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Fluroxypyr	ug/l	0.0084	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Free - Residual disinfectant	mg Cl/l	1.74	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Glyphosate	ug/l	<0.0077	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Isoproturon	ug/l	<0.0025	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Linuron	ug/l	<0.0034	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	MCPA	ug/l	0.017	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	MCPB	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Mecoprop	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Metaxyl	ug/l	<0.0097	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Metamitron	ug/l	<0.0074	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Metazachlor	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Metoxuron	ug/l	<0.0080	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Metribuzin	ug/l	<0.0060	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Oxamyl	ug/l	<0.0023	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Pendimethalin	ug/l	<0.0064	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Pesticides - Total Substances	ug/l	0.0254	0.5
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Phorate	ug/l	<0.0092	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Pirimicarb	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Propachlor	ug/l	<0.0096	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Propiconazole	ug/l	<0.0029	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Propyzamide	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Prothioconazole	ug/l	<0.0019	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Tebuconazole	ug/l	<0.0039	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Total - Residual disinfectant	mg Cl/l	1.92	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Triclopyr	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Algae Diatom Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Algae Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Aluminium	ug Al/l	24	200

W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Bromodichloromethane	ug/l	8.2	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Chloroform	ug/l	16	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Dibromochloromethane	ug/l	3.2	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Iron	ug/l Fe	<1.538	200
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Manganese	ug Mn/l	<0.80	50
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	MIB	ng/l	<1.9	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Microcystin-LR	ug/l	<0.024	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Most numerous Algae		---	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Second most numerous Algae		---	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Third most numerous Algae		---	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Total Organic Carbon	mg C/l	2.7	
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	Total Trihalomethanes	ug/l	28	100
W2308POUT	Castor Bay PPP Final Water Outlet	4964635	03/09/2024 11:48	WHO Index		0.23	1
W1301POUT	Moyola PPP Final Water Outlet	4964809	04/09/2024 07:19	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4964809	04/09/2024 07:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4964809	04/09/2024 07:19	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4964809	04/09/2024 07:19	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4964809	04/09/2024 07:19	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4964809	04/09/2024 07:19	Free - Residual disinfectant	mg Cl/l	1.33	
W1301POUT	Moyola PPP Final Water Outlet	4964809	04/09/2024 07:19	Total - Residual disinfectant	mg Cl/l	1.39	
W1301POUT	Moyola PPP Final Water Outlet	4964809	04/09/2024 07:19	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4964809	04/09/2024 07:19	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Free - Residual disinfectant	mg Cl/l	1.72	
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Total - Residual disinfectant	mg Cl/l	1.91	
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964807	04/09/2024 07:46	Taste - Nature		No taste	
W1302OUT	Lough Fea Final Water Outlet	4964790	04/09/2024 07:59	Colony Counts 22	CFU/1 ml	0	

W1302OUT	Lough Fea Final Water Outlet	4964790	04/09/2024 07:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4964790	04/09/2024 07:59	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4964790	04/09/2024 07:59	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4964790	04/09/2024 07:59	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4964790	04/09/2024 07:59	Free - Residual disinfectant	mg Cl/l	0.7	
W1302OUT	Lough Fea Final Water Outlet	4964790	04/09/2024 07:59	Total - Residual disinfectant	mg Cl/l	0.88	
W1302OUT	Lough Fea Final Water Outlet	4964790	04/09/2024 07:59	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4964790	04/09/2024 07:59	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4964791	04/09/2024 10:13	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4964791	04/09/2024 10:13	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4964791	04/09/2024 10:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4964791	04/09/2024 10:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4964791	04/09/2024 10:13	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4964791	04/09/2024 10:13	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4964791	04/09/2024 10:13	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4964791	04/09/2024 10:13	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4964791	04/09/2024 10:13	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4964791	04/09/2024 10:13	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4964791	04/09/2024 10:13	Free - Residual disinfectant	mg Cl/l	0.88	
W4523OUT	Lough Macrory Final Water Outlet	4964791	04/09/2024 10:13	Free - Residual disinfectant	mg Cl/l	0.88	
W4523OUT	Lough Macrory Final Water Outlet	4964791	04/09/2024 10:13	Total - Residual disinfectant	mg Cl/l	0.95	
W4523OUT	Lough Macrory Final Water Outlet	4964791	04/09/2024 10:13	Total - Residual disinfectant	mg Cl/l	0.95	
W4523OUT	Lough Macrory Final Water Outlet	4964791	04/09/2024 10:13	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4964791	04/09/2024 10:13	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4964791	04/09/2024 10:13	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4964791	04/09/2024 10:13	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Conductivity	uS/cm 20 C	410	2500
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Free - Residual disinfectant	mg Cl/l	1.54	
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Total - Residual disinfectant	mg Cl/l	1.6	
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	2,4-D	ug/l	<0.011	0.1
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	2,4-DB	ug/l	<0.016	0.1
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Algae Blue Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Algae Diatom Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Algae Flagellate Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Algae Green Total	per ml	0	

W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Algae Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Aluminium	ug Al/l	25	200
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Asulam	ug/l	<0.015	0.1
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Bentazone	ug/l	<0.0044	0.1
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Bromodichloromethane	ug/l	11	
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Bromoform	ug/l	<3.5	
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Bromoxynil	ug/l	<0.0079	0.1
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Chloroform	ug/l	35	
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Clopyralid	ug/l	<0.0097	0.1
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Dibromochloromethane	ug/l	3	
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Dichlorprop	ug/l	<0.011	0.1
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Geosmin	ng/l	<1.1	
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Iron	ug/l Fe	5	200
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Manganese	ug Mn/l	1.6	50
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	MCPA	ug/l	0.025	0.1
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	MCPB	ug/l	<0.015	0.1
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Mecoprop	ug/l	<0.011	0.1
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	MIB	ng/l	<1.9	
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Microcystin-LR	ug/l	<0.024	
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Propyzamide	ug/l	<0.012	0.1
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Second most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Third most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Total Organic Carbon	mg C/l	2.4	
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Total Trihalomethanes	ug/l	50	100
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	Triclopyr	ug/l	<0.012	0.1
W4701OUT	Killyhevlin Final Water Outlet	4964800	04/09/2024 10:17	WHO Index		0.34	1
W2514OUT	Seagahan Final Water Outlet	4964796	04/09/2024 10:57	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4964796	04/09/2024 10:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4964796	04/09/2024 10:57	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4964796	04/09/2024 10:57	Conductivity	uS/cm 20 C	420	2500
W2514OUT	Seagahan Final Water Outlet	4964796	04/09/2024 10:57	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4964796	04/09/2024 10:57	Free - Residual disinfectant	mg Cl/l	0.99	
W2514OUT	Seagahan Final Water Outlet	4964796	04/09/2024 10:57	Total - Residual disinfectant	mg Cl/l	1.26	
W2514OUT	Seagahan Final Water Outlet	4964796	04/09/2024 10:57	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4964796	04/09/2024 10:57	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4964966	05/09/2024 07:19	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4964966	05/09/2024 07:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4964966	05/09/2024 07:19	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4964966	05/09/2024 07:19	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4964966	05/09/2024 07:19	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4964966	05/09/2024 07:19	Free - Residual disinfectant	mg Cl/l	1.77	

W1301POUT	Moyola PPP Final Water Outlet	4964966	05/09/2024 07:19	Total - Residual disinfectant	mg Cl/l	2	
W1301POUT	Moyola PPP Final Water Outlet	4964966	05/09/2024 07:19	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4964966	05/09/2024 07:19	Turbidity	NTU	0.12	1
W1302OUT	Lough Fea Final Water Outlet	4964947	05/09/2024 08:06	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4964947	05/09/2024 08:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4964947	05/09/2024 08:06	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4964947	05/09/2024 08:06	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4964947	05/09/2024 08:06	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4964947	05/09/2024 08:06	Free - Residual disinfectant	mg Cl/l	0.8	
W1302OUT	Lough Fea Final Water Outlet	4964947	05/09/2024 08:06	Total - Residual disinfectant	mg Cl/l	0.91	
W1302OUT	Lough Fea Final Water Outlet	4964947	05/09/2024 08:06	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4964947	05/09/2024 08:06	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4964963	05/09/2024 08:53	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964963	05/09/2024 08:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4964963	05/09/2024 08:53	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4964963	05/09/2024 08:53	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4964963	05/09/2024 08:53	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964963	05/09/2024 08:53	Free - Residual disinfectant	mg Cl/l	1.35	
W2308POUT	Castor Bay PPP Final Water Outlet	4964963	05/09/2024 08:53	Total - Residual disinfectant	mg Cl/l	1.44	
W2308POUT	Castor Bay PPP Final Water Outlet	4964963	05/09/2024 08:53	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4964963	05/09/2024 08:53	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4964956	05/09/2024 09:04	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4964956	05/09/2024 09:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4964956	05/09/2024 09:04	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4964956	05/09/2024 09:04	Conductivity	uS/cm 20 C	410	2500
W4701OUT	Killyhevlin Final Water Outlet	4964956	05/09/2024 09:04	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4964956	05/09/2024 09:04	Free - Residual disinfectant	mg Cl/l	1.62	
W4701OUT	Killyhevlin Final Water Outlet	4964956	05/09/2024 09:04	Total - Residual disinfectant	mg Cl/l	1.7	
W4701OUT	Killyhevlin Final Water Outlet	4964956	05/09/2024 09:04	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4964956	05/09/2024 09:04	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Conductivity	uS/cm 20 C	410	2500
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Free - Residual disinfectant	mg Cl/l	1.08	
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Total - Residual disinfectant	mg Cl/l	1.29	
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Algae Blue Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Algae Diatom Total	per ml	0	

W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Algae Flagellate Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Algae Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Algae Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Aluminium	ug Al/l	4.7	200
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Bromodichloromethane	ug/l	15	
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Bromoform	ug/l	<3.5	
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Chloroform	ug/l	42	
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Dibromochloromethane	ug/l	3.4	
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Geosmin	ng/l	<1.1	
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Iron	ug/l Fe	<1.538	200
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Manganese	ug Mn/l	<0.80	50
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	MIB	ng/l	<1.9	
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Microcystin-LR	ug/l	<0.024	
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Second most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Third most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Total Organic Carbon	mg C/l	3.3	
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	Total Trihalomethanes	ug/l	61	100
W2514OUT	Seagahan Final Water Outlet	4964953	05/09/2024 11:24	WHO Index		0.43	1
W4523OUT	Lough Macrory Final Water Outlet	4964948	05/09/2024 11:55	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4964948	05/09/2024 11:55	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4964948	05/09/2024 11:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4964948	05/09/2024 11:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4964948	05/09/2024 11:55	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4964948	05/09/2024 11:55	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4964948	05/09/2024 11:55	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4964948	05/09/2024 11:55	Conductivity	uS/cm 20 C	120	2500
W4523OUT	Lough Macrory Final Water Outlet	4964948	05/09/2024 11:55	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4964948	05/09/2024 11:55	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4964948	05/09/2024 11:55	Free - Residual disinfectant	mg Cl/l	0.83	
W4523OUT	Lough Macrory Final Water Outlet	4964948	05/09/2024 11:55	Free - Residual disinfectant	mg Cl/l	0.83	
W4523OUT	Lough Macrory Final Water Outlet	4964948	05/09/2024 11:55	Total - Residual disinfectant	mg Cl/l	0.9	
W4523OUT	Lough Macrory Final Water Outlet	4964948	05/09/2024 11:55	Total - Residual disinfectant	mg Cl/l	0.9	
W4523OUT	Lough Macrory Final Water Outlet	4964948	05/09/2024 11:55	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4964948	05/09/2024 11:55	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4964948	05/09/2024 11:55	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4964948	05/09/2024 11:55	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4965144	06/09/2024 08:18	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4965144	06/09/2024 08:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4965144	06/09/2024 08:18	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4965144	06/09/2024 08:18	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4965144	06/09/2024 08:18	E. coli	CFU/100 ml	0	0

W1302OUT	Lough Fea Final Water Outlet	4965144	06/09/2024 08:18	Free - Residual disinfectant	mg Cl/l	0.76	
W1302OUT	Lough Fea Final Water Outlet	4965144	06/09/2024 08:18	Total - Residual disinfectant	mg Cl/l	0.87	
W1302OUT	Lough Fea Final Water Outlet	4965144	06/09/2024 08:18	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4965144	06/09/2024 08:18	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4965146	06/09/2024 09:08	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4965146	06/09/2024 09:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4965146	06/09/2024 09:08	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4965146	06/09/2024 09:08	Conductivity	uS/cm 20 C	410	2500
W4701OUT	Killyhevlin Final Water Outlet	4965146	06/09/2024 09:08	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4965146	06/09/2024 09:08	Free - Residual disinfectant	mg Cl/l	1.62	
W4701OUT	Killyhevlin Final Water Outlet	4965146	06/09/2024 09:08	Total - Residual disinfectant	mg Cl/l	1.7	
W4701OUT	Killyhevlin Final Water Outlet	4965146	06/09/2024 09:08	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4965146	06/09/2024 09:08	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4965152	06/09/2024 09:50	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4965152	06/09/2024 09:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4965152	06/09/2024 09:50	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4965152	06/09/2024 09:50	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4965152	06/09/2024 09:50	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4965152	06/09/2024 09:50	Free - Residual disinfectant	mg Cl/l	1.5	
W1301POUT	Moyola PPP Final Water Outlet	4965152	06/09/2024 09:50	Total - Residual disinfectant	mg Cl/l	1.79	
W1301POUT	Moyola PPP Final Water Outlet	4965152	06/09/2024 09:50	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4965152	06/09/2024 09:50	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4965151	06/09/2024 10:22	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4965151	06/09/2024 10:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4965151	06/09/2024 10:22	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4965151	06/09/2024 10:22	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4965151	06/09/2024 10:22	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4965151	06/09/2024 10:22	Free - Residual disinfectant	mg Cl/l	1.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4965151	06/09/2024 10:22	Total - Residual disinfectant	mg Cl/l	1.64	
W2308POUT	Castor Bay PPP Final Water Outlet	4965151	06/09/2024 10:22	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4965151	06/09/2024 10:22	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4965244	07/09/2024 09:06	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4965244	07/09/2024 09:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4965244	07/09/2024 09:06	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4965244	07/09/2024 09:06	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4965244	07/09/2024 09:06	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4965244	07/09/2024 09:06	Free - Residual disinfectant	mg Cl/l	1.17	
W4701OUT	Killyhevlin Final Water Outlet	4965244	07/09/2024 09:06	Total - Residual disinfectant	mg Cl/l	1.38	
W4701OUT	Killyhevlin Final Water Outlet	4965244	07/09/2024 09:06	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4965244	07/09/2024 09:06	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4965249	07/09/2024 09:36	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4965249	07/09/2024 09:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	

W1301POUT	Moyola PPP Final Water Outlet	4965249	07/09/2024 09:36	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4965249	07/09/2024 09:36	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4965249	07/09/2024 09:36	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4965249	07/09/2024 09:36	Free - Residual disinfectant	mg Cl/l	1.42	
W1301POUT	Moyola PPP Final Water Outlet	4965249	07/09/2024 09:36	Total - Residual disinfectant	mg Cl/l	1.48	
W1301POUT	Moyola PPP Final Water Outlet	4965249	07/09/2024 09:36	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4965249	07/09/2024 09:36	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4965243	07/09/2024 10:26	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4965243	07/09/2024 10:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4965243	07/09/2024 10:26	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4965243	07/09/2024 10:26	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4965243	07/09/2024 10:26	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4965243	07/09/2024 10:26	Free - Residual disinfectant	mg Cl/l	0.77	
W1302OUT	Lough Fea Final Water Outlet	4965243	07/09/2024 10:26	Total - Residual disinfectant	mg Cl/l	0.83	
W1302OUT	Lough Fea Final Water Outlet	4965243	07/09/2024 10:26	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4965243	07/09/2024 10:26	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4965248	07/09/2024 12:34	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4965248	07/09/2024 12:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4965248	07/09/2024 12:34	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4965248	07/09/2024 12:34	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4965248	07/09/2024 12:34	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4965248	07/09/2024 12:34	Free - Residual disinfectant	mg Cl/l	1.24	
W2308POUT	Castor Bay PPP Final Water Outlet	4965248	07/09/2024 12:34	Total - Residual disinfectant	mg Cl/l	1.27	
W2308POUT	Castor Bay PPP Final Water Outlet	4965248	07/09/2024 12:34	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4965248	07/09/2024 12:34	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4965262	08/09/2024 08:48	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4965262	08/09/2024 08:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4965262	08/09/2024 08:48	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4965262	08/09/2024 08:48	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4965262	08/09/2024 08:48	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4965262	08/09/2024 08:48	Free - Residual disinfectant	mg Cl/l	1.22	
W4701OUT	Killyhevlin Final Water Outlet	4965262	08/09/2024 08:48	Total - Residual disinfectant	mg Cl/l	1.3	
W4701OUT	Killyhevlin Final Water Outlet	4965262	08/09/2024 08:48	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4965262	08/09/2024 08:48	Turbidity	NTU	0.12	1
W1301POUT	Moyola PPP Final Water Outlet	4965267	08/09/2024 09:38	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4965267	08/09/2024 09:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4965267	08/09/2024 09:38	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4965267	08/09/2024 09:38	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4965267	08/09/2024 09:38	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4965267	08/09/2024 09:38	Free - Residual disinfectant	mg Cl/l	1.58	
W1301POUT	Moyola PPP Final Water Outlet	4965267	08/09/2024 09:38	Total - Residual disinfectant	mg Cl/l	1.71	
W1301POUT	Moyola PPP Final Water Outlet	4965267	08/09/2024 09:38	Total Coliforms	CFU/100 ml	0	0

W1301POUT	Moyola PPP Final Water Outlet	4965267	08/09/2024 09:38	Turbidity	NTU	0.13	1
W1302OUT	Lough Fea Final Water Outlet	4965261	08/09/2024 10:26	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4965261	08/09/2024 10:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4965261	08/09/2024 10:26	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4965261	08/09/2024 10:26	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4965261	08/09/2024 10:26	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4965261	08/09/2024 10:26	Free - Residual disinfectant	mg Cl/l	0.79	
W1302OUT	Lough Fea Final Water Outlet	4965261	08/09/2024 10:26	Total - Residual disinfectant	mg Cl/l	0.81	
W1302OUT	Lough Fea Final Water Outlet	4965261	08/09/2024 10:26	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4965261	08/09/2024 10:26	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4965266	08/09/2024 12:11	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4965266	08/09/2024 12:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4965266	08/09/2024 12:11	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4965266	08/09/2024 12:11	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4965266	08/09/2024 12:11	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4965266	08/09/2024 12:11	Free - Residual disinfectant	mg Cl/l	1.53	
W2308POUT	Castor Bay PPP Final Water Outlet	4965266	08/09/2024 12:11	Total - Residual disinfectant	mg Cl/l	1.6	
W2308POUT	Castor Bay PPP Final Water Outlet	4965266	08/09/2024 12:11	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4965266	08/09/2024 12:11	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4967481	09/09/2024 07:16	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4967481	09/09/2024 07:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4967481	09/09/2024 07:16	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4967481	09/09/2024 07:16	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4967481	09/09/2024 07:16	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4967481	09/09/2024 07:16	Free - Residual disinfectant	mg Cl/l	1.44	
W1301POUT	Moyola PPP Final Water Outlet	4967481	09/09/2024 07:16	Total - Residual disinfectant	mg Cl/l	1.51	
W1301POUT	Moyola PPP Final Water Outlet	4967481	09/09/2024 07:16	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4967481	09/09/2024 07:16	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Free - Residual disinfectant	mg Cl/l	1.35	
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Total - Residual disinfectant	mg Cl/l	1.46	
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Turbidity	NTU	0.091	1
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4967475	09/09/2024 08:28	Taste - Nature		No taste	
W1302OUT	Lough Fea Final Water Outlet	4967442	09/09/2024 09:02	Colony Counts 22	CFU/1 ml	1	

W1302OUT	Lough Fea Final Water Outlet	4967442	09/09/2024 09:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4967442	09/09/2024 09:02	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4967442	09/09/2024 09:02	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4967442	09/09/2024 09:02	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4967442	09/09/2024 09:02	Free - Residual disinfectant	mg Cl/l	0.81	
W1302OUT	Lough Fea Final Water Outlet	4967442	09/09/2024 09:02	Total - Residual disinfectant	mg Cl/l	1.26	
W1302OUT	Lough Fea Final Water Outlet	4967442	09/09/2024 09:02	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4967442	09/09/2024 09:02	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4967443	09/09/2024 10:15	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4967443	09/09/2024 10:15	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4967443	09/09/2024 10:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4967443	09/09/2024 10:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4967443	09/09/2024 10:15	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4967443	09/09/2024 10:15	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4967443	09/09/2024 10:15	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4967443	09/09/2024 10:15	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4967443	09/09/2024 10:15	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4967443	09/09/2024 10:15	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4967443	09/09/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.94	
W4523OUT	Lough Macrory Final Water Outlet	4967443	09/09/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.94	
W4523OUT	Lough Macrory Final Water Outlet	4967443	09/09/2024 10:15	Total - Residual disinfectant	mg Cl/l	1	
W4523OUT	Lough Macrory Final Water Outlet	4967443	09/09/2024 10:15	Total - Residual disinfectant	mg Cl/l	1	
W4523OUT	Lough Macrory Final Water Outlet	4967443	09/09/2024 10:15	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4967443	09/09/2024 10:15	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4967443	09/09/2024 10:15	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4967443	09/09/2024 10:15	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4967450	09/09/2024 10:43	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4967450	09/09/2024 10:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4967450	09/09/2024 10:43	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4967450	09/09/2024 10:43	Conductivity	uS/cm 20 C	420	2500
W2514OUT	Seagahan Final Water Outlet	4967450	09/09/2024 10:43	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4967450	09/09/2024 10:43	Free - Residual disinfectant	mg Cl/l	0.98	
W2514OUT	Seagahan Final Water Outlet	4967450	09/09/2024 10:43	Total - Residual disinfectant	mg Cl/l	1.27	
W2514OUT	Seagahan Final Water Outlet	4967450	09/09/2024 10:43	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4967450	09/09/2024 10:43	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4967450	09/09/2024 10:43	Algae Blue Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4967450	09/09/2024 10:43	Algae Diatom Total	per ml	80	
W2514OUT	Seagahan Final Water Outlet	4967450	09/09/2024 10:43	Algae Flagellate Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4967450	09/09/2024 10:43	Algae Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4967450	09/09/2024 10:43	Algae Total	per ml	80	
W2514OUT	Seagahan Final Water Outlet	4967450	09/09/2024 10:43	Aluminium	ug Al/l	4.2	200
W2514OUT	Seagahan Final Water Outlet	4967450	09/09/2024 10:43	Iron	ug/l Fe	2.8	200

W2514OUT	Seagahan Final Water Outlet	4967450	09/09/2024 10:43	Manganese	ug Mn/l	<0.80	50
W2514OUT	Seagahan Final Water Outlet	4967450	09/09/2024 10:43	Most numerous Algae		Centric diatom	
W2514OUT	Seagahan Final Water Outlet	4967450	09/09/2024 10:43	Second most numerous Algae		---	
W2514OUT	Seagahan Final Water Outlet	4967450	09/09/2024 10:43	Third most numerous Algae		---	
W2514OUT	Seagahan Final Water Outlet	4967450	09/09/2024 10:43	Total Organic Carbon	mg C/l	3.3	
W4701OUT	Killyhevlin Final Water Outlet	4967460	09/09/2024 11:25	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4967460	09/09/2024 11:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4967460	09/09/2024 11:25	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4967460	09/09/2024 11:25	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4967460	09/09/2024 11:25	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4967460	09/09/2024 11:25	Free - Residual disinfectant	mg Cl/l	1.54	
W4701OUT	Killyhevlin Final Water Outlet	4967460	09/09/2024 11:25	Total - Residual disinfectant	mg Cl/l	1.63	
W4701OUT	Killyhevlin Final Water Outlet	4967460	09/09/2024 11:25	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4967460	09/09/2024 11:25	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4979076	09/09/2024 14:20	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4979076	09/09/2024 14:20	Free - Residual disinfectant	mg Cl/l	1.44	
W1301POUT	Moyola PPP Final Water Outlet	4979076	09/09/2024 14:20	Odour	Diln No	10	0
W1301POUT	Moyola PPP Final Water Outlet	4979076	09/09/2024 14:20	Odour - Nature		Earthy	
W1301POUT	Moyola PPP Final Water Outlet	4979076	09/09/2024 14:20	Taste	Diln No	10	0
W1301POUT	Moyola PPP Final Water Outlet	4979076	09/09/2024 14:20	Taste - Nature		Earthy	
W1301POUT	Moyola PPP Final Water Outlet	4979076	09/09/2024 14:20	Total - Residual disinfectant	mg Cl/l	1.62	
W1301POUT	Moyola PPP Final Water Outlet	4979076	09/09/2024 14:20	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Free - Residual disinfectant	mg Cl/l	1.07	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Total - Residual disinfectant	mg Cl/l	1.13	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Algae Diatom Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Algae Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Aluminium	ug Al/l	22	200
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Bromodichloromethane	ug/l	8	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Chloroform	ug/l	20	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Dibromochloromethane	ug/l	2	

W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Iron	ug/l Fe	<1.538	200
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Manganese	ug Mn/l	<0.80	50
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	MIB	ng/l	17	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Microcystin-LR	ug/l	<0.024	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Second most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Third most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	Total Trihalomethanes	ug/l	31	100
W2308POUT	Castor Bay PPP Final Water Outlet	4967797	10/09/2024 08:26	WHO Index		0.23	1
W1302OUT	Lough Fea Final Water Outlet	4967777	10/09/2024 09:16	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4967777	10/09/2024 09:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4967777	10/09/2024 09:16	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4967777	10/09/2024 09:16	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4967777	10/09/2024 09:16	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4967777	10/09/2024 09:16	Free - Residual disinfectant	mg Cl/l	0.81	
W1302OUT	Lough Fea Final Water Outlet	4967777	10/09/2024 09:16	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4967777	10/09/2024 09:16	Total - Residual disinfectant	mg Cl/l	0.95	
W1302OUT	Lough Fea Final Water Outlet	4967777	10/09/2024 09:16	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4967777	10/09/2024 09:16	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4967783	10/09/2024 09:42	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4967783	10/09/2024 09:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4967783	10/09/2024 09:42	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4967783	10/09/2024 09:42	Conductivity	uS/cm 20 C	420	2500
W2514OUT	Seagahan Final Water Outlet	4967783	10/09/2024 09:42	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4967783	10/09/2024 09:42	Free - Residual disinfectant	mg Cl/l	1.06	
W2514OUT	Seagahan Final Water Outlet	4967783	10/09/2024 09:42	Hydrogen Ion	pH value	7.4	9.5
W2514OUT	Seagahan Final Water Outlet	4967783	10/09/2024 09:42	Total - Residual disinfectant	mg Cl/l	1.47	
W2514OUT	Seagahan Final Water Outlet	4967783	10/09/2024 09:42	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4967783	10/09/2024 09:42	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Free - Residual disinfectant	mg Cl/l	1.54	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Hydrogen Ion	pH value	7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Total - Residual disinfectant	mg Cl/l	1.62	

W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	2,4-D	ug/l	<0.022	0.1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	2,4-DB	ug/l	<0.016	0.1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Algae Blue Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Algae Diatom Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Algae Flagellate Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Algae Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Algae Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Aluminium	ug Al/l	30	200
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Asulam	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Bentazone	ug/l	<0.0044	0.1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Bromoxynil	ug/l	<0.0079	0.1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Clopyralid	ug/l	<0.019	0.1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Dichlorprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Geosmin	ng/l	<1.1	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Iron	ug/l Fe	<1.538	200
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Manganese	ug Mn/l	<0.80	50
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	MCPA	ug/l	<0.019	0.1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	MCPB	ug/l	<0.030	0.1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Mecoprop	ug/l	0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Microcystin-LR	ug/l	<0.024	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Odour	Diln No	10	0
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Odour - Nature		Earthy	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Propyzamide	ug/l	<0.024	0.1
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Second most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Taste - Nature		No taste	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Third most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4967801	10/09/2024 10:48	Triclopyr	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Free - Residual disinfectant	mg Cl/l	0.83	

W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Free - Residual disinfectant	mg Cl/l	0.83	
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Total - Residual disinfectant	mg Cl/l	0.86	
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Total - Residual disinfectant	mg Cl/l	0.86	
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Aluminium	ug Al/l	10	200
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Aluminium	ug Al/l	10	200
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Bromodichloromethane	ug/l	7.2	
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Bromodichloromethane	ug/l	7.2	
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Bromoform	ug/l	<3.5	
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Bromoform	ug/l	<3.5	
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Chloroform	ug/l	32	
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Chloroform	ug/l	32	
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Dibromochloromethane	ug/l	<1.6	
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Dibromochloromethane	ug/l	<1.6	
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Iron	ug/l Fe	2.6	200
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Iron	ug/l Fe	2.6	200
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Manganese	ug Mn/l	<0.80	50
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Manganese	ug Mn/l	<0.80	50
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Total Trihalomethanes	ug/l	41	100
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	Total Trihalomethanes	ug/l	41	100
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	WHO Index		0.24	1
W4523OUT	Lough Macrory Final Water Outlet	4967778	10/09/2024 11:27	WHO Index		0.24	1
W4701OUT	Killyhevlin Final Water Outlet	4967788	10/09/2024 11:37	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4967788	10/09/2024 11:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4967788	10/09/2024 11:37	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4967788	10/09/2024 11:37	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4967788	10/09/2024 11:37	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4967788	10/09/2024 11:37	Free - Residual disinfectant	mg Cl/l	1.34	
W4701OUT	Killyhevlin Final Water Outlet	4967788	10/09/2024 11:37	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4967788	10/09/2024 11:37	Total - Residual disinfectant	mg Cl/l	1.42	
W4701OUT	Killyhevlin Final Water Outlet	4967788	10/09/2024 11:37	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4967788	10/09/2024 11:37	Turbidity	NTU	0.095	1
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Conductivity	uS/cm 20 C	370	2500
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	E. coli	CFU/100 ml	0	0

W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Free - Residual disinfectant	mg Cl/l	1.38	
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Total - Residual disinfectant	mg Cl/l	1.54	
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4968010	11/09/2024 07:34	Taste - Nature		No taste	
W1302OUT	Lough Fea Final Water Outlet	4967987	11/09/2024 08:59	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4967987	11/09/2024 08:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4967987	11/09/2024 08:59	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4967987	11/09/2024 08:59	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4967987	11/09/2024 08:59	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4967987	11/09/2024 08:59	Free - Residual disinfectant	mg Cl/l	0.96	
W1302OUT	Lough Fea Final Water Outlet	4967987	11/09/2024 08:59	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4967987	11/09/2024 08:59	Total - Residual disinfectant	mg Cl/l	1.07	
W1302OUT	Lough Fea Final Water Outlet	4967987	11/09/2024 08:59	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4967987	11/09/2024 08:59	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4967987	11/09/2024 08:59	Aluminium	ug Al/l	12	200
W1302OUT	Lough Fea Final Water Outlet	4967987	11/09/2024 08:59	Bromodichloromethane	ug/l	10	
W1302OUT	Lough Fea Final Water Outlet	4967987	11/09/2024 08:59	Bromoform	ug/l	<3.5	
W1302OUT	Lough Fea Final Water Outlet	4967987	11/09/2024 08:59	Chloroform	ug/l	46	
W1302OUT	Lough Fea Final Water Outlet	4967987	11/09/2024 08:59	Dibromochloromethane	ug/l	<1.6	
W1302OUT	Lough Fea Final Water Outlet	4967987	11/09/2024 08:59	Iron	ug/l Fe	2.8	200
W1302OUT	Lough Fea Final Water Outlet	4967987	11/09/2024 08:59	Manganese	ug Mn/l	<0.80	50
W1302OUT	Lough Fea Final Water Outlet	4967987	11/09/2024 08:59	Total Trihalomethanes	ug/l	58	100
W1302OUT	Lough Fea Final Water Outlet	4967987	11/09/2024 08:59	WHO Index		0.34	1
W2514OUT	Seagahan Final Water Outlet	4967997	11/09/2024 09:20	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4967997	11/09/2024 09:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4967997	11/09/2024 09:20	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4967997	11/09/2024 09:20	Conductivity	uS/cm 20 C	420	2500
W2514OUT	Seagahan Final Water Outlet	4967997	11/09/2024 09:20	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4967997	11/09/2024 09:20	Free - Residual disinfectant	mg Cl/l	0.99	
W2514OUT	Seagahan Final Water Outlet	4967997	11/09/2024 09:20	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4967997	11/09/2024 09:20	Total - Residual disinfectant	mg Cl/l	1.07	
W2514OUT	Seagahan Final Water Outlet	4967997	11/09/2024 09:20	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4967997	11/09/2024 09:20	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4968000	11/09/2024 10:28	Colony Counts 22	CFU/1 ml	1	
W4701OUT	Killyhevlin Final Water Outlet	4968000	11/09/2024 10:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4968000	11/09/2024 10:28	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4968000	11/09/2024 10:28	Conductivity	uS/cm 20 C	420	2500

W4701OUT	Killyhevlin Final Water Outlet	4968000	11/09/2024 10:28	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4968000	11/09/2024 10:28	Free - Residual disinfectant	mg Cl/l	1.54	
W4701OUT	Killyhevlin Final Water Outlet	4968000	11/09/2024 10:28	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4968000	11/09/2024 10:28	Total - Residual disinfectant	mg Cl/l	1.62	
W4701OUT	Killyhevlin Final Water Outlet	4968000	11/09/2024 10:28	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4968000	11/09/2024 10:28	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4967988	11/09/2024 11:16	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4967988	11/09/2024 11:16	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4967988	11/09/2024 11:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4967988	11/09/2024 11:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4967988	11/09/2024 11:16	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4967988	11/09/2024 11:16	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4967988	11/09/2024 11:16	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4967988	11/09/2024 11:16	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4967988	11/09/2024 11:16	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4967988	11/09/2024 11:16	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4967988	11/09/2024 11:16	Free - Residual disinfectant	mg Cl/l	0.91	
W4523OUT	Lough Macrory Final Water Outlet	4967988	11/09/2024 11:16	Free - Residual disinfectant	mg Cl/l	0.91	
W4523OUT	Lough Macrory Final Water Outlet	4967988	11/09/2024 11:16	Hydrogen Ion	pH value	7.4	9.5
W4523OUT	Lough Macrory Final Water Outlet	4967988	11/09/2024 11:16	Hydrogen Ion	pH value	7.4	9.5
W4523OUT	Lough Macrory Final Water Outlet	4967988	11/09/2024 11:16	Total - Residual disinfectant	mg Cl/l	0.99	
W4523OUT	Lough Macrory Final Water Outlet	4967988	11/09/2024 11:16	Total - Residual disinfectant	mg Cl/l	0.99	
W4523OUT	Lough Macrory Final Water Outlet	4967988	11/09/2024 11:16	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4967988	11/09/2024 11:16	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4967988	11/09/2024 11:16	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4967988	11/09/2024 11:16	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Free - Residual disinfectant	mg Cl/l	1.47	
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Total - Residual disinfectant	mg Cl/l	1.63	
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968007	11/09/2024 12:34	Taste - Nature		No taste	
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	

W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Conductivity	uS/cm 20 C	380	2500
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Free - Residual disinfectant	mg Cl/l	1.54	
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Hydrogen Ion	pH value	7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Total - Residual disinfectant	mg Cl/l	1.7	
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Odour	Diln No	7	0
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Odour - Nature		Earthy/Musty	
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4968203	12/09/2024 07:10	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Free - Residual disinfectant	mg Cl/l	1.55	
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Hydrogen Ion	pH value	7.4	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Total - Residual disinfectant	mg Cl/l	1.66	
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Odour	Diln No	7	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Odour - Nature		Earthy/Musty	
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Taste	Diln No	6	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968201	12/09/2024 07:31	Taste - Nature		Earthy	
W1302OUT	Lough Fea Final Water Outlet	4968179	12/09/2024 09:21	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4968179	12/09/2024 09:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4968179	12/09/2024 09:21	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4968179	12/09/2024 09:21	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4968179	12/09/2024 09:21	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4968179	12/09/2024 09:21	Free - Residual disinfectant	mg Cl/l	0.91	
W1302OUT	Lough Fea Final Water Outlet	4968179	12/09/2024 09:21	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4968179	12/09/2024 09:21	Odour	Diln No	0	0
W1302OUT	Lough Fea Final Water Outlet	4968179	12/09/2024 09:21	Odour - Nature		No odour	
W1302OUT	Lough Fea Final Water Outlet	4968179	12/09/2024 09:21	Taste	Diln No	0	0
W1302OUT	Lough Fea Final Water Outlet	4968179	12/09/2024 09:21	Taste - Nature		No taste	
W1302OUT	Lough Fea Final Water Outlet	4968179	12/09/2024 09:21	Total - Residual disinfectant	mg Cl/l	0.99	
W1302OUT	Lough Fea Final Water Outlet	4968179	12/09/2024 09:21	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4968179	12/09/2024 09:21	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4968193	12/09/2024 10:52	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4968193	12/09/2024 10:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	

W4701OUT	Killyhevlin Final Water Outlet	4968193	12/09/2024 10:52	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4968193	12/09/2024 10:52	Conductivity	uS/cm 20 C	410	2500
W4701OUT	Killyhevlin Final Water Outlet	4968193	12/09/2024 10:52	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4968193	12/09/2024 10:52	Free - Residual disinfectant	mg Cl/l	1.63	
W4701OUT	Killyhevlin Final Water Outlet	4968193	12/09/2024 10:52	Hydrogen Ion	pH value	7.8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4968193	12/09/2024 10:52	Total - Residual disinfectant	mg Cl/l	1.8	
W4701OUT	Killyhevlin Final Water Outlet	4968193	12/09/2024 10:52	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4968193	12/09/2024 10:52	Turbidity	NTU	0.091	1
W4701OUT	Killyhevlin Final Water Outlet	4968193	12/09/2024 10:52	Algae Blue Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4968193	12/09/2024 10:52	Algae Diatom Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4968193	12/09/2024 10:52	Algae Flagellate Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4968193	12/09/2024 10:52	Algae Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4968193	12/09/2024 10:52	Algae Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4968193	12/09/2024 10:52	Aluminium	ug Al/l	23	200
W4701OUT	Killyhevlin Final Water Outlet	4968193	12/09/2024 10:52	Iron	ug/l Fe	3.6	200
W4701OUT	Killyhevlin Final Water Outlet	4968193	12/09/2024 10:52	Manganese	ug Mn/l	1.6	50
W4701OUT	Killyhevlin Final Water Outlet	4968193	12/09/2024 10:52	Most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4968193	12/09/2024 10:52	Second most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4968193	12/09/2024 10:52	Third most numerous Algae		---	
W2514OUT	Seagahan Final Water Outlet	4968186	12/09/2024 10:58	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4968186	12/09/2024 10:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4968186	12/09/2024 10:58	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4968186	12/09/2024 10:58	Conductivity	uS/cm 20 C	400	2500
W2514OUT	Seagahan Final Water Outlet	4968186	12/09/2024 10:58	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4968186	12/09/2024 10:58	Free - Residual disinfectant	mg Cl/l	1.15	
W2514OUT	Seagahan Final Water Outlet	4968186	12/09/2024 10:58	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4968186	12/09/2024 10:58	Total - Residual disinfectant	mg Cl/l	1.36	
W2514OUT	Seagahan Final Water Outlet	4968186	12/09/2024 10:58	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4968186	12/09/2024 10:58	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4968180	12/09/2024 11:41	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4968180	12/09/2024 11:41	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4968180	12/09/2024 11:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4968180	12/09/2024 11:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4968180	12/09/2024 11:41	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4968180	12/09/2024 11:41	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4968180	12/09/2024 11:41	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4968180	12/09/2024 11:41	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4968180	12/09/2024 11:41	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4968180	12/09/2024 11:41	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4968180	12/09/2024 11:41	Free - Residual disinfectant	mg Cl/l	0.81	
W4523OUT	Lough Macrory Final Water Outlet	4968180	12/09/2024 11:41	Free - Residual disinfectant	mg Cl/l	0.81	
W4523OUT	Lough Macrory Final Water Outlet	4968180	12/09/2024 11:41	Hydrogen Ion	pH value	7.6	9.5

W4523OUT	Lough Macrory Final Water Outlet	4968180	12/09/2024 11:41	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4968180	12/09/2024 11:41	Total - Residual disinfectant	mg Cl/l	0.88	
W4523OUT	Lough Macrory Final Water Outlet	4968180	12/09/2024 11:41	Total - Residual disinfectant	mg Cl/l	0.88	
W4523OUT	Lough Macrory Final Water Outlet	4968180	12/09/2024 11:41	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4968180	12/09/2024 11:41	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4968180	12/09/2024 11:41	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4968180	12/09/2024 11:41	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Conductivity	uS/cm 20 C	390	2500
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Free - Residual disinfectant	mg Cl/l	1.53	
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Total - Residual disinfectant	mg Cl/l	1.85	
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Taste	Diln No	7	0
W1301POUT	Moyola PPP Final Water Outlet	4968365	13/09/2024 06:44	Taste - Nature		Earthy/Musty	
W2308POUT	Castor Bay PPP Final Water Outlet	4968364	13/09/2024 08:17	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4968364	13/09/2024 08:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4968364	13/09/2024 08:17	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4968364	13/09/2024 08:17	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4968364	13/09/2024 08:17	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968364	13/09/2024 08:17	Free - Residual disinfectant	mg Cl/l	1.53	
W2308POUT	Castor Bay PPP Final Water Outlet	4968364	13/09/2024 08:17	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4968364	13/09/2024 08:17	Total - Residual disinfectant	mg Cl/l	1.63	
W2308POUT	Castor Bay PPP Final Water Outlet	4968364	13/09/2024 08:17	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968364	13/09/2024 08:17	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4968359	13/09/2024 09:56	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4968359	13/09/2024 09:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4968359	13/09/2024 09:56	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4968359	13/09/2024 09:56	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4968359	13/09/2024 09:56	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4968359	13/09/2024 09:56	Free - Residual disinfectant	mg Cl/l	1.34	
W4701OUT	Killyhevlin Final Water Outlet	4968359	13/09/2024 09:56	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4968359	13/09/2024 09:56	Total - Residual disinfectant	mg Cl/l	1.46	
W4701OUT	Killyhevlin Final Water Outlet	4968359	13/09/2024 09:56	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4968359	13/09/2024 09:56	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4968357	13/09/2024 10:13	Colony Counts 22	CFU/1 ml	0	

W1302OUT	Lough Fea Final Water Outlet	4968357	13/09/2024 10:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4968357	13/09/2024 10:13	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4968357	13/09/2024 10:13	Conductivity	uS/cm 20 C	130	2500
W1302OUT	Lough Fea Final Water Outlet	4968357	13/09/2024 10:13	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4968357	13/09/2024 10:13	Free - Residual disinfectant	mg Cl/l	0.96	
W1302OUT	Lough Fea Final Water Outlet	4968357	13/09/2024 10:13	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4968357	13/09/2024 10:13	Total - Residual disinfectant	mg Cl/l	1.04	
W1302OUT	Lough Fea Final Water Outlet	4968357	13/09/2024 10:13	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4968357	13/09/2024 10:13	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Conductivity	uS/cm 20 C	380	2500
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Free - Residual disinfectant	mg Cl/l	1.5	
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Hydrogen Ion	pH value	7.4	9.5
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Total - Residual disinfectant	mg Cl/l	1.64	
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Odour	Diln No	10	0
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Odour - Nature		Earthy	
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Taste	Diln No	10	0
W1301POUT	Moyola PPP Final Water Outlet	4968446	14/09/2024 08:18	Taste - Nature		Earthy	
W4701OUT	Killyhevlin Final Water Outlet	4968441	14/09/2024 09:21	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4968441	14/09/2024 09:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4968441	14/09/2024 09:21	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4968441	14/09/2024 09:21	Conductivity	uS/cm 20 C	410	2500
W4701OUT	Killyhevlin Final Water Outlet	4968441	14/09/2024 09:21	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4968441	14/09/2024 09:21	Free - Residual disinfectant	mg Cl/l	1.39	
W4701OUT	Killyhevlin Final Water Outlet	4968441	14/09/2024 09:21	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4968441	14/09/2024 09:21	Total - Residual disinfectant	mg Cl/l	1.68	
W4701OUT	Killyhevlin Final Water Outlet	4968441	14/09/2024 09:21	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4968441	14/09/2024 09:21	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4968440	14/09/2024 09:33	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4968440	14/09/2024 09:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4968440	14/09/2024 09:33	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4968440	14/09/2024 09:33	Conductivity	uS/cm 20 C	140	2500
W1302OUT	Lough Fea Final Water Outlet	4968440	14/09/2024 09:33	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4968440	14/09/2024 09:33	Free - Residual disinfectant	mg Cl/l	0.98	
W1302OUT	Lough Fea Final Water Outlet	4968440	14/09/2024 09:33	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4968440	14/09/2024 09:33	Total - Residual disinfectant	mg Cl/l	1.02	
W1302OUT	Lough Fea Final Water Outlet	4968440	14/09/2024 09:33	Total Coliforms	CFU/100 ml	0	0

W1302OUT	Lough Fea Final Water Outlet	4968440	14/09/2024 09:33	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Conductivity	uS/cm 20 C	360	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Free - Residual disinfectant	mg Cl/l	1.48	
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Hydrogen Ion	pH value	7.4	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Total - Residual disinfectant	mg Cl/l	1.64	
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968445	14/09/2024 10:22	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Conductivity	uS/cm 20 C	390	2500
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Free - Residual disinfectant	mg Cl/l	1.51	
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Hydrogen Ion	pH value	7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Total - Residual disinfectant	mg Cl/l	1.58	
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4968475	15/09/2024 08:02	Taste - Nature		No taste	
W4701OUT	Killyhevlin Final Water Outlet	4968470	15/09/2024 09:56	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4968470	15/09/2024 09:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4968470	15/09/2024 09:56	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4968470	15/09/2024 09:56	Conductivity	uS/cm 20 C	440	2500
W4701OUT	Killyhevlin Final Water Outlet	4968470	15/09/2024 09:56	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4968470	15/09/2024 09:56	Free - Residual disinfectant	mg Cl/l	1.51	
W4701OUT	Killyhevlin Final Water Outlet	4968470	15/09/2024 09:56	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4968470	15/09/2024 09:56	Total - Residual disinfectant	mg Cl/l	1.63	
W4701OUT	Killyhevlin Final Water Outlet	4968470	15/09/2024 09:56	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4968470	15/09/2024 09:56	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4968469	15/09/2024 11:04	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4968469	15/09/2024 11:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4968469	15/09/2024 11:04	Colour	mg/l Pt/Co	<4.56	20

W1302OUT	Lough Fea Final Water Outlet	4968469	15/09/2024 11:04	Conductivity	uS/cm 20 C	140	2500
W1302OUT	Lough Fea Final Water Outlet	4968469	15/09/2024 11:04	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4968469	15/09/2024 11:04	Free - Residual disinfectant	mg Cl/l	0.9	
W1302OUT	Lough Fea Final Water Outlet	4968469	15/09/2024 11:04	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4968469	15/09/2024 11:04	Total - Residual disinfectant	mg Cl/l	0.98	
W1302OUT	Lough Fea Final Water Outlet	4968469	15/09/2024 11:04	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4968469	15/09/2024 11:04	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Free - Residual disinfectant	mg Cl/l	1.51	
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Total - Residual disinfectant	mg Cl/l	1.71	
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4968474	15/09/2024 11:07	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	2,4-D	ug/l	<0.011	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	2,4-DB	ug/l	<0.016	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Asulam	ug/l	<0.015	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Bentazone	ug/l	<0.0044	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Bromoxynil	ug/l	<0.0079	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Chlorotoluron	ug/l	<0.0031	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Chlorpyrifos	ug/l	<0.0070	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Clopyralid	ug/l	<0.0097	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Conductivity	uS/cm 20 C	440	2500
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Cyanide	ug/l CN	<5.5	50
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Dicamba	ug/l	<0.028	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Dichlorprop	ug/l	<0.011	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Diflufenican	ug/l	<0.0072	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Dimethenamid	ug/l	<0.0063	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Diuron	ug/l	<0.0055	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Epoxiconazole	ug/l	<0.0049	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Fenpropimorph	ug/l	<0.0083	0.1

W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Flufenacet	ug/l	<0.0052	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Fluroxypyr	ug/l	<0.0063	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Free - Residual disinfectant	mg Cl/l	1.52	
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Glyphosate	ug/l	<0.0077	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Isoproturon	ug/l	<0.0025	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Linuron	ug/l	<0.0034	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	MCPA	ug/l	0.021	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	MCPB	ug/l	<0.015	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Mecoprop	ug/l	<0.011	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Metalaxyl	ug/l	<0.0097	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Metamitron	ug/l	<0.0074	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Metazachlor	ug/l	<0.015	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Metoxuron	ug/l	<0.0080	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Metribuzin	ug/l	<0.0060	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Oxamyl	ug/l	<0.0023	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Pendimethalin	ug/l	<0.0064	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Pesticides - Total Substances	ug/l	0.021	0.5
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Phorate	ug/l	<0.0092	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Pirimicarb	ug/l	<0.0063	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Propachlor	ug/l	<0.0096	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Propiconazole	ug/l	<0.0029	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Propyzamide	ug/l	<0.012	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Prothioconazole	ug/l	<0.0019	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Tebuconazole	ug/l	<0.0039	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Total - Residual disinfectant	mg Cl/l	1.61	
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Triclopyr	ug/l	<0.012	0.1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Turbidity	NTU	0.11	1
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Algae Blue Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Algae Diatom Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Algae Flagellate Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Algae Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Algae Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Aluminium	ug Al/l	24	200
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Iron	ug/l Fe	5.4	200
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Manganese	ug Mn/l	1.7	50
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Odour	Diln No	0	0
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Odour - Nature		No odour	
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Second most numerous Algae		---	
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Taste	Diln No	0	0

W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Taste - Nature		No taste	
W4701OUT	Killyhevlin Final Water Outlet	4970824	16/09/2024 08:55	Third most numerous Algae		---	
W1302OUT	Lough Fea Final Water Outlet	4970805	16/09/2024 09:24	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4970805	16/09/2024 09:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4970805	16/09/2024 09:24	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4970805	16/09/2024 09:24	Conductivity	uS/cm 20 C	140	2500
W1302OUT	Lough Fea Final Water Outlet	4970805	16/09/2024 09:24	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4970805	16/09/2024 09:24	Free - Residual disinfectant	mg Cl/l	0.76	
W1302OUT	Lough Fea Final Water Outlet	4970805	16/09/2024 09:24	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4970805	16/09/2024 09:24	Total - Residual disinfectant	mg Cl/l	0.86	
W1302OUT	Lough Fea Final Water Outlet	4970805	16/09/2024 09:24	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4970805	16/09/2024 09:24	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Free - Residual disinfectant	mg Cl/l	1.48	
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Hydrogen Ion	pH value	7.4	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Total - Residual disinfectant	mg Cl/l	1.55	
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4970834	16/09/2024 10:17	Taste - Nature		No taste	
W2514OUT	Seagahan Final Water Outlet	4970800	16/09/2024 11:04	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4970800	16/09/2024 11:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4970800	16/09/2024 11:04	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4970800	16/09/2024 11:04	Conductivity	uS/cm 20 C	420	2500
W2514OUT	Seagahan Final Water Outlet	4970800	16/09/2024 11:04	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4970800	16/09/2024 11:04	Free - Residual disinfectant	mg Cl/l	1.06	
W2514OUT	Seagahan Final Water Outlet	4970800	16/09/2024 11:04	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4970800	16/09/2024 11:04	Total - Residual disinfectant	mg Cl/l	1.28	
W2514OUT	Seagahan Final Water Outlet	4970800	16/09/2024 11:04	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4970800	16/09/2024 11:04	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4970806	16/09/2024 11:53	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4970806	16/09/2024 11:53	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4970806	16/09/2024 11:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4970806	16/09/2024 11:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4970806	16/09/2024 11:53	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4970806	16/09/2024 11:53	Colour	mg/l Pt/Co	<4.56	20

W4523OUT	Lough Macrory Final Water Outlet	4970806	16/09/2024 11:53	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4970806	16/09/2024 11:53	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4970806	16/09/2024 11:53	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4970806	16/09/2024 11:53	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4970806	16/09/2024 11:53	Free - Residual disinfectant	mg Cl/l	0.81	
W4523OUT	Lough Macrory Final Water Outlet	4970806	16/09/2024 11:53	Free - Residual disinfectant	mg Cl/l	0.81	
W4523OUT	Lough Macrory Final Water Outlet	4970806	16/09/2024 11:53	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4970806	16/09/2024 11:53	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4970806	16/09/2024 11:53	Total - Residual disinfectant	mg Cl/l	0.88	
W4523OUT	Lough Macrory Final Water Outlet	4970806	16/09/2024 11:53	Total - Residual disinfectant	mg Cl/l	0.88	
W4523OUT	Lough Macrory Final Water Outlet	4970806	16/09/2024 11:53	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4970806	16/09/2024 11:53	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4970806	16/09/2024 11:53	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4970806	16/09/2024 11:53	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Conductivity	uS/cm 20 C	380	2500
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Free - Residual disinfectant	mg Cl/l	1.48	
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Total - Residual disinfectant	mg Cl/l	1.55	
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4970838	16/09/2024 11:59	Taste - Nature		No taste	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	2,4-D	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	2,4-DB	ug/l	<0.016	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Asulam	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Bentazone	ug/l	<0.0044	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Bromoxynil	ug/l	<0.0079	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Chlorotoluron	ug/l	<0.0031	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Chlorpyrifos	ug/l	<0.0070	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Clopyralid	ug/l	<0.0097	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Conductivity	uS/cm 20 C	380	2500
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Cyanide	ug/l CN	<5.5	50
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Dicamba	ug/l	<0.028	0.1

W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Dichlorprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Diflufenican	ug/l	<0.0072	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Dimethenamid	ug/l	<0.0063	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Diuron	ug/l	<0.0055	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Epoxiconazole	ug/l	<0.0049	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Fenpropimorph	ug/l	<0.0083	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Flufenacet	ug/l	<0.0052	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Fluroxypyr	ug/l	<0.0063	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Free - Residual disinfectant	mg Cl/l	1.59	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Glyphosate	ug/l	<0.0077	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Hydrogen Ion	pH value	7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Isoproturon	ug/l	<0.0025	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Linuron	ug/l	<0.0034	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	MCPA	ug/l	<0.0093	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	MCPB	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Mecoprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Metaxyl	ug/l	<0.0097	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Metamitron	ug/l	<0.0074	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Metazachlor	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Metoxuron	ug/l	<0.0080	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Metribuzin	ug/l	<0.0060	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Oxamyl	ug/l	<0.0023	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Pendimethalin	ug/l	<0.0064	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Pesticides - Total Substances	ug/l	0	0.5
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Phorate	ug/l	<0.0092	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Pirimicarb	ug/l	<0.0063	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Propachlor	ug/l	<0.0096	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Propiconazole	ug/l	<0.0029	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Propyzamide	ug/l	<0.012	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Prothioconazole	ug/l	<0.0019	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Tebuconazole	ug/l	<0.0039	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Total - Residual disinfectant	mg Cl/l	1.67	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Triclopyr	ug/l	<0.012	0.1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Algae Blue Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Algae Diatom Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Algae Flagellate Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Algae Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Algae Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Aluminium	ug Al/l	36	200

W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Geosmin	ng/l	<1.1	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Iron	ug/l Fe	2	200
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Manganese	ug Mn/l	<0.80	50
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Microcystin-LR	ug/l	<0.024	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Most numerous Algae		---	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Second most numerous Algae		---	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Taste - Nature		No taste	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Third most numerous Algae		---	
W1301POUT	Moyola PPP Final Water Outlet	4971092	17/09/2024 06:47	Total Organic Carbon	mg C/l	2.4	
W1302OUT	Lough Fea Final Water Outlet	4971070	17/09/2024 08:18	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4971070	17/09/2024 08:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4971070	17/09/2024 08:18	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4971070	17/09/2024 08:18	Conductivity	uS/cm 20 C	140	2500
W1302OUT	Lough Fea Final Water Outlet	4971070	17/09/2024 08:18	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4971070	17/09/2024 08:18	Free - Residual disinfectant	mg Cl/l	0.76	
W1302OUT	Lough Fea Final Water Outlet	4971070	17/09/2024 08:18	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4971070	17/09/2024 08:18	Total - Residual disinfectant	mg Cl/l	0.92	
W1302OUT	Lough Fea Final Water Outlet	4971070	17/09/2024 08:18	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4971070	17/09/2024 08:18	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	2,4-D	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	2,4-DB	ug/l	<0.016	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Asulam	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Bentazone	ug/l	<0.0044	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Bromoxynil	ug/l	<0.0079	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Chlorotoluron	ug/l	<0.0031	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Chlorpyrifos	ug/l	<0.0070	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Clopyralid	ug/l	<0.0097	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Cyanide	ug/l CN	<5.5	50
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Dicamba	ug/l	<0.028	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Dichlorprop	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Diflufenican	ug/l	<0.0072	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Dimethenamid	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Diuron	ug/l	<0.0055	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Epoxiconazole	ug/l	<0.0049	0.1

W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Fenpropimorph	ug/l	<0.0083	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Flufenacet	ug/l	<0.0052	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Fluroxypyr	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Free - Residual disinfectant	mg Cl/l	1.42	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Glyphosate	ug/l	<0.0077	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Isoproturon	ug/l	<0.0025	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Linuron	ug/l	<0.0034	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	MCPA	ug/l	0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	MCPB	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Mecoprop	ug/l	<0.011	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Metaxyl	ug/l	<0.0097	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Metamitron	ug/l	<0.0074	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Metazachlor	ug/l	<0.015	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Metoxuron	ug/l	<0.0080	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Metribuzin	ug/l	<0.0060	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Oxamyl	ug/l	<0.0023	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Pendimethalin	ug/l	<0.0064	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Pesticides - Total Substances	ug/l	0.012	0.5
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Phorate	ug/l	<0.0092	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Pirimicarb	ug/l	<0.0063	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Propachlor	ug/l	<0.0096	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Propiconazole	ug/l	<0.0029	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Propyzamide	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Prothioconazole	ug/l	<0.0019	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Tebuconazole	ug/l	<0.0039	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Total - Residual disinfectant	mg Cl/l	1.52	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Triclopyr	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Turbidity	NTU	0.096	1
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Algae Diatom Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Algae Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Aluminium	ug Al/l	26	200
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Bromodichloromethane	ug/l	4.6	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Chloroform	ug/l	7.3	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Dibromochloromethane	ug/l	4	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Geosmin	ng/l	<1.1	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Iron	ug/l Fe	2.1	200

W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Manganese	ug Mn/l	<0.80	50
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	MIB	ng/l	17	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Microcystin-LR	ug/l	<0.024	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Most numerous Algae		---	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Second most numerous Algae		---	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Third most numerous Algae		---	
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	Total Trihalomethanes	ug/l	17	100
W2308POUT	Castor Bay PPP Final Water Outlet	4971087	17/09/2024 08:35	WHO Index		0.15	1
W4701OUT	Killyhevlin Final Water Outlet	4971078	17/09/2024 09:14	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4971078	17/09/2024 09:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4971078	17/09/2024 09:14	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4971078	17/09/2024 09:14	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4971078	17/09/2024 09:14	Free - Residual disinfectant	mg Cl/l	1.32	
W4701OUT	Killyhevlin Final Water Outlet	4971078	17/09/2024 09:14	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4971078	17/09/2024 09:14	Total - Residual disinfectant	mg Cl/l	1.44	
W4701OUT	Killyhevlin Final Water Outlet	4971078	17/09/2024 09:14	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4971071	17/09/2024 10:26	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4971071	17/09/2024 10:26	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4971071	17/09/2024 10:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4971071	17/09/2024 10:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4971071	17/09/2024 10:26	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4971071	17/09/2024 10:26	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4971071	17/09/2024 10:26	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4971071	17/09/2024 10:26	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4971071	17/09/2024 10:26	Free - Residual disinfectant	mg Cl/l	0.88	
W4523OUT	Lough Macrory Final Water Outlet	4971071	17/09/2024 10:26	Free - Residual disinfectant	mg Cl/l	0.88	
W4523OUT	Lough Macrory Final Water Outlet	4971071	17/09/2024 10:26	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4971071	17/09/2024 10:26	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4971071	17/09/2024 10:26	Total - Residual disinfectant	mg Cl/l	0.94	
W4523OUT	Lough Macrory Final Water Outlet	4971071	17/09/2024 10:26	Total - Residual disinfectant	mg Cl/l	0.94	
W4523OUT	Lough Macrory Final Water Outlet	4971071	17/09/2024 10:26	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4971071	17/09/2024 10:26	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	2,4-D	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	2,4-DB	ug/l	<0.016	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Asulam	ug/l	<0.015	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Bentazone	ug/l	<0.0044	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Bromoxynil	ug/l	<0.0079	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Chlorotoluron	ug/l	<0.0031	0.1

W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Chlorpyrifos	ug/l	<0.0070	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Clopyralid	ug/l	<0.0097	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Conductivity	uS/cm 20 C	420	2500
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Cyanide	ug/l CN	<5.5	50
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Dicamba	ug/l	<0.028	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Dichlorprop	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Diflufenican	ug/l	<0.0072	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Dimethenamid	ug/l	<0.0063	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Diuron	ug/l	<0.0055	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Epoxiconazole	ug/l	<0.0049	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Fenpropimorph	ug/l	<0.0083	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Flufenacet	ug/l	<0.0052	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Fluroxypyr	ug/l	<0.0063	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Free - Residual disinfectant	mg Cl/l	1	
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Glyphosate	ug/l	<0.0077	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Isoproturon	ug/l	<0.0025	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Linuron	ug/l	<0.0034	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	MCPA	ug/l	0.019	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	MCPB	ug/l	<0.015	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Mecoprop	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Metalaxyl	ug/l	<0.0097	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Metamitron	ug/l	<0.0074	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Metazachlor	ug/l	<0.015	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Metoxuron	ug/l	<0.0080	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Metribuzin	ug/l	<0.0060	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Oxamyl	ug/l	<0.0023	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Pendimethalin	ug/l	<0.0064	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Pesticides - Total Substances	ug/l	0.019	0.5
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Phorate	ug/l	<0.0092	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Pirimicarb	ug/l	<0.0063	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Propachlor	ug/l	<0.0096	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Propiconazole	ug/l	<0.0029	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Propyzamide	ug/l	<0.012	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Prothioconazole	ug/l	<0.0019	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Tebuconazole	ug/l	<0.0039	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Total - Residual disinfectant	mg Cl/l	1.26	
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Total Coliforms	CFU/100 ml	0	0

W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Triclopyr	ug/l	<0.012	0.1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Algae Blue Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Algae Diatom Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Algae Flagellate Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Algae Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Algae Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Aluminium	ug Al/l	4.4	200
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Iron	ug/l Fe	<1.538	200
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Manganese	ug Mn/l	<0.80	50
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Most numerous Algae		---	
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Second most numerous Algae		---	
W2514OUT	Seagahan Final Water Outlet	4971066	17/09/2024 10:33	Third most numerous Algae		---	
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Free - Residual disinfectant	mg Cl/l	1.48	
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Total - Residual disinfectant	mg Cl/l	1.56	
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971300	18/09/2024 07:30	Taste - Nature		No taste	
W4701OUT	Killyhevlin Final Water Outlet	4971293	18/09/2024 08:12	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4971293	18/09/2024 08:12	Colony Counts 37 (48hrs)	CFU/1 ml	1	
W4701OUT	Killyhevlin Final Water Outlet	4971293	18/09/2024 08:12	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4971293	18/09/2024 08:12	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4971293	18/09/2024 08:12	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4971293	18/09/2024 08:12	Free - Residual disinfectant	mg Cl/l	1.42	
W4701OUT	Killyhevlin Final Water Outlet	4971293	18/09/2024 08:12	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4971293	18/09/2024 08:12	Total - Residual disinfectant	mg Cl/l	1.5	
W4701OUT	Killyhevlin Final Water Outlet	4971293	18/09/2024 08:12	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4971293	18/09/2024 08:12	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	E. coli	CFU/100 ml	0	0

W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Free - Residual disinfectant	mg Cl/l	1.39	
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Total - Residual disinfectant	mg Cl/l	1.44	
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4971302	18/09/2024 08:30	Taste - Nature		No taste	
W2514OUT	Seagahan Final Water Outlet	4971278	18/09/2024 09:31	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4971278	18/09/2024 09:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4971278	18/09/2024 09:31	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4971278	18/09/2024 09:31	Conductivity	uS/cm 20 C	420	2500
W2514OUT	Seagahan Final Water Outlet	4971278	18/09/2024 09:31	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4971278	18/09/2024 09:31	Free - Residual disinfectant	mg Cl/l	1.16	
W2514OUT	Seagahan Final Water Outlet	4971278	18/09/2024 09:31	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4971278	18/09/2024 09:31	Total - Residual disinfectant	mg Cl/l	1.4	
W2514OUT	Seagahan Final Water Outlet	4971278	18/09/2024 09:31	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4971278	18/09/2024 09:31	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4971286	18/09/2024 10:38	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4971286	18/09/2024 10:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4971286	18/09/2024 10:38	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4971286	18/09/2024 10:38	Conductivity	uS/cm 20 C	140	2500
W1302OUT	Lough Fea Final Water Outlet	4971286	18/09/2024 10:38	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4971286	18/09/2024 10:38	Free - Residual disinfectant	mg Cl/l	0.84	
W1302OUT	Lough Fea Final Water Outlet	4971286	18/09/2024 10:38	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4971286	18/09/2024 10:38	Total - Residual disinfectant	mg Cl/l	0.86	
W1302OUT	Lough Fea Final Water Outlet	4971286	18/09/2024 10:38	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4971286	18/09/2024 10:38	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Free - Residual disinfectant	mg Cl/l	0.53	
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Free - Residual disinfectant	mg Cl/l	0.53	
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Hydrogen Ion	pH value	7.4	9.5

W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Hydrogen Ion	pH value	7.4	9.5
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Total - Residual disinfectant	mg Cl/l	0.68	
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Total - Residual disinfectant	mg Cl/l	0.68	
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	2,4-D	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	2,4-D	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	2,4-DB	ug/l	<0.016	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	2,4-DB	ug/l	<0.016	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Aluminium	ug Al/l	14	200
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Aluminium	ug Al/l	14	200
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Asulam	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Asulam	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Bentazone	ug/l	<0.0044	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Bentazone	ug/l	<0.0044	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Bromoxynil	ug/l	<0.0079	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Bromoxynil	ug/l	<0.0079	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Clopyralid	ug/l	<0.0097	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Clopyralid	ug/l	<0.0097	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Dichlorprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Dichlorprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Iron	ug/l Fe	5.3	200
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Iron	ug/l Fe	5.3	200
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Manganese	ug Mn/l	<0.80	50
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Manganese	ug Mn/l	<0.80	50
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	MCPA	ug/l	<0.0093	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	MCPA	ug/l	<0.0093	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	MCPB	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	MCPB	ug/l	<0.015	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Mecoprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Mecoprop	ug/l	<0.011	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Propyzamide	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Propyzamide	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Total Organic Carbon	mg C/l	2.1	
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Total Organic Carbon	mg C/l	2.1	
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Triclopyr	ug/l	<0.012	0.1
W4523OUT	Lough Macrory Final Water Outlet	4971287	18/09/2024 10:43	Triclopyr	ug/l	<0.012	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4971470	19/09/2024 07:45	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971470	19/09/2024 07:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971470	19/09/2024 07:45	Colour	mg/l Pt/Co	<4.56	20

W2308POUT	Castor Bay PPP Final Water Outlet	4971470	19/09/2024 07:45	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4971470	19/09/2024 07:45	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971470	19/09/2024 07:45	Free - Residual disinfectant	mg Cl/l	1.54	
W2308POUT	Castor Bay PPP Final Water Outlet	4971470	19/09/2024 07:45	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4971470	19/09/2024 07:45	Total - Residual disinfectant	mg Cl/l	1.62	
W2308POUT	Castor Bay PPP Final Water Outlet	4971470	19/09/2024 07:45	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971470	19/09/2024 07:45	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4971470	19/09/2024 07:45	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971470	19/09/2024 07:45	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4971470	19/09/2024 07:45	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971470	19/09/2024 07:45	Taste - Nature		No taste	
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Free - Residual disinfectant	mg Cl/l	1.41	
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Total - Residual disinfectant	mg Cl/l	1.45	
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Taste	Diln No	7	0
W1301POUT	Moyola PPP Final Water Outlet	4971473	19/09/2024 07:46	Taste - Nature		Earthy/Musty	
W4701OUT	Killyhevlin Final Water Outlet	4971463	19/09/2024 09:11	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4971463	19/09/2024 09:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4971463	19/09/2024 09:11	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4971463	19/09/2024 09:11	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4971463	19/09/2024 09:11	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4971463	19/09/2024 09:11	Free - Residual disinfectant	mg Cl/l	1.47	
W4701OUT	Killyhevlin Final Water Outlet	4971463	19/09/2024 09:11	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4971463	19/09/2024 09:11	Total - Residual disinfectant	mg Cl/l	1.59	
W4701OUT	Killyhevlin Final Water Outlet	4971463	19/09/2024 09:11	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4971463	19/09/2024 09:11	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Conductivity	uS/cm 20 C	140	2500
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Free - Residual disinfectant	mg Cl/l	0.9	
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Hydrogen Ion	pH value	7.2	9.5

W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Total - Residual disinfectant	mg Cl/l	0.96	
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	2,4-D	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	2,4-DB	ug/l	<0.016	0.1
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Aluminium	ug Al/l	13	200
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Asulam	ug/l	<0.015	0.1
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Bentazone	ug/l	<0.0044	0.1
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Bromodichloromethane	ug/l	8	
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Bromoform	ug/l	<3.5	
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Bromoxynil	ug/l	<0.0079	0.1
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Chloroform	ug/l	41	
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Clopyralid	ug/l	<0.0097	0.1
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Dibromochloromethane	ug/l	<1.6	
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Dichlorprop	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Iron	ug/l Fe	4.3	200
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Manganese	ug Mn/l	<0.80	50
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	MCPA	ug/l	<0.0093	0.1
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	MCPB	ug/l	<0.015	0.1
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Mecoprop	ug/l	<0.011	0.1
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Propyzamide	ug/l	<0.012	0.1
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Total Trihalomethanes	ug/l	51	100
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	Triclopyr	ug/l	<0.012	0.1
W1302OUT	Lough Fea Final Water Outlet	4971453	19/09/2024 09:40	WHO Index		0.29	1
W2514OUT	Seagahan Final Water Outlet	4971447	19/09/2024 10:28	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4971447	19/09/2024 10:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4971447	19/09/2024 10:28	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4971447	19/09/2024 10:28	Conductivity	uS/cm 20 C	420	2500
W2514OUT	Seagahan Final Water Outlet	4971447	19/09/2024 10:28	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4971447	19/09/2024 10:28	Free - Residual disinfectant	mg Cl/l	1.2	
W2514OUT	Seagahan Final Water Outlet	4971447	19/09/2024 10:28	Hydrogen Ion	pH value	7.6	9.5
W2514OUT	Seagahan Final Water Outlet	4971447	19/09/2024 10:28	Total - Residual disinfectant	mg Cl/l	1.48	
W2514OUT	Seagahan Final Water Outlet	4971447	19/09/2024 10:28	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4971447	19/09/2024 10:28	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4971454	19/09/2024 11:10	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4971454	19/09/2024 11:10	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4971454	19/09/2024 11:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4971454	19/09/2024 11:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4971454	19/09/2024 11:10	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4971454	19/09/2024 11:10	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4971454	19/09/2024 11:10	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4971454	19/09/2024 11:10	Conductivity	uS/cm 20 C	130	2500

W4523OUT	Lough Macrory Final Water Outlet	4971454	19/09/2024 11:10	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4971454	19/09/2024 11:10	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4971454	19/09/2024 11:10	Free - Residual disinfectant	mg Cl/l	0.81	
W4523OUT	Lough Macrory Final Water Outlet	4971454	19/09/2024 11:10	Free - Residual disinfectant	mg Cl/l	0.81	
W4523OUT	Lough Macrory Final Water Outlet	4971454	19/09/2024 11:10	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4971454	19/09/2024 11:10	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4971454	19/09/2024 11:10	Total - Residual disinfectant	mg Cl/l	0.89	
W4523OUT	Lough Macrory Final Water Outlet	4971454	19/09/2024 11:10	Total - Residual disinfectant	mg Cl/l	0.89	
W4523OUT	Lough Macrory Final Water Outlet	4971454	19/09/2024 11:10	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4971454	19/09/2024 11:10	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4971454	19/09/2024 11:10	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4971454	19/09/2024 11:10	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Free - Residual disinfectant	mg Cl/l	1.42	
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Hydrogen Ion	pH value	7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Total - Residual disinfectant	mg Cl/l	1.6	
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Taste	Diln No	10	0
W1301POUT	Moyola PPP Final Water Outlet	4971630	20/09/2024 07:24	Taste - Nature		Earthy	
W2308POUT	Castor Bay PPP Final Water Outlet	4971629	20/09/2024 08:01	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971629	20/09/2024 08:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971629	20/09/2024 08:01	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4971629	20/09/2024 08:01	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4971629	20/09/2024 08:01	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971629	20/09/2024 08:01	Free - Residual disinfectant	mg Cl/l	1.82	
W2308POUT	Castor Bay PPP Final Water Outlet	4971629	20/09/2024 08:01	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4971629	20/09/2024 08:01	Total - Residual disinfectant	mg Cl/l	1.97	
W2308POUT	Castor Bay PPP Final Water Outlet	4971629	20/09/2024 08:01	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971629	20/09/2024 08:01	Turbidity	NTU	0.12	1
W2308POUT	Castor Bay PPP Final Water Outlet	4971629	20/09/2024 08:01	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971629	20/09/2024 08:01	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4971629	20/09/2024 08:01	Taste	Diln No	10	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971629	20/09/2024 08:01	Taste - Nature		Earthy	
W1302OUT	Lough Fea Final Water Outlet	4971622	20/09/2024 08:59	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4971622	20/09/2024 08:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	

W1302OUT	Lough Fea Final Water Outlet	4971622	20/09/2024 08:59	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4971622	20/09/2024 08:59	Conductivity	uS/cm 20 C	140	2500
W1302OUT	Lough Fea Final Water Outlet	4971622	20/09/2024 08:59	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4971622	20/09/2024 08:59	Free - Residual disinfectant	mg Cl/l	0.92	
W1302OUT	Lough Fea Final Water Outlet	4971622	20/09/2024 08:59	Hydrogen Ion	pH value	6.9	9.5
W1302OUT	Lough Fea Final Water Outlet	4971622	20/09/2024 08:59	Total - Residual disinfectant	mg Cl/l	1.03	
W1302OUT	Lough Fea Final Water Outlet	4971622	20/09/2024 08:59	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4971622	20/09/2024 08:59	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4978301	20/09/2024 11:13	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4978301	20/09/2024 11:13	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4978301	20/09/2024 11:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4978301	20/09/2024 11:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4978301	20/09/2024 11:13	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4978301	20/09/2024 11:13	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4978301	20/09/2024 11:13	Free - Residual disinfectant	mg Cl/l	0.79	
W4523OUT	Lough Macrory Final Water Outlet	4978301	20/09/2024 11:13	Free - Residual disinfectant	mg Cl/l	0.79	
W4523OUT	Lough Macrory Final Water Outlet	4978301	20/09/2024 11:13	Total - Residual disinfectant	mg Cl/l	0.85	
W4523OUT	Lough Macrory Final Water Outlet	4978301	20/09/2024 11:13	Total - Residual disinfectant	mg Cl/l	0.85	
W4523OUT	Lough Macrory Final Water Outlet	4978301	20/09/2024 11:13	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4978301	20/09/2024 11:13	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4971624	20/09/2024 12:20	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4971624	20/09/2024 12:20	Colony Counts 37 (48hrs)	CFU/1 ml	1	
W4701OUT	Killyhevlin Final Water Outlet	4971624	20/09/2024 12:20	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4971624	20/09/2024 12:20	Conductivity	uS/cm 20 C	440	2500
W4701OUT	Killyhevlin Final Water Outlet	4971624	20/09/2024 12:20	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4971624	20/09/2024 12:20	Free - Residual disinfectant	mg Cl/l	1.44	
W4701OUT	Killyhevlin Final Water Outlet	4971624	20/09/2024 12:20	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4971624	20/09/2024 12:20	Total - Residual disinfectant	mg Cl/l	1.51	
W4701OUT	Killyhevlin Final Water Outlet	4971624	20/09/2024 12:20	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4971624	20/09/2024 12:20	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4971724	21/09/2024 06:26	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971724	21/09/2024 06:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971724	21/09/2024 06:26	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4971724	21/09/2024 06:26	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4971724	21/09/2024 06:26	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971724	21/09/2024 06:26	Free - Residual disinfectant	mg Cl/l	1.48	
W2308POUT	Castor Bay PPP Final Water Outlet	4971724	21/09/2024 06:26	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4971724	21/09/2024 06:26	Total - Residual disinfectant	mg Cl/l	1.69	
W2308POUT	Castor Bay PPP Final Water Outlet	4971724	21/09/2024 06:26	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971724	21/09/2024 06:26	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4971724	21/09/2024 06:26	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971724	21/09/2024 06:26	Odour - Nature		No odour	

W2308POUT	Castor Bay PPP Final Water Outlet	4971724	21/09/2024 06:26	Taste	Diln No	5	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971724	21/09/2024 06:26	Taste - Nature		Earthy	
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Free - Residual disinfectant	mg Cl/l	1.66	
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Hydrogen Ion	pH value	7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Total - Residual disinfectant	mg Cl/l	1.84	
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4971725	21/09/2024 07:26	Taste - Nature		No taste	
W1302OUT	Lough Fea Final Water Outlet	4971719	21/09/2024 07:58	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4971719	21/09/2024 07:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4971719	21/09/2024 07:58	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4971719	21/09/2024 07:58	Conductivity	uS/cm 20 C	140	2500
W1302OUT	Lough Fea Final Water Outlet	4971719	21/09/2024 07:58	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4971719	21/09/2024 07:58	Free - Residual disinfectant	mg Cl/l	0.97	
W1302OUT	Lough Fea Final Water Outlet	4971719	21/09/2024 07:58	Hydrogen Ion	pH value	6.9	9.5
W1302OUT	Lough Fea Final Water Outlet	4971719	21/09/2024 07:58	Total - Residual disinfectant	mg Cl/l	1.06	
W1302OUT	Lough Fea Final Water Outlet	4971719	21/09/2024 07:58	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4971719	21/09/2024 07:58	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4971720	21/09/2024 08:57	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4971720	21/09/2024 08:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4971720	21/09/2024 08:57	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4971720	21/09/2024 08:57	Conductivity	uS/cm 20 C	440	2500
W4701OUT	Killyhevlin Final Water Outlet	4971720	21/09/2024 08:57	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4971720	21/09/2024 08:57	Free - Residual disinfectant	mg Cl/l	1.3	
W4701OUT	Killyhevlin Final Water Outlet	4971720	21/09/2024 08:57	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4971720	21/09/2024 08:57	Total - Residual disinfectant	mg Cl/l	1.37	
W4701OUT	Killyhevlin Final Water Outlet	4971720	21/09/2024 08:57	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4971720	21/09/2024 08:57	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4971742	22/09/2024 07:11	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971742	22/09/2024 07:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4971742	22/09/2024 07:11	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4971742	22/09/2024 07:11	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4971742	22/09/2024 07:11	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971742	22/09/2024 07:11	Free - Residual disinfectant	mg Cl/l	1.3	

W2308POUT	Castor Bay PPP Final Water Outlet	4971742	22/09/2024 07:11	Hydrogen Ion	pH value	7.7	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4971742	22/09/2024 07:11	Total - Residual disinfectant	mg Cl/l	1.41	
W2308POUT	Castor Bay PPP Final Water Outlet	4971742	22/09/2024 07:11	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971742	22/09/2024 07:11	Turbidity	NTU	0.092	1
W2308POUT	Castor Bay PPP Final Water Outlet	4971742	22/09/2024 07:11	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971742	22/09/2024 07:11	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4971742	22/09/2024 07:11	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4971742	22/09/2024 07:11	Taste - Nature		No taste	
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Free - Residual disinfectant	mg Cl/l	1.7	
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Hydrogen Ion	pH value	7.4	9.5
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Total - Residual disinfectant	mg Cl/l	1.9	
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4971743	22/09/2024 09:16	Taste - Nature		No taste	
W4701OUT	Killyhevlin Final Water Outlet	4971738	22/09/2024 09:20	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4971738	22/09/2024 09:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4971738	22/09/2024 09:20	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4971738	22/09/2024 09:20	Conductivity	uS/cm 20 C	440	2500
W4701OUT	Killyhevlin Final Water Outlet	4971738	22/09/2024 09:20	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4971738	22/09/2024 09:20	Free - Residual disinfectant	mg Cl/l	1.33	
W4701OUT	Killyhevlin Final Water Outlet	4971738	22/09/2024 09:20	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4971738	22/09/2024 09:20	Total - Residual disinfectant	mg Cl/l	1.46	
W4701OUT	Killyhevlin Final Water Outlet	4971738	22/09/2024 09:20	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4971738	22/09/2024 09:20	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4971737	22/09/2024 09:58	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4971737	22/09/2024 09:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4971737	22/09/2024 09:58	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4971737	22/09/2024 09:58	Conductivity	uS/cm 20 C	140	2500
W1302OUT	Lough Fea Final Water Outlet	4971737	22/09/2024 09:58	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4971737	22/09/2024 09:58	Free - Residual disinfectant	mg Cl/l	0.97	
W1302OUT	Lough Fea Final Water Outlet	4971737	22/09/2024 09:58	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4971737	22/09/2024 09:58	Total - Residual disinfectant	mg Cl/l	1.21	
W1302OUT	Lough Fea Final Water Outlet	4971737	22/09/2024 09:58	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4971737	22/09/2024 09:58	Turbidity	NTU	<0.09	1

W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Free - Residual disinfectant	mg Cl/l	1.48	
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Hydrogen Ion	pH value	7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Total - Residual disinfectant	mg Cl/l	1.6	
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4973390	23/09/2024 07:23	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4973387	23/09/2024 07:58	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4973387	23/09/2024 07:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4973387	23/09/2024 07:58	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4973387	23/09/2024 07:58	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4973387	23/09/2024 07:58	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4973387	23/09/2024 07:58	Free - Residual disinfectant	mg Cl/l	1.42	
W2308POUT	Castor Bay PPP Final Water Outlet	4973387	23/09/2024 07:58	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4973387	23/09/2024 07:58	Total - Residual disinfectant	mg Cl/l	1.48	
W2308POUT	Castor Bay PPP Final Water Outlet	4973387	23/09/2024 07:58	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4973387	23/09/2024 07:58	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4973387	23/09/2024 07:58	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4973387	23/09/2024 07:58	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4973387	23/09/2024 07:58	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4973387	23/09/2024 07:58	Taste - Nature		No taste	
W1302OUT	Lough Fea Final Water Outlet	4973358	23/09/2024 09:11	Colony Counts 22	CFU/1 ml	1	
W1302OUT	Lough Fea Final Water Outlet	4973358	23/09/2024 09:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4973358	23/09/2024 09:11	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4973358	23/09/2024 09:11	Conductivity	uS/cm 20 C	140	2500
W1302OUT	Lough Fea Final Water Outlet	4973358	23/09/2024 09:11	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4973358	23/09/2024 09:11	Free - Residual disinfectant	mg Cl/l	0.87	
W1302OUT	Lough Fea Final Water Outlet	4973358	23/09/2024 09:11	Hydrogen Ion	pH value	7.4	9.5
W1302OUT	Lough Fea Final Water Outlet	4973358	23/09/2024 09:11	Total - Residual disinfectant	mg Cl/l	0.97	
W1302OUT	Lough Fea Final Water Outlet	4973358	23/09/2024 09:11	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4973358	23/09/2024 09:11	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4973358	23/09/2024 09:11	Aluminium	ug Al/l	13	200
W1302OUT	Lough Fea Final Water Outlet	4973358	23/09/2024 09:11	Iron	ug/l Fe	3.6	200
W1302OUT	Lough Fea Final Water Outlet	4973358	23/09/2024 09:11	Manganese	ug Mn/l	<0.80	50
W4523OUT	Lough Macrory Final Water Outlet	4973359	23/09/2024 10:01	Colony Counts 22	CFU/1 ml	0	

W4523OUT	Lough Macrory Final Water Outlet	4973359	23/09/2024 10:01	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4973359	23/09/2024 10:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4973359	23/09/2024 10:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4973359	23/09/2024 10:01	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4973359	23/09/2024 10:01	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4973359	23/09/2024 10:01	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4973359	23/09/2024 10:01	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4973359	23/09/2024 10:01	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4973359	23/09/2024 10:01	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4973359	23/09/2024 10:01	Free - Residual disinfectant	mg Cl/l	0.88	
W4523OUT	Lough Macrory Final Water Outlet	4973359	23/09/2024 10:01	Free - Residual disinfectant	mg Cl/l	0.88	
W4523OUT	Lough Macrory Final Water Outlet	4973359	23/09/2024 10:01	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4973359	23/09/2024 10:01	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4973359	23/09/2024 10:01	Total - Residual disinfectant	mg Cl/l	0.94	
W4523OUT	Lough Macrory Final Water Outlet	4973359	23/09/2024 10:01	Total - Residual disinfectant	mg Cl/l	0.94	
W4523OUT	Lough Macrory Final Water Outlet	4973359	23/09/2024 10:01	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4973359	23/09/2024 10:01	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4973359	23/09/2024 10:01	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4973359	23/09/2024 10:01	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4973377	23/09/2024 10:28	Colony Counts 22	CFU/1 ml	1	
W4701OUT	Killyhevlin Final Water Outlet	4973377	23/09/2024 10:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4973377	23/09/2024 10:28	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4973377	23/09/2024 10:28	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4973377	23/09/2024 10:28	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4973377	23/09/2024 10:28	Free - Residual disinfectant	mg Cl/l	1.52	
W4701OUT	Killyhevlin Final Water Outlet	4973377	23/09/2024 10:28	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4973377	23/09/2024 10:28	Total - Residual disinfectant	mg Cl/l	1.6	
W4701OUT	Killyhevlin Final Water Outlet	4973377	23/09/2024 10:28	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4973377	23/09/2024 10:28	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4973352	23/09/2024 11:28	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4973352	23/09/2024 11:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4973352	23/09/2024 11:28	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4973352	23/09/2024 11:28	Conductivity	uS/cm 20 C	430	2500
W2514OUT	Seagahan Final Water Outlet	4973352	23/09/2024 11:28	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4973352	23/09/2024 11:28	Free - Residual disinfectant	mg Cl/l	0.82	
W2514OUT	Seagahan Final Water Outlet	4973352	23/09/2024 11:28	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4973352	23/09/2024 11:28	Total - Residual disinfectant	mg Cl/l	1.07	
W2514OUT	Seagahan Final Water Outlet	4973352	23/09/2024 11:28	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4973352	23/09/2024 11:28	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	

W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Free - Residual disinfectant	mg Cl/l	1.29	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Hydrogen Ion	pH value	7.5	9.5
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Nitrite	mg/l	<0.03	0.1
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Total - Residual disinfectant	mg Cl/l	1.58	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	2,4-D	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	2,4-DB	ug/l	<0.016	0.1
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Algae Blue Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Algae Diatom Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Algae Flagellate Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Algae Green Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Algae Total	per ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Aluminium	ug Al/l	30	200
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Asulam	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Bentazone	ug/l	<0.0044	0.1
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Bromodichloromethane	ug/l	4.6	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Bromoform	ug/l	<3.5	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Bromoxynil	ug/l	<0.0079	0.1
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Chloroform	ug/l	7.3	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Clopyralid	ug/l	<0.0097	0.1
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Dibromochloromethane	ug/l	3.7	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Dichlorprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Geosmin	ng/l	<1.1	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Iron	ug/l Fe	2.4	200
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Manganese	ug Mn/l	<0.642	50
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	MCPA	ug/l	0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	MCPB	ug/l	<0.015	0.1
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Mecoprop	ug/l	<0.011	0.1
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	MIB	ng/l	33	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Microcystin-LR	ug/l	<0.024	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Propyzamide	ug/l	<0.012	0.1
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Second most numerous Algae		-	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Taste - Nature		No taste	
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Third most numerous Algae		-	

W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Total Trihalomethanes	ug/l	16	100
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	Triclopyr	ug/l	<0.012	0.1
W1301POUT	Moyola PPP Final Water Outlet	4973697	24/09/2024 07:19	WHO Index		0.14	1
W1302OUT	Lough Fea Final Water Outlet	4973674	24/09/2024 08:59	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4973674	24/09/2024 08:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4973674	24/09/2024 08:59	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4973674	24/09/2024 08:59	Conductivity	uS/cm 20 C	140	2500
W1302OUT	Lough Fea Final Water Outlet	4973674	24/09/2024 08:59	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4973674	24/09/2024 08:59	Free - Residual disinfectant	mg Cl/l	0.89	
W1302OUT	Lough Fea Final Water Outlet	4973674	24/09/2024 08:59	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4973674	24/09/2024 08:59	Total - Residual disinfectant	mg Cl/l	0.96	
W1302OUT	Lough Fea Final Water Outlet	4973674	24/09/2024 08:59	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4973674	24/09/2024 08:59	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Conductivity	uS/cm 20 C	440	2500
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Free - Residual disinfectant	mg Cl/l	1.62	
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Total - Residual disinfectant	mg Cl/l	1.71	
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Algae Blue Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Algae Diatom Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Algae Flagellate Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Algae Green Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Algae Total	per ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Aluminium	ug Al/l	30	200
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Bromodichloromethane	ug/l	11	
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Bromoform	ug/l	<3.5	
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Chloroform	ug/l	38	
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Dibromochloromethane	ug/l	2.7	
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Iron	ug/l Fe	8.3	200
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Manganese	ug Mn/l	3.3	50
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Most numerous Algae		-	
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Second most numerous Algae		-	
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Third most numerous Algae		-	
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	Total Trihalomethanes	ug/l	52	100
W4701OUT	Killyhevlin Final Water Outlet	4973685	24/09/2024 09:12	WHO Index		0.34	1
W2514OUT	Seagahan Final Water Outlet	4973670	24/09/2024 10:00	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4973670	24/09/2024 10:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	

W2514OUT	Seagahan Final Water Outlet	4973670	24/09/2024 10:00	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4973670	24/09/2024 10:00	Conductivity	uS/cm 20 C	410	2500
W2514OUT	Seagahan Final Water Outlet	4973670	24/09/2024 10:00	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4973670	24/09/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.64	
W2514OUT	Seagahan Final Water Outlet	4973670	24/09/2024 10:00	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4973670	24/09/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.96	
W2514OUT	Seagahan Final Water Outlet	4973670	24/09/2024 10:00	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4973670	24/09/2024 10:00	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4973675	24/09/2024 11:59	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4973675	24/09/2024 11:59	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4973675	24/09/2024 11:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4973675	24/09/2024 11:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4973675	24/09/2024 11:59	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4973675	24/09/2024 11:59	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4973675	24/09/2024 11:59	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4973675	24/09/2024 11:59	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4973675	24/09/2024 11:59	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4973675	24/09/2024 11:59	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4973675	24/09/2024 11:59	Free - Residual disinfectant	mg Cl/l	0.91	
W4523OUT	Lough Macrory Final Water Outlet	4973675	24/09/2024 11:59	Free - Residual disinfectant	mg Cl/l	0.91	
W4523OUT	Lough Macrory Final Water Outlet	4973675	24/09/2024 11:59	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4973675	24/09/2024 11:59	Hydrogen Ion	pH value	7.5	9.5
W4523OUT	Lough Macrory Final Water Outlet	4973675	24/09/2024 11:59	Total - Residual disinfectant	mg Cl/l	0.97	
W4523OUT	Lough Macrory Final Water Outlet	4973675	24/09/2024 11:59	Total - Residual disinfectant	mg Cl/l	0.97	
W4523OUT	Lough Macrory Final Water Outlet	4973675	24/09/2024 11:59	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4973675	24/09/2024 11:59	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4973675	24/09/2024 11:59	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4973675	24/09/2024 11:59	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Clostridium perfringens (sulph red)	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Free - Residual disinfectant	mg Cl/l	1.7	
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Nitrite	mg/l	<0.03	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Total - Residual disinfectant	mg Cl/l	1.88	
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Algae Blue Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Algae Diatom Total	per ml	0	

W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Algae Flagellate Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Algae Green Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Algae Total	per ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Aluminium	ug Al/l	200	200
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Bromodichloromethane	ug/l	4.2	
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Bromoform	ug/l	<3.5	
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Chloroform	ug/l	6.6	
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Dibromochloromethane	ug/l	3.9	
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Iron	ug/l Fe	86	200
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Manganese	ug Mn/l	6.5	50
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Second most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Third most numerous Algae		-	
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	Total Trihalomethanes	ug/l	15	100
W2308POUT	Castor Bay PPP Final Water Outlet	4973694	24/09/2024 12:40	WHO Index		0.14	1
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Free - Residual disinfectant	mg Cl/l	1.44	
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Total - Residual disinfectant	mg Cl/l	1.62	
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4973876	25/09/2024 07:25	Taste - Nature		No taste	
W1316OUT	Moneymore Borewell Final Water Outlet	4982010	25/09/2024 08:25	Colony Counts 22	CFU/1 ml	0	
W1316OUT	Moneymore Borewell Final Water Outlet	4982010	25/09/2024 08:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1316OUT	Moneymore Borewell Final Water Outlet	4982010	25/09/2024 08:25	Colour	mg/l Pt/Co	<4.56	20
W1316OUT	Moneymore Borewell Final Water Outlet	4982010	25/09/2024 08:25	Conductivity	uS/cm 20 C	360	2500
W1316OUT	Moneymore Borewell Final Water Outlet	4982010	25/09/2024 08:25	E. coli	CFU/100 ml	0	0
W1316OUT	Moneymore Borewell Final Water Outlet	4982010	25/09/2024 08:25	Free - Residual disinfectant	mg Cl/l	0.4	
W1316OUT	Moneymore Borewell Final Water Outlet	4982010	25/09/2024 08:25	Hydrogen Ion	pH value	7.7	9.5
W1316OUT	Moneymore Borewell Final Water Outlet	4982010	25/09/2024 08:25	Total - Residual disinfectant	mg Cl/l	0.46	
W1316OUT	Moneymore Borewell Final Water Outlet	4982010	25/09/2024 08:25	Total Coliforms	CFU/100 ml	0	0

W1316OUT	Money more Borewell Final Water Outlet	4982010	25/09/2024 08:25	Turbidity	NTU	0.15	1
W1316OUT	Money more Borewell Final Water Outlet	4982010	25/09/2024 08:25	Aluminium	ug Al/l	16	200
W1316OUT	Money more Borewell Final Water Outlet	4982010	25/09/2024 08:25	Antimony	ug/l Sb	0.11	5
W1316OUT	Money more Borewell Final Water Outlet	4982010	25/09/2024 08:25	Arsenic	ug/l As	1.1	10
W1316OUT	Money more Borewell Final Water Outlet	4982010	25/09/2024 08:25	Boron	mg/l B	<0.0586	1000
W1316OUT	Money more Borewell Final Water Outlet	4982010	25/09/2024 08:25	Bromodichloromethane	ug/l	9.9	
W1316OUT	Money more Borewell Final Water Outlet	4982010	25/09/2024 08:25	Bromoform	ug/l	<3.5	
W1316OUT	Money more Borewell Final Water Outlet	4982010	25/09/2024 08:25	Cadmium	ug/l Cd	<0.042	5
W1316OUT	Money more Borewell Final Water Outlet	4982010	25/09/2024 08:25	Chloroform	ug/l	20	
W1316OUT	Money more Borewell Final Water Outlet	4982010	25/09/2024 08:25	Chromium	ug/l Cr	1.9	50
W1316OUT	Money more Borewell Final Water Outlet	4982010	25/09/2024 08:25	Dibromochloromethane	ug/l	5.9	
W1316OUT	Money more Borewell Final Water Outlet	4982010	25/09/2024 08:25	Iron	ug/l Fe	25	200
W1316OUT	Money more Borewell Final Water Outlet	4982010	25/09/2024 08:25	Manganese	ug Mn/l	0.86	50
W1316OUT	Money more Borewell Final Water Outlet	4982010	25/09/2024 08:25	Selenium	ug/l Se	0.19	10
W1316OUT	Money more Borewell Final Water Outlet	4982010	25/09/2024 08:25	Total Trihalomethanes	ug/l	37	100
W1316OUT	Money more Borewell Final Water Outlet	4982010	25/09/2024 08:25	WHO Index		0.3	1
W2308POUT	Castor Bay PPP Final Water Outlet	4973874	25/09/2024 08:40	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4973874	25/09/2024 08:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4973874	25/09/2024 08:40	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4973874	25/09/2024 08:40	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4973874	25/09/2024 08:40	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4973874	25/09/2024 08:40	Free - Residual disinfectant	mg Cl/l	2	
W2308POUT	Castor Bay PPP Final Water Outlet	4973874	25/09/2024 08:40	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4973874	25/09/2024 08:40	Total - Residual disinfectant	mg Cl/l	2.06	
W2308POUT	Castor Bay PPP Final Water Outlet	4973874	25/09/2024 08:40	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4973874	25/09/2024 08:40	Turbidity	NTU	0.11	1
W2308POUT	Castor Bay PPP Final Water Outlet	4973874	25/09/2024 08:40	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4973874	25/09/2024 08:40	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4973874	25/09/2024 08:40	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4973874	25/09/2024 08:40	Taste - Nature		No taste	
W1302OUT	Lough Fea Final Water Outlet	4973859	25/09/2024 08:43	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4973859	25/09/2024 08:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4973859	25/09/2024 08:43	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4973859	25/09/2024 08:43	Conductivity	uS/cm 20 C	140	2500
W1302OUT	Lough Fea Final Water Outlet	4973859	25/09/2024 08:43	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4973859	25/09/2024 08:43	Free - Residual disinfectant	mg Cl/l	0.94	
W1302OUT	Lough Fea Final Water Outlet	4973859	25/09/2024 08:43	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4973859	25/09/2024 08:43	Total - Residual disinfectant	mg Cl/l	1.05	
W1302OUT	Lough Fea Final Water Outlet	4973859	25/09/2024 08:43	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4973859	25/09/2024 08:43	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4973860	25/09/2024 10:07	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4973860	25/09/2024 10:07	Colony Counts 22	CFU/1 ml	0	

W4523OUT	Lough Macrory Final Water Outlet	4973860	25/09/2024 10:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4973860	25/09/2024 10:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4973860	25/09/2024 10:07	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4973860	25/09/2024 10:07	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4973860	25/09/2024 10:07	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4973860	25/09/2024 10:07	Conductivity	uS/cm 20 C	130	2500
W4523OUT	Lough Macrory Final Water Outlet	4973860	25/09/2024 10:07	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4973860	25/09/2024 10:07	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4973860	25/09/2024 10:07	Free - Residual disinfectant	mg Cl/l	0.83	
W4523OUT	Lough Macrory Final Water Outlet	4973860	25/09/2024 10:07	Free - Residual disinfectant	mg Cl/l	0.83	
W4523OUT	Lough Macrory Final Water Outlet	4973860	25/09/2024 10:07	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4973860	25/09/2024 10:07	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4973860	25/09/2024 10:07	Total - Residual disinfectant	mg Cl/l	0.89	
W4523OUT	Lough Macrory Final Water Outlet	4973860	25/09/2024 10:07	Total - Residual disinfectant	mg Cl/l	0.89	
W4523OUT	Lough Macrory Final Water Outlet	4973860	25/09/2024 10:07	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4973860	25/09/2024 10:07	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4973860	25/09/2024 10:07	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4973860	25/09/2024 10:07	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Conductivity	uS/cm 20 C	420	2500
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Free - Residual disinfectant	mg Cl/l	0.83	
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Total - Residual disinfectant	mg Cl/l	1.1	
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	2,4-D	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	2,4-DB	ug/l	<0.016	0.1
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Algae Blue Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Algae Diatom Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Algae Flagellate Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Algae Green Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Algae Total	per ml	0	
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Aluminium	ug Al/l	3.8	200
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Asulam	ug/l	<0.015	0.1
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Bentazone	ug/l	<0.0044	0.1
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Bromodichloromethane	ug/l	14	
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Bromoform	ug/l	<3.5	
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Bromoxynil	ug/l	<0.0079	0.1
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Chloroform	ug/l	38	

W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Clopyralid	ug/l	<0.0097	0.1
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Dibromochloromethane	ug/l	4	
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Dichlorprop	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Geosmin	ng/l	<1.1	
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Iron	ug/l Fe	<1.538	200
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Manganese	ug Mn/l	0.88	50
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	MCPA	ug/l	0.027	0.1
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	MCPB	ug/l	<0.015	0.1
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Mecoprop	ug/l	<0.011	0.1
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	MIB	ng/l	2.1	
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Propyzamide	ug/l	<0.012	0.1
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Second most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Third most numerous Algae		-	
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Total Trihalomethanes	ug/l	57	100
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	Triclopyr	ug/l	0.014	0.1
W2514OUT	Seagahan Final Water Outlet	4973855	25/09/2024 10:58	WHO Index		0.41	1
W4701OUT	Killyhevlin Final Water Outlet	4973868	25/09/2024 11:14	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4973868	25/09/2024 11:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4973868	25/09/2024 11:14	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4973868	25/09/2024 11:14	Conductivity	uS/cm 20 C	440	2500
W4701OUT	Killyhevlin Final Water Outlet	4973868	25/09/2024 11:14	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4973868	25/09/2024 11:14	Free - Residual disinfectant	mg Cl/l	1.42	
W4701OUT	Killyhevlin Final Water Outlet	4973868	25/09/2024 11:14	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4973868	25/09/2024 11:14	Total - Residual disinfectant	mg Cl/l	1.53	
W4701OUT	Killyhevlin Final Water Outlet	4973868	25/09/2024 11:14	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4973868	25/09/2024 11:14	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4974040	26/09/2024 08:38	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4974040	26/09/2024 08:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4974040	26/09/2024 08:38	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4974040	26/09/2024 08:38	Conductivity	uS/cm 20 C	380	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4974040	26/09/2024 08:38	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4974040	26/09/2024 08:38	Free - Residual disinfectant	mg Cl/l	1.4	
W2308POUT	Castor Bay PPP Final Water Outlet	4974040	26/09/2024 08:38	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4974040	26/09/2024 08:38	Total - Residual disinfectant	mg Cl/l	1.53	
W2308POUT	Castor Bay PPP Final Water Outlet	4974040	26/09/2024 08:38	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4974040	26/09/2024 08:38	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4974040	26/09/2024 08:38	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4974040	26/09/2024 08:38	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4974040	26/09/2024 08:38	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4974040	26/09/2024 08:38	Taste - Nature		No taste	
W2514OUT	Seagahan Final Water Outlet	4974016	26/09/2024 10:02	Colony Counts 22	CFU/1 ml	0	

W2514OUT	Seagahan Final Water Outlet	4974016	26/09/2024 10:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4974016	26/09/2024 10:02	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4974016	26/09/2024 10:02	Conductivity	uS/cm 20 C	420	2500
W2514OUT	Seagahan Final Water Outlet	4974016	26/09/2024 10:02	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4974016	26/09/2024 10:02	Free - Residual disinfectant	mg Cl/l	0.85	
W2514OUT	Seagahan Final Water Outlet	4974016	26/09/2024 10:02	Hydrogen Ion	pH value	7.5	9.5
W2514OUT	Seagahan Final Water Outlet	4974016	26/09/2024 10:02	Total - Residual disinfectant	mg Cl/l	1.05	
W2514OUT	Seagahan Final Water Outlet	4974016	26/09/2024 10:02	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4974016	26/09/2024 10:02	Turbidity	NTU	<0.09	1
W1302OUT	Lough Fea Final Water Outlet	4974024	26/09/2024 10:31	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4974024	26/09/2024 10:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4974024	26/09/2024 10:31	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4974024	26/09/2024 10:31	Conductivity	uS/cm 20 C	140	2500
W1302OUT	Lough Fea Final Water Outlet	4974024	26/09/2024 10:31	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4974024	26/09/2024 10:31	Free - Residual disinfectant	mg Cl/l	1.05	
W1302OUT	Lough Fea Final Water Outlet	4974024	26/09/2024 10:31	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4974024	26/09/2024 10:31	Total - Residual disinfectant	mg Cl/l	1.1	
W1302OUT	Lough Fea Final Water Outlet	4974024	26/09/2024 10:31	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4974024	26/09/2024 10:31	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4974034	26/09/2024 10:47	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4974034	26/09/2024 10:47	Colony Counts 37 (48hrs)	CFU/1 ml	1	
W4701OUT	Killyhevlin Final Water Outlet	4974034	26/09/2024 10:47	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4974034	26/09/2024 10:47	Conductivity	uS/cm 20 C	440	2500
W4701OUT	Killyhevlin Final Water Outlet	4974034	26/09/2024 10:47	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4974034	26/09/2024 10:47	Free - Residual disinfectant	mg Cl/l	1.39	
W4701OUT	Killyhevlin Final Water Outlet	4974034	26/09/2024 10:47	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4974034	26/09/2024 10:47	Total - Residual disinfectant	mg Cl/l	1.52	
W4701OUT	Killyhevlin Final Water Outlet	4974034	26/09/2024 10:47	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4974034	26/09/2024 10:47	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Conductivity	uS/cm 20 C	140	2500
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Conductivity	uS/cm 20 C	140	2500
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Free - Residual disinfectant	mg Cl/l	0.85	
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Free - Residual disinfectant	mg Cl/l	0.85	
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Hydrogen Ion	pH value	7.6	9.5

W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Total - Residual disinfectant	mg Cl/l	0.92	
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Total - Residual disinfectant	mg Cl/l	0.92	
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Turbidity	NTU	0.1	1
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Turbidity	NTU	0.1	1
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Aluminium	ug Al/l	5.8	200
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Aluminium	ug Al/l	5.8	200
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Iron	ug/l Fe	3.5	200
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Iron	ug/l Fe	3.5	200
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Manganese	ug Mn/l	0.97	50
W4523OUT	Lough Macrory Final Water Outlet	4974025	26/09/2024 11:06	Manganese	ug Mn/l	0.97	50
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Free - Residual disinfectant	mg Cl/l	1.45	
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Total - Residual disinfectant	mg Cl/l	1.47	
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4974041	26/09/2024 12:28	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4974197	27/09/2024 08:02	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4974197	27/09/2024 08:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4974197	27/09/2024 08:02	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4974197	27/09/2024 08:02	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4974197	27/09/2024 08:02	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4974197	27/09/2024 08:02	Free - Residual disinfectant	mg Cl/l	1.59	
W2308POUT	Castor Bay PPP Final Water Outlet	4974197	27/09/2024 08:02	Hydrogen Ion	pH value	7.6	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4974197	27/09/2024 08:02	Total - Residual disinfectant	mg Cl/l	1.66	
W2308POUT	Castor Bay PPP Final Water Outlet	4974197	27/09/2024 08:02	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4974197	27/09/2024 08:02	Turbidity	NTU	0.15	1
W2308POUT	Castor Bay PPP Final Water Outlet	4974197	27/09/2024 08:02	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4974197	27/09/2024 08:02	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4974197	27/09/2024 08:02	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4974197	27/09/2024 08:02	Taste - Nature		No taste	
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Colony Counts 22	CFU/1 ml	0	

W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Free - Residual disinfectant	mg Cl/l	1.35	
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Total - Residual disinfectant	mg Cl/l	1.5	
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4974198	27/09/2024 08:09	Taste - Nature		No taste	
W1302OUT	Lough Fea Final Water Outlet	4974190	27/09/2024 09:24	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4974190	27/09/2024 09:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4974190	27/09/2024 09:24	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4974190	27/09/2024 09:24	Conductivity	uS/cm 20 C	140	2500
W1302OUT	Lough Fea Final Water Outlet	4974190	27/09/2024 09:24	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4974190	27/09/2024 09:24	Free - Residual disinfectant	mg Cl/l	1.03	
W1302OUT	Lough Fea Final Water Outlet	4974190	27/09/2024 09:24	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4974190	27/09/2024 09:24	Total - Residual disinfectant	mg Cl/l	1.06	
W1302OUT	Lough Fea Final Water Outlet	4974190	27/09/2024 09:24	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4974190	27/09/2024 09:24	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4974192	27/09/2024 10:29	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4974192	27/09/2024 10:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4974192	27/09/2024 10:29	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4974192	27/09/2024 10:29	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4974192	27/09/2024 10:29	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4974192	27/09/2024 10:29	Free - Residual disinfectant	mg Cl/l	1.26	
W4701OUT	Killyhevlin Final Water Outlet	4974192	27/09/2024 10:29	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4974192	27/09/2024 10:29	Total - Residual disinfectant	mg Cl/l	1.39	
W4701OUT	Killyhevlin Final Water Outlet	4974192	27/09/2024 10:29	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4974192	27/09/2024 10:29	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Conductivity	uS/cm 20 C	350	2500
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Free - Residual disinfectant	mg Cl/l	1.55	
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Total - Residual disinfectant	mg Cl/l	1.6	
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Total Coliforms	CFU/100 ml	0	0

W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Odour	Diln No	2	0
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Odour - Nature		Earthy/Musty	
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Taste	Diln No	2	0
W1301POUT	Moyola PPP Final Water Outlet	4974247	28/09/2024 06:49	Taste - Nature		Earthy/Musty	
W2308POUT	Castor Bay PPP Final Water Outlet	4974246	28/09/2024 07:19	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4974246	28/09/2024 07:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4974246	28/09/2024 07:19	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4974246	28/09/2024 07:19	Conductivity	uS/cm 20 C	360	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4974246	28/09/2024 07:19	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4974246	28/09/2024 07:19	Free - Residual disinfectant	mg Cl/l	1.71	
W2308POUT	Castor Bay PPP Final Water Outlet	4974246	28/09/2024 07:19	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4974246	28/09/2024 07:19	Total - Residual disinfectant	mg Cl/l	1.94	
W2308POUT	Castor Bay PPP Final Water Outlet	4974246	28/09/2024 07:19	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4974246	28/09/2024 07:19	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4974246	28/09/2024 07:19	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4974246	28/09/2024 07:19	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4974246	28/09/2024 07:19	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4974246	28/09/2024 07:19	Taste - Nature		No taste	
W1302OUT	Lough Fea Final Water Outlet	4974241	28/09/2024 07:48	Colony Counts 22	CFU/1 ml	4	
W1302OUT	Lough Fea Final Water Outlet	4974241	28/09/2024 07:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4974241	28/09/2024 07:48	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4974241	28/09/2024 07:48	Conductivity	uS/cm 20 C	140	2500
W1302OUT	Lough Fea Final Water Outlet	4974241	28/09/2024 07:48	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4974241	28/09/2024 07:48	Free - Residual disinfectant	mg Cl/l	0.91	
W1302OUT	Lough Fea Final Water Outlet	4974241	28/09/2024 07:48	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4974241	28/09/2024 07:48	Total - Residual disinfectant	mg Cl/l	0.99	
W1302OUT	Lough Fea Final Water Outlet	4974241	28/09/2024 07:48	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4974241	28/09/2024 07:48	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4974242	28/09/2024 08:54	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4974242	28/09/2024 08:54	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4974242	28/09/2024 08:54	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4974242	28/09/2024 08:54	Conductivity	uS/cm 20 C	430	2500
W4701OUT	Killyhevlin Final Water Outlet	4974242	28/09/2024 08:54	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4974242	28/09/2024 08:54	Free - Residual disinfectant	mg Cl/l	1.25	
W4701OUT	Killyhevlin Final Water Outlet	4974242	28/09/2024 08:54	Hydrogen Ion	pH value	7.9	9.5
W4701OUT	Killyhevlin Final Water Outlet	4974242	28/09/2024 08:54	Total - Residual disinfectant	mg Cl/l	1.45	
W4701OUT	Killyhevlin Final Water Outlet	4974242	28/09/2024 08:54	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4974242	28/09/2024 08:54	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4974264	29/09/2024 07:18	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4974264	29/09/2024 07:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4974264	29/09/2024 07:18	Colour	mg/l Pt/Co	<4.56	20

W2308POUT	Castor Bay PPP Final Water Outlet	4974264	29/09/2024 07:18	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4974264	29/09/2024 07:18	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4974264	29/09/2024 07:18	Free - Residual disinfectant	mg Cl/l	1.4	
W2308POUT	Castor Bay PPP Final Water Outlet	4974264	29/09/2024 07:18	Hydrogen Ion	pH value	7.5	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4974264	29/09/2024 07:18	Total - Residual disinfectant	mg Cl/l	1.58	
W2308POUT	Castor Bay PPP Final Water Outlet	4974264	29/09/2024 07:18	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4974264	29/09/2024 07:18	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4974264	29/09/2024 07:18	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4974264	29/09/2024 07:18	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4974264	29/09/2024 07:18	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4974264	29/09/2024 07:18	Taste - Nature		No taste	
W4701OUT	Killyhevlin Final Water Outlet	4986912	29/09/2024 09:00	Free - Residual disinfectant	mg Cl/l	1.3	
W4701OUT	Killyhevlin Final Water Outlet	4986912	29/09/2024 09:00	Odour	Diln No	0	0
W4701OUT	Killyhevlin Final Water Outlet	4986912	29/09/2024 09:00	Odour - Nature		No odour	
W4701OUT	Killyhevlin Final Water Outlet	4986912	29/09/2024 09:00	Taste	Diln No	0	0
W4701OUT	Killyhevlin Final Water Outlet	4986912	29/09/2024 09:00	Taste - Nature		No taste	
W4701OUT	Killyhevlin Final Water Outlet	4986912	29/09/2024 09:00	Total - Residual disinfectant	mg Cl/l	1.53	
W4701OUT	Killyhevlin Final Water Outlet	4974260	29/09/2024 09:01	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4974260	29/09/2024 09:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4974260	29/09/2024 09:01	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4974260	29/09/2024 09:01	Conductivity	uS/cm 20 C	420	2500
W4701OUT	Killyhevlin Final Water Outlet	4974260	29/09/2024 09:01	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4974260	29/09/2024 09:01	Free - Residual disinfectant	mg Cl/l	1.3	
W4701OUT	Killyhevlin Final Water Outlet	4974260	29/09/2024 09:01	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4974260	29/09/2024 09:01	Total - Residual disinfectant	mg Cl/l	1.53	
W4701OUT	Killyhevlin Final Water Outlet	4974260	29/09/2024 09:01	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4974260	29/09/2024 09:01	Turbidity	NTU	0.09	1
W1302OUT	Lough Fea Final Water Outlet	4974259	29/09/2024 09:19	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4974259	29/09/2024 09:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4974259	29/09/2024 09:19	Colour	mg/l Pt/Co	<4.56	20
W1302OUT	Lough Fea Final Water Outlet	4974259	29/09/2024 09:19	Conductivity	uS/cm 20 C	140	2500
W1302OUT	Lough Fea Final Water Outlet	4974259	29/09/2024 09:19	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4974259	29/09/2024 09:19	Free - Residual disinfectant	mg Cl/l	0.91	
W1302OUT	Lough Fea Final Water Outlet	4974259	29/09/2024 09:19	Hydrogen Ion	pH value	7.3	9.5
W1302OUT	Lough Fea Final Water Outlet	4974259	29/09/2024 09:19	Total - Residual disinfectant	mg Cl/l	0.95	
W1302OUT	Lough Fea Final Water Outlet	4974259	29/09/2024 09:19	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4974259	29/09/2024 09:19	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Colony Counts 22	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Conductivity	uS/cm 20 C	350	2500
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	E. coli	CFU/100 ml	0	0

W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Free - Residual disinfectant	mg Cl/l	1.44	
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Hydrogen Ion	pH value	7.6	9.5
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Total - Residual disinfectant	mg Cl/l	1.61	
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4974265	29/09/2024 10:57	Taste - Nature		No taste	
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Colony Counts 22	CFU/1 ml	1	
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Colour	mg/l Pt/Co	<4.56	20
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Conductivity	uS/cm 20 C	360	2500
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	E. coli	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Free - Residual disinfectant	mg Cl/l	1.44	
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Hydrogen Ion	pH value	7.7	9.5
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Nitrite	mg/l	<0.03	0.1
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Total - Residual disinfectant	mg Cl/l	1.55	
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Total Coliforms	CFU/100 ml	0	0
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Turbidity	NTU	<0.09	1
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Odour	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Odour - Nature		No odour	
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Taste	Diln No	0	0
W1301POUT	Moyola PPP Final Water Outlet	4976472	30/09/2024 07:00	Taste - Nature		No taste	
W2308POUT	Castor Bay PPP Final Water Outlet	4976470	30/09/2024 08:17	Colony Counts 22	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4976470	30/09/2024 08:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2308POUT	Castor Bay PPP Final Water Outlet	4976470	30/09/2024 08:17	Colour	mg/l Pt/Co	<4.56	20
W2308POUT	Castor Bay PPP Final Water Outlet	4976470	30/09/2024 08:17	Conductivity	uS/cm 20 C	370	2500
W2308POUT	Castor Bay PPP Final Water Outlet	4976470	30/09/2024 08:17	E. coli	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4976470	30/09/2024 08:17	Free - Residual disinfectant	mg Cl/l	1.52	
W2308POUT	Castor Bay PPP Final Water Outlet	4976470	30/09/2024 08:17	Hydrogen Ion	pH value	7.3	9.5
W2308POUT	Castor Bay PPP Final Water Outlet	4976470	30/09/2024 08:17	Nitrite	mg/l	<0.03	0.1
W2308POUT	Castor Bay PPP Final Water Outlet	4976470	30/09/2024 08:17	Total - Residual disinfectant	mg Cl/l	1.58	
W2308POUT	Castor Bay PPP Final Water Outlet	4976470	30/09/2024 08:17	Total Coliforms	CFU/100 ml	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4976470	30/09/2024 08:17	Turbidity	NTU	<0.09	1
W2308POUT	Castor Bay PPP Final Water Outlet	4976470	30/09/2024 08:17	Odour	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4976470	30/09/2024 08:17	Odour - Nature		No odour	
W2308POUT	Castor Bay PPP Final Water Outlet	4976470	30/09/2024 08:17	Taste	Diln No	0	0
W2308POUT	Castor Bay PPP Final Water Outlet	4976470	30/09/2024 08:17	Taste - Nature		No taste	
W1302OUT	Lough Fea Final Water Outlet	4976443	30/09/2024 08:18	Colony Counts 22	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4976443	30/09/2024 08:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W1302OUT	Lough Fea Final Water Outlet	4976443	30/09/2024 08:18	Colour	mg/l Pt/Co	<4.56	20

W1302OUT	Lough Fea Final Water Outlet	4976443	30/09/2024 08:18	Conductivity	uS/cm 20 C	140	2500
W1302OUT	Lough Fea Final Water Outlet	4976443	30/09/2024 08:18	E. coli	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4976443	30/09/2024 08:18	Free - Residual disinfectant	mg Cl/l	0.83	
W1302OUT	Lough Fea Final Water Outlet	4976443	30/09/2024 08:18	Hydrogen Ion	pH value	7.2	9.5
W1302OUT	Lough Fea Final Water Outlet	4976443	30/09/2024 08:18	Nitrite	mg/l	<0.03	0.1
W1302OUT	Lough Fea Final Water Outlet	4976443	30/09/2024 08:18	Total - Residual disinfectant	mg Cl/l	0.9	
W1302OUT	Lough Fea Final Water Outlet	4976443	30/09/2024 08:18	Total Coliforms	CFU/100 ml	0	0
W1302OUT	Lough Fea Final Water Outlet	4976443	30/09/2024 08:18	Turbidity	NTU	<0.09	1
W4701OUT	Killyhevlin Final Water Outlet	4976461	30/09/2024 09:13	Colony Counts 22	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4976461	30/09/2024 09:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4701OUT	Killyhevlin Final Water Outlet	4976461	30/09/2024 09:13	Colour	mg/l Pt/Co	<4.56	20
W4701OUT	Killyhevlin Final Water Outlet	4976461	30/09/2024 09:13	Conductivity	uS/cm 20 C	460	2500
W4701OUT	Killyhevlin Final Water Outlet	4976461	30/09/2024 09:13	E. coli	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4976461	30/09/2024 09:13	Free - Residual disinfectant	mg Cl/l	1.71	
W4701OUT	Killyhevlin Final Water Outlet	4976461	30/09/2024 09:13	Hydrogen Ion	pH value	8	9.5
W4701OUT	Killyhevlin Final Water Outlet	4976461	30/09/2024 09:13	Nitrite	mg/l	<0.03	0.1
W4701OUT	Killyhevlin Final Water Outlet	4976461	30/09/2024 09:13	Total - Residual disinfectant	mg Cl/l	1.8	
W4701OUT	Killyhevlin Final Water Outlet	4976461	30/09/2024 09:13	Total Coliforms	CFU/100 ml	0	0
W4701OUT	Killyhevlin Final Water Outlet	4976461	30/09/2024 09:13	Turbidity	NTU	<0.09	1
W2514OUT	Seagahan Final Water Outlet	4976435	30/09/2024 10:39	Colony Counts 22	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4976435	30/09/2024 10:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W2514OUT	Seagahan Final Water Outlet	4976435	30/09/2024 10:39	Colour	mg/l Pt/Co	<4.56	20
W2514OUT	Seagahan Final Water Outlet	4976435	30/09/2024 10:39	Conductivity	uS/cm 20 C	400	2500
W2514OUT	Seagahan Final Water Outlet	4976435	30/09/2024 10:39	E. coli	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4976435	30/09/2024 10:39	Free - Residual disinfectant	mg Cl/l	1.05	
W2514OUT	Seagahan Final Water Outlet	4976435	30/09/2024 10:39	Hydrogen Ion	pH value	7.3	9.5
W2514OUT	Seagahan Final Water Outlet	4976435	30/09/2024 10:39	Nitrite	mg/l	<0.03	0.1
W2514OUT	Seagahan Final Water Outlet	4976435	30/09/2024 10:39	Total - Residual disinfectant	mg Cl/l	1.3	
W2514OUT	Seagahan Final Water Outlet	4976435	30/09/2024 10:39	Total Coliforms	CFU/100 ml	0	0
W2514OUT	Seagahan Final Water Outlet	4976435	30/09/2024 10:39	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Colony Counts 22	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Colour	mg/l Pt/Co	<4.56	20
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Conductivity	uS/cm 20 C	140	2500
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Conductivity	uS/cm 20 C	140	2500
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	E. coli	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Free - Residual disinfectant	mg Cl/l	1.04	
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Free - Residual disinfectant	mg Cl/l	1.04	

W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Hydrogen Ion	pH value	7.6	9.5
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Total - Residual disinfectant	mg Cl/l	1.1	
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Total - Residual disinfectant	mg Cl/l	1.1	
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Total Coliforms	CFU/100 ml	0	0
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Turbidity	NTU	<0.09	1
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Aluminium	ug Al/l	4.5	200
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Aluminium	ug Al/l	4.5	200
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Iron	ug/l Fe	<1.538	200
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Iron	ug/l Fe	<1.538	200
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Manganese	ug Mn/l	<0.80	50
W4523OUT	Lough Macrory Final Water Outlet	4976444	30/09/2024 10:42	Manganese	ug Mn/l	<0.80	50

SERVICE RESERVOIRS

Sample Point	Location	Sample Id	Sample Date	Parameter	Units	Auth Result	PCV Limit
V1365OUT	Lough Fea North (Blacks) SR Outlet	4923999	03/06/2024 08:54	Colony Counts 22	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4923999	03/06/2024 08:54	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4923999	03/06/2024 08:54	E. coli	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4923999	03/06/2024 08:54	Free - Residual disinfectant	mg Cl/l	0.87	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4923999	03/06/2024 08:54	Total - Residual disinfectant	mg Cl/l	0.94	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4923999	03/06/2024 08:54	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4924011	03/06/2024 10:00	Colony Counts 22	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4924011	03/06/2024 10:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4924011	03/06/2024 10:00	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4924011	03/06/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.27	
V1348OUT	Moydamlaght Draperstown SR Outlet	4924011	03/06/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.42	
V1348OUT	Moydamlaght Draperstown SR Outlet	4924011	03/06/2024 10:00	Total Coliforms	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4923990	03/06/2024 10:28	Colony Counts 22	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4923990	03/06/2024 10:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4923990	03/06/2024 10:28	E. coli	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4923990	03/06/2024 10:28	Free - Residual disinfectant	mg Cl/l	0.64	
V4540OUT	Radergan SR Outlet	4923990	03/06/2024 10:28	Total - Residual disinfectant	mg Cl/l	0.72	
V4540OUT	Radergan SR Outlet	4923990	03/06/2024 10:28	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4924016	03/06/2024 10:28	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4924016	03/06/2024 10:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4924016	03/06/2024 10:28	E. coli	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4924016	03/06/2024 10:28	Free - Residual disinfectant	mg Cl/l	0.53	
V1356OUT	Mormeal SR Outlet	4924016	03/06/2024 10:28	Total - Residual disinfectant	mg Cl/l	0.65	
V1356OUT	Mormeal SR Outlet	4924016	03/06/2024 10:28	Total Coliforms	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4924014	03/06/2024 10:42	Colony Counts 22	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4924014	03/06/2024 10:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4924014	03/06/2024 10:42	E. coli	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4924014	03/06/2024 10:42	Free - Residual disinfectant	mg Cl/l	0.69	
V4531OUT	Foremass SR Outlet	4924014	03/06/2024 10:42	Total - Residual disinfectant	mg Cl/l	0.75	
V4531OUT	Foremass SR Outlet	4924014	03/06/2024 10:42	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4923839	03/06/2024 10:46	Colony Counts 22	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4923839	03/06/2024 10:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4923839	03/06/2024 10:46	E. coli	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4923839	03/06/2024 10:46	Free - Residual disinfectant	mg Cl/l	0.96	
V2301OUT	Ballydougan Command SR Outlet	4923839	03/06/2024 10:46	Total - Residual disinfectant	mg Cl/l	1.04	
V2301OUT	Ballydougan Command SR Outlet	4923839	03/06/2024 10:46	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4923839	03/06/2024 10:46	Odour	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4923839	03/06/2024 10:46	Odour - Nature		No odour	
V2301OUT	Ballydougan Command SR Outlet	4923839	03/06/2024 10:46	Taste	Diln No	0	0

V2301OUT	Ballydougan Command SR Outlet	4923839	03/06/2024 10:46	Taste - Nature		No taste	
V4537OUT	Sixmilecross SR Outlet	4924017	03/06/2024 10:59	Colony Counts 22	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4924017	03/06/2024 10:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4924017	03/06/2024 10:59	E. coli	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4924017	03/06/2024 10:59	Free - Residual disinfectant	mg Cl/l	0.71	
V4537OUT	Sixmilecross SR Outlet	4924017	03/06/2024 10:59	Total - Residual disinfectant	mg Cl/l	0.8	
V4537OUT	Sixmilecross SR Outlet	4924017	03/06/2024 10:59	Total Coliforms	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4923841	03/06/2024 11:02	Colony Counts 22	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4923841	03/06/2024 11:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4923841	03/06/2024 11:02	E. coli	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4923841	03/06/2024 11:02	Free - Residual disinfectant	mg Cl/l	0.76	
V2302OUT	Ballyhannon SR Outlet	4923841	03/06/2024 11:02	Total - Residual disinfectant	mg Cl/l	0.85	
V2302OUT	Ballyhannon SR Outlet	4923841	03/06/2024 11:02	Total Coliforms	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4924022	03/06/2024 11:15	Colony Counts 22	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4924022	03/06/2024 11:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4924022	03/06/2024 11:15	E. coli	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4924022	03/06/2024 11:15	Free - Residual disinfectant	mg Cl/l	0.56	
V4528OUT	Crocknabohil SR Outlet	4924022	03/06/2024 11:15	Total - Residual disinfectant	mg Cl/l	0.67	
V4528OUT	Crocknabohil SR Outlet	4924022	03/06/2024 11:15	Total Coliforms	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4924340	04/06/2024 07:27	Colony Counts 22	CFU/1 ml	1	
V1702OUT	Cam SR Outlet	4924340	04/06/2024 07:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4924340	04/06/2024 07:27	E. coli	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4924340	04/06/2024 07:27	Free - Residual disinfectant	mg Cl/l	0.65	
V1702OUT	Cam SR Outlet	4924340	04/06/2024 07:27	Total - Residual disinfectant	mg Cl/l	0.76	
V1702OUT	Cam SR Outlet	4924340	04/06/2024 07:27	Total Coliforms	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4924339	04/06/2024 07:56	Colony Counts 22	CFU/1 ml	1	
V1706OUT	Killeague SR Outlet	4924339	04/06/2024 07:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4924339	04/06/2024 07:56	E. coli	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4924339	04/06/2024 07:56	Free - Residual disinfectant	mg Cl/l	0.6	
V1706OUT	Killeague SR Outlet	4924339	04/06/2024 07:56	Total - Residual disinfectant	mg Cl/l	0.71	
V1706OUT	Killeague SR Outlet	4924339	04/06/2024 07:56	Total Coliforms	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4924341	04/06/2024 08:22	Colony Counts 22	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4924341	04/06/2024 08:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4924341	04/06/2024 08:22	E. coli	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4924341	04/06/2024 08:22	Free - Residual disinfectant	mg Cl/l	0.35	
V1708OUT	North Garvagh SR Outlet	4924341	04/06/2024 08:22	Total - Residual disinfectant	mg Cl/l	0.49	
V1708OUT	North Garvagh SR Outlet	4924341	04/06/2024 08:22	Total Coliforms	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4924345	04/06/2024 08:56	Colony Counts 22	CFU/1 ml	1	
V1713OUT	Trienaltenagh SR Outlet	4924345	04/06/2024 08:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4924345	04/06/2024 08:56	E. coli	CFU/100 ml	0	0

V1713OUT	Trienaltenagh SR Outlet	4924345	04/06/2024 08:56	Free - Residual disinfectant	mg Cl/l	0.3	
V1713OUT	Trienaltenagh SR Outlet	4924345	04/06/2024 08:56	Total - Residual disinfectant	mg Cl/l	0.39	
V1713OUT	Trienaltenagh SR Outlet	4924345	04/06/2024 08:56	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4924231	04/06/2024 08:57	Colony Counts 22	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4924231	04/06/2024 08:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4924231	04/06/2024 08:57	E. coli	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4924231	04/06/2024 08:57	Free - Residual disinfectant	mg Cl/l	0.87	
V2508OUT	Carland SR Outlet	4924231	04/06/2024 08:57	Total - Residual disinfectant	mg Cl/l	0.98	
V2508OUT	Carland SR Outlet	4924231	04/06/2024 08:57	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4924231	04/06/2024 08:57	Odour	Diln No	0	0
V2508OUT	Carland SR Outlet	4924231	04/06/2024 08:57	Odour - Nature		No odour	
V2508OUT	Carland SR Outlet	4924231	04/06/2024 08:57	Taste	Diln No	0	0
V2508OUT	Carland SR Outlet	4924231	04/06/2024 08:57	Taste - Nature		No taste	
V1351OUT	Cranny Moneymore SR Outlet	4924346	04/06/2024 09:06	Colony Counts 22	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4924346	04/06/2024 09:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4924346	04/06/2024 09:06	E. coli	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4924346	04/06/2024 09:06	Free - Residual disinfectant	mg Cl/l	0.68	
V1351OUT	Cranny Moneymore SR Outlet	4924346	04/06/2024 09:06	Total - Residual disinfectant	mg Cl/l	0.71	
V1351OUT	Cranny Moneymore SR Outlet	4924346	04/06/2024 09:06	Total Coliforms	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4924232	04/06/2024 09:18	Colony Counts 22	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4924232	04/06/2024 09:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4924232	04/06/2024 09:18	E. coli	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4924232	04/06/2024 09:18	Free - Residual disinfectant	mg Cl/l	0.74	
V2509OUT	Castlehill Drumcoo SR Outlet	4924232	04/06/2024 09:18	Total - Residual disinfectant	mg Cl/l	0.83	
V2509OUT	Castlehill Drumcoo SR Outlet	4924232	04/06/2024 09:18	Total Coliforms	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4924347	04/06/2024 09:33	Colony Counts 22	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4924347	04/06/2024 09:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4924347	04/06/2024 09:33	E. coli	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4924347	04/06/2024 09:33	Free - Residual disinfectant	mg Cl/l	0.38	
V1352OUT	Cullion Desertmartin SR Outlet	4924347	04/06/2024 09:33	Total - Residual disinfectant	mg Cl/l	0.45	
V1352OUT	Cullion Desertmartin SR Outlet	4924347	04/06/2024 09:33	Total Coliforms	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4924320	04/06/2024 09:35	Colony Counts 22	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4924320	04/06/2024 09:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4924320	04/06/2024 09:35	E. coli	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4924320	04/06/2024 09:35	Free - Residual disinfectant	mg Cl/l	0.68	
V2521OUT	Mullaghanagh SR Outlet	4924320	04/06/2024 09:35	Total - Residual disinfectant	mg Cl/l	0.77	
V2521OUT	Mullaghanagh SR Outlet	4924320	04/06/2024 09:35	Total Coliforms	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4924356	04/06/2024 10:02	Colony Counts 22	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4924356	04/06/2024 10:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4924356	04/06/2024 10:02	E. coli	CFU/100 ml	0	0

V1343OUT	Ballybriest SR Outlet	4924356	04/06/2024 10:02	Free - Residual disinfectant	mg Cl/l	0.71	
V1343OUT	Ballybriest SR Outlet	4924356	04/06/2024 10:02	Total - Residual disinfectant	mg Cl/l	0.79	
V1343OUT	Ballybriest SR Outlet	4924356	04/06/2024 10:02	Total Coliforms	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4924344	04/06/2024 10:05	Colony Counts 22	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4924344	04/06/2024 10:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4924344	04/06/2024 10:05	E. coli	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4924344	04/06/2024 10:05	Free - Residual disinfectant	mg Cl/l	0.74	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4924344	04/06/2024 10:05	Total - Residual disinfectant	mg Cl/l	0.81	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4924344	04/06/2024 10:05	Total Coliforms	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4924334	04/06/2024 10:12	Colony Counts 22	CFU/1 ml	2	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4924334	04/06/2024 10:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4924334	04/06/2024 10:12	E. coli	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4924334	04/06/2024 10:12	Free - Residual disinfectant	mg Cl/l	0.64	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4924334	04/06/2024 10:12	Total - Residual disinfectant	mg Cl/l	0.75	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4924334	04/06/2024 10:12	Total Coliforms	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4924342	04/06/2024 10:24	Colony Counts 22	CFU/1 ml	1	
V4742OUT	Tattinbar SR Outlet	4924342	04/06/2024 10:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4924342	04/06/2024 10:24	E. coli	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4924342	04/06/2024 10:24	Free - Residual disinfectant	mg Cl/l	0.86	
V4742OUT	Tattinbar SR Outlet	4924342	04/06/2024 10:24	Total - Residual disinfectant	mg Cl/l	0.93	
V4742OUT	Tattinbar SR Outlet	4924342	04/06/2024 10:24	Total Coliforms	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4924359	04/06/2024 10:48	Colony Counts 22	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4924359	04/06/2024 10:48	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V4715OUT	Brookeborough High SR Outlet	4924359	04/06/2024 10:48	E. coli	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4924359	04/06/2024 10:48	Free - Residual disinfectant	mg Cl/l	0.77	
V4715OUT	Brookeborough High SR Outlet	4924359	04/06/2024 10:48	Total - Residual disinfectant	mg Cl/l	0.88	
V4715OUT	Brookeborough High SR Outlet	4924359	04/06/2024 10:48	Total Coliforms	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4924343	04/06/2024 11:17	Colony Counts 22	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4924343	04/06/2024 11:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4924343	04/06/2024 11:17	E. coli	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4924343	04/06/2024 11:17	Free - Residual disinfectant	mg Cl/l	0.62	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4924343	04/06/2024 11:17	Total - Residual disinfectant	mg Cl/l	0.74	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4924343	04/06/2024 11:17	Total Coliforms	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4924577	05/06/2024 07:44	Colony Counts 22	CFU/1 ml	2	
V1711OUT	Sconce Hill SR Outlet	4924577	05/06/2024 07:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1711OUT	Sconce Hill SR Outlet	4924577	05/06/2024 07:44	E. coli	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4924577	05/06/2024 07:44	Free - Residual disinfectant	mg Cl/l	0.51	
V1711OUT	Sconce Hill SR Outlet	4924577	05/06/2024 07:44	Total - Residual disinfectant	mg Cl/l	0.68	
V1711OUT	Sconce Hill SR Outlet	4924577	05/06/2024 07:44	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4924576	05/06/2024 08:05	Colony Counts 22	CFU/1 ml	0	

V1704OUT	Castlerock Downhill SR Outlet	4924576	05/06/2024 08:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4924576	05/06/2024 08:05	E. coli	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4924576	05/06/2024 08:05	Free - Residual disinfectant	mg Cl/l	0.38	
V1704OUT	Castlerock Downhill SR Outlet	4924576	05/06/2024 08:05	Total - Residual disinfectant	mg Cl/l	0.57	
V1704OUT	Castlerock Downhill SR Outlet	4924576	05/06/2024 08:05	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4924576	05/06/2024 08:05	Odour	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4924576	05/06/2024 08:05	Odour - Nature		No odour	
V1704OUT	Castlerock Downhill SR Outlet	4924576	05/06/2024 08:05	Taste	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4924576	05/06/2024 08:05	Taste - Nature		No taste	
V1338OUT	Coagh SR Outlet	4924585	05/06/2024 08:57	Colony Counts 22	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4924585	05/06/2024 08:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4924585	05/06/2024 08:57	E. coli	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4924585	05/06/2024 08:57	Free - Residual disinfectant	mg Cl/l	0.51	
V1338OUT	Coagh SR Outlet	4924585	05/06/2024 08:57	Total - Residual disinfectant	mg Cl/l	0.59	
V1338OUT	Coagh SR Outlet	4924585	05/06/2024 08:57	Total Coliforms	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4924592	05/06/2024 09:25	Colony Counts 22	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4924592	05/06/2024 09:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4924592	05/06/2024 09:25	E. coli	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4924592	05/06/2024 09:25	Free - Residual disinfectant	mg Cl/l	0.62	
V4713OUT	Knocknalosset SR Outlet	4924592	05/06/2024 09:25	Total - Residual disinfectant	mg Cl/l	0.73	
V4713OUT	Knocknalosset SR Outlet	4924592	05/06/2024 09:25	Total Coliforms	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4924588	05/06/2024 09:30	Colony Counts 22	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4924588	05/06/2024 09:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4924588	05/06/2024 09:30	E. coli	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4924588	05/06/2024 09:30	Free - Residual disinfectant	mg Cl/l	0.63	
V1342OUT	Dromore High SR Outlet	4924588	05/06/2024 09:30	Total - Residual disinfectant	mg Cl/l	0.73	
V1342OUT	Dromore High SR Outlet	4924588	05/06/2024 09:30	Total Coliforms	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4924486	05/06/2024 09:35	Colony Counts 22	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4924486	05/06/2024 09:35	Colony Counts 37 (48hrs)	CFU/1 ml	3	
V2511OUT	Corran Armagh SR Outlet	4924486	05/06/2024 09:35	E. coli	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4924486	05/06/2024 09:35	Free - Residual disinfectant	mg Cl/l	0.87	
V2511OUT	Corran Armagh SR Outlet	4924486	05/06/2024 09:35	Total - Residual disinfectant	mg Cl/l	0.95	
V2511OUT	Corran Armagh SR Outlet	4924486	05/06/2024 09:35	Total Coliforms	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4924589	05/06/2024 09:42	Colony Counts 22	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4924589	05/06/2024 09:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4924589	05/06/2024 09:42	E. coli	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4924589	05/06/2024 09:42	Free - Residual disinfectant	mg Cl/l	0.74	
V4712OUT	Corranny SR Outlet	4924589	05/06/2024 09:42	Total - Residual disinfectant	mg Cl/l	0.91	
V4712OUT	Corranny SR Outlet	4924589	05/06/2024 09:42	Total Coliforms	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4924584	05/06/2024 10:00	Colony Counts 22	CFU/1 ml	0	

V1335OUT	Brigh Quarry SR Outlet	4924584	05/06/2024 10:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4924584	05/06/2024 10:00	E. coli	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4924584	05/06/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.6	
V1335OUT	Brigh Quarry SR Outlet	4924584	05/06/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.71	
V1335OUT	Brigh Quarry SR Outlet	4924584	05/06/2024 10:00	Total Coliforms	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4924550	05/06/2024 10:15	Colony Counts 22	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4924550	05/06/2024 10:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4924550	05/06/2024 10:15	E. coli	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4924550	05/06/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.59	
V2518OUT	Lisnastrane SR Outlet	4924550	05/06/2024 10:15	Total - Residual disinfectant	mg Cl/l	0.68	
V2518OUT	Lisnastrane SR Outlet	4924550	05/06/2024 10:15	Total Coliforms	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4924485	05/06/2024 10:21	Colony Counts 22	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4924485	05/06/2024 10:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4924485	05/06/2024 10:21	E. coli	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4924485	05/06/2024 10:21	Free - Residual disinfectant	mg Cl/l	0.63	
V2510OUT	Calone SR Outlet	4924485	05/06/2024 10:21	Total - Residual disinfectant	mg Cl/l	0.75	
V2510OUT	Calone SR Outlet	4924485	05/06/2024 10:21	Total Coliforms	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4924548	05/06/2024 10:38	Colony Counts 22	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4924548	05/06/2024 10:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4924548	05/06/2024 10:38	E. coli	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4924548	05/06/2024 10:38	Free - Residual disinfectant	mg Cl/l	0.84	
V2514OUT	Edenaveys Command SR Outlet	4924548	05/06/2024 10:38	Total - Residual disinfectant	mg Cl/l	1.01	
V2514OUT	Edenaveys Command SR Outlet	4924548	05/06/2024 10:38	Total Coliforms	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4924581	05/06/2024 10:39	Colony Counts 22	CFU/1 ml	1	
V4533OUT	Inisclan SR Outlet	4924581	05/06/2024 10:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4924581	05/06/2024 10:39	E. coli	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4924581	05/06/2024 10:39	Free - Residual disinfectant	mg Cl/l	0.54	
V4533OUT	Inisclan SR Outlet	4924581	05/06/2024 10:39	Total - Residual disinfectant	mg Cl/l	0.7	
V4533OUT	Inisclan SR Outlet	4924581	05/06/2024 10:39	Total Coliforms	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4924482	05/06/2024 11:01	Colony Counts 22	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4924482	05/06/2024 11:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4924482	05/06/2024 11:01	E. coli	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4924482	05/06/2024 11:01	Free - Residual disinfectant	mg Cl/l	0.89	
V2523OUT	Rough Fort SR Outlet	4924482	05/06/2024 11:01	Total - Residual disinfectant	mg Cl/l	1.02	
V2523OUT	Rough Fort SR Outlet	4924482	05/06/2024 11:01	Total Coliforms	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4925222	06/06/2024 08:19	Colony Counts 22	CFU/1 ml	64	
V4527OUT	Carryglass SR Outlet	4925222	06/06/2024 08:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4925222	06/06/2024 08:19	E. coli	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4925222	06/06/2024 08:19	Free - Residual disinfectant	mg Cl/l	0.61	
V4527OUT	Carryglass SR Outlet	4925222	06/06/2024 08:19	Total - Residual disinfectant	mg Cl/l	0.66	

V4527OUT	Carryglass SR Outlet	4925222	06/06/2024 08:19	Total Coliforms	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4924774	06/06/2024 08:30	Colony Counts 22	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4924774	06/06/2024 08:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4924774	06/06/2024 08:30	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4924774	06/06/2024 08:30	Free - Residual disinfectant	mg Cl/l	0.51	
V1362OUT	Unagh SR Outlet	4924774	06/06/2024 08:30	Total - Residual disinfectant	mg Cl/l	0.62	
V1362OUT	Unagh SR Outlet	4924774	06/06/2024 08:30	Total Coliforms	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4924788	06/06/2024 09:00	Colony Counts 22	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4924788	06/06/2024 09:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4924788	06/06/2024 09:00	E. coli	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4924788	06/06/2024 09:00	Free - Residual disinfectant	mg Cl/l	0.57	
V1344OUT	Craigs Cookstown SR Outlet	4924788	06/06/2024 09:00	Total - Residual disinfectant	mg Cl/l	0.65	
V1344OUT	Craigs Cookstown SR Outlet	4924788	06/06/2024 09:00	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4924773	06/06/2024 09:07	Colony Counts 22	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4924773	06/06/2024 09:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4924773	06/06/2024 09:07	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4924773	06/06/2024 09:07	Free - Residual disinfectant	mg Cl/l	0.5	
V1360OUT	Windmill Hill SR Outlet	4924773	06/06/2024 09:07	Total - Residual disinfectant	mg Cl/l	0.64	
V1360OUT	Windmill Hill SR Outlet	4924773	06/06/2024 09:07	Total Coliforms	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4924785	06/06/2024 09:30	Colony Counts 22	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4924785	06/06/2024 09:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4924785	06/06/2024 09:30	E. coli	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4924785	06/06/2024 09:30	Free - Residual disinfectant	mg Cl/l	0.59	
V1339OUT	Corvanaghan High SR Outlet	4924785	06/06/2024 09:30	Total - Residual disinfectant	mg Cl/l	0.68	
V1339OUT	Corvanaghan High SR Outlet	4924785	06/06/2024 09:30	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4924784	06/06/2024 09:34	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4924784	06/06/2024 09:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4924784	06/06/2024 09:34	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4924784	06/06/2024 09:34	Free - Residual disinfectant	mg Cl/l	0.83	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4924784	06/06/2024 09:34	Total - Residual disinfectant	mg Cl/l	0.93	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4924784	06/06/2024 09:34	Total Coliforms	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4924789	06/06/2024 10:00	Colony Counts 22	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4924789	06/06/2024 10:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4924789	06/06/2024 10:00	E. coli	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4924789	06/06/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.48	
V1346OUT	Gortaclady Evishanoran SR Outlet	4924789	06/06/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.59	
V1346OUT	Gortaclady Evishanoran SR Outlet	4924789	06/06/2024 10:00	Total Coliforms	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4924754	06/06/2024 10:03	Colony Counts 22	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4924754	06/06/2024 10:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4924754	06/06/2024 10:03	E. coli	CFU/100 ml	0	0

V4539OUT	Erganagh SR Outlet	4924754	06/06/2024 10:03	Free - Residual disinfectant	mg Cl/l	0.28	
V4539OUT	Erganagh SR Outlet	4924754	06/06/2024 10:03	Total - Residual disinfectant	mg Cl/l	0.4	
V4539OUT	Erganagh SR Outlet	4924754	06/06/2024 10:03	Total Coliforms	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4924786	06/06/2024 10:20	Colony Counts 22	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4924786	06/06/2024 10:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4924786	06/06/2024 10:20	E. coli	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4924786	06/06/2024 10:20	Free - Residual disinfectant	mg Cl/l	0.46	
V1340OUT	Craigballyharkey SR Outlet	4924786	06/06/2024 10:20	Total - Residual disinfectant	mg Cl/l	0.55	
V1340OUT	Craigballyharkey SR Outlet	4924786	06/06/2024 10:20	Total Coliforms	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4924752	06/06/2024 10:37	Colony Counts 22	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4924752	06/06/2024 10:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4924752	06/06/2024 10:37	E. coli	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4924752	06/06/2024 10:37	Free - Residual disinfectant	mg Cl/l	0.64	
V4538OUT	Killyclogher SR Outlet	4924752	06/06/2024 10:37	Total - Residual disinfectant	mg Cl/l	0.8	
V4538OUT	Killyclogher SR Outlet	4924752	06/06/2024 10:37	Total Coliforms	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4924761	06/06/2024 11:31	Colony Counts 22	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4924761	06/06/2024 11:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4924761	06/06/2024 11:31	E. coli	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4924761	06/06/2024 11:31	Free - Residual disinfectant	mg Cl/l	0.89	
V4536OUT	Lough Macrory North SR Outlet	4924761	06/06/2024 11:31	Total - Residual disinfectant	mg Cl/l	0.96	
V4536OUT	Lough Macrory North SR Outlet	4924761	06/06/2024 11:31	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4924780	06/06/2024 11:34	Colony Counts 22	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4924780	06/06/2024 11:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4924780	06/06/2024 11:34	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4924780	06/06/2024 11:34	Free - Residual disinfectant	mg Cl/l	0.34	
V1350OUT	Carnaman SR Outlet	4924780	06/06/2024 11:34	Total - Residual disinfectant	mg Cl/l	0.53	
V1350OUT	Carnaman SR Outlet	4924780	06/06/2024 11:34	Total Coliforms	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4924751	06/06/2024 11:49	Colony Counts 22	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4924751	06/06/2024 11:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4924751	06/06/2024 11:49	E. coli	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4924751	06/06/2024 11:49	Free - Residual disinfectant	mg Cl/l	0.59	
V4526OUT	Black Lough Pomeroy SR Outlet	4924751	06/06/2024 11:49	Total - Residual disinfectant	mg Cl/l	0.69	
V4526OUT	Black Lough Pomeroy SR Outlet	4924751	06/06/2024 11:49	Total Coliforms	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4924956	07/06/2024 07:29	Colony Counts 22	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4924956	07/06/2024 07:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4924956	07/06/2024 07:29	E. coli	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4924956	07/06/2024 07:29	Free - Residual disinfectant	mg Cl/l	0.62	
V1715OUT	Ballystrone (Calvins) SR Outlet	4924956	07/06/2024 07:29	Total - Residual disinfectant	mg Cl/l	0.87	
V1715OUT	Ballystrone (Calvins) SR Outlet	4924956	07/06/2024 07:29	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4924873	07/06/2024 08:01	Colony Counts 22	CFU/1 ml	0	

V1725OUT	Glenlough SR Outlet	4924873	07/06/2024 08:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4924873	07/06/2024 08:01	E. coli	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4924873	07/06/2024 08:01	Free - Residual disinfectant	mg Cl/l	0.49	
V1725OUT	Glenlough SR Outlet	4924873	07/06/2024 08:01	Total - Residual disinfectant	mg Cl/l	0.56	
V1725OUT	Glenlough SR Outlet	4924873	07/06/2024 08:01	Total Coliforms	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4924930	07/06/2024 08:18	Colony Counts 22	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4924930	07/06/2024 08:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4924930	07/06/2024 08:18	E. coli	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4924930	07/06/2024 08:18	Free - Residual disinfectant	mg Cl/l	0.38	
V4527OUT	Carryglass SR Outlet	4924930	07/06/2024 08:18	Total - Residual disinfectant	mg Cl/l	0.44	
V4527OUT	Carryglass SR Outlet	4924930	07/06/2024 08:18	Total Coliforms	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4924924	07/06/2024 08:53	Colony Counts 22	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4924924	07/06/2024 08:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4924924	07/06/2024 08:53	E. coli	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4924924	07/06/2024 08:53	Free - Residual disinfectant	mg Cl/l	0.74	
V4707OUT	Sidaire SR Outlet	4924924	07/06/2024 08:53	Total - Residual disinfectant	mg Cl/l	0.86	
V4707OUT	Sidaire SR Outlet	4924924	07/06/2024 08:53	Total Coliforms	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4924963	07/06/2024 09:10	Colony Counts 22	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4924963	07/06/2024 09:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4924963	07/06/2024 09:10	E. coli	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4924963	07/06/2024 09:10	Free - Residual disinfectant	mg Cl/l	0.55	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4924963	07/06/2024 09:10	Total - Residual disinfectant	mg Cl/l	0.66	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4924963	07/06/2024 09:10	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4924954	07/06/2024 09:26	Colony Counts 22	CFU/1 ml	107	
V1349OUT	Ballyknock Magherafelt SR Outlet	4924954	07/06/2024 09:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4924954	07/06/2024 09:26	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4924954	07/06/2024 09:26	Free - Residual disinfectant	mg Cl/l	0.3	
V1349OUT	Ballyknock Magherafelt SR Outlet	4924954	07/06/2024 09:26	Total - Residual disinfectant	mg Cl/l	0.56	
V1349OUT	Ballyknock Magherafelt SR Outlet	4924954	07/06/2024 09:26	Total Coliforms	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4924935	07/06/2024 09:31	Colony Counts 22	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4924935	07/06/2024 09:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4924935	07/06/2024 09:31	E. coli	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4924935	07/06/2024 09:31	Free - Residual disinfectant	mg Cl/l	0.73	
V2501OUT	Altmore River SR Outlet	4924935	07/06/2024 09:31	Total - Residual disinfectant	mg Cl/l	0.86	
V2501OUT	Altmore River SR Outlet	4924935	07/06/2024 09:31	Total Coliforms	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4924864	07/06/2024 09:45	Colony Counts 22	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4924864	07/06/2024 09:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4924864	07/06/2024 09:45	E. coli	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4924864	07/06/2024 09:45	Free - Residual disinfectant	mg Cl/l	0.69	
V2507OUT	Cappagh SR Outlet	4924864	07/06/2024 09:45	Total - Residual disinfectant	mg Cl/l	0.81	

V2507OUT	Cappagh SR Outlet	4924864	07/06/2024 09:45	Total Coliforms	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4924961	07/06/2024 09:47	Colony Counts 22	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4924961	07/06/2024 09:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4924961	07/06/2024 09:47	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4924961	07/06/2024 09:47	Free - Residual disinfectant	mg Cl/l	0.57	
V1358OUT	Slaughtneil SR Outlet	4924961	07/06/2024 09:47	Total - Residual disinfectant	mg Cl/l	0.73	
V1358OUT	Slaughtneil SR Outlet	4924961	07/06/2024 09:47	Total Coliforms	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4924965	07/06/2024 09:49	Colony Counts 22	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4924965	07/06/2024 09:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4924965	07/06/2024 09:49	E. coli	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4924965	07/06/2024 09:49	Free - Residual disinfectant	mg Cl/l	1.16	
V4708OUT	Cavanacross Enniskillen SR Outlet	4924965	07/06/2024 09:49	Total - Residual disinfectant	mg Cl/l	1.29	
V4708OUT	Cavanacross Enniskillen SR Outlet	4924965	07/06/2024 09:49	Total Coliforms	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4924968	07/06/2024 09:50	Colony Counts 22	CFU/1 ml	1	
V4530OUT	Dungoran SR Outlet	4924968	07/06/2024 09:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4924968	07/06/2024 09:50	E. coli	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4924968	07/06/2024 09:50	Free - Residual disinfectant	mg Cl/l	0.36	
V4530OUT	Dungoran SR Outlet	4924968	07/06/2024 09:50	Total - Residual disinfectant	mg Cl/l	0.44	
V4530OUT	Dungoran SR Outlet	4924968	07/06/2024 09:50	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4924959	07/06/2024 10:08	Colony Counts 22	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4924959	07/06/2024 10:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4924959	07/06/2024 10:08	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4924959	07/06/2024 10:08	Free - Residual disinfectant	mg Cl/l	0.24	
V1354OUT	Knockoneill SR Outlet	4924959	07/06/2024 10:08	Total - Residual disinfectant	mg Cl/l	0.44	
V1354OUT	Knockoneill SR Outlet	4924959	07/06/2024 10:08	Total Coliforms	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4924863	07/06/2024 10:10	Colony Counts 22	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4924863	07/06/2024 10:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4924863	07/06/2024 10:10	E. coli	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4924863	07/06/2024 10:10	Free - Residual disinfectant	mg Cl/l	0.66	
V2505OUT	Cabragh Fasglashagh SR Outlet	4924863	07/06/2024 10:10	Total - Residual disinfectant	mg Cl/l	0.78	
V2505OUT	Cabragh Fasglashagh SR Outlet	4924863	07/06/2024 10:10	Total Coliforms	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4924960	07/06/2024 10:12	Colony Counts 22	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4924960	07/06/2024 10:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4924960	07/06/2024 10:12	E. coli	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4924960	07/06/2024 10:12	Free - Residual disinfectant	mg Cl/l	0.75	
V4535OUT	Lisnagardy SR Outlet	4924960	07/06/2024 10:12	Total - Residual disinfectant	mg Cl/l	0.86	
V4535OUT	Lisnagardy SR Outlet	4924960	07/06/2024 10:12	Total Coliforms	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4924958	07/06/2024 10:43	Colony Counts 22	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4924958	07/06/2024 10:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4924958	07/06/2024 10:43	E. coli	CFU/100 ml	0	0

V4719OUT	Glenchuil SR Outlet	4924958	07/06/2024 10:43	Free - Residual disinfectant	mg Cl/l	0.3	
V4719OUT	Glenchuil SR Outlet	4924958	07/06/2024 10:43	Total - Residual disinfectant	mg Cl/l	0.49	
V4719OUT	Glenchuil SR Outlet	4924958	07/06/2024 10:43	Total Coliforms	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4927165	10/06/2024 07:22	Colony Counts 22	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4927165	10/06/2024 07:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4927165	10/06/2024 07:22	E. coli	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4927165	10/06/2024 07:22	Free - Residual disinfectant	mg Cl/l	0.62	
V4527OUT	Carryglass SR Outlet	4927165	10/06/2024 07:22	Total - Residual disinfectant	mg Cl/l	0.68	
V4527OUT	Carryglass SR Outlet	4927165	10/06/2024 07:22	Total Coliforms	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4927192	10/06/2024 08:07	Colony Counts 22	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4927192	10/06/2024 08:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4927192	10/06/2024 08:07	E. coli	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4927192	10/06/2024 08:07	Free - Residual disinfectant	mg Cl/l	0.87	
V4535OUT	Lisnagardy SR Outlet	4927192	10/06/2024 08:07	Total - Residual disinfectant	mg Cl/l	1.01	
V4535OUT	Lisnagardy SR Outlet	4927192	10/06/2024 08:07	Total Coliforms	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4927200	10/06/2024 08:32	Colony Counts 22	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4927200	10/06/2024 08:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4927200	10/06/2024 08:32	E. coli	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4927200	10/06/2024 08:32	Free - Residual disinfectant	mg Cl/l	0.71	
V4530OUT	Dungoran SR Outlet	4927200	10/06/2024 08:32	Total - Residual disinfectant	mg Cl/l	0.8	
V4530OUT	Dungoran SR Outlet	4927200	10/06/2024 08:32	Total Coliforms	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4927195	10/06/2024 08:47	Colony Counts 22	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4927195	10/06/2024 08:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4927195	10/06/2024 08:47	E. coli	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4927195	10/06/2024 08:47	Free - Residual disinfectant	mg Cl/l	0.53	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4927195	10/06/2024 08:47	Total - Residual disinfectant	mg Cl/l	0.62	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4927195	10/06/2024 08:47	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4927186	10/06/2024 08:59	Colony Counts 22	CFU/1 ml	46	
V1349OUT	Ballyknock Magherafelt SR Outlet	4927186	10/06/2024 08:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4927186	10/06/2024 08:59	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4927186	10/06/2024 08:59	Free - Residual disinfectant	mg Cl/l	0.47	
V1349OUT	Ballyknock Magherafelt SR Outlet	4927186	10/06/2024 08:59	Total - Residual disinfectant	mg Cl/l	0.69	
V1349OUT	Ballyknock Magherafelt SR Outlet	4927186	10/06/2024 08:59	Total Coliforms	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4927167	10/06/2024 09:18	Colony Counts 22	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4927167	10/06/2024 09:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4927167	10/06/2024 09:18	E. coli	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4927167	10/06/2024 09:18	Free - Residual disinfectant	mg Cl/l	0.87	
V2501OUT	Altmore River SR Outlet	4927167	10/06/2024 09:18	Total - Residual disinfectant	mg Cl/l	0.97	
V2501OUT	Altmore River SR Outlet	4927167	10/06/2024 09:18	Total Coliforms	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4927193	10/06/2024 09:18	Colony Counts 22	CFU/1 ml	0	

V1358OUT	Slaughtneil SR Outlet	4927193	10/06/2024 09:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4927193	10/06/2024 09:18	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4927193	10/06/2024 09:18	Free - Residual disinfectant	mg Cl/l	0.56	
V1358OUT	Slaughtneil SR Outlet	4927193	10/06/2024 09:18	Total - Residual disinfectant	mg Cl/l	0.73	
V1358OUT	Slaughtneil SR Outlet	4927193	10/06/2024 09:18	Total Coliforms	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4927163	10/06/2024 09:36	Colony Counts 22	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4927163	10/06/2024 09:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4927163	10/06/2024 09:36	E. coli	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4927163	10/06/2024 09:36	Free - Residual disinfectant	mg Cl/l	0.78	
V4707OUT	Sidaire SR Outlet	4927163	10/06/2024 09:36	Total - Residual disinfectant	mg Cl/l	0.92	
V4707OUT	Sidaire SR Outlet	4927163	10/06/2024 09:36	Total Coliforms	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4927144	10/06/2024 09:37	Colony Counts 22	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4927144	10/06/2024 09:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4927144	10/06/2024 09:37	E. coli	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4927144	10/06/2024 09:37	Free - Residual disinfectant	mg Cl/l	0.76	
V2507OUT	Cappagh SR Outlet	4927144	10/06/2024 09:37	Total - Residual disinfectant	mg Cl/l	0.84	
V2507OUT	Cappagh SR Outlet	4927144	10/06/2024 09:37	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4927191	10/06/2024 09:42	Colony Counts 22	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4927191	10/06/2024 09:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4927191	10/06/2024 09:42	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4927191	10/06/2024 09:42	Free - Residual disinfectant	mg Cl/l	0.23	
V1354OUT	Knockoneill SR Outlet	4927191	10/06/2024 09:42	Total - Residual disinfectant	mg Cl/l	0.44	
V1354OUT	Knockoneill SR Outlet	4927191	10/06/2024 09:42	Total Coliforms	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4927197	10/06/2024 10:29	Colony Counts 22	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4927197	10/06/2024 10:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4927197	10/06/2024 10:29	E. coli	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4927197	10/06/2024 10:29	Free - Residual disinfectant	mg Cl/l	1.18	
V4708OUT	Cavanacross Enniskillen SR Outlet	4927197	10/06/2024 10:29	Total - Residual disinfectant	mg Cl/l	1.32	
V4708OUT	Cavanacross Enniskillen SR Outlet	4927197	10/06/2024 10:29	Total Coliforms	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4927143	10/06/2024 10:34	Colony Counts 22	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4927143	10/06/2024 10:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4927143	10/06/2024 10:34	E. coli	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4927143	10/06/2024 10:34	Free - Residual disinfectant	mg Cl/l	0.78	
V2505OUT	Cabragh Fasglashagh SR Outlet	4927143	10/06/2024 10:34	Total - Residual disinfectant	mg Cl/l	0.92	
V2505OUT	Cabragh Fasglashagh SR Outlet	4927143	10/06/2024 10:34	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4927154	10/06/2024 11:09	Colony Counts 22	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4927154	10/06/2024 11:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4927154	10/06/2024 11:09	E. coli	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4927154	10/06/2024 11:09	Free - Residual disinfectant	mg Cl/l	0.42	
V1725OUT	Glenlough SR Outlet	4927154	10/06/2024 11:09	Total - Residual disinfectant	mg Cl/l	0.55	

V1725OUT	Glenlough SR Outlet	4927154	10/06/2024 11:09	Total Coliforms	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4927188	10/06/2024 12:02	Colony Counts 22	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4927188	10/06/2024 12:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4927188	10/06/2024 12:02	E. coli	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4927188	10/06/2024 12:02	Free - Residual disinfectant	mg Cl/l	0.55	
V1715OUT	Ballystrone (Calvins) SR Outlet	4927188	10/06/2024 12:02	Total - Residual disinfectant	mg Cl/l	0.7	
V1715OUT	Ballystrone (Calvins) SR Outlet	4927188	10/06/2024 12:02	Total Coliforms	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4927542	11/06/2024 08:30	Colony Counts 22	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4927542	11/06/2024 08:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4927542	11/06/2024 08:30	E. coli	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4927542	11/06/2024 08:30	Free - Residual disinfectant	mg Cl/l	0.75	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4927542	11/06/2024 08:30	Total - Residual disinfectant	mg Cl/l	0.78	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4927542	11/06/2024 08:30	Total Coliforms	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4927190	11/06/2024 08:47	Colony Counts 22	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4927190	11/06/2024 08:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4927190	11/06/2024 08:47	E. coli	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4927190	11/06/2024 08:47	Free - Residual disinfectant	mg Cl/l	0.8	
V4719OUT	Glenchuil SR Outlet	4927190	11/06/2024 08:47	Total - Residual disinfectant	mg Cl/l	0.98	
V4719OUT	Glenchuil SR Outlet	4927190	11/06/2024 08:47	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4927554	11/06/2024 09:32	Colony Counts 22	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4927554	11/06/2024 09:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4927554	11/06/2024 09:32	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4927554	11/06/2024 09:32	Free - Residual disinfectant	mg Cl/l	0.19	
V1348OUT	Moydamlaght Draperstown SR Outlet	4927554	11/06/2024 09:32	Total - Residual disinfectant	mg Cl/l	0.36	
V1348OUT	Moydamlaght Draperstown SR Outlet	4927554	11/06/2024 09:32	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4927511	11/06/2024 10:10	Colony Counts 22	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4927511	11/06/2024 10:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4927511	11/06/2024 10:10	E. coli	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4927511	11/06/2024 10:10	Free - Residual disinfectant	mg Cl/l	0.84	
V2301OUT	Ballydougan Command SR Outlet	4927511	11/06/2024 10:10	Total - Residual disinfectant	mg Cl/l	0.92	
V2301OUT	Ballydougan Command SR Outlet	4927511	11/06/2024 10:10	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4927511	11/06/2024 10:10	Odour	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4927511	11/06/2024 10:10	Odour - Nature		No odour	
V2301OUT	Ballydougan Command SR Outlet	4927511	11/06/2024 10:10	Taste	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4927511	11/06/2024 10:10	Taste - Nature		No taste	
V4540OUT	Radergan SR Outlet	4927531	11/06/2024 10:17	Colony Counts 22	CFU/1 ml	2	
V4540OUT	Radergan SR Outlet	4927531	11/06/2024 10:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4927531	11/06/2024 10:17	E. coli	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4927531	11/06/2024 10:17	Free - Residual disinfectant	mg Cl/l	0.51	
V4540OUT	Radergan SR Outlet	4927531	11/06/2024 10:17	Total - Residual disinfectant	mg Cl/l	0.6	

V4540OUT	Radergan SR Outlet	4927531	11/06/2024 10:17	Total Coliforms	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4927513	11/06/2024 10:24	Colony Counts 22	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4927513	11/06/2024 10:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4927513	11/06/2024 10:24	E. coli	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4927513	11/06/2024 10:24	Free - Residual disinfectant	mg Cl/l	0.78	
V2302OUT	Ballyhannon SR Outlet	4927513	11/06/2024 10:24	Total - Residual disinfectant	mg Cl/l	0.84	
V2302OUT	Ballyhannon SR Outlet	4927513	11/06/2024 10:24	Total Coliforms	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4927557	11/06/2024 10:32	Colony Counts 22	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4927557	11/06/2024 10:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4927557	11/06/2024 10:32	E. coli	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4927557	11/06/2024 10:32	Free - Residual disinfectant	mg Cl/l	0.64	
V4531OUT	Foremass SR Outlet	4927557	11/06/2024 10:32	Total - Residual disinfectant	mg Cl/l	0.77	
V4531OUT	Foremass SR Outlet	4927557	11/06/2024 10:32	Total Coliforms	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4927560	11/06/2024 10:50	Colony Counts 22	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4927560	11/06/2024 10:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4927560	11/06/2024 10:50	E. coli	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4927560	11/06/2024 10:50	Free - Residual disinfectant	mg Cl/l	0.69	
V4537OUT	Sixmilecross SR Outlet	4927560	11/06/2024 10:50	Total - Residual disinfectant	mg Cl/l	0.81	
V4537OUT	Sixmilecross SR Outlet	4927560	11/06/2024 10:50	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4927559	11/06/2024 11:10	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4927559	11/06/2024 11:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4927559	11/06/2024 11:10	E. coli	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4927559	11/06/2024 11:10	Free - Residual disinfectant	mg Cl/l	0.55	
V1356OUT	Mormeal SR Outlet	4927559	11/06/2024 11:10	Total - Residual disinfectant	mg Cl/l	0.7	
V1356OUT	Mormeal SR Outlet	4927559	11/06/2024 11:10	Total Coliforms	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4927565	11/06/2024 11:12	Colony Counts 22	CFU/1 ml	1	
V4528OUT	Crocknabohil SR Outlet	4927565	11/06/2024 11:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4927565	11/06/2024 11:12	E. coli	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4927565	11/06/2024 11:12	Free - Residual disinfectant	mg Cl/l	0.68	
V4528OUT	Crocknabohil SR Outlet	4927565	11/06/2024 11:12	Total - Residual disinfectant	mg Cl/l	0.8	
V4528OUT	Crocknabohil SR Outlet	4927565	11/06/2024 11:12	Total Coliforms	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4927775	12/06/2024 07:30	Colony Counts 22	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4927775	12/06/2024 07:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4927775	12/06/2024 07:30	E. coli	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4927775	12/06/2024 07:30	Free - Residual disinfectant	mg Cl/l	0.44	
V1702OUT	Cam SR Outlet	4927775	12/06/2024 07:30	Total - Residual disinfectant	mg Cl/l	0.59	
V1702OUT	Cam SR Outlet	4927775	12/06/2024 07:30	Total Coliforms	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4927774	12/06/2024 07:56	Colony Counts 22	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4927774	12/06/2024 07:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4927774	12/06/2024 07:56	E. coli	CFU/100 ml	0	0

V1706OUT	Killeague SR Outlet	4927774	12/06/2024 07:56	Free - Residual disinfectant	mg Cl/l	0.57	
V1706OUT	Killeague SR Outlet	4927774	12/06/2024 07:56	Total - Residual disinfectant	mg Cl/l	0.81	
V1706OUT	Killeague SR Outlet	4927774	12/06/2024 07:56	Total Coliforms	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4927781	12/06/2024 07:58	Colony Counts 22	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4927781	12/06/2024 07:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4927781	12/06/2024 07:58	E. coli	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4927781	12/06/2024 07:58	Free - Residual disinfectant	mg Cl/l	0.63	
V1351OUT	Cranny Moneymore SR Outlet	4927781	12/06/2024 07:58	Total - Residual disinfectant	mg Cl/l	0.7	
V1351OUT	Cranny Moneymore SR Outlet	4927781	12/06/2024 07:58	Total Coliforms	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4927769	12/06/2024 08:20	Colony Counts 22	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4927769	12/06/2024 08:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4927769	12/06/2024 08:20	E. coli	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4927769	12/06/2024 08:20	Free - Residual disinfectant	mg Cl/l	0.32	
V1352OUT	Cullion Desertmartin SR Outlet	4927769	12/06/2024 08:20	Total - Residual disinfectant	mg Cl/l	0.39	
V1352OUT	Cullion Desertmartin SR Outlet	4927769	12/06/2024 08:20	Total Coliforms	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4927776	12/06/2024 08:24	Colony Counts 22	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4927776	12/06/2024 08:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4927776	12/06/2024 08:24	E. coli	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4927776	12/06/2024 08:24	Free - Residual disinfectant	mg Cl/l	0.28	
V1708OUT	North Garvagh SR Outlet	4927776	12/06/2024 08:24	Total - Residual disinfectant	mg Cl/l	0.4	
V1708OUT	North Garvagh SR Outlet	4927776	12/06/2024 08:24	Total Coliforms	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4927792	12/06/2024 08:41	Colony Counts 22	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4927792	12/06/2024 08:41	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V1343OUT	Ballybriest SR Outlet	4927792	12/06/2024 08:41	E. coli	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4927792	12/06/2024 08:41	Free - Residual disinfectant	mg Cl/l	0.7	
V1343OUT	Ballybriest SR Outlet	4927792	12/06/2024 08:41	Total - Residual disinfectant	mg Cl/l	0.77	
V1343OUT	Ballybriest SR Outlet	4927792	12/06/2024 08:41	Total Coliforms	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4927778	12/06/2024 08:43	Colony Counts 22	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4927778	12/06/2024 08:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4927778	12/06/2024 08:43	E. coli	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4927778	12/06/2024 08:43	Free - Residual disinfectant	mg Cl/l	0.85	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4927778	12/06/2024 08:43	Total - Residual disinfectant	mg Cl/l	1.01	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4927778	12/06/2024 08:43	Total Coliforms	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4927780	12/06/2024 08:51	Colony Counts 22	CFU/1 ml	2	
V1713OUT	Trienaltenagh SR Outlet	4927780	12/06/2024 08:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4927780	12/06/2024 08:51	E. coli	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4927780	12/06/2024 08:51	Free - Residual disinfectant	mg Cl/l	0.3	
V1713OUT	Trienaltenagh SR Outlet	4927780	12/06/2024 08:51	Total - Residual disinfectant	mg Cl/l	0.6	
V1713OUT	Trienaltenagh SR Outlet	4927780	12/06/2024 08:51	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4927735	12/06/2024 09:10	Colony Counts 22	CFU/1 ml	0	

V2508OUT	Carland SR Outlet	4927735	12/06/2024 09:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4927735	12/06/2024 09:10	E. coli	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4927735	12/06/2024 09:10	Free - Residual disinfectant	mg Cl/l	1.04	
V2508OUT	Carland SR Outlet	4927735	12/06/2024 09:10	Total - Residual disinfectant	mg Cl/l	1.16	
V2508OUT	Carland SR Outlet	4927735	12/06/2024 09:10	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4927735	12/06/2024 09:10	Odour	Diln No	0	0
V2508OUT	Carland SR Outlet	4927735	12/06/2024 09:10	Odour - Nature		No odour	
V2508OUT	Carland SR Outlet	4927735	12/06/2024 09:10	Taste	Diln No	0	0
V2508OUT	Carland SR Outlet	4927735	12/06/2024 09:10	Taste - Nature		No taste	
V4715OUT	Brookeborough High SR Outlet	4927793	12/06/2024 09:19	Colony Counts 22	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4927793	12/06/2024 09:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4927793	12/06/2024 09:19	E. coli	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4927793	12/06/2024 09:19	Free - Residual disinfectant	mg Cl/l	1.06	
V4715OUT	Brookeborough High SR Outlet	4927793	12/06/2024 09:19	Total - Residual disinfectant	mg Cl/l	1.29	
V4715OUT	Brookeborough High SR Outlet	4927793	12/06/2024 09:19	Total Coliforms	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4927736	12/06/2024 09:30	Colony Counts 22	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4927736	12/06/2024 09:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4927736	12/06/2024 09:30	E. coli	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4927736	12/06/2024 09:30	Free - Residual disinfectant	mg Cl/l	0.78	
V2509OUT	Castlehill Drumcoo SR Outlet	4927736	12/06/2024 09:30	Total - Residual disinfectant	mg Cl/l	0.87	
V2509OUT	Castlehill Drumcoo SR Outlet	4927736	12/06/2024 09:30	Total Coliforms	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4927751	12/06/2024 09:55	Colony Counts 22	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4927751	12/06/2024 09:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4927751	12/06/2024 09:55	E. coli	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4927751	12/06/2024 09:55	Free - Residual disinfectant	mg Cl/l	0.97	
V2521OUT	Mullaghanagh SR Outlet	4927751	12/06/2024 09:55	Total - Residual disinfectant	mg Cl/l	1.08	
V2521OUT	Mullaghanagh SR Outlet	4927751	12/06/2024 09:55	Total Coliforms	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4927777	12/06/2024 09:57	Colony Counts 22	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4927777	12/06/2024 09:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4927777	12/06/2024 09:57	E. coli	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4927777	12/06/2024 09:57	Free - Residual disinfectant	mg Cl/l	0.9	
V4742OUT	Tattinbar SR Outlet	4927777	12/06/2024 09:57	Total - Residual disinfectant	mg Cl/l	1.08	
V4742OUT	Tattinbar SR Outlet	4927777	12/06/2024 09:57	Total Coliforms	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4927768	12/06/2024 10:10	Colony Counts 22	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4927768	12/06/2024 10:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4927768	12/06/2024 10:10	E. coli	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4927768	12/06/2024 10:10	Free - Residual disinfectant	mg Cl/l	0.82	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4927768	12/06/2024 10:10	Total - Residual disinfectant	mg Cl/l	0.91	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4927768	12/06/2024 10:10	Total Coliforms	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4927779	12/06/2024 10:19	Colony Counts 22	CFU/1 ml	0	

V4745OUT	Glasdrumman Lisnaskea SR Outlet	4927779	12/06/2024 10:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4927779	12/06/2024 10:19	E. coli	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4927779	12/06/2024 10:19	Free - Residual disinfectant	mg Cl/l	0.76	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4927779	12/06/2024 10:19	Total - Residual disinfectant	mg Cl/l	0.84	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4927779	12/06/2024 10:19	Total Coliforms	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4927956	13/06/2024 07:21	Colony Counts 22	CFU/1 ml	4	
V1711OUT	Sconce Hill SR Outlet	4927956	13/06/2024 07:21	Colony Counts 37 (48hrs)	CFU/1 ml	2	
V1711OUT	Sconce Hill SR Outlet	4927956	13/06/2024 07:21	E. coli	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4927956	13/06/2024 07:21	Free - Residual disinfectant	mg Cl/l	0.56	
V1711OUT	Sconce Hill SR Outlet	4927956	13/06/2024 07:21	Total - Residual disinfectant	mg Cl/l	0.71	
V1711OUT	Sconce Hill SR Outlet	4927956	13/06/2024 07:21	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4927954	13/06/2024 07:50	Colony Counts 22	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4927954	13/06/2024 07:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4927954	13/06/2024 07:50	E. coli	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4927954	13/06/2024 07:50	Free - Residual disinfectant	mg Cl/l	0.36	
V1704OUT	Castlerock Downhill SR Outlet	4927954	13/06/2024 07:50	Total - Residual disinfectant	mg Cl/l	0.6	
V1704OUT	Castlerock Downhill SR Outlet	4927954	13/06/2024 07:50	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4927954	13/06/2024 07:50	Odour	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4927954	13/06/2024 07:50	Odour - Nature		No odour	
V1704OUT	Castlerock Downhill SR Outlet	4927954	13/06/2024 07:50	Taste	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4927954	13/06/2024 07:50	Taste - Nature		No taste	
V1338OUT	Coagh SR Outlet	4927963	13/06/2024 08:20	Colony Counts 22	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4927963	13/06/2024 08:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4927963	13/06/2024 08:20	E. coli	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4927963	13/06/2024 08:20	Free - Residual disinfectant	mg Cl/l	0.54	
V1338OUT	Coagh SR Outlet	4927963	13/06/2024 08:20	Total - Residual disinfectant	mg Cl/l	0.65	
V1338OUT	Coagh SR Outlet	4927963	13/06/2024 08:20	Total Coliforms	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4927966	13/06/2024 08:45	Colony Counts 22	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4927966	13/06/2024 08:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4927966	13/06/2024 08:45	E. coli	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4927966	13/06/2024 08:45	Free - Residual disinfectant	mg Cl/l	0.52	
V1342OUT	Dromore High SR Outlet	4927966	13/06/2024 08:45	Total - Residual disinfectant	mg Cl/l	0.62	
V1342OUT	Dromore High SR Outlet	4927966	13/06/2024 08:45	Total Coliforms	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4927970	13/06/2024 08:57	Colony Counts 22	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4927970	13/06/2024 08:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4927970	13/06/2024 08:57	E. coli	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4927970	13/06/2024 08:57	Free - Residual disinfectant	mg Cl/l	0.86	
V4713OUT	Knocknalosset SR Outlet	4927970	13/06/2024 08:57	Total - Residual disinfectant	mg Cl/l	0.97	
V4713OUT	Knocknalosset SR Outlet	4927970	13/06/2024 08:57	Total Coliforms	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4927962	13/06/2024 09:10	Colony Counts 22	CFU/1 ml	0	

V1335OUT	Brigh Quarry SR Outlet	4927962	13/06/2024 09:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4927962	13/06/2024 09:10	E. coli	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4927962	13/06/2024 09:10	Free - Residual disinfectant	mg Cl/l	0.58	
V1335OUT	Brigh Quarry SR Outlet	4927962	13/06/2024 09:10	Total - Residual disinfectant	mg Cl/l	0.69	
V1335OUT	Brigh Quarry SR Outlet	4927962	13/06/2024 09:10	Total Coliforms	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4927967	13/06/2024 09:13	Colony Counts 22	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4927967	13/06/2024 09:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4927967	13/06/2024 09:13	E. coli	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4927967	13/06/2024 09:13	Free - Residual disinfectant	mg Cl/l	0.69	
V4712OUT	Corranny SR Outlet	4927967	13/06/2024 09:13	Total - Residual disinfectant	mg Cl/l	1.17	
V4712OUT	Corranny SR Outlet	4927967	13/06/2024 09:13	Total Coliforms	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4927926	13/06/2024 09:22	Colony Counts 22	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4927926	13/06/2024 09:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4927926	13/06/2024 09:22	E. coli	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4927926	13/06/2024 09:22	Free - Residual disinfectant	mg Cl/l	0.98	
V2511OUT	Corran Armagh SR Outlet	4927926	13/06/2024 09:22	Total - Residual disinfectant	mg Cl/l	1.07	
V2511OUT	Corran Armagh SR Outlet	4927926	13/06/2024 09:22	Total Coliforms	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4927934	13/06/2024 09:35	Colony Counts 22	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4927934	13/06/2024 09:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4927934	13/06/2024 09:35	E. coli	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4927934	13/06/2024 09:35	Free - Residual disinfectant	mg Cl/l	0.56	
V2518OUT	Lisnastrane SR Outlet	4927934	13/06/2024 09:35	Total - Residual disinfectant	mg Cl/l	0.67	
V2518OUT	Lisnastrane SR Outlet	4927934	13/06/2024 09:35	Total Coliforms	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4927925	13/06/2024 10:02	Colony Counts 22	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4927925	13/06/2024 10:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4927925	13/06/2024 10:02	E. coli	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4927925	13/06/2024 10:02	Free - Residual disinfectant	mg Cl/l	0.58	
V2510OUT	Calone SR Outlet	4927925	13/06/2024 10:02	Total - Residual disinfectant	mg Cl/l	0.66	
V2510OUT	Calone SR Outlet	4927925	13/06/2024 10:02	Total Coliforms	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4927932	13/06/2024 10:17	Colony Counts 22	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4927932	13/06/2024 10:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4927932	13/06/2024 10:17	E. coli	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4927932	13/06/2024 10:17	Free - Residual disinfectant	mg Cl/l	0.83	
V2514OUT	Edenaveys Command SR Outlet	4927932	13/06/2024 10:17	Total - Residual disinfectant	mg Cl/l	1.01	
V2514OUT	Edenaveys Command SR Outlet	4927932	13/06/2024 10:17	Total Coliforms	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4927922	13/06/2024 10:45	Colony Counts 22	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4927922	13/06/2024 10:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4927922	13/06/2024 10:45	E. coli	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4927922	13/06/2024 10:45	Free - Residual disinfectant	mg Cl/l	0.96	
V2523OUT	Rough Fort SR Outlet	4927922	13/06/2024 10:45	Total - Residual disinfectant	mg Cl/l	1.09	

V2523OUT	Rough Fort SR Outlet	4927922	13/06/2024 10:45	Total Coliforms	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4927960	13/06/2024 10:46	Colony Counts 22	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4927960	13/06/2024 10:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4927960	13/06/2024 10:46	E. coli	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4927960	13/06/2024 10:46	Free - Residual disinfectant	mg Cl/l	0.85	
V4533OUT	Inisclan SR Outlet	4927960	13/06/2024 10:46	Total - Residual disinfectant	mg Cl/l	0.93	
V4533OUT	Inisclan SR Outlet	4927960	13/06/2024 10:46	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4928135	14/06/2024 08:09	Colony Counts 22	CFU/1 ml	7	
V1360OUT	Windmill Hill SR Outlet	4928135	14/06/2024 08:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4928135	14/06/2024 08:09	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4928135	14/06/2024 08:09	Free - Residual disinfectant	mg Cl/l	0.53	
V1360OUT	Windmill Hill SR Outlet	4928135	14/06/2024 08:09	Total - Residual disinfectant	mg Cl/l	0.7	
V1360OUT	Windmill Hill SR Outlet	4928135	14/06/2024 08:09	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4928146	14/06/2024 08:28	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4928146	14/06/2024 08:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4928146	14/06/2024 08:28	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4928146	14/06/2024 08:28	Free - Residual disinfectant	mg Cl/l	0.58	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4928146	14/06/2024 08:28	Total - Residual disinfectant	mg Cl/l	0.74	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4928146	14/06/2024 08:28	Total Coliforms	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4928136	14/06/2024 08:48	Colony Counts 22	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4928136	14/06/2024 08:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4928136	14/06/2024 08:48	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4928136	14/06/2024 08:48	Free - Residual disinfectant	mg Cl/l	0.47	
V1362OUT	Unagh SR Outlet	4928136	14/06/2024 08:48	Total - Residual disinfectant	mg Cl/l	0.58	
V1362OUT	Unagh SR Outlet	4928136	14/06/2024 08:48	Total Coliforms	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4928150	14/06/2024 09:08	Colony Counts 22	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4928150	14/06/2024 09:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4928150	14/06/2024 09:08	E. coli	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4928150	14/06/2024 09:08	Free - Residual disinfectant	mg Cl/l	0.52	
V1344OUT	Craigs Cookstown SR Outlet	4928150	14/06/2024 09:08	Total - Residual disinfectant	mg Cl/l	0.61	
V1344OUT	Craigs Cookstown SR Outlet	4928150	14/06/2024 09:08	Total Coliforms	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4928147	14/06/2024 09:28	Colony Counts 22	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4928147	14/06/2024 09:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4928147	14/06/2024 09:28	E. coli	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4928147	14/06/2024 09:28	Free - Residual disinfectant	mg Cl/l	0.55	
V1339OUT	Corvanaghan High SR Outlet	4928147	14/06/2024 09:28	Total - Residual disinfectant	mg Cl/l	0.66	
V1339OUT	Corvanaghan High SR Outlet	4928147	14/06/2024 09:28	Total Coliforms	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4928151	14/06/2024 09:50	Colony Counts 22	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4928151	14/06/2024 09:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4928151	14/06/2024 09:50	E. coli	CFU/100 ml	0	0

V1346OUT	Gortaclady Evishanoran SR Outlet	4928151	14/06/2024 09:50	Free - Residual disinfectant	mg Cl/l	0.46	
V1346OUT	Gortaclady Evishanoran SR Outlet	4928151	14/06/2024 09:50	Total - Residual disinfectant	mg Cl/l	0.55	
V1346OUT	Gortaclady Evishanoran SR Outlet	4928151	14/06/2024 09:50	Total Coliforms	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4928116	14/06/2024 09:51	Colony Counts 22	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4928116	14/06/2024 09:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4928116	14/06/2024 09:51	E. coli	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4928116	14/06/2024 09:51	Free - Residual disinfectant	mg Cl/l	0.64	
V4539OUT	Erganagh SR Outlet	4928116	14/06/2024 09:51	Total - Residual disinfectant	mg Cl/l	0.71	
V4539OUT	Erganagh SR Outlet	4928116	14/06/2024 09:51	Total Coliforms	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4928148	14/06/2024 10:08	Colony Counts 22	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4928148	14/06/2024 10:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4928148	14/06/2024 10:08	E. coli	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4928148	14/06/2024 10:08	Free - Residual disinfectant	mg Cl/l	0.49	
V1340OUT	Craigballyharkey SR Outlet	4928148	14/06/2024 10:08	Total - Residual disinfectant	mg Cl/l	0.61	
V1340OUT	Craigballyharkey SR Outlet	4928148	14/06/2024 10:08	Total Coliforms	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4928113	14/06/2024 10:09	Colony Counts 22	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4928113	14/06/2024 10:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4928113	14/06/2024 10:09	E. coli	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4928113	14/06/2024 10:09	Free - Residual disinfectant	mg Cl/l	0.77	
V4538OUT	Killyclogher SR Outlet	4928113	14/06/2024 10:09	Total - Residual disinfectant	mg Cl/l	0.86	
V4538OUT	Killyclogher SR Outlet	4928113	14/06/2024 10:09	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4928142	14/06/2024 10:28	Colony Counts 22	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4928142	14/06/2024 10:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4928142	14/06/2024 10:28	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4928142	14/06/2024 10:28	Free - Residual disinfectant	mg Cl/l	0.26	
V1350OUT	Carnaman SR Outlet	4928142	14/06/2024 10:28	Total - Residual disinfectant	mg Cl/l	0.53	
V1350OUT	Carnaman SR Outlet	4928142	14/06/2024 10:28	Total Coliforms	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4928123	14/06/2024 10:40	Colony Counts 22	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4928123	14/06/2024 10:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4928123	14/06/2024 10:40	E. coli	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4928123	14/06/2024 10:40	Free - Residual disinfectant	mg Cl/l	0.72	
V4536OUT	Lough Macrory North SR Outlet	4928123	14/06/2024 10:40	Total - Residual disinfectant	mg Cl/l	0.88	
V4536OUT	Lough Macrory North SR Outlet	4928123	14/06/2024 10:40	Total Coliforms	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4928112	14/06/2024 10:58	Colony Counts 22	CFU/1 ml	5	
V4526OUT	Black Lough Pomeroy SR Outlet	4928112	14/06/2024 10:58	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V4526OUT	Black Lough Pomeroy SR Outlet	4928112	14/06/2024 10:58	E. coli	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4928112	14/06/2024 10:58	Free - Residual disinfectant	mg Cl/l	0.8	
V4526OUT	Black Lough Pomeroy SR Outlet	4928112	14/06/2024 10:58	Total - Residual disinfectant	mg Cl/l	0.9	
V4526OUT	Black Lough Pomeroy SR Outlet	4928112	14/06/2024 10:58	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4941863	14/06/2024 11:35	E. coli	CFU/100 ml	0	0

V2301OUT	Ballydougan Command SR Outlet	4941863	14/06/2024 11:35	Free - Residual disinfectant	mg Cl/l	0.99	
V2301OUT	Ballydougan Command SR Outlet	4941863	14/06/2024 11:35	Total - Residual disinfectant	mg Cl/l	1.08	
V2301OUT	Ballydougan Command SR Outlet	4941863	14/06/2024 11:35	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4930529	17/06/2024 08:18	Colony Counts 22	CFU/1 ml	6	
V1360OUT	Windmill Hill SR Outlet	4930529	17/06/2024 08:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4930529	17/06/2024 08:18	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4930529	17/06/2024 08:18	Free - Residual disinfectant	mg Cl/l	0.49	
V1360OUT	Windmill Hill SR Outlet	4930529	17/06/2024 08:18	Total - Residual disinfectant	mg Cl/l	0.68	
V1360OUT	Windmill Hill SR Outlet	4930529	17/06/2024 08:18	Total Coliforms	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4930530	17/06/2024 08:37	Colony Counts 22	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4930530	17/06/2024 08:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4930530	17/06/2024 08:37	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4930530	17/06/2024 08:37	Free - Residual disinfectant	mg Cl/l	0.52	
V1362OUT	Unagh SR Outlet	4930530	17/06/2024 08:37	Total - Residual disinfectant	mg Cl/l	0.61	
V1362OUT	Unagh SR Outlet	4930530	17/06/2024 08:37	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4930540	17/06/2024 08:40	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4930540	17/06/2024 08:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4930540	17/06/2024 08:40	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4930540	17/06/2024 08:40	Free - Residual disinfectant	mg Cl/l	0.76	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4930540	17/06/2024 08:40	Total - Residual disinfectant	mg Cl/l	0.95	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4930540	17/06/2024 08:40	Total Coliforms	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4930544	17/06/2024 08:55	Colony Counts 22	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4930544	17/06/2024 08:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4930544	17/06/2024 08:55	E. coli	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4930544	17/06/2024 08:55	Free - Residual disinfectant	mg Cl/l	0.53	
V1344OUT	Craigs Cookstown SR Outlet	4930544	17/06/2024 08:55	Total - Residual disinfectant	mg Cl/l	0.64	
V1344OUT	Craigs Cookstown SR Outlet	4930544	17/06/2024 08:55	Total Coliforms	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4930541	17/06/2024 09:28	Colony Counts 22	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4930541	17/06/2024 09:28	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V1339OUT	Corvanaghan High SR Outlet	4930541	17/06/2024 09:28	E. coli	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4930541	17/06/2024 09:28	Free - Residual disinfectant	mg Cl/l	0.49	
V1339OUT	Corvanaghan High SR Outlet	4930541	17/06/2024 09:28	Total - Residual disinfectant	mg Cl/l	0.57	
V1339OUT	Corvanaghan High SR Outlet	4930541	17/06/2024 09:28	Total Coliforms	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4930545	17/06/2024 09:51	Colony Counts 22	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4930545	17/06/2024 09:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4930545	17/06/2024 09:51	E. coli	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4930545	17/06/2024 09:51	Free - Residual disinfectant	mg Cl/l	0.64	
V1346OUT	Gortaclady Evishanoran SR Outlet	4930545	17/06/2024 09:51	Total - Residual disinfectant	mg Cl/l	0.75	
V1346OUT	Gortaclady Evishanoran SR Outlet	4930545	17/06/2024 09:51	Total Coliforms	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4930512	17/06/2024 10:04	Colony Counts 22	CFU/1 ml	0	

V4539OUT	Erganagh SR Outlet	4930512	17/06/2024 10:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4930512	17/06/2024 10:04	E. coli	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4930512	17/06/2024 10:04	Free - Residual disinfectant	mg Cl/l	0.5	
V4539OUT	Erganagh SR Outlet	4930512	17/06/2024 10:04	Total - Residual disinfectant	mg Cl/l	0.6	
V4539OUT	Erganagh SR Outlet	4930512	17/06/2024 10:04	Total Coliforms	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4930542	17/06/2024 10:10	Colony Counts 22	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4930542	17/06/2024 10:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4930542	17/06/2024 10:10	E. coli	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4930542	17/06/2024 10:10	Free - Residual disinfectant	mg Cl/l	0.57	
V1340OUT	Craigballyharkey SR Outlet	4930542	17/06/2024 10:10	Total - Residual disinfectant	mg Cl/l	0.65	
V1340OUT	Craigballyharkey SR Outlet	4930542	17/06/2024 10:10	Total Coliforms	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4930517	17/06/2024 11:27	Colony Counts 22	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4930517	17/06/2024 11:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4930517	17/06/2024 11:27	E. coli	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4930517	17/06/2024 11:27	Free - Residual disinfectant	mg Cl/l	0.95	
V4536OUT	Lough Macrory North SR Outlet	4930517	17/06/2024 11:27	Total - Residual disinfectant	mg Cl/l	1.08	
V4536OUT	Lough Macrory North SR Outlet	4930517	17/06/2024 11:27	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4930536	17/06/2024 11:32	Colony Counts 22	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4930536	17/06/2024 11:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4930536	17/06/2024 11:32	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4930536	17/06/2024 11:32	Free - Residual disinfectant	mg Cl/l	0.25	
V1350OUT	Carnaman SR Outlet	4930536	17/06/2024 11:32	Total - Residual disinfectant	mg Cl/l	0.45	
V1350OUT	Carnaman SR Outlet	4930536	17/06/2024 11:32	Total Coliforms	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4930509	17/06/2024 11:45	Colony Counts 22	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4930509	17/06/2024 11:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4930509	17/06/2024 11:45	E. coli	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4930509	17/06/2024 11:45	Free - Residual disinfectant	mg Cl/l	0.7	
V4526OUT	Black Lough Pomeroy SR Outlet	4930509	17/06/2024 11:45	Total - Residual disinfectant	mg Cl/l	0.8	
V4526OUT	Black Lough Pomeroy SR Outlet	4930509	17/06/2024 11:45	Total Coliforms	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4930825	18/06/2024 07:34	Colony Counts 22	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4930825	18/06/2024 07:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4930825	18/06/2024 07:34	E. coli	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4930825	18/06/2024 07:34	Free - Residual disinfectant	mg Cl/l	0.65	
V1715OUT	Ballystrone (Calvins) SR Outlet	4930825	18/06/2024 07:34	Total - Residual disinfectant	mg Cl/l	0.78	
V1715OUT	Ballystrone (Calvins) SR Outlet	4930825	18/06/2024 07:34	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4930787	18/06/2024 08:07	Colony Counts 22	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4930787	18/06/2024 08:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4930787	18/06/2024 08:07	E. coli	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4930787	18/06/2024 08:07	Free - Residual disinfectant	mg Cl/l	0.53	
V1725OUT	Glenlough SR Outlet	4930787	18/06/2024 08:07	Total - Residual disinfectant	mg Cl/l	0.68	

V1725OUT	Glenlough SR Outlet	4930787	18/06/2024 08:07	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4930787	18/06/2024 08:07	Odour	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4930787	18/06/2024 08:07	Odour - Nature		No odour	
V1725OUT	Glenlough SR Outlet	4930787	18/06/2024 08:07	Taste	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4930787	18/06/2024 08:07	Taste - Nature		No taste	
V4527OUT	Carryglass SR Outlet	4930799	18/06/2024 08:08	Colony Counts 22	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4930799	18/06/2024 08:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4930799	18/06/2024 08:08	E. coli	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4930799	18/06/2024 08:08	Free - Residual disinfectant	mg Cl/l	0.46	
V4527OUT	Carryglass SR Outlet	4930799	18/06/2024 08:08	Total - Residual disinfectant	mg Cl/l	0.52	
V4527OUT	Carryglass SR Outlet	4930799	18/06/2024 08:08	Total Coliforms	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4930832	18/06/2024 09:16	Colony Counts 22	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4930832	18/06/2024 09:16	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4930832	18/06/2024 09:16	E. coli	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4930832	18/06/2024 09:16	Free - Residual disinfectant	mg Cl/l	0.54	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4930832	18/06/2024 09:16	Total - Residual disinfectant	mg Cl/l	0.63	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4930832	18/06/2024 09:16	Total Coliforms	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4930796	18/06/2024 09:19	Colony Counts 22	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4930796	18/06/2024 09:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4930796	18/06/2024 09:19	E. coli	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4930796	18/06/2024 09:19	Free - Residual disinfectant	mg Cl/l	0.84	
V4707OUT	Sidaire SR Outlet	4930796	18/06/2024 09:19	Total - Residual disinfectant	mg Cl/l	0.98	
V4707OUT	Sidaire SR Outlet	4930796	18/06/2024 09:19	Total Coliforms	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4930804	18/06/2024 09:37	Colony Counts 22	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4930804	18/06/2024 09:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4930804	18/06/2024 09:37	E. coli	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4930804	18/06/2024 09:37	Free - Residual disinfectant	mg Cl/l	0.87	
V2501OUT	Altmore River SR Outlet	4930804	18/06/2024 09:37	Total - Residual disinfectant	mg Cl/l	0.98	
V2501OUT	Altmore River SR Outlet	4930804	18/06/2024 09:37	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4930822	18/06/2024 09:38	Colony Counts 22	CFU/1 ml	>300	
V1349OUT	Ballyknock Magherafelt SR Outlet	4930822	18/06/2024 09:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4930822	18/06/2024 09:38	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4930822	18/06/2024 09:38	Free - Residual disinfectant	mg Cl/l	0.38	
V1349OUT	Ballyknock Magherafelt SR Outlet	4930822	18/06/2024 09:38	Total - Residual disinfectant	mg Cl/l	0.54	
V1349OUT	Ballyknock Magherafelt SR Outlet	4930822	18/06/2024 09:38	Total Coliforms	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4930777	18/06/2024 09:51	Colony Counts 22	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4930777	18/06/2024 09:51	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V2507OUT	Cappagh SR Outlet	4930777	18/06/2024 09:51	E. coli	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4930777	18/06/2024 09:51	Free - Residual disinfectant	mg Cl/l	0.73	
V2507OUT	Cappagh SR Outlet	4930777	18/06/2024 09:51	Total - Residual disinfectant	mg Cl/l	0.81	

V2507OUT	Cappagh SR Outlet	4930777	18/06/2024 09:51	Total Coliforms	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4930830	18/06/2024 09:59	Colony Counts 22	CFU/1 ml	3	
V1358OUT	Slaughtneil SR Outlet	4930830	18/06/2024 09:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4930830	18/06/2024 09:59	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4930830	18/06/2024 09:59	Free - Residual disinfectant	mg Cl/l	0.52	
V1358OUT	Slaughtneil SR Outlet	4930830	18/06/2024 09:59	Total - Residual disinfectant	mg Cl/l	0.68	
V1358OUT	Slaughtneil SR Outlet	4930830	18/06/2024 09:59	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4930828	18/06/2024 10:21	Colony Counts 22	CFU/1 ml	2	
V1354OUT	Knockoneill SR Outlet	4930828	18/06/2024 10:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4930828	18/06/2024 10:21	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4930828	18/06/2024 10:21	Free - Residual disinfectant	mg Cl/l	0.29	
V1354OUT	Knockoneill SR Outlet	4930828	18/06/2024 10:21	Total - Residual disinfectant	mg Cl/l	0.38	
V1354OUT	Knockoneill SR Outlet	4930828	18/06/2024 10:21	Total Coliforms	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4930776	18/06/2024 10:24	Colony Counts 22	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4930776	18/06/2024 10:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4930776	18/06/2024 10:24	E. coli	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4930776	18/06/2024 10:24	Free - Residual disinfectant	mg Cl/l	0.71	
V2505OUT	Cabragh Fasglashagh SR Outlet	4930776	18/06/2024 10:24	Total - Residual disinfectant	mg Cl/l	0.86	
V2505OUT	Cabragh Fasglashagh SR Outlet	4930776	18/06/2024 10:24	Total Coliforms	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4930827	18/06/2024 10:39	Colony Counts 22	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4930827	18/06/2024 10:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4930827	18/06/2024 10:39	E. coli	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4930827	18/06/2024 10:39	Free - Residual disinfectant	mg Cl/l	0.43	
V4719OUT	Glenchuil SR Outlet	4930827	18/06/2024 10:39	Total - Residual disinfectant	mg Cl/l	0.51	
V4719OUT	Glenchuil SR Outlet	4930827	18/06/2024 10:39	Total Coliforms	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4930829	18/06/2024 11:12	Colony Counts 22	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4930829	18/06/2024 11:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4930829	18/06/2024 11:12	E. coli	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4930829	18/06/2024 11:12	Free - Residual disinfectant	mg Cl/l	0.5	
V4535OUT	Lisnagardy SR Outlet	4930829	18/06/2024 11:12	Total - Residual disinfectant	mg Cl/l	0.66	
V4535OUT	Lisnagardy SR Outlet	4930829	18/06/2024 11:12	Total Coliforms	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4930837	18/06/2024 11:24	Colony Counts 22	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4930837	18/06/2024 11:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4930837	18/06/2024 11:24	E. coli	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4930837	18/06/2024 11:24	Free - Residual disinfectant	mg Cl/l	0.53	
V4530OUT	Dungoran SR Outlet	4930837	18/06/2024 11:24	Total - Residual disinfectant	mg Cl/l	0.6	
V4530OUT	Dungoran SR Outlet	4930837	18/06/2024 11:24	Total Coliforms	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4931030	19/06/2024 08:53	Colony Counts 22	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4931030	19/06/2024 08:53	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4931030	19/06/2024 08:53	E. coli	CFU/100 ml	0	0

V1365OUT	Lough Fea North (Blacks) SR Outlet	4931030	19/06/2024 08:53	Free - Residual disinfectant	mg Cl/l	0.77	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4931030	19/06/2024 08:53	Total - Residual disinfectant	mg Cl/l	0.8	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4931030	19/06/2024 08:53	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4931042	19/06/2024 09:55	Colony Counts 22	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4931042	19/06/2024 09:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4931042	19/06/2024 09:55	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4931042	19/06/2024 09:55	Free - Residual disinfectant	mg Cl/l	0.21	
V1348OUT	Moydamlaght Draperstown SR Outlet	4931042	19/06/2024 09:55	Total - Residual disinfectant	mg Cl/l	0.38	
V1348OUT	Moydamlaght Draperstown SR Outlet	4931042	19/06/2024 09:55	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4930995	19/06/2024 10:17	Colony Counts 22	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4930995	19/06/2024 10:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4930995	19/06/2024 10:17	E. coli	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4930995	19/06/2024 10:17	Free - Residual disinfectant	mg Cl/l	0.87	
V2301OUT	Ballydougan Command SR Outlet	4930995	19/06/2024 10:17	Total - Residual disinfectant	mg Cl/l	0.99	
V2301OUT	Ballydougan Command SR Outlet	4930995	19/06/2024 10:17	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4930995	19/06/2024 10:17	Odour	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4930995	19/06/2024 10:17	Odour - Nature		No odour	
V2301OUT	Ballydougan Command SR Outlet	4930995	19/06/2024 10:17	Taste	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4930995	19/06/2024 10:17	Taste - Nature		No taste	
V1356OUT	Mormeal SR Outlet	4931047	19/06/2024 10:23	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4931047	19/06/2024 10:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4931047	19/06/2024 10:23	E. coli	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4931047	19/06/2024 10:23	Free - Residual disinfectant	mg Cl/l	0.46	
V1356OUT	Mormeal SR Outlet	4931047	19/06/2024 10:23	Total - Residual disinfectant	mg Cl/l	0.65	
V1356OUT	Mormeal SR Outlet	4931047	19/06/2024 10:23	Total Coliforms	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4930997	19/06/2024 10:34	Colony Counts 22	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4930997	19/06/2024 10:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4930997	19/06/2024 10:34	E. coli	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4930997	19/06/2024 10:34	Free - Residual disinfectant	mg Cl/l	0.59	
V2302OUT	Ballyhannon SR Outlet	4930997	19/06/2024 10:34	Total - Residual disinfectant	mg Cl/l	0.71	
V2302OUT	Ballyhannon SR Outlet	4930997	19/06/2024 10:34	Total Coliforms	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4931219	20/06/2024 07:26	Colony Counts 22	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4931219	20/06/2024 07:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4931219	20/06/2024 07:26	E. coli	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4931219	20/06/2024 07:26	Free - Residual disinfectant	mg Cl/l	0.76	
V1702OUT	Cam SR Outlet	4931219	20/06/2024 07:26	Total - Residual disinfectant	mg Cl/l	0.96	
V1702OUT	Cam SR Outlet	4931219	20/06/2024 07:26	Total Coliforms	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4931217	20/06/2024 07:54	Colony Counts 22	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4931217	20/06/2024 07:54	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4931217	20/06/2024 07:54	E. coli	CFU/100 ml	0	0

V1706OUT	Killeague SR Outlet	4931217	20/06/2024 07:54	Free - Residual disinfectant	mg Cl/l	0.57	
V1706OUT	Killeague SR Outlet	4931217	20/06/2024 07:54	Total - Residual disinfectant	mg Cl/l	0.65	
V1706OUT	Killeague SR Outlet	4931217	20/06/2024 07:54	Total Coliforms	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4931220	20/06/2024 08:24	Colony Counts 22	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4931220	20/06/2024 08:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4931220	20/06/2024 08:24	E. coli	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4931220	20/06/2024 08:24	Free - Residual disinfectant	mg Cl/l	0.39	
V1708OUT	North Garvagh SR Outlet	4931220	20/06/2024 08:24	Total - Residual disinfectant	mg Cl/l	0.51	
V1708OUT	North Garvagh SR Outlet	4931220	20/06/2024 08:24	Total Coliforms	CFU/100 ml	18	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4931222	20/06/2024 08:50	Colony Counts 22	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4931222	20/06/2024 08:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4931222	20/06/2024 08:50	E. coli	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4931222	20/06/2024 08:50	Free - Residual disinfectant	mg Cl/l	0.82	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4931222	20/06/2024 08:50	Total - Residual disinfectant	mg Cl/l	0.94	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4931222	20/06/2024 08:50	Total Coliforms	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4931224	20/06/2024 08:55	Colony Counts 22	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4931224	20/06/2024 08:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4931224	20/06/2024 08:55	E. coli	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4931224	20/06/2024 08:55	Free - Residual disinfectant	mg Cl/l	0.37	
V1713OUT	Trienaltenagh SR Outlet	4931224	20/06/2024 08:55	Total - Residual disinfectant	mg Cl/l	0.45	
V1713OUT	Trienaltenagh SR Outlet	4931224	20/06/2024 08:55	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4931184	20/06/2024 08:56	Colony Counts 22	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4931184	20/06/2024 08:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4931184	20/06/2024 08:56	E. coli	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4931184	20/06/2024 08:56	Free - Residual disinfectant	mg Cl/l	0.92	
V2508OUT	Carland SR Outlet	4931184	20/06/2024 08:56	Total - Residual disinfectant	mg Cl/l	1.04	
V2508OUT	Carland SR Outlet	4931184	20/06/2024 08:56	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4931184	20/06/2024 08:56	Odour	Diln No	0	0
V2508OUT	Carland SR Outlet	4931184	20/06/2024 08:56	Odour - Nature		No odour	
V2508OUT	Carland SR Outlet	4931184	20/06/2024 08:56	Taste	Diln No	0	0
V2508OUT	Carland SR Outlet	4931184	20/06/2024 08:56	Taste - Nature		No taste	
V2509OUT	Castlehill Drumcoo SR Outlet	4931185	20/06/2024 09:25	Colony Counts 22	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4931185	20/06/2024 09:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4931185	20/06/2024 09:25	E. coli	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4931185	20/06/2024 09:25	Free - Residual disinfectant	mg Cl/l	0.73	
V2509OUT	Castlehill Drumcoo SR Outlet	4931185	20/06/2024 09:25	Total - Residual disinfectant	mg Cl/l	0.85	
V2509OUT	Castlehill Drumcoo SR Outlet	4931185	20/06/2024 09:25	Total Coliforms	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4931237	20/06/2024 09:27	Colony Counts 22	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4931237	20/06/2024 09:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4931237	20/06/2024 09:27	E. coli	CFU/100 ml	0	0

V4715OUT	Brookeborough High SR Outlet	4931237	20/06/2024 09:27	Free - Residual disinfectant	mg Cl/l	0.89	
V4715OUT	Brookeborough High SR Outlet	4931237	20/06/2024 09:27	Total - Residual disinfectant	mg Cl/l	1.06	
V4715OUT	Brookeborough High SR Outlet	4931237	20/06/2024 09:27	Total Coliforms	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4931199	20/06/2024 09:41	Colony Counts 22	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4931199	20/06/2024 09:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4931199	20/06/2024 09:41	E. coli	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4931199	20/06/2024 09:41	Free - Residual disinfectant	mg Cl/l	0.93	
V2521OUT	Mullaghanagh SR Outlet	4931199	20/06/2024 09:41	Total - Residual disinfectant	mg Cl/l	1.06	
V2521OUT	Mullaghanagh SR Outlet	4931199	20/06/2024 09:41	Total Coliforms	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4931019	20/06/2024 09:44	Colony Counts 22	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4931019	20/06/2024 09:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4931019	20/06/2024 09:44	E. coli	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4931019	20/06/2024 09:44	Free - Residual disinfectant	mg Cl/l	0.83	
V4540OUT	Radergan SR Outlet	4931019	20/06/2024 09:44	Total - Residual disinfectant	mg Cl/l	0.88	
V4540OUT	Radergan SR Outlet	4931019	20/06/2024 09:44	Total Coliforms	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4931221	20/06/2024 09:56	Colony Counts 22	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4931221	20/06/2024 09:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4931221	20/06/2024 09:56	E. coli	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4931221	20/06/2024 09:56	Free - Residual disinfectant	mg Cl/l	0.77	
V4742OUT	Tattinbar SR Outlet	4931221	20/06/2024 09:56	Total - Residual disinfectant	mg Cl/l	0.98	
V4742OUT	Tattinbar SR Outlet	4931221	20/06/2024 09:56	Total Coliforms	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4931045	20/06/2024 10:01	Colony Counts 22	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4931045	20/06/2024 10:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4931045	20/06/2024 10:01	E. coli	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4931045	20/06/2024 10:01	Free - Residual disinfectant	mg Cl/l	0.69	
V4531OUT	Foremass SR Outlet	4931045	20/06/2024 10:01	Total - Residual disinfectant	mg Cl/l	0.82	
V4531OUT	Foremass SR Outlet	4931045	20/06/2024 10:01	Total Coliforms	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4931212	20/06/2024 10:21	Colony Counts 22	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4931212	20/06/2024 10:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4931212	20/06/2024 10:21	E. coli	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4931212	20/06/2024 10:21	Free - Residual disinfectant	mg Cl/l	0.82	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4931212	20/06/2024 10:21	Total - Residual disinfectant	mg Cl/l	0.93	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4931212	20/06/2024 10:21	Total Coliforms	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4931223	20/06/2024 10:23	Colony Counts 22	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4931223	20/06/2024 10:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4931223	20/06/2024 10:23	E. coli	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4931223	20/06/2024 10:23	Free - Residual disinfectant	mg Cl/l	0.79	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4931223	20/06/2024 10:23	Total - Residual disinfectant	mg Cl/l	0.87	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4931223	20/06/2024 10:23	Total Coliforms	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4930510	20/06/2024 10:24	Colony Counts 22	CFU/1 ml	0	

V4538OUT	Killiclogher SR Outlet	4930510	20/06/2024 10:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4538OUT	Killiclogher SR Outlet	4930510	20/06/2024 10:24	E. coli	CFU/100 ml	0	0
V4538OUT	Killiclogher SR Outlet	4930510	20/06/2024 10:24	Free - Residual disinfectant	mg Cl/l	0.65	
V4538OUT	Killiclogher SR Outlet	4930510	20/06/2024 10:24	Total - Residual disinfectant	mg Cl/l	0.73	
V4538OUT	Killiclogher SR Outlet	4930510	20/06/2024 10:24	Total Coliforms	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4931236	20/06/2024 10:24	Colony Counts 22	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4931236	20/06/2024 10:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4931236	20/06/2024 10:24	E. coli	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4931236	20/06/2024 10:24	Free - Residual disinfectant	mg Cl/l	0.8	
V1343OUT	Ballybriest SR Outlet	4931236	20/06/2024 10:24	Total - Residual disinfectant	mg Cl/l	0.85	
V1343OUT	Ballybriest SR Outlet	4931236	20/06/2024 10:24	Total Coliforms	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4931048	20/06/2024 10:25	Colony Counts 22	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4931048	20/06/2024 10:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4931048	20/06/2024 10:25	E. coli	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4931048	20/06/2024 10:25	Free - Residual disinfectant	mg Cl/l	0.53	
V4537OUT	Sixmilecross SR Outlet	4931048	20/06/2024 10:25	Total - Residual disinfectant	mg Cl/l	0.66	
V4537OUT	Sixmilecross SR Outlet	4931048	20/06/2024 10:25	Total Coliforms	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4931053	20/06/2024 10:46	Colony Counts 22	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4931053	20/06/2024 10:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4931053	20/06/2024 10:46	E. coli	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4931053	20/06/2024 10:46	Free - Residual disinfectant	mg Cl/l	0.66	
V4528OUT	Crocknabohil SR Outlet	4931053	20/06/2024 10:46	Total - Residual disinfectant	mg Cl/l	0.72	
V4528OUT	Crocknabohil SR Outlet	4931053	20/06/2024 10:46	Total Coliforms	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4931213	20/06/2024 10:49	Colony Counts 22	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4931213	20/06/2024 10:49	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V1352OUT	Cullion Desertmartin SR Outlet	4931213	20/06/2024 10:49	E. coli	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4931213	20/06/2024 10:49	Free - Residual disinfectant	mg Cl/l	0.31	
V1352OUT	Cullion Desertmartin SR Outlet	4931213	20/06/2024 10:49	Total - Residual disinfectant	mg Cl/l	0.39	
V1352OUT	Cullion Desertmartin SR Outlet	4931213	20/06/2024 10:49	Total Coliforms	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4931225	20/06/2024 11:09	Colony Counts 22	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4931225	20/06/2024 11:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4931225	20/06/2024 11:09	E. coli	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4931225	20/06/2024 11:09	Free - Residual disinfectant	mg Cl/l	0.72	
V1351OUT	Cranny Moneymore SR Outlet	4931225	20/06/2024 11:09	Total - Residual disinfectant	mg Cl/l	0.82	
V1351OUT	Cranny Moneymore SR Outlet	4931225	20/06/2024 11:09	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4931379	21/06/2024 07:38	Colony Counts 22	CFU/1 ml	1	
V1704OUT	Castlerock Downhill SR Outlet	4931379	21/06/2024 07:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4931379	21/06/2024 07:38	E. coli	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4931379	21/06/2024 07:38	Free - Residual disinfectant	mg Cl/l	0.46	
V1704OUT	Castlerock Downhill SR Outlet	4931379	21/06/2024 07:38	Total - Residual disinfectant	mg Cl/l	0.58	

V1704OUT	Castlerock Downhill SR Outlet	4931379	21/06/2024 07:38	Total Coliforms	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4931388	21/06/2024 08:51	Colony Counts 22	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4931388	21/06/2024 08:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4931388	21/06/2024 08:51	E. coli	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4931388	21/06/2024 08:51	Free - Residual disinfectant	mg Cl/l	0.46	
V1338OUT	Coagh SR Outlet	4931388	21/06/2024 08:51	Total - Residual disinfectant	mg Cl/l	0.58	
V1338OUT	Coagh SR Outlet	4931388	21/06/2024 08:51	Total Coliforms	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4931395	21/06/2024 09:01	Colony Counts 22	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4931395	21/06/2024 09:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4931395	21/06/2024 09:01	E. coli	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4931395	21/06/2024 09:01	Free - Residual disinfectant	mg Cl/l	0.88	
V4713OUT	Knocknalosset SR Outlet	4931395	21/06/2024 09:01	Total - Residual disinfectant	mg Cl/l	1.03	
V4713OUT	Knocknalosset SR Outlet	4931395	21/06/2024 09:01	Total Coliforms	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4931391	21/06/2024 09:09	Colony Counts 22	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4931391	21/06/2024 09:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4931391	21/06/2024 09:09	E. coli	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4931391	21/06/2024 09:09	Free - Residual disinfectant	mg Cl/l	0.65	
V1342OUT	Dromore High SR Outlet	4931391	21/06/2024 09:09	Total - Residual disinfectant	mg Cl/l	0.74	
V1342OUT	Dromore High SR Outlet	4931391	21/06/2024 09:09	Total Coliforms	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4931349	21/06/2024 09:19	Colony Counts 22	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4931349	21/06/2024 09:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4931349	21/06/2024 09:19	E. coli	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4931349	21/06/2024 09:19	Free - Residual disinfectant	mg Cl/l	1.06	
V2511OUT	Corran Armagh SR Outlet	4931349	21/06/2024 09:19	Total - Residual disinfectant	mg Cl/l	1.14	
V2511OUT	Corran Armagh SR Outlet	4931349	21/06/2024 09:19	Total Coliforms	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4931392	21/06/2024 09:21	Colony Counts 22	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4931392	21/06/2024 09:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4931392	21/06/2024 09:21	E. coli	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4931392	21/06/2024 09:21	Free - Residual disinfectant	mg Cl/l	0.61	
V4712OUT	Corranny SR Outlet	4931392	21/06/2024 09:21	Total - Residual disinfectant	mg Cl/l	0.72	
V4712OUT	Corranny SR Outlet	4931392	21/06/2024 09:21	Total Coliforms	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4931348	21/06/2024 09:37	Colony Counts 22	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4931348	21/06/2024 09:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4931348	21/06/2024 09:37	E. coli	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4931348	21/06/2024 09:37	Free - Residual disinfectant	mg Cl/l	0.71	
V2510OUT	Calone SR Outlet	4931348	21/06/2024 09:37	Total - Residual disinfectant	mg Cl/l	0.81	
V2510OUT	Calone SR Outlet	4931348	21/06/2024 09:37	Total Coliforms	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4931387	21/06/2024 09:43	Colony Counts 22	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4931387	21/06/2024 09:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4931387	21/06/2024 09:43	E. coli	CFU/100 ml	0	0

V1335OUT	Brigh Quarry SR Outlet	4931387	21/06/2024 09:43	Free - Residual disinfectant	mg Cl/l	0.64	
V1335OUT	Brigh Quarry SR Outlet	4931387	21/06/2024 09:43	Total - Residual disinfectant	mg Cl/l	0.75	
V1335OUT	Brigh Quarry SR Outlet	4931387	21/06/2024 09:43	Total Coliforms	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4931353	21/06/2024 09:51	Colony Counts 22	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4931353	21/06/2024 09:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4931353	21/06/2024 09:51	E. coli	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4931353	21/06/2024 09:51	Free - Residual disinfectant	mg Cl/l	0.91	
V2514OUT	Edenaveys Command SR Outlet	4931353	21/06/2024 09:51	Total - Residual disinfectant	mg Cl/l	1.01	
V2514OUT	Edenaveys Command SR Outlet	4931353	21/06/2024 09:51	Total Coliforms	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4931385	21/06/2024 10:08	Colony Counts 22	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4931385	21/06/2024 10:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4931385	21/06/2024 10:08	E. coli	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4931385	21/06/2024 10:08	Free - Residual disinfectant	mg Cl/l	0.78	
V4533OUT	Inisclan SR Outlet	4931385	21/06/2024 10:08	Total - Residual disinfectant	mg Cl/l	0.88	
V4533OUT	Inisclan SR Outlet	4931385	21/06/2024 10:08	Total Coliforms	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4931345	21/06/2024 10:13	Colony Counts 22	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4931345	21/06/2024 10:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4931345	21/06/2024 10:13	E. coli	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4931345	21/06/2024 10:13	Free - Residual disinfectant	mg Cl/l	0.76	
V2523OUT	Rough Fort SR Outlet	4931345	21/06/2024 10:13	Total - Residual disinfectant	mg Cl/l	0.85	
V2523OUT	Rough Fort SR Outlet	4931345	21/06/2024 10:13	Total Coliforms	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4931355	21/06/2024 10:16	Colony Counts 22	CFU/1 ml	2	
V2518OUT	Lisnastrane SR Outlet	4931355	21/06/2024 10:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4931355	21/06/2024 10:16	E. coli	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4931355	21/06/2024 10:16	Free - Residual disinfectant	mg Cl/l	0.63	
V2518OUT	Lisnastrane SR Outlet	4931355	21/06/2024 10:16	Total - Residual disinfectant	mg Cl/l	0.74	
V2518OUT	Lisnastrane SR Outlet	4931355	21/06/2024 10:16	Total Coliforms	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4930834	21/06/2024 11:11	Colony Counts 22	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4930834	21/06/2024 11:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4930834	21/06/2024 11:11	E. coli	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4930834	21/06/2024 11:11	Free - Residual disinfectant	mg Cl/l	1.14	
V4708OUT	Cavanacross Enniskillen SR Outlet	4930834	21/06/2024 11:11	Total - Residual disinfectant	mg Cl/l	1.27	
V4708OUT	Cavanacross Enniskillen SR Outlet	4930834	21/06/2024 11:11	Total Coliforms	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4945120	21/06/2024 11:15	E. coli	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4945120	21/06/2024 11:15	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4933287	24/06/2024 07:37	Colony Counts 22	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4933287	24/06/2024 07:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4933287	24/06/2024 07:37	E. coli	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4933287	24/06/2024 07:37	Free - Residual disinfectant	mg Cl/l	0.41	
V1704OUT	Castlerock Downhill SR Outlet	4933287	24/06/2024 07:37	Total - Residual disinfectant	mg Cl/l	0.58	

V1704OUT	Castlerock Downhill SR Outlet	4933287	24/06/2024 07:37	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4933287	24/06/2024 07:37	Odour	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4933287	24/06/2024 07:37	Odour - Nature		No odour	
V1704OUT	Castlerock Downhill SR Outlet	4933287	24/06/2024 07:37	Taste	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4933287	24/06/2024 07:37	Taste - Nature		No taste	
V1338OUT	Coagh SR Outlet	4933296	24/06/2024 08:21	Colony Counts 22	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4933296	24/06/2024 08:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4933296	24/06/2024 08:21	E. coli	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4933296	24/06/2024 08:21	Free - Residual disinfectant	mg Cl/l	0.39	
V1338OUT	Coagh SR Outlet	4933296	24/06/2024 08:21	Total - Residual disinfectant	mg Cl/l	0.46	
V1338OUT	Coagh SR Outlet	4933296	24/06/2024 08:21	Total Coliforms	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4933299	24/06/2024 08:38	Colony Counts 22	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4933299	24/06/2024 08:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4933299	24/06/2024 08:38	E. coli	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4933299	24/06/2024 08:38	Free - Residual disinfectant	mg Cl/l	0.6	
V1342OUT	Dromore High SR Outlet	4933299	24/06/2024 08:38	Total - Residual disinfectant	mg Cl/l	0.64	
V1342OUT	Dromore High SR Outlet	4933299	24/06/2024 08:38	Total Coliforms	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4931381	24/06/2024 09:20	Colony Counts 22	CFU/1 ml	12	
V1711OUT	Sconce Hill SR Outlet	4931381	24/06/2024 09:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1711OUT	Sconce Hill SR Outlet	4931381	24/06/2024 09:20	E. coli	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4931381	24/06/2024 09:20	Free - Residual disinfectant	mg Cl/l	0.61	
V1711OUT	Sconce Hill SR Outlet	4931381	24/06/2024 09:20	Total - Residual disinfectant	mg Cl/l	0.77	
V1711OUT	Sconce Hill SR Outlet	4931381	24/06/2024 09:20	Total Coliforms	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4933295	24/06/2024 09:23	Colony Counts 22	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4933295	24/06/2024 09:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4933295	24/06/2024 09:23	E. coli	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4933295	24/06/2024 09:23	Free - Residual disinfectant	mg Cl/l	0.61	
V1335OUT	Brigh Quarry SR Outlet	4933295	24/06/2024 09:23	Total - Residual disinfectant	mg Cl/l	0.66	
V1335OUT	Brigh Quarry SR Outlet	4933295	24/06/2024 09:23	Total Coliforms	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4933303	24/06/2024 09:31	Colony Counts 22	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4933303	24/06/2024 09:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4933303	24/06/2024 09:31	E. coli	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4933303	24/06/2024 09:31	Free - Residual disinfectant	mg Cl/l	0.54	
V4713OUT	Knocknalosset SR Outlet	4933303	24/06/2024 09:31	Total - Residual disinfectant	mg Cl/l	0.62	
V4713OUT	Knocknalosset SR Outlet	4933303	24/06/2024 09:31	Total Coliforms	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4933213	24/06/2024 09:44	Colony Counts 22	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4933213	24/06/2024 09:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4933213	24/06/2024 09:44	E. coli	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4933213	24/06/2024 09:44	Free - Residual disinfectant	mg Cl/l	1.06	
V2511OUT	Corran Armagh SR Outlet	4933213	24/06/2024 09:44	Total - Residual disinfectant	mg Cl/l	1.18	

V2511OUT	Corran Armagh SR Outlet	4933213	24/06/2024 09:44	Total Coliforms	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4933300	24/06/2024 09:54	Colony Counts 22	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4933300	24/06/2024 09:54	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4933300	24/06/2024 09:54	E. coli	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4933300	24/06/2024 09:54	Free - Residual disinfectant	mg Cl/l	0.72	
V4712OUT	Corranny SR Outlet	4933300	24/06/2024 09:54	Total - Residual disinfectant	mg Cl/l	0.75	
V4712OUT	Corranny SR Outlet	4933300	24/06/2024 09:54	Total Coliforms	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4933269	24/06/2024 10:09	Colony Counts 22	CFU/1 ml	143	
V2518OUT	Lisnastrane SR Outlet	4933269	24/06/2024 10:09	Colony Counts 37 (48hrs)	CFU/1 ml	74	
V2518OUT	Lisnastrane SR Outlet	4933269	24/06/2024 10:09	E. coli	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4933269	24/06/2024 10:09	Free - Residual disinfectant	mg Cl/l	0.58	
V2518OUT	Lisnastrane SR Outlet	4933269	24/06/2024 10:09	Total - Residual disinfectant	mg Cl/l	0.62	
V2518OUT	Lisnastrane SR Outlet	4933269	24/06/2024 10:09	Total Coliforms	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4933212	24/06/2024 10:18	Colony Counts 22	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4933212	24/06/2024 10:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4933212	24/06/2024 10:18	E. coli	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4933212	24/06/2024 10:18	Free - Residual disinfectant	mg Cl/l	0.74	
V2510OUT	Calone SR Outlet	4933212	24/06/2024 10:18	Total - Residual disinfectant	mg Cl/l	0.92	
V2510OUT	Calone SR Outlet	4933212	24/06/2024 10:18	Total Coliforms	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4933293	24/06/2024 10:31	Colony Counts 22	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4933293	24/06/2024 10:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4933293	24/06/2024 10:31	E. coli	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4933293	24/06/2024 10:31	Free - Residual disinfectant	mg Cl/l	0.8	
V4533OUT	Inisclan SR Outlet	4933293	24/06/2024 10:31	Total - Residual disinfectant	mg Cl/l	0.89	
V4533OUT	Inisclan SR Outlet	4933293	24/06/2024 10:31	Total Coliforms	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4933268	24/06/2024 10:37	Colony Counts 22	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4933268	24/06/2024 10:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4933268	24/06/2024 10:37	E. coli	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4933268	24/06/2024 10:37	Free - Residual disinfectant	mg Cl/l	1.02	
V2514OUT	Edenaveys Command SR Outlet	4933268	24/06/2024 10:37	Total - Residual disinfectant	mg Cl/l	1.17	
V2514OUT	Edenaveys Command SR Outlet	4933268	24/06/2024 10:37	Total Coliforms	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4933209	24/06/2024 11:00	Colony Counts 22	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4933209	24/06/2024 11:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4933209	24/06/2024 11:00	E. coli	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4933209	24/06/2024 11:00	Free - Residual disinfectant	mg Cl/l	0.94	
V2523OUT	Rough Fort SR Outlet	4933209	24/06/2024 11:00	Total - Residual disinfectant	mg Cl/l	1.08	
V2523OUT	Rough Fort SR Outlet	4933209	24/06/2024 11:00	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4933532	25/06/2024 07:22	Colony Counts 22	CFU/1 ml	19	
V1360OUT	Windmill Hill SR Outlet	4933532	25/06/2024 07:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4933532	25/06/2024 07:22	E. coli	CFU/100 ml	0	0

V1360OUT	Windmill Hill SR Outlet	4933532	25/06/2024 07:22	Free - Residual disinfectant	mg Cl/l	0.47	
V1360OUT	Windmill Hill SR Outlet	4933532	25/06/2024 07:22	Total - Residual disinfectant	mg Cl/l	0.78	
V1360OUT	Windmill Hill SR Outlet	4933532	25/06/2024 07:22	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4933543	25/06/2024 07:43	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4933543	25/06/2024 07:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4933543	25/06/2024 07:43	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4933543	25/06/2024 07:43	Free - Residual disinfectant	mg Cl/l	0.91	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4933543	25/06/2024 07:43	Total - Residual disinfectant	mg Cl/l	1	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4933543	25/06/2024 07:43	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4933543	25/06/2024 07:43	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4933543	25/06/2024 07:43	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4933543	25/06/2024 07:43	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4933543	25/06/2024 07:43	Taste - Nature		No taste	
V4526OUT	Black Lough Pomeroy SR Outlet	4933509	25/06/2024 08:37	Colony Counts 22	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4933509	25/06/2024 08:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4933509	25/06/2024 08:37	E. coli	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4933509	25/06/2024 08:37	Free - Residual disinfectant	mg Cl/l	0.83	
V4526OUT	Black Lough Pomeroy SR Outlet	4933509	25/06/2024 08:37	Total - Residual disinfectant	mg Cl/l	0.9	
V4526OUT	Black Lough Pomeroy SR Outlet	4933509	25/06/2024 08:37	Total Coliforms	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4933520	25/06/2024 09:01	Colony Counts 22	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4933520	25/06/2024 09:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4933520	25/06/2024 09:01	E. coli	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4933520	25/06/2024 09:01	Free - Residual disinfectant	mg Cl/l	1.52	
V4536OUT	Lough Macrory North SR Outlet	4933520	25/06/2024 09:01	Total - Residual disinfectant	mg Cl/l	1.79	
V4536OUT	Lough Macrory North SR Outlet	4933520	25/06/2024 09:01	Total Coliforms	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4933547	25/06/2024 09:26	Colony Counts 22	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4933547	25/06/2024 09:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4933547	25/06/2024 09:26	E. coli	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4933547	25/06/2024 09:26	Free - Residual disinfectant	mg Cl/l	0.52	
V1344OUT	Craigs Cookstown SR Outlet	4933547	25/06/2024 09:26	Total - Residual disinfectant	mg Cl/l	0.56	
V1344OUT	Craigs Cookstown SR Outlet	4933547	25/06/2024 09:26	Total Coliforms	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4933533	25/06/2024 09:46	Colony Counts 22	CFU/1 ml	20	
V1362OUT	Unagh SR Outlet	4933533	25/06/2024 09:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4933533	25/06/2024 09:46	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4933533	25/06/2024 09:46	Free - Residual disinfectant	mg Cl/l	0.48	
V1362OUT	Unagh SR Outlet	4933533	25/06/2024 09:46	Total - Residual disinfectant	mg Cl/l	0.53	
V1362OUT	Unagh SR Outlet	4933533	25/06/2024 09:46	Total Coliforms	CFU/100 ml	0	0
V4538OUT	Killiclogher SR Outlet	4933510	25/06/2024 10:14	Colony Counts 22	CFU/1 ml	0	
V4538OUT	Killiclogher SR Outlet	4933510	25/06/2024 10:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4538OUT	Killiclogher SR Outlet	4933510	25/06/2024 10:14	E. coli	CFU/100 ml	0	0

V4538OUT	Killyclogher SR Outlet	4933510	25/06/2024 10:14	Free - Residual disinfectant	mg Cl/l	0.76	
V4538OUT	Killyclogher SR Outlet	4933510	25/06/2024 10:14	Total - Residual disinfectant	mg Cl/l	0.9	
V4538OUT	Killyclogher SR Outlet	4933510	25/06/2024 10:14	Total Coliforms	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4933544	25/06/2024 10:20	Colony Counts 22	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4933544	25/06/2024 10:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4933544	25/06/2024 10:20	E. coli	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4933544	25/06/2024 10:20	Free - Residual disinfectant	mg Cl/l	0.69	
V1339OUT	Corvanaghan High SR Outlet	4933544	25/06/2024 10:20	Total - Residual disinfectant	mg Cl/l	0.73	
V1339OUT	Corvanaghan High SR Outlet	4933544	25/06/2024 10:20	Total Coliforms	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4933548	25/06/2024 10:37	Colony Counts 22	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4933548	25/06/2024 10:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4933548	25/06/2024 10:37	E. coli	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4933548	25/06/2024 10:37	Free - Residual disinfectant	mg Cl/l	0.44	
V1346OUT	Gortaclady Evishanoran SR Outlet	4933548	25/06/2024 10:37	Total - Residual disinfectant	mg Cl/l	0.48	
V1346OUT	Gortaclady Evishanoran SR Outlet	4933548	25/06/2024 10:37	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4933539	25/06/2024 10:47	Colony Counts 22	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4933539	25/06/2024 10:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4933539	25/06/2024 10:47	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4933539	25/06/2024 10:47	Free - Residual disinfectant	mg Cl/l	0.18	
V1350OUT	Carnaman SR Outlet	4933539	25/06/2024 10:47	Total - Residual disinfectant	mg Cl/l	0.4	
V1350OUT	Carnaman SR Outlet	4933539	25/06/2024 10:47	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4933539	25/06/2024 10:47	Odour	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4933539	25/06/2024 10:47	Odour - Nature		No odour	
V1350OUT	Carnaman SR Outlet	4933539	25/06/2024 10:47	Taste	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4933539	25/06/2024 10:47	Taste - Nature		No taste	
V1340OUT	Craigballyharkey SR Outlet	4933545	25/06/2024 10:59	Colony Counts 22	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4933545	25/06/2024 10:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4933545	25/06/2024 10:59	E. coli	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4933545	25/06/2024 10:59	Free - Residual disinfectant	mg Cl/l	0.65	
V1340OUT	Craigballyharkey SR Outlet	4933545	25/06/2024 10:59	Total - Residual disinfectant	mg Cl/l	0.7	
V1340OUT	Craigballyharkey SR Outlet	4933545	25/06/2024 10:59	Total Coliforms	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4933512	25/06/2024 11:36	Colony Counts 22	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4933512	25/06/2024 11:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4933512	25/06/2024 11:36	E. coli	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4933512	25/06/2024 11:36	Free - Residual disinfectant	mg Cl/l	0.95	
V4539OUT	Erganagh SR Outlet	4933512	25/06/2024 11:36	Total - Residual disinfectant	mg Cl/l	1	
V4539OUT	Erganagh SR Outlet	4933512	25/06/2024 11:36	Total Coliforms	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4933763	26/06/2024 07:34	Colony Counts 22	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4933763	26/06/2024 07:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4933763	26/06/2024 07:34	E. coli	CFU/100 ml	0	0

V1715OUT	Ballystrone (Calvins) SR Outlet	4933763	26/06/2024 07:34	Free - Residual disinfectant	mg Cl/l	0.67	
V1715OUT	Ballystrone (Calvins) SR Outlet	4933763	26/06/2024 07:34	Total - Residual disinfectant	mg Cl/l	0.85	
V1715OUT	Ballystrone (Calvins) SR Outlet	4933763	26/06/2024 07:34	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4933689	26/06/2024 08:07	Colony Counts 22	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4933689	26/06/2024 08:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4933689	26/06/2024 08:07	E. coli	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4933689	26/06/2024 08:07	Free - Residual disinfectant	mg Cl/l	0.39	
V1725OUT	Glenlough SR Outlet	4933689	26/06/2024 08:07	Total - Residual disinfectant	mg Cl/l	0.48	
V1725OUT	Glenlough SR Outlet	4933689	26/06/2024 08:07	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4933689	26/06/2024 08:07	Odour	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4933689	26/06/2024 08:07	Odour - Nature		No odour	
V1725OUT	Glenlough SR Outlet	4933689	26/06/2024 08:07	Taste	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4933689	26/06/2024 08:07	Taste - Nature		No taste	
V4527OUT	Carryglass SR Outlet	4933736	26/06/2024 08:08	Colony Counts 22	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4933736	26/06/2024 08:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4933736	26/06/2024 08:08	E. coli	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4933736	26/06/2024 08:08	Free - Residual disinfectant	mg Cl/l	0.61	
V4527OUT	Carryglass SR Outlet	4933736	26/06/2024 08:08	Total - Residual disinfectant	mg Cl/l	0.7	
V4527OUT	Carryglass SR Outlet	4933736	26/06/2024 08:08	Total Coliforms	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4933728	26/06/2024 08:58	Colony Counts 22	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4933728	26/06/2024 08:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4933728	26/06/2024 08:58	E. coli	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4933728	26/06/2024 08:58	Free - Residual disinfectant	mg Cl/l	0.99	
V4707OUT	Sidaire SR Outlet	4933728	26/06/2024 08:58	Total - Residual disinfectant	mg Cl/l	1.07	
V4707OUT	Sidaire SR Outlet	4933728	26/06/2024 08:58	Total Coliforms	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4933770	26/06/2024 09:05	Colony Counts 22	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4933770	26/06/2024 09:05	Colony Counts 37 (48hrs)	CFU/1 ml	10	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4933770	26/06/2024 09:05	E. coli	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4933770	26/06/2024 09:05	Free - Residual disinfectant	mg Cl/l	0.51	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4933770	26/06/2024 09:05	Total - Residual disinfectant	mg Cl/l	0.58	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4933770	26/06/2024 09:05	Total Coliforms	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4933742	26/06/2024 09:24	Colony Counts 22	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4933742	26/06/2024 09:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4933742	26/06/2024 09:24	E. coli	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4933742	26/06/2024 09:24	Free - Residual disinfectant	mg Cl/l	1.02	
V2501OUT	Altmore River SR Outlet	4933742	26/06/2024 09:24	Total - Residual disinfectant	mg Cl/l	1.12	
V2501OUT	Altmore River SR Outlet	4933742	26/06/2024 09:24	Total Coliforms	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4933681	26/06/2024 09:50	Colony Counts 22	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4933681	26/06/2024 09:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4933681	26/06/2024 09:50	E. coli	CFU/100 ml	0	0

V2507OUT	Cappagh SR Outlet	4933681	26/06/2024 09:50	Free - Residual disinfectant	mg Cl/l	0.84	
V2507OUT	Cappagh SR Outlet	4933681	26/06/2024 09:50	Total - Residual disinfectant	mg Cl/l	0.94	
V2507OUT	Cappagh SR Outlet	4933681	26/06/2024 09:50	Total Coliforms	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4933772	26/06/2024 10:00	Colony Counts 22	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4933772	26/06/2024 10:00	Colony Counts 37 (48hrs)	CFU/1 ml	2	
V4708OUT	Cavanacross Enniskillen SR Outlet	4933772	26/06/2024 10:00	E. coli	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4933772	26/06/2024 10:00	Free - Residual disinfectant	mg Cl/l	1.04	
V4708OUT	Cavanacross Enniskillen SR Outlet	4933772	26/06/2024 10:00	Total - Residual disinfectant	mg Cl/l	1.15	
V4708OUT	Cavanacross Enniskillen SR Outlet	4933772	26/06/2024 10:00	Total Coliforms	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4933680	26/06/2024 10:09	Colony Counts 22	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4933680	26/06/2024 10:09	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V2505OUT	Cabragh Fasglashagh SR Outlet	4933680	26/06/2024 10:09	E. coli	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4933680	26/06/2024 10:09	Free - Residual disinfectant	mg Cl/l	0.84	
V2505OUT	Cabragh Fasglashagh SR Outlet	4933680	26/06/2024 10:09	Total - Residual disinfectant	mg Cl/l	0.95	
V2505OUT	Cabragh Fasglashagh SR Outlet	4933680	26/06/2024 10:09	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4933760	26/06/2024 10:13	Colony Counts 22	CFU/1 ml	37	
V1349OUT	Ballyknock Magherafelt SR Outlet	4933760	26/06/2024 10:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4933760	26/06/2024 10:13	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4933760	26/06/2024 10:13	Free - Residual disinfectant	mg Cl/l	0.38	
V1349OUT	Ballyknock Magherafelt SR Outlet	4933760	26/06/2024 10:13	Total - Residual disinfectant	mg Cl/l	0.55	
V1349OUT	Ballyknock Magherafelt SR Outlet	4933760	26/06/2024 10:13	Total Coliforms	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4933768	26/06/2024 10:39	Colony Counts 22	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4933768	26/06/2024 10:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4933768	26/06/2024 10:39	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4933768	26/06/2024 10:39	Free - Residual disinfectant	mg Cl/l	0.42	
V1358OUT	Slaughtneil SR Outlet	4933768	26/06/2024 10:39	Total - Residual disinfectant	mg Cl/l	0.55	
V1358OUT	Slaughtneil SR Outlet	4933768	26/06/2024 10:39	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4933766	26/06/2024 11:01	Colony Counts 22	CFU/1 ml	14	
V1354OUT	Knockoneill SR Outlet	4933766	26/06/2024 11:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4933766	26/06/2024 11:01	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4933766	26/06/2024 11:01	Free - Residual disinfectant	mg Cl/l	0.2	
V1354OUT	Knockoneill SR Outlet	4933766	26/06/2024 11:01	Total - Residual disinfectant	mg Cl/l	0.35	
V1354OUT	Knockoneill SR Outlet	4933766	26/06/2024 11:01	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4933766	26/06/2024 11:01	Odour	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4933766	26/06/2024 11:01	Odour - Nature		No odour	
V1354OUT	Knockoneill SR Outlet	4933766	26/06/2024 11:01	Taste	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4933766	26/06/2024 11:01	Taste - Nature		No taste	
V4719OUT	Glenchuil SR Outlet	4933765	26/06/2024 11:17	Colony Counts 22	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4933765	26/06/2024 11:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4933765	26/06/2024 11:17	E. coli	CFU/100 ml	0	0

V4719OUT	Glenchuil SR Outlet	4933765	26/06/2024 11:17	Free - Residual disinfectant	mg Cl/l	0.56	
V4719OUT	Glenchuil SR Outlet	4933765	26/06/2024 11:17	Total - Residual disinfectant	mg Cl/l	0.66	
V4719OUT	Glenchuil SR Outlet	4933765	26/06/2024 11:17	Total Coliforms	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4933775	26/06/2024 11:41	Colony Counts 22	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4933775	26/06/2024 11:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4933775	26/06/2024 11:41	E. coli	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4933775	26/06/2024 11:41	Free - Residual disinfectant	mg Cl/l	0.44	
V4530OUT	Dungoran SR Outlet	4933775	26/06/2024 11:41	Total - Residual disinfectant	mg Cl/l	0.6	
V4530OUT	Dungoran SR Outlet	4933775	26/06/2024 11:41	Total Coliforms	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4933767	26/06/2024 11:51	Colony Counts 22	CFU/1 ml	1	
V4535OUT	Lisnagardy SR Outlet	4933767	26/06/2024 11:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4933767	26/06/2024 11:51	E. coli	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4933767	26/06/2024 11:51	Free - Residual disinfectant	mg Cl/l	0.59	
V4535OUT	Lisnagardy SR Outlet	4933767	26/06/2024 11:51	Total - Residual disinfectant	mg Cl/l	0.65	
V4535OUT	Lisnagardy SR Outlet	4933767	26/06/2024 11:51	Total Coliforms	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4933926	27/06/2024 08:43	Colony Counts 22	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4933926	27/06/2024 08:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4933926	27/06/2024 08:43	E. coli	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4933926	27/06/2024 08:43	Free - Residual disinfectant	mg Cl/l	0.78	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4933926	27/06/2024 08:43	Total - Residual disinfectant	mg Cl/l	0.8	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4933926	27/06/2024 08:43	Total Coliforms	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4933289	27/06/2024 09:03	Colony Counts 22	CFU/1 ml	91	
V1711OUT	Sconce Hill SR Outlet	4933289	27/06/2024 09:03	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V1711OUT	Sconce Hill SR Outlet	4933289	27/06/2024 09:03	E. coli	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4933289	27/06/2024 09:03	Free - Residual disinfectant	mg Cl/l	0.57	
V1711OUT	Sconce Hill SR Outlet	4933289	27/06/2024 09:03	Total - Residual disinfectant	mg Cl/l	0.69	
V1711OUT	Sconce Hill SR Outlet	4933289	27/06/2024 09:03	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4933861	27/06/2024 09:03	Colony Counts 22	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4933861	27/06/2024 09:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4933861	27/06/2024 09:03	E. coli	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4933861	27/06/2024 09:03	Free - Residual disinfectant	mg Cl/l	0.86	
V2301OUT	Ballydougan Command SR Outlet	4933861	27/06/2024 09:03	Total - Residual disinfectant	mg Cl/l	0.94	
V2301OUT	Ballydougan Command SR Outlet	4933861	27/06/2024 09:03	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4933861	27/06/2024 09:03	Hydrogen Ion	pH value	7.6	9.5
V2301OUT	Ballydougan Command SR Outlet	4933861	27/06/2024 09:03	Odour	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4933861	27/06/2024 09:03	Odour - Nature		No odour	
V2301OUT	Ballydougan Command SR Outlet	4933861	27/06/2024 09:03	Taste	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4933861	27/06/2024 09:03	Taste - Nature		No taste	
V1348OUT	Moydamlaght Draperstown SR Outlet	4933938	27/06/2024 09:29	Colony Counts 22	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4933938	27/06/2024 09:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	

V1348OUT	Moydamlaght Draperstown SR Outlet	4933938	27/06/2024 09:29	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4933938	27/06/2024 09:29	Free - Residual disinfectant	mg Cl/l	0.11	
V1348OUT	Moydamlaght Draperstown SR Outlet	4933938	27/06/2024 09:29	Total - Residual disinfectant	mg Cl/l	0.15	
V1348OUT	Moydamlaght Draperstown SR Outlet	4933938	27/06/2024 09:29	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4933943	27/06/2024 09:58	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4933943	27/06/2024 09:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4933943	27/06/2024 09:58	E. coli	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4933943	27/06/2024 09:58	Free - Residual disinfectant	mg Cl/l	0.58	
V1356OUT	Mormeal SR Outlet	4933943	27/06/2024 09:58	Total - Residual disinfectant	mg Cl/l	0.77	
V1356OUT	Mormeal SR Outlet	4933943	27/06/2024 09:58	Total Coliforms	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4933915	27/06/2024 10:35	Colony Counts 22	CFU/1 ml	2	
V4540OUT	Radergan SR Outlet	4933915	27/06/2024 10:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4933915	27/06/2024 10:35	E. coli	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4933915	27/06/2024 10:35	Free - Residual disinfectant	mg Cl/l	0.61	
V4540OUT	Radergan SR Outlet	4933915	27/06/2024 10:35	Total - Residual disinfectant	mg Cl/l	0.69	
V4540OUT	Radergan SR Outlet	4933915	27/06/2024 10:35	Total Coliforms	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4933941	27/06/2024 10:49	Colony Counts 22	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4933941	27/06/2024 10:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4933941	27/06/2024 10:49	E. coli	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4933941	27/06/2024 10:49	Free - Residual disinfectant	mg Cl/l	0.65	
V4531OUT	Foremass SR Outlet	4933941	27/06/2024 10:49	Total - Residual disinfectant	mg Cl/l	0.77	
V4531OUT	Foremass SR Outlet	4933941	27/06/2024 10:49	Total Coliforms	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4933944	27/06/2024 11:04	Colony Counts 22	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4933944	27/06/2024 11:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4933944	27/06/2024 11:04	E. coli	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4933944	27/06/2024 11:04	Free - Residual disinfectant	mg Cl/l	0.73	
V4537OUT	Sixmilecross SR Outlet	4933944	27/06/2024 11:04	Total - Residual disinfectant	mg Cl/l	0.81	
V4537OUT	Sixmilecross SR Outlet	4933944	27/06/2024 11:04	Total Coliforms	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4933949	27/06/2024 11:22	Colony Counts 22	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4933949	27/06/2024 11:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4933949	27/06/2024 11:22	E. coli	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4933949	27/06/2024 11:22	Free - Residual disinfectant	mg Cl/l	0.67	
V4528OUT	Crocknabohil SR Outlet	4933949	27/06/2024 11:22	Total - Residual disinfectant	mg Cl/l	0.77	
V4528OUT	Crocknabohil SR Outlet	4933949	27/06/2024 11:22	Total Coliforms	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4933863	27/06/2024 11:30	Colony Counts 22	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4933863	27/06/2024 11:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4933863	27/06/2024 11:30	E. coli	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4933863	27/06/2024 11:30	Free - Residual disinfectant	mg Cl/l	0.4	
V2302OUT	Ballyhannon SR Outlet	4933863	27/06/2024 11:30	Total - Residual disinfectant	mg Cl/l	0.48	
V2302OUT	Ballyhannon SR Outlet	4933863	27/06/2024 11:30	Total Coliforms	CFU/100 ml	0	0

V1357OUT	Mullaghboy Magherafelt SR Outlet	4948183	27/06/2024 12:50	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4948183	27/06/2024 12:50	Free - Residual disinfectant	mg Cl/l	0.77	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4948183	27/06/2024 12:50	Total - Residual disinfectant	mg Cl/l	0.93	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4948183	27/06/2024 12:50	Total Coliforms	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4934067	28/06/2024 07:26	Colony Counts 22	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4934067	28/06/2024 07:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4934067	28/06/2024 07:26	E. coli	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4934067	28/06/2024 07:26	Free - Residual disinfectant	mg Cl/l	0.69	
V1702OUT	Cam SR Outlet	4934067	28/06/2024 07:26	Total - Residual disinfectant	mg Cl/l	0.81	
V1702OUT	Cam SR Outlet	4934067	28/06/2024 07:26	Total Coliforms	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4934065	28/06/2024 07:55	Colony Counts 22	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4934065	28/06/2024 07:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4934065	28/06/2024 07:55	E. coli	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4934065	28/06/2024 07:55	Free - Residual disinfectant	mg Cl/l	0.69	
V1706OUT	Killeague SR Outlet	4934065	28/06/2024 07:55	Total - Residual disinfectant	mg Cl/l	0.8	
V1706OUT	Killeague SR Outlet	4934065	28/06/2024 07:55	Total Coliforms	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4934073	28/06/2024 07:55	Colony Counts 22	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4934073	28/06/2024 07:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4934073	28/06/2024 07:55	E. coli	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4934073	28/06/2024 07:55	Free - Residual disinfectant	mg Cl/l	0.59	
V1351OUT	Cranny Moneymore SR Outlet	4934073	28/06/2024 07:55	Total - Residual disinfectant	mg Cl/l	0.69	
V1351OUT	Cranny Moneymore SR Outlet	4934073	28/06/2024 07:55	Total Coliforms	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4934068	28/06/2024 08:19	Colony Counts 22	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4934068	28/06/2024 08:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4934068	28/06/2024 08:19	E. coli	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4934068	28/06/2024 08:19	Free - Residual disinfectant	mg Cl/l	0.42	
V1708OUT	North Garvagh SR Outlet	4934068	28/06/2024 08:19	Total - Residual disinfectant	mg Cl/l	0.56	
V1708OUT	North Garvagh SR Outlet	4934068	28/06/2024 08:19	Total Coliforms	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4934061	28/06/2024 08:29	Colony Counts 22	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4934061	28/06/2024 08:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4934061	28/06/2024 08:29	E. coli	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4934061	28/06/2024 08:29	Free - Residual disinfectant	mg Cl/l	0.2	
V1352OUT	Cullion Desertmartin SR Outlet	4934061	28/06/2024 08:29	Total - Residual disinfectant	mg Cl/l	0.26	
V1352OUT	Cullion Desertmartin SR Outlet	4934061	28/06/2024 08:29	Total Coliforms	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4934072	28/06/2024 08:41	Colony Counts 22	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4934072	28/06/2024 08:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4934072	28/06/2024 08:41	E. coli	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4934072	28/06/2024 08:41	Free - Residual disinfectant	mg Cl/l	0.35	
V1713OUT	Trienaltenagh SR Outlet	4934072	28/06/2024 08:41	Total - Residual disinfectant	mg Cl/l	0.48	
V1713OUT	Trienaltenagh SR Outlet	4934072	28/06/2024 08:41	Total Coliforms	CFU/100 ml	0	0

V2508OUT	Carland SR Outlet	4934012	28/06/2024 08:47	Colony Counts 22	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4934012	28/06/2024 08:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4934012	28/06/2024 08:47	E. coli	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4934012	28/06/2024 08:47	Free - Residual disinfectant	mg Cl/l	1.02	
V2508OUT	Carland SR Outlet	4934012	28/06/2024 08:47	Total - Residual disinfectant	mg Cl/l	1.12	
V2508OUT	Carland SR Outlet	4934012	28/06/2024 08:47	Total Coliforms	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4934070	28/06/2024 08:49	Colony Counts 22	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4934070	28/06/2024 08:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4934070	28/06/2024 08:49	E. coli	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4934070	28/06/2024 08:49	Free - Residual disinfectant	mg Cl/l	0.61	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4934070	28/06/2024 08:49	Total - Residual disinfectant	mg Cl/l	0.82	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4934070	28/06/2024 08:49	Total Coliforms	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4934084	28/06/2024 08:57	Colony Counts 22	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4934084	28/06/2024 08:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4934084	28/06/2024 08:57	E. coli	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4934084	28/06/2024 08:57	Free - Residual disinfectant	mg Cl/l	0.74	
V1343OUT	Ballybriest SR Outlet	4934084	28/06/2024 08:57	Total - Residual disinfectant	mg Cl/l	0.75	
V1343OUT	Ballybriest SR Outlet	4934084	28/06/2024 08:57	Total Coliforms	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4934013	28/06/2024 09:07	Colony Counts 22	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4934013	28/06/2024 09:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4934013	28/06/2024 09:07	E. coli	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4934013	28/06/2024 09:07	Free - Residual disinfectant	mg Cl/l	0.63	
V2509OUT	Castlehill Drumcoo SR Outlet	4934013	28/06/2024 09:07	Total - Residual disinfectant	mg Cl/l	0.74	
V2509OUT	Castlehill Drumcoo SR Outlet	4934013	28/06/2024 09:07	Total Coliforms	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4934044	28/06/2024 09:26	Colony Counts 22	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4934044	28/06/2024 09:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4934044	28/06/2024 09:26	E. coli	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4934044	28/06/2024 09:26	Free - Residual disinfectant	mg Cl/l	0.91	
V2521OUT	Mullaghanagh SR Outlet	4934044	28/06/2024 09:26	Total - Residual disinfectant	mg Cl/l	1	
V2521OUT	Mullaghanagh SR Outlet	4934044	28/06/2024 09:26	Total Coliforms	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4934085	28/06/2024 09:32	Colony Counts 22	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4934085	28/06/2024 09:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4934085	28/06/2024 09:32	E. coli	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4934085	28/06/2024 09:32	Free - Residual disinfectant	mg Cl/l	0.97	
V4715OUT	Brookeborough High SR Outlet	4934085	28/06/2024 09:32	Total - Residual disinfectant	mg Cl/l	1.35	
V4715OUT	Brookeborough High SR Outlet	4934085	28/06/2024 09:32	Total Coliforms	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4934069	28/06/2024 10:01	Colony Counts 22	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4934069	28/06/2024 10:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4934069	28/06/2024 10:01	E. coli	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4934069	28/06/2024 10:01	Free - Residual disinfectant	mg Cl/l	0.64	

V4742OUT	Tattinbar SR Outlet	4934069	28/06/2024 10:01	Total - Residual disinfectant	mg Cl/l	0.86	
V4742OUT	Tattinbar SR Outlet	4934069	28/06/2024 10:01	Total Coliforms	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4934060	28/06/2024 10:07	Colony Counts 22	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4934060	28/06/2024 10:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4934060	28/06/2024 10:07	E. coli	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4934060	28/06/2024 10:07	Free - Residual disinfectant	mg Cl/l	0.65	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4934060	28/06/2024 10:07	Total - Residual disinfectant	mg Cl/l	0.78	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4934060	28/06/2024 10:07	Total Coliforms	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4934071	28/06/2024 10:29	Colony Counts 22	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4934071	28/06/2024 10:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4934071	28/06/2024 10:29	E. coli	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4934071	28/06/2024 10:29	Free - Residual disinfectant	mg Cl/l	0.74	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4934071	28/06/2024 10:29	Total - Residual disinfectant	mg Cl/l	0.83	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4934071	28/06/2024 10:29	Total Coliforms	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4936166	01/07/2024 07:34	Colony Counts 22	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4936166	01/07/2024 07:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4936166	01/07/2024 07:34	E. coli	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4936166	01/07/2024 07:34	Free - Residual disinfectant	mg Cl/l	0.63	
V1702OUT	Cam SR Outlet	4936166	01/07/2024 07:34	Total - Residual disinfectant	mg Cl/l	0.81	
V1702OUT	Cam SR Outlet	4936166	01/07/2024 07:34	Total Coliforms	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4936164	01/07/2024 08:01	Colony Counts 22	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4936164	01/07/2024 08:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4936164	01/07/2024 08:01	E. coli	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4936164	01/07/2024 08:01	Free - Residual disinfectant	mg Cl/l	0.44	
V1706OUT	Killeague SR Outlet	4936164	01/07/2024 08:01	Total - Residual disinfectant	mg Cl/l	0.58	
V1706OUT	Killeague SR Outlet	4936164	01/07/2024 08:01	Total Coliforms	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4936167	01/07/2024 08:27	Colony Counts 22	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4936167	01/07/2024 08:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4936167	01/07/2024 08:27	E. coli	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4936167	01/07/2024 08:27	Free - Residual disinfectant	mg Cl/l	0.35	
V1708OUT	North Garvagh SR Outlet	4936167	01/07/2024 08:27	Total - Residual disinfectant	mg Cl/l	0.5	
V1708OUT	North Garvagh SR Outlet	4936167	01/07/2024 08:27	Total Coliforms	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4936171	01/07/2024 08:57	Colony Counts 22	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4936171	01/07/2024 08:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4936171	01/07/2024 08:57	E. coli	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4936171	01/07/2024 08:57	Free - Residual disinfectant	mg Cl/l	0.32	
V1713OUT	Trienaltenagh SR Outlet	4936171	01/07/2024 08:57	Total - Residual disinfectant	mg Cl/l	0.41	
V1713OUT	Trienaltenagh SR Outlet	4936171	01/07/2024 08:57	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4936104	01/07/2024 08:58	Colony Counts 22	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4936104	01/07/2024 08:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	

V2508OUT	Carland SR Outlet	4936104	01/07/2024 08:58	E. coli	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4936104	01/07/2024 08:58	Free - Residual disinfectant	mg Cl/l	1.03	
V2508OUT	Carland SR Outlet	4936104	01/07/2024 08:58	Total - Residual disinfectant	mg Cl/l	1.15	
V2508OUT	Carland SR Outlet	4936104	01/07/2024 08:58	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4936104	01/07/2024 08:58	Odour	Diln No	0	0
V2508OUT	Carland SR Outlet	4936104	01/07/2024 08:58	Odour - Nature		No odour	
V2508OUT	Carland SR Outlet	4936104	01/07/2024 08:58	Taste	Diln No	0	0
V2508OUT	Carland SR Outlet	4936104	01/07/2024 08:58	Taste - Nature		No taste	
V2509OUT	Castlehill Drumcoo SR Outlet	4936105	01/07/2024 09:21	Colony Counts 22	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4936105	01/07/2024 09:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4936105	01/07/2024 09:21	E. coli	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4936105	01/07/2024 09:21	Free - Residual disinfectant	mg Cl/l	0.65	
V2509OUT	Castlehill Drumcoo SR Outlet	4936105	01/07/2024 09:21	Total - Residual disinfectant	mg Cl/l	0.76	
V2509OUT	Castlehill Drumcoo SR Outlet	4936105	01/07/2024 09:21	Total Coliforms	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4936169	01/07/2024 09:31	Colony Counts 22	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4936169	01/07/2024 09:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4936169	01/07/2024 09:31	E. coli	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4936169	01/07/2024 09:31	Free - Residual disinfectant	mg Cl/l	0.63	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4936169	01/07/2024 09:31	Total - Residual disinfectant	mg Cl/l	0.7	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4936169	01/07/2024 09:31	Total Coliforms	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4936145	01/07/2024 09:41	Colony Counts 22	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4936145	01/07/2024 09:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4936145	01/07/2024 09:41	E. coli	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4936145	01/07/2024 09:41	Free - Residual disinfectant	mg Cl/l	0.94	
V2521OUT	Mullaghanagh SR Outlet	4936145	01/07/2024 09:41	Total - Residual disinfectant	mg Cl/l	1.03	
V2521OUT	Mullaghanagh SR Outlet	4936145	01/07/2024 09:41	Total Coliforms	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4936184	01/07/2024 09:58	Colony Counts 22	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4936184	01/07/2024 09:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4936184	01/07/2024 09:58	E. coli	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4936184	01/07/2024 09:58	Free - Residual disinfectant	mg Cl/l	0.82	
V4715OUT	Brookeborough High SR Outlet	4936184	01/07/2024 09:58	Total - Residual disinfectant	mg Cl/l	0.96	
V4715OUT	Brookeborough High SR Outlet	4936184	01/07/2024 09:58	Total Coliforms	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4936159	01/07/2024 10:23	Colony Counts 22	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4936159	01/07/2024 10:23	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4936159	01/07/2024 10:23	E. coli	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4936159	01/07/2024 10:23	Free - Residual disinfectant	mg Cl/l	0.74	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4936159	01/07/2024 10:23	Total - Residual disinfectant	mg Cl/l	0.84	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4936159	01/07/2024 10:23	Total Coliforms	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4936168	01/07/2024 10:34	Colony Counts 22	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4936168	01/07/2024 10:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	

V4742OUT	Tattinbar SR Outlet	4936168	01/07/2024 10:34	E. coli	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4936168	01/07/2024 10:34	Free - Residual disinfectant	mg Cl/l	1.02	
V4742OUT	Tattinbar SR Outlet	4936168	01/07/2024 10:34	Total - Residual disinfectant	mg Cl/l	1.18	
V4742OUT	Tattinbar SR Outlet	4936168	01/07/2024 10:34	Total Coliforms	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4936170	01/07/2024 10:51	Colony Counts 22	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4936170	01/07/2024 10:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4936170	01/07/2024 10:51	E. coli	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4936170	01/07/2024 10:51	Free - Residual disinfectant	mg Cl/l	0.77	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4936170	01/07/2024 10:51	Total - Residual disinfectant	mg Cl/l	0.89	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4936170	01/07/2024 10:51	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4949073	01/07/2024 12:00	Enterococci	CFU/100ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4949073	01/07/2024 12:00	Free - Residual disinfectant	mg Cl/l	0.76	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4949073	01/07/2024 12:00	Total - Residual disinfectant	mg Cl/l	0.95	
V1711OUT	Sconce Hill SR Outlet	4936581	02/07/2024 07:22	Colony Counts 22	CFU/1 ml	0	
V1711OUT	Sconce Hill SR Outlet	4936581	02/07/2024 07:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1711OUT	Sconce Hill SR Outlet	4936581	02/07/2024 07:22	E. coli	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4936581	02/07/2024 07:22	Free - Residual disinfectant	mg Cl/l	0.4	
V1711OUT	Sconce Hill SR Outlet	4936581	02/07/2024 07:22	Total - Residual disinfectant	mg Cl/l	0.54	
V1711OUT	Sconce Hill SR Outlet	4936581	02/07/2024 07:22	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4936579	02/07/2024 07:47	Colony Counts 22	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4936579	02/07/2024 07:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4936579	02/07/2024 07:47	E. coli	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4936579	02/07/2024 07:47	Free - Residual disinfectant	mg Cl/l	0.48	
V1704OUT	Castlerock Downhill SR Outlet	4936579	02/07/2024 07:47	Total - Residual disinfectant	mg Cl/l	0.64	
V1704OUT	Castlerock Downhill SR Outlet	4936579	02/07/2024 07:47	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4936579	02/07/2024 07:47	Odour	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4936579	02/07/2024 07:47	Odour - Nature		No odour	
V1704OUT	Castlerock Downhill SR Outlet	4936579	02/07/2024 07:47	Taste	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4936579	02/07/2024 07:47	Taste - Nature		No taste	
V1351OUT	Cranny Moneymore SR Outlet	4936172	02/07/2024 09:00	Colony Counts 22	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4936172	02/07/2024 09:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4936172	02/07/2024 09:00	E. coli	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4936172	02/07/2024 09:00	Free - Residual disinfectant	mg Cl/l	0.85	
V1351OUT	Cranny Moneymore SR Outlet	4936172	02/07/2024 09:00	Total - Residual disinfectant	mg Cl/l	0.89	
V1351OUT	Cranny Moneymore SR Outlet	4936172	02/07/2024 09:00	Total Coliforms	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4936545	02/07/2024 09:05	Colony Counts 22	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4936545	02/07/2024 09:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4936545	02/07/2024 09:05	E. coli	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4936545	02/07/2024 09:05	Free - Residual disinfectant	mg Cl/l	0.94	
V2511OUT	Corran Armagh SR Outlet	4936545	02/07/2024 09:05	Total - Residual disinfectant	mg Cl/l	1.05	

V2511OUT	Corran Armagh SR Outlet	4936545	02/07/2024 09:05	Total Coliforms	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4936589	02/07/2024 09:16	Colony Counts 22	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4936589	02/07/2024 09:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4936589	02/07/2024 09:16	E. coli	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4936589	02/07/2024 09:16	Free - Residual disinfectant	mg Cl/l	0.33	
V1338OUT	Coagh SR Outlet	4936589	02/07/2024 09:16	Total - Residual disinfectant	mg Cl/l	0.42	
V1338OUT	Coagh SR Outlet	4936589	02/07/2024 09:16	Total Coliforms	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4936160	02/07/2024 09:26	Colony Counts 22	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4936160	02/07/2024 09:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4936160	02/07/2024 09:26	E. coli	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4936160	02/07/2024 09:26	Free - Residual disinfectant	mg Cl/l	0.23	
V1352OUT	Cullion Desertmartin SR Outlet	4936160	02/07/2024 09:26	Total - Residual disinfectant	mg Cl/l	0.25	
V1352OUT	Cullion Desertmartin SR Outlet	4936160	02/07/2024 09:26	Total Coliforms	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4936588	02/07/2024 09:33	Colony Counts 22	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4936588	02/07/2024 09:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4936588	02/07/2024 09:33	E. coli	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4936588	02/07/2024 09:33	Free - Residual disinfectant	mg Cl/l	0.83	
V1335OUT	Brigh Quarry SR Outlet	4936588	02/07/2024 09:33	Total - Residual disinfectant	mg Cl/l	0.87	
V1335OUT	Brigh Quarry SR Outlet	4936588	02/07/2024 09:33	Total Coliforms	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4936544	02/07/2024 09:39	Colony Counts 22	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4936544	02/07/2024 09:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4936544	02/07/2024 09:39	E. coli	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4936544	02/07/2024 09:39	Free - Residual disinfectant	mg Cl/l	0.58	
V2510OUT	Calone SR Outlet	4936544	02/07/2024 09:39	Total - Residual disinfectant	mg Cl/l	0.73	
V2510OUT	Calone SR Outlet	4936544	02/07/2024 09:39	Total Coliforms	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4936592	02/07/2024 09:49	Colony Counts 22	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4936592	02/07/2024 09:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4936592	02/07/2024 09:49	E. coli	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4936592	02/07/2024 09:49	Free - Residual disinfectant	mg Cl/l	0.68	
V1342OUT	Dromore High SR Outlet	4936592	02/07/2024 09:49	Total - Residual disinfectant	mg Cl/l	0.74	
V1342OUT	Dromore High SR Outlet	4936592	02/07/2024 09:49	Total Coliforms	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4936183	02/07/2024 09:55	Colony Counts 22	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4936183	02/07/2024 09:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4936183	02/07/2024 09:55	E. coli	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4936183	02/07/2024 09:55	Free - Residual disinfectant	mg Cl/l	0.89	
V1343OUT	Ballybriest SR Outlet	4936183	02/07/2024 09:55	Total - Residual disinfectant	mg Cl/l	0.95	
V1343OUT	Ballybriest SR Outlet	4936183	02/07/2024 09:55	Total Coliforms	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4936556	02/07/2024 09:59	Colony Counts 22	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4936556	02/07/2024 09:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4936556	02/07/2024 09:59	E. coli	CFU/100 ml	0	0

V2514OUT	Edenaveys Command SR Outlet	4936556	02/07/2024 09:59	Free - Residual disinfectant	mg Cl/l	0.74	
V2514OUT	Edenaveys Command SR Outlet	4936556	02/07/2024 09:59	Total - Residual disinfectant	mg Cl/l	0.94	
V2514OUT	Edenaveys Command SR Outlet	4936556	02/07/2024 09:59	Total Coliforms	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4936558	02/07/2024 10:22	Colony Counts 22	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4936558	02/07/2024 10:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4936558	02/07/2024 10:22	E. coli	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4936558	02/07/2024 10:22	Free - Residual disinfectant	mg Cl/l	0.89	
V2518OUT	Lisnastrane SR Outlet	4936558	02/07/2024 10:22	Total - Residual disinfectant	mg Cl/l	0.94	
V2518OUT	Lisnastrane SR Outlet	4936558	02/07/2024 10:22	Total Coliforms	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4936541	02/07/2024 10:25	Colony Counts 22	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4936541	02/07/2024 10:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4936541	02/07/2024 10:25	E. coli	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4936541	02/07/2024 10:25	Free - Residual disinfectant	mg Cl/l	0.92	
V2523OUT	Rough Fort SR Outlet	4936541	02/07/2024 10:25	Total - Residual disinfectant	mg Cl/l	1.02	
V2523OUT	Rough Fort SR Outlet	4936541	02/07/2024 10:25	Total Coliforms	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4936593	02/07/2024 10:57	Colony Counts 22	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4936593	02/07/2024 10:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4936593	02/07/2024 10:57	E. coli	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4936593	02/07/2024 10:57	Free - Residual disinfectant	mg Cl/l	0.66	
V4712OUT	Corranny SR Outlet	4936593	02/07/2024 10:57	Total - Residual disinfectant	mg Cl/l	0.75	
V4712OUT	Corranny SR Outlet	4936593	02/07/2024 10:57	Total Coliforms	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4936585	02/07/2024 11:04	Colony Counts 22	CFU/1 ml	1	
V4533OUT	Inisclan SR Outlet	4936585	02/07/2024 11:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4936585	02/07/2024 11:04	E. coli	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4936585	02/07/2024 11:04	Free - Residual disinfectant	mg Cl/l	0.66	
V4533OUT	Inisclan SR Outlet	4936585	02/07/2024 11:04	Total - Residual disinfectant	mg Cl/l	0.74	
V4533OUT	Inisclan SR Outlet	4936585	02/07/2024 11:04	Total Coliforms	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4936596	02/07/2024 11:09	Colony Counts 22	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4936596	02/07/2024 11:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4936596	02/07/2024 11:09	E. coli	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4936596	02/07/2024 11:09	Free - Residual disinfectant	mg Cl/l	0.61	
V4713OUT	Knocknalosset SR Outlet	4936596	02/07/2024 11:09	Total - Residual disinfectant	mg Cl/l	0.7	
V4713OUT	Knocknalosset SR Outlet	4936596	02/07/2024 11:09	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4936794	03/07/2024 08:12	Colony Counts 22	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4936794	03/07/2024 08:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4936794	03/07/2024 08:12	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4936794	03/07/2024 08:12	Free - Residual disinfectant	mg Cl/l	0.49	
V1360OUT	Windmill Hill SR Outlet	4936794	03/07/2024 08:12	Total - Residual disinfectant	mg Cl/l	0.66	
V1360OUT	Windmill Hill SR Outlet	4936794	03/07/2024 08:12	Total Coliforms	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4936809	03/07/2024 08:35	Colony Counts 22	CFU/1 ml	0	

V1344OUT	Craigs Cookstown SR Outlet	4936809	03/07/2024 08:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4936809	03/07/2024 08:35	E. coli	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4936809	03/07/2024 08:35	Free - Residual disinfectant	mg Cl/l	0.51	
V1344OUT	Craigs Cookstown SR Outlet	4936809	03/07/2024 08:35	Total - Residual disinfectant	mg Cl/l	0.55	
V1344OUT	Craigs Cookstown SR Outlet	4936809	03/07/2024 08:35	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4936805	03/07/2024 08:39	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4936805	03/07/2024 08:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4936805	03/07/2024 08:39	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4936805	03/07/2024 08:39	Free - Residual disinfectant	mg Cl/l	0.79	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4936805	03/07/2024 08:39	Total - Residual disinfectant	mg Cl/l	0.98	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4936805	03/07/2024 08:39	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4936805	03/07/2024 08:39	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4936805	03/07/2024 08:39	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4936805	03/07/2024 08:39	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4936805	03/07/2024 08:39	Taste - Nature		No taste	
V1362OUT	Unagh SR Outlet	4936795	03/07/2024 08:52	Colony Counts 22	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4936795	03/07/2024 08:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4936795	03/07/2024 08:52	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4936795	03/07/2024 08:52	Free - Residual disinfectant	mg Cl/l	0.48	
V1362OUT	Unagh SR Outlet	4936795	03/07/2024 08:52	Total - Residual disinfectant	mg Cl/l	0.53	
V1362OUT	Unagh SR Outlet	4936795	03/07/2024 08:52	Total Coliforms	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4936806	03/07/2024 09:21	Colony Counts 22	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4936806	03/07/2024 09:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4936806	03/07/2024 09:21	E. coli	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4936806	03/07/2024 09:21	Free - Residual disinfectant	mg Cl/l	0.7	
V1339OUT	Corvanaghan High SR Outlet	4936806	03/07/2024 09:21	Total - Residual disinfectant	mg Cl/l	0.76	
V1339OUT	Corvanaghan High SR Outlet	4936806	03/07/2024 09:21	Total Coliforms	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4936775	03/07/2024 09:37	Colony Counts 22	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4936775	03/07/2024 09:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4936775	03/07/2024 09:37	E. coli	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4936775	03/07/2024 09:37	Free - Residual disinfectant	mg Cl/l	0.64	
V4539OUT	Erganagh SR Outlet	4936775	03/07/2024 09:37	Total - Residual disinfectant	mg Cl/l	0.71	
V4539OUT	Erganagh SR Outlet	4936775	03/07/2024 09:37	Total Coliforms	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4936810	03/07/2024 09:41	Colony Counts 22	CFU/1 ml	5	
V1346OUT	Gortaclady Evishanoran SR Outlet	4936810	03/07/2024 09:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4936810	03/07/2024 09:41	E. coli	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4936810	03/07/2024 09:41	Free - Residual disinfectant	mg Cl/l	0.73	
V1346OUT	Gortaclady Evishanoran SR Outlet	4936810	03/07/2024 09:41	Total - Residual disinfectant	mg Cl/l	0.78	
V1346OUT	Gortaclady Evishanoran SR Outlet	4936810	03/07/2024 09:41	Total Coliforms	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4936773	03/07/2024 09:58	Colony Counts 22	CFU/1 ml	0	

V4538OUT	Killyclogher SR Outlet	4936773	03/07/2024 09:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4936773	03/07/2024 09:58	E. coli	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4936773	03/07/2024 09:58	Free - Residual disinfectant	mg Cl/l	0.64	
V4538OUT	Killyclogher SR Outlet	4936773	03/07/2024 09:58	Total - Residual disinfectant	mg Cl/l	0.76	
V4538OUT	Killyclogher SR Outlet	4936773	03/07/2024 09:58	Total Coliforms	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4936807	03/07/2024 10:00	Colony Counts 22	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4936807	03/07/2024 10:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4936807	03/07/2024 10:00	E. coli	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4936807	03/07/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.65	
V1340OUT	Craigballyharkey SR Outlet	4936807	03/07/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.71	
V1340OUT	Craigballyharkey SR Outlet	4936807	03/07/2024 10:00	Total Coliforms	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4936782	03/07/2024 10:36	Colony Counts 22	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4936782	03/07/2024 10:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4936782	03/07/2024 10:36	E. coli	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4936782	03/07/2024 10:36	Free - Residual disinfectant	mg Cl/l	0.77	
V4536OUT	Lough Macrory North SR Outlet	4936782	03/07/2024 10:36	Total - Residual disinfectant	mg Cl/l	0.85	
V4536OUT	Lough Macrory North SR Outlet	4936782	03/07/2024 10:36	Total Coliforms	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4936770	03/07/2024 10:57	Colony Counts 22	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4936770	03/07/2024 10:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4936770	03/07/2024 10:57	E. coli	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4936770	03/07/2024 10:57	Free - Residual disinfectant	mg Cl/l	0.7	
V4526OUT	Black Lough Pomeroy SR Outlet	4936770	03/07/2024 10:57	Total - Residual disinfectant	mg Cl/l	0.8	
V4526OUT	Black Lough Pomeroy SR Outlet	4936770	03/07/2024 10:57	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4936801	03/07/2024 11:16	Colony Counts 22	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4936801	03/07/2024 11:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4936801	03/07/2024 11:16	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4936801	03/07/2024 11:16	Free - Residual disinfectant	mg Cl/l	0.08	
V1350OUT	Carnaman SR Outlet	4936801	03/07/2024 11:16	Total - Residual disinfectant	mg Cl/l	0.25	
V1350OUT	Carnaman SR Outlet	4936801	03/07/2024 11:16	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4936801	03/07/2024 11:16	Odour	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4936801	03/07/2024 11:16	Odour - Nature		No odour	
V1350OUT	Carnaman SR Outlet	4936801	03/07/2024 11:16	Taste	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4936801	03/07/2024 11:16	Taste - Nature		No taste	
V1715OUT	Ballystrone (Calvins) SR Outlet	4936971	04/07/2024 07:25	Colony Counts 22	CFU/1 ml	1	
V1715OUT	Ballystrone (Calvins) SR Outlet	4936971	04/07/2024 07:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4936971	04/07/2024 07:25	E. coli	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4936971	04/07/2024 07:25	Free - Residual disinfectant	mg Cl/l	0.6	
V1715OUT	Ballystrone (Calvins) SR Outlet	4936971	04/07/2024 07:25	Total - Residual disinfectant	mg Cl/l	0.71	
V1715OUT	Ballystrone (Calvins) SR Outlet	4936971	04/07/2024 07:25	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4936934	04/07/2024 08:00	Colony Counts 22	CFU/1 ml	0	

V1725OUT	Glenlough SR Outlet	4936934	04/07/2024 08:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4936934	04/07/2024 08:00	E. coli	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4936934	04/07/2024 08:00	Free - Residual disinfectant	mg Cl/l	0.22	
V1725OUT	Glenlough SR Outlet	4936934	04/07/2024 08:00	Total - Residual disinfectant	mg Cl/l	0.33	
V1725OUT	Glenlough SR Outlet	4936934	04/07/2024 08:00	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4936934	04/07/2024 08:00	Odour	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4936934	04/07/2024 08:00	Odour - Nature		No odour	
V1725OUT	Glenlough SR Outlet	4936934	04/07/2024 08:00	Taste	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4936934	04/07/2024 08:00	Taste - Nature		No taste	
V4527OUT	Carryglass SR Outlet	4936946	04/07/2024 08:33	Colony Counts 22	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4936946	04/07/2024 08:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4936946	04/07/2024 08:33	E. coli	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4936946	04/07/2024 08:33	Free - Residual disinfectant	mg Cl/l	0.51	
V4527OUT	Carryglass SR Outlet	4936946	04/07/2024 08:33	Total - Residual disinfectant	mg Cl/l	0.59	
V4527OUT	Carryglass SR Outlet	4936946	04/07/2024 08:33	Total Coliforms	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4936979	04/07/2024 09:01	Colony Counts 22	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4936979	04/07/2024 09:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4936979	04/07/2024 09:01	E. coli	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4936979	04/07/2024 09:01	Free - Residual disinfectant	mg Cl/l	0.52	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4936979	04/07/2024 09:01	Total - Residual disinfectant	mg Cl/l	0.61	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4936979	04/07/2024 09:01	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4936968	04/07/2024 09:13	Colony Counts 22	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4936968	04/07/2024 09:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4936968	04/07/2024 09:13	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4936968	04/07/2024 09:13	Free - Residual disinfectant	mg Cl/l	0.41	
V1349OUT	Ballyknock Magherafelt SR Outlet	4936968	04/07/2024 09:13	Total - Residual disinfectant	mg Cl/l	0.56	
V1349OUT	Ballyknock Magherafelt SR Outlet	4936968	04/07/2024 09:13	Total Coliforms	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4936942	04/07/2024 09:21	Colony Counts 22	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4936942	04/07/2024 09:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4936942	04/07/2024 09:21	E. coli	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4936942	04/07/2024 09:21	Free - Residual disinfectant	mg Cl/l	0.87	
V4707OUT	Sidaire SR Outlet	4936942	04/07/2024 09:21	Total - Residual disinfectant	mg Cl/l	1.12	
V4707OUT	Sidaire SR Outlet	4936942	04/07/2024 09:21	Total Coliforms	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4936950	04/07/2024 09:27	Colony Counts 22	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4936950	04/07/2024 09:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4936950	04/07/2024 09:27	E. coli	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4936950	04/07/2024 09:27	Free - Residual disinfectant	mg Cl/l	0.84	
V2501OUT	Altmore River SR Outlet	4936950	04/07/2024 09:27	Total - Residual disinfectant	mg Cl/l	0.92	
V2501OUT	Altmore River SR Outlet	4936950	04/07/2024 09:27	Total Coliforms	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4936926	04/07/2024 09:42	Colony Counts 22	CFU/1 ml	0	

V2507OUT	Cappagh SR Outlet	4936926	04/07/2024 09:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4936926	04/07/2024 09:42	E. coli	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4936926	04/07/2024 09:42	Free - Residual disinfectant	mg Cl/l	0.76	
V2507OUT	Cappagh SR Outlet	4936926	04/07/2024 09:42	Total - Residual disinfectant	mg Cl/l	0.85	
V2507OUT	Cappagh SR Outlet	4936926	04/07/2024 09:42	Total Coliforms	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4936976	04/07/2024 09:44	Colony Counts 22	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4936976	04/07/2024 09:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4936976	04/07/2024 09:44	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4936976	04/07/2024 09:44	Free - Residual disinfectant	mg Cl/l	0.51	
V1358OUT	Slaughtneil SR Outlet	4936976	04/07/2024 09:44	Total - Residual disinfectant	mg Cl/l	0.63	
V1358OUT	Slaughtneil SR Outlet	4936976	04/07/2024 09:44	Total Coliforms	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4936983	04/07/2024 09:46	Colony Counts 22	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4936983	04/07/2024 09:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4936983	04/07/2024 09:46	E. coli	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4936983	04/07/2024 09:46	Free - Residual disinfectant	mg Cl/l	0.46	
V4530OUT	Dungoran SR Outlet	4936983	04/07/2024 09:46	Total - Residual disinfectant	mg Cl/l	0.56	
V4530OUT	Dungoran SR Outlet	4936983	04/07/2024 09:46	Total Coliforms	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4936975	04/07/2024 09:56	Colony Counts 22	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4936975	04/07/2024 09:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4936975	04/07/2024 09:56	E. coli	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4936975	04/07/2024 09:56	Free - Residual disinfectant	mg Cl/l	0.6	
V4535OUT	Lisnagardy SR Outlet	4936975	04/07/2024 09:56	Total - Residual disinfectant	mg Cl/l	0.71	
V4535OUT	Lisnagardy SR Outlet	4936975	04/07/2024 09:56	Total Coliforms	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4936925	04/07/2024 10:13	Colony Counts 22	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4936925	04/07/2024 10:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4936925	04/07/2024 10:13	E. coli	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4936925	04/07/2024 10:13	Free - Residual disinfectant	mg Cl/l	0.66	
V2505OUT	Cabragh Fasglashagh SR Outlet	4936925	04/07/2024 10:13	Total - Residual disinfectant	mg Cl/l	0.78	
V2505OUT	Cabragh Fasglashagh SR Outlet	4936925	04/07/2024 10:13	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4936974	04/07/2024 10:19	Colony Counts 22	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4936974	04/07/2024 10:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4936974	04/07/2024 10:19	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4936974	04/07/2024 10:19	Free - Residual disinfectant	mg Cl/l	0.14	
V1354OUT	Knockoneill SR Outlet	4936974	04/07/2024 10:19	Total - Residual disinfectant	mg Cl/l	0.33	
V1354OUT	Knockoneill SR Outlet	4936974	04/07/2024 10:19	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4936974	04/07/2024 10:19	Odour	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4936974	04/07/2024 10:19	Odour - Nature		No odour	
V1354OUT	Knockoneill SR Outlet	4936974	04/07/2024 10:19	Taste	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4936974	04/07/2024 10:19	Taste - Nature		No taste	
V4719OUT	Glenchuil SR Outlet	4936973	04/07/2024 10:21	Colony Counts 22	CFU/1 ml	0	

V4719OUT	Glenchuil SR Outlet	4936973	04/07/2024 10:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4936973	04/07/2024 10:21	E. coli	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4936973	04/07/2024 10:21	Free - Residual disinfectant	mg Cl/l	0.35	
V4719OUT	Glenchuil SR Outlet	4936973	04/07/2024 10:21	Total - Residual disinfectant	mg Cl/l	0.44	
V4719OUT	Glenchuil SR Outlet	4936973	04/07/2024 10:21	Total Coliforms	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4936980	04/07/2024 11:49	Colony Counts 22	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4936980	04/07/2024 11:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4936980	04/07/2024 11:49	E. coli	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4936980	04/07/2024 11:49	Free - Residual disinfectant	mg Cl/l	1.22	
V4708OUT	Cavanacross Enniskillen SR Outlet	4936980	04/07/2024 11:49	Total - Residual disinfectant	mg Cl/l	1.4	
V4708OUT	Cavanacross Enniskillen SR Outlet	4936980	04/07/2024 11:49	Total Coliforms	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4937126	05/07/2024 08:37	Colony Counts 22	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4937126	05/07/2024 08:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4937126	05/07/2024 08:37	E. coli	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4937126	05/07/2024 08:37	Free - Residual disinfectant	mg Cl/l	0.92	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4937126	05/07/2024 08:37	Total - Residual disinfectant	mg Cl/l	1.04	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4937126	05/07/2024 08:37	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4937138	05/07/2024 09:22	Colony Counts 22	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4937138	05/07/2024 09:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4937138	05/07/2024 09:22	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4937138	05/07/2024 09:22	Free - Residual disinfectant	mg Cl/l	0.08	
V1348OUT	Moydamlaght Draperstown SR Outlet	4937138	05/07/2024 09:22	Total - Residual disinfectant	mg Cl/l	0.26	
V1348OUT	Moydamlaght Draperstown SR Outlet	4937138	05/07/2024 09:22	Total Coliforms	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4937115	05/07/2024 09:27	Colony Counts 22	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4937115	05/07/2024 09:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4937115	05/07/2024 09:27	E. coli	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4937115	05/07/2024 09:27	Free - Residual disinfectant	mg Cl/l	0.56	
V4540OUT	Radergan SR Outlet	4937115	05/07/2024 09:27	Total - Residual disinfectant	mg Cl/l	0.64	
V4540OUT	Radergan SR Outlet	4937115	05/07/2024 09:27	Total Coliforms	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4937141	05/07/2024 09:43	Colony Counts 22	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4937141	05/07/2024 09:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4937141	05/07/2024 09:43	E. coli	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4937141	05/07/2024 09:43	Free - Residual disinfectant	mg Cl/l	0.63	
V4531OUT	Foremass SR Outlet	4937141	05/07/2024 09:43	Total - Residual disinfectant	mg Cl/l	0.7	
V4531OUT	Foremass SR Outlet	4937141	05/07/2024 09:43	Total Coliforms	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4937144	05/07/2024 09:56	Colony Counts 22	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4937144	05/07/2024 09:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4937144	05/07/2024 09:56	E. coli	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4937144	05/07/2024 09:56	Free - Residual disinfectant	mg Cl/l	0.77	
V4537OUT	Sixmilecross SR Outlet	4937144	05/07/2024 09:56	Total - Residual disinfectant	mg Cl/l	0.9	

V4537OUT	Sixmilecross SR Outlet	4937144	05/07/2024 09:56	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4937143	05/07/2024 10:04	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4937143	05/07/2024 10:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4937143	05/07/2024 10:04	E. coli	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4937143	05/07/2024 10:04	Free - Residual disinfectant	mg Cl/l	0.58	
V1356OUT	Mormeal SR Outlet	4937143	05/07/2024 10:04	Total - Residual disinfectant	mg Cl/l	0.71	
V1356OUT	Mormeal SR Outlet	4937143	05/07/2024 10:04	Total Coliforms	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4937149	05/07/2024 10:11	Colony Counts 22	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4937149	05/07/2024 10:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4937149	05/07/2024 10:11	E. coli	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4937149	05/07/2024 10:11	Free - Residual disinfectant	mg Cl/l	0.71	
V4528OUT	Crocknabohil SR Outlet	4937149	05/07/2024 10:11	Total - Residual disinfectant	mg Cl/l	0.88	
V4528OUT	Crocknabohil SR Outlet	4937149	05/07/2024 10:11	Total Coliforms	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4937100	05/07/2024 10:38	Colony Counts 22	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4937100	05/07/2024 10:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4937100	05/07/2024 10:38	E. coli	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4937100	05/07/2024 10:38	Free - Residual disinfectant	mg Cl/l	0.73	
V2302OUT	Ballyhannon SR Outlet	4937100	05/07/2024 10:38	Total - Residual disinfectant	mg Cl/l	0.85	
V2302OUT	Ballyhannon SR Outlet	4937100	05/07/2024 10:38	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4937098	05/07/2024 10:59	Colony Counts 22	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4937098	05/07/2024 10:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4937098	05/07/2024 10:59	E. coli	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4937098	05/07/2024 10:59	Free - Residual disinfectant	mg Cl/l	0.72	
V2301OUT	Ballydougan Command SR Outlet	4937098	05/07/2024 10:59	Total - Residual disinfectant	mg Cl/l	0.85	
V2301OUT	Ballydougan Command SR Outlet	4937098	05/07/2024 10:59	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4939539	08/07/2024 08:02	Colony Counts 22	CFU/1 ml	86	
V1349OUT	Ballyknock Magherafelt SR Outlet	4939539	08/07/2024 08:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4939539	08/07/2024 08:02	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4939539	08/07/2024 08:02	Free - Residual disinfectant	mg Cl/l	0.65	
V1349OUT	Ballyknock Magherafelt SR Outlet	4939539	08/07/2024 08:02	Total - Residual disinfectant	mg Cl/l	0.83	
V1349OUT	Ballyknock Magherafelt SR Outlet	4939539	08/07/2024 08:02	Total Coliforms	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4939359	08/07/2024 08:20	Colony Counts 22	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4939359	08/07/2024 08:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4939359	08/07/2024 08:20	E. coli	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4939359	08/07/2024 08:20	Free - Residual disinfectant	mg Cl/l	0.84	
V4540OUT	Radergan SR Outlet	4939359	08/07/2024 08:20	Total - Residual disinfectant	mg Cl/l	0.94	
V4540OUT	Radergan SR Outlet	4939359	08/07/2024 08:20	Total Coliforms	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4939541	08/07/2024 08:23	Colony Counts 22	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4939541	08/07/2024 08:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4939541	08/07/2024 08:23	E. coli	CFU/100 ml	0	0

V1358OUT	Slaughtneil SR Outlet	4939541	08/07/2024 08:23	Free - Residual disinfectant	mg Cl/l	0.66	
V1358OUT	Slaughtneil SR Outlet	4939541	08/07/2024 08:23	Total - Residual disinfectant	mg Cl/l	0.77	
V1358OUT	Slaughtneil SR Outlet	4939541	08/07/2024 08:23	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4939540	08/07/2024 08:41	Colony Counts 22	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4939540	08/07/2024 08:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4939540	08/07/2024 08:41	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4939540	08/07/2024 08:41	Free - Residual disinfectant	mg Cl/l	0.38	
V1354OUT	Knockoneill SR Outlet	4939540	08/07/2024 08:41	Total - Residual disinfectant	mg Cl/l	0.44	
V1354OUT	Knockoneill SR Outlet	4939540	08/07/2024 08:41	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4939540	08/07/2024 08:41	Odour	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4939540	08/07/2024 08:41	Odour - Nature		No odour	
V1354OUT	Knockoneill SR Outlet	4939540	08/07/2024 08:41	Taste	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4939540	08/07/2024 08:41	Taste - Nature		No taste	
V4537OUT	Sixmilecross SR Outlet	4939386	08/07/2024 08:47	Colony Counts 22	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4939386	08/07/2024 08:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4939386	08/07/2024 08:47	E. coli	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4939386	08/07/2024 08:47	Free - Residual disinfectant	mg Cl/l	0.98	
V4537OUT	Sixmilecross SR Outlet	4939386	08/07/2024 08:47	Total - Residual disinfectant	mg Cl/l	1.11	
V4537OUT	Sixmilecross SR Outlet	4939386	08/07/2024 08:47	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4939380	08/07/2024 09:20	Colony Counts 22	CFU/1 ml	1	
V1348OUT	Moydamlaght Draperstown SR Outlet	4939380	08/07/2024 09:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4939380	08/07/2024 09:20	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4939380	08/07/2024 09:20	Free - Residual disinfectant	mg Cl/l	0.3	
V1348OUT	Moydamlaght Draperstown SR Outlet	4939380	08/07/2024 09:20	Total - Residual disinfectant	mg Cl/l	0.35	
V1348OUT	Moydamlaght Draperstown SR Outlet	4939380	08/07/2024 09:20	Total Coliforms	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4939383	08/07/2024 09:35	Colony Counts 22	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4939383	08/07/2024 09:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4939383	08/07/2024 09:35	E. coli	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4939383	08/07/2024 09:35	Free - Residual disinfectant	mg Cl/l	0.84	
V4531OUT	Foremass SR Outlet	4939383	08/07/2024 09:35	Total - Residual disinfectant	mg Cl/l	0.98	
V4531OUT	Foremass SR Outlet	4939383	08/07/2024 09:35	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4939385	08/07/2024 09:36	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4939385	08/07/2024 09:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4939385	08/07/2024 09:36	E. coli	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4939385	08/07/2024 09:36	Free - Residual disinfectant	mg Cl/l	0.36	
V1356OUT	Mormeal SR Outlet	4939385	08/07/2024 09:36	Total - Residual disinfectant	mg Cl/l	0.38	
V1356OUT	Mormeal SR Outlet	4939385	08/07/2024 09:36	Total Coliforms	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4939368	08/07/2024 10:00	Colony Counts 22	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4939368	08/07/2024 10:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4939368	08/07/2024 10:00	E. coli	CFU/100 ml	0	0

V1365OUT	Lough Fea North (Blacks) SR Outlet	4939368	08/07/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.69	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4939368	08/07/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.75	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4939368	08/07/2024 10:00	Total Coliforms	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4939391	08/07/2024 10:14	Colony Counts 22	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4939391	08/07/2024 10:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4939391	08/07/2024 10:14	E. coli	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4939391	08/07/2024 10:14	Free - Residual disinfectant	mg Cl/l	0.7	
V4528OUT	Crocknabohil SR Outlet	4939391	08/07/2024 10:14	Total - Residual disinfectant	mg Cl/l	0.82	
V4528OUT	Crocknabohil SR Outlet	4939391	08/07/2024 10:14	Total Coliforms	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4939348	08/07/2024 10:18	Colony Counts 22	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4939348	08/07/2024 10:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4939348	08/07/2024 10:18	E. coli	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4939348	08/07/2024 10:18	Free - Residual disinfectant	mg Cl/l	0.76	
V2302OUT	Ballyhannon SR Outlet	4939348	08/07/2024 10:18	Total - Residual disinfectant	mg Cl/l	0.88	
V2302OUT	Ballyhannon SR Outlet	4939348	08/07/2024 10:18	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4939346	08/07/2024 10:33	Colony Counts 22	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4939346	08/07/2024 10:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4939346	08/07/2024 10:33	E. coli	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4939346	08/07/2024 10:33	Free - Residual disinfectant	mg Cl/l	0.88	
V2301OUT	Ballydougan Command SR Outlet	4939346	08/07/2024 10:33	Total - Residual disinfectant	mg Cl/l	0.96	
V2301OUT	Ballydougan Command SR Outlet	4939346	08/07/2024 10:33	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4939346	08/07/2024 10:33	Odour	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4939346	08/07/2024 10:33	Odour - Nature		No odour	
V2301OUT	Ballydougan Command SR Outlet	4939346	08/07/2024 10:33	Taste	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4939346	08/07/2024 10:33	Taste - Nature		No taste	
V1352OUT	Cullion Desertmartin SR Outlet	4939774	09/07/2024 07:53	Colony Counts 22	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4939774	09/07/2024 07:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4939774	09/07/2024 07:53	E. coli	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4939774	09/07/2024 07:53	Free - Residual disinfectant	mg Cl/l	0.2	
V1352OUT	Cullion Desertmartin SR Outlet	4939774	09/07/2024 07:53	Total - Residual disinfectant	mg Cl/l	0.24	
V1352OUT	Cullion Desertmartin SR Outlet	4939774	09/07/2024 07:53	Total Coliforms	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4939786	09/07/2024 08:20	Colony Counts 22	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4939786	09/07/2024 08:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4939786	09/07/2024 08:20	E. coli	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4939786	09/07/2024 08:20	Free - Residual disinfectant	mg Cl/l	0.6	
V1351OUT	Cranny Moneymore SR Outlet	4939786	09/07/2024 08:20	Total - Residual disinfectant	mg Cl/l	0.7	
V1351OUT	Cranny Moneymore SR Outlet	4939786	09/07/2024 08:20	Total Coliforms	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4939780	09/07/2024 08:52	Colony Counts 22	CFU/1 ml	1	
V1702OUT	Cam SR Outlet	4939780	09/07/2024 08:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4939780	09/07/2024 08:52	E. coli	CFU/100 ml	0	0

V1702OUT	Cam SR Outlet	4939780	09/07/2024 08:52	Free - Residual disinfectant	mg Cl/l	0.51	
V1702OUT	Cam SR Outlet	4939780	09/07/2024 08:52	Total - Residual disinfectant	mg Cl/l	0.62	
V1702OUT	Cam SR Outlet	4939780	09/07/2024 08:52	Total Coliforms	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4939778	09/07/2024 09:06	Colony Counts 22	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4939778	09/07/2024 09:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4939778	09/07/2024 09:06	E. coli	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4939778	09/07/2024 09:06	Free - Residual disinfectant	mg Cl/l	0.46	
V1706OUT	Killeague SR Outlet	4939778	09/07/2024 09:06	Total - Residual disinfectant	mg Cl/l	0.6	
V1706OUT	Killeague SR Outlet	4939778	09/07/2024 09:06	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4939737	09/07/2024 09:19	Colony Counts 22	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4939737	09/07/2024 09:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4939737	09/07/2024 09:19	E. coli	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4939737	09/07/2024 09:19	Free - Residual disinfectant	mg Cl/l	1.02	
V2508OUT	Carland SR Outlet	4939737	09/07/2024 09:19	Total - Residual disinfectant	mg Cl/l	1.12	
V2508OUT	Carland SR Outlet	4939737	09/07/2024 09:19	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4939737	09/07/2024 09:19	Odour	Diln No	0	0
V2508OUT	Carland SR Outlet	4939737	09/07/2024 09:19	Odour - Nature		No odour	
V2508OUT	Carland SR Outlet	4939737	09/07/2024 09:19	Taste	Diln No	0	0
V2508OUT	Carland SR Outlet	4939737	09/07/2024 09:19	Taste - Nature		No taste	
V1708OUT	North Garvagh SR Outlet	4939781	09/07/2024 09:21	Colony Counts 22	CFU/1 ml	1	
V1708OUT	North Garvagh SR Outlet	4939781	09/07/2024 09:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4939781	09/07/2024 09:21	E. coli	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4939781	09/07/2024 09:21	Free - Residual disinfectant	mg Cl/l	0.5	
V1708OUT	North Garvagh SR Outlet	4939781	09/07/2024 09:21	Total - Residual disinfectant	mg Cl/l	0.63	
V1708OUT	North Garvagh SR Outlet	4939781	09/07/2024 09:21	Total Coliforms	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4939797	09/07/2024 09:21	Colony Counts 22	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4939797	09/07/2024 09:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4939797	09/07/2024 09:21	E. coli	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4939797	09/07/2024 09:21	Free - Residual disinfectant	mg Cl/l	0.63	
V1343OUT	Ballybriest SR Outlet	4939797	09/07/2024 09:21	Total - Residual disinfectant	mg Cl/l	0.74	
V1343OUT	Ballybriest SR Outlet	4939797	09/07/2024 09:21	Total Coliforms	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4939785	09/07/2024 10:00	Colony Counts 22	CFU/1 ml	2	
V1713OUT	Trienaltenagh SR Outlet	4939785	09/07/2024 10:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4939785	09/07/2024 10:00	E. coli	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4939785	09/07/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.54	
V1713OUT	Trienaltenagh SR Outlet	4939785	09/07/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.66	
V1713OUT	Trienaltenagh SR Outlet	4939785	09/07/2024 10:00	Total Coliforms	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4939495	09/07/2024 10:00	Colony Counts 22	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4939495	09/07/2024 10:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4939495	09/07/2024 10:00	E. coli	CFU/100 ml	0	0

V1363OUT	Pomeroy Cavanakeeran SR Outlet	4939495	09/07/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.67	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4939495	09/07/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.73	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4939495	09/07/2024 10:00	Total Coliforms	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4939496	09/07/2024 10:18	Colony Counts 22	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4939496	09/07/2024 10:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4939496	09/07/2024 10:18	E. coli	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4939496	09/07/2024 10:18	Free - Residual disinfectant	mg Cl/l	0.96	
V2501OUT	Altmore River SR Outlet	4939496	09/07/2024 10:18	Total - Residual disinfectant	mg Cl/l	1.11	
V2501OUT	Altmore River SR Outlet	4939496	09/07/2024 10:18	Total Coliforms	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4939498	09/07/2024 10:43	Colony Counts 22	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4939498	09/07/2024 10:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4939498	09/07/2024 10:43	E. coli	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4939498	09/07/2024 10:43	Free - Residual disinfectant	mg Cl/l	0.74	
V2507OUT	Cappagh SR Outlet	4939498	09/07/2024 10:43	Total - Residual disinfectant	mg Cl/l	0.78	
V2507OUT	Cappagh SR Outlet	4939498	09/07/2024 10:43	Total Coliforms	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4939497	09/07/2024 11:00	Colony Counts 22	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4939497	09/07/2024 11:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4939497	09/07/2024 11:00	E. coli	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4939497	09/07/2024 11:00	Free - Residual disinfectant	mg Cl/l	0.92	
V2505OUT	Cabragh Fasglashagh SR Outlet	4939497	09/07/2024 11:00	Total - Residual disinfectant	mg Cl/l	0.96	
V2505OUT	Cabragh Fasglashagh SR Outlet	4939497	09/07/2024 11:00	Total Coliforms	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4939738	09/07/2024 11:24	Colony Counts 22	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4939738	09/07/2024 11:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4939738	09/07/2024 11:24	E. coli	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4939738	09/07/2024 11:24	Free - Residual disinfectant	mg Cl/l	0.64	
V2509OUT	Castlehill Drumcoo SR Outlet	4939738	09/07/2024 11:24	Total - Residual disinfectant	mg Cl/l	0.7	
V2509OUT	Castlehill Drumcoo SR Outlet	4939738	09/07/2024 11:24	Total Coliforms	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4939759	09/07/2024 11:41	Colony Counts 22	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4939759	09/07/2024 11:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4939759	09/07/2024 11:41	E. coli	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4939759	09/07/2024 11:41	Free - Residual disinfectant	mg Cl/l	1.02	
V2521OUT	Mullaghanagh SR Outlet	4939759	09/07/2024 11:41	Total - Residual disinfectant	mg Cl/l	1.09	
V2521OUT	Mullaghanagh SR Outlet	4939759	09/07/2024 11:41	Total Coliforms	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4939773	09/07/2024 12:03	Colony Counts 22	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4939773	09/07/2024 12:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4939773	09/07/2024 12:03	E. coli	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4939773	09/07/2024 12:03	Free - Residual disinfectant	mg Cl/l	0.77	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4939773	09/07/2024 12:03	Total - Residual disinfectant	mg Cl/l	0.83	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4939773	09/07/2024 12:03	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4939487	10/07/2024 08:42	Colony Counts 22	CFU/1 ml	0	

V1725OUT	Glenlough SR Outlet	4939487	10/07/2024 08:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4939487	10/07/2024 08:42	E. coli	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4939487	10/07/2024 08:42	Free - Residual disinfectant	mg Cl/l	0.46	
V1725OUT	Glenlough SR Outlet	4939487	10/07/2024 08:42	Total - Residual disinfectant	mg Cl/l	0.59	
V1725OUT	Glenlough SR Outlet	4939487	10/07/2024 08:42	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4939487	10/07/2024 08:42	Odour	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4939487	10/07/2024 08:42	Odour - Nature		No odour	
V1725OUT	Glenlough SR Outlet	4939487	10/07/2024 08:42	Taste	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4939487	10/07/2024 08:42	Taste - Nature		No taste	
V1338OUT	Coagh SR Outlet	4940021	10/07/2024 08:57	Colony Counts 22	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4940021	10/07/2024 08:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4940021	10/07/2024 08:57	E. coli	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4940021	10/07/2024 08:57	Free - Residual disinfectant	mg Cl/l	0.35	
V1338OUT	Coagh SR Outlet	4940021	10/07/2024 08:57	Total - Residual disinfectant	mg Cl/l	0.4	
V1338OUT	Coagh SR Outlet	4940021	10/07/2024 08:57	Total Coliforms	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4940017	10/07/2024 09:14	Colony Counts 22	CFU/1 ml	1	
V4533OUT	Inisclan SR Outlet	4940017	10/07/2024 09:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4940017	10/07/2024 09:14	E. coli	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4940017	10/07/2024 09:14	Free - Residual disinfectant	mg Cl/l	0.78	
V4533OUT	Inisclan SR Outlet	4940017	10/07/2024 09:14	Total - Residual disinfectant	mg Cl/l	0.85	
V4533OUT	Inisclan SR Outlet	4940017	10/07/2024 09:14	Total Coliforms	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4940020	10/07/2024 09:16	Colony Counts 22	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4940020	10/07/2024 09:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4940020	10/07/2024 09:16	E. coli	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4940020	10/07/2024 09:16	Free - Residual disinfectant	mg Cl/l	0.52	
V1335OUT	Brigh Quarry SR Outlet	4940020	10/07/2024 09:16	Total - Residual disinfectant	mg Cl/l	0.57	
V1335OUT	Brigh Quarry SR Outlet	4940020	10/07/2024 09:16	Total Coliforms	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4940024	10/07/2024 09:41	Colony Counts 22	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4940024	10/07/2024 09:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4940024	10/07/2024 09:41	E. coli	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4940024	10/07/2024 09:41	Free - Residual disinfectant	mg Cl/l	0.6	
V1342OUT	Dromore High SR Outlet	4940024	10/07/2024 09:41	Total - Residual disinfectant	mg Cl/l	0.65	
V1342OUT	Dromore High SR Outlet	4940024	10/07/2024 09:41	Total Coliforms	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4939976	10/07/2024 09:46	Colony Counts 22	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4939976	10/07/2024 09:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4939976	10/07/2024 09:46	E. coli	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4939976	10/07/2024 09:46	Free - Residual disinfectant	mg Cl/l	0.96	
V2511OUT	Corran Armagh SR Outlet	4939976	10/07/2024 09:46	Total - Residual disinfectant	mg Cl/l	0.97	
V2511OUT	Corran Armagh SR Outlet	4939976	10/07/2024 09:46	Total Coliforms	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4940025	10/07/2024 09:55	Colony Counts 22	CFU/1 ml	0	

V4712OUT	Corranny SR Outlet	4940025	10/07/2024 09:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4940025	10/07/2024 09:55	E. coli	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4940025	10/07/2024 09:55	Free - Residual disinfectant	mg Cl/l	0.62	
V4712OUT	Corranny SR Outlet	4940025	10/07/2024 09:55	Total - Residual disinfectant	mg Cl/l	0.71	
V4712OUT	Corranny SR Outlet	4940025	10/07/2024 09:55	Total Coliforms	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4939986	10/07/2024 10:06	Colony Counts 22	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4939986	10/07/2024 10:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4939986	10/07/2024 10:06	E. coli	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4939986	10/07/2024 10:06	Free - Residual disinfectant	mg Cl/l	0.97	
V2518OUT	Lisnastrane SR Outlet	4939986	10/07/2024 10:06	Total - Residual disinfectant	mg Cl/l	1.03	
V2518OUT	Lisnastrane SR Outlet	4939986	10/07/2024 10:06	Total Coliforms	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4940027	10/07/2024 10:07	Colony Counts 22	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4940027	10/07/2024 10:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4940027	10/07/2024 10:07	E. coli	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4940027	10/07/2024 10:07	Free - Residual disinfectant	mg Cl/l	0.66	
V4713OUT	Knocknalosset SR Outlet	4940027	10/07/2024 10:07	Total - Residual disinfectant	mg Cl/l	0.79	
V4713OUT	Knocknalosset SR Outlet	4940027	10/07/2024 10:07	Total Coliforms	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4939782	10/07/2024 10:25	Colony Counts 22	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4939782	10/07/2024 10:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4939782	10/07/2024 10:25	E. coli	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4939782	10/07/2024 10:25	Free - Residual disinfectant	mg Cl/l	1.02	
V4742OUT	Tattinbar SR Outlet	4939782	10/07/2024 10:25	Total - Residual disinfectant	mg Cl/l	1.09	
V4742OUT	Tattinbar SR Outlet	4939782	10/07/2024 10:25	Total Coliforms	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4939975	10/07/2024 10:32	Colony Counts 22	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4939975	10/07/2024 10:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4939975	10/07/2024 10:32	E. coli	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4939975	10/07/2024 10:32	Free - Residual disinfectant	mg Cl/l	0.59	
V2510OUT	Calone SR Outlet	4939975	10/07/2024 10:32	Total - Residual disinfectant	mg Cl/l	0.68	
V2510OUT	Calone SR Outlet	4939975	10/07/2024 10:32	Total Coliforms	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4939799	10/07/2024 10:48	Colony Counts 22	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4939799	10/07/2024 10:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4939799	10/07/2024 10:48	E. coli	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4939799	10/07/2024 10:48	Free - Residual disinfectant	mg Cl/l	0.82	
V4715OUT	Brookeborough High SR Outlet	4939799	10/07/2024 10:48	Total - Residual disinfectant	mg Cl/l	0.9	
V4715OUT	Brookeborough High SR Outlet	4939799	10/07/2024 10:48	Total Coliforms	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4939984	10/07/2024 10:54	Colony Counts 22	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4939984	10/07/2024 10:54	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4939984	10/07/2024 10:54	E. coli	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4939984	10/07/2024 10:54	Free - Residual disinfectant	mg Cl/l	0.72	
V2514OUT	Edenaveys Command SR Outlet	4939984	10/07/2024 10:54	Total - Residual disinfectant	mg Cl/l	0.91	

V2514OUT	Edenaveys Command SR Outlet	4939984	10/07/2024 10:54	Total Coliforms	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4939972	10/07/2024 11:27	Colony Counts 22	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4939972	10/07/2024 11:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4939972	10/07/2024 11:27	E. coli	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4939972	10/07/2024 11:27	Free - Residual disinfectant	mg Cl/l	0.94	
V2523OUT	Rough Fort SR Outlet	4939972	10/07/2024 11:27	Total - Residual disinfectant	mg Cl/l	1.17	
V2523OUT	Rough Fort SR Outlet	4939972	10/07/2024 11:27	Total Coliforms	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4939783	10/07/2024 11:31	Colony Counts 22	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4939783	10/07/2024 11:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4939783	10/07/2024 11:31	E. coli	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4939783	10/07/2024 11:31	Free - Residual disinfectant	mg Cl/l	0.86	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4939783	10/07/2024 11:31	Total - Residual disinfectant	mg Cl/l	0.92	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4939783	10/07/2024 11:31	Total Coliforms	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4939486	10/07/2024 12:10	Colony Counts 22	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4939486	10/07/2024 12:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4939486	10/07/2024 12:10	E. coli	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4939486	10/07/2024 12:10	Free - Residual disinfectant	mg Cl/l	0.51	
V1715OUT	Ballystrone (Calvins) SR Outlet	4939486	10/07/2024 12:10	Total - Residual disinfectant	mg Cl/l	0.64	
V1715OUT	Ballystrone (Calvins) SR Outlet	4939486	10/07/2024 12:10	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4940219	11/07/2024 07:53	Colony Counts 22	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4940219	11/07/2024 07:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4940219	11/07/2024 07:53	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4940219	11/07/2024 07:53	Free - Residual disinfectant	mg Cl/l	0.37	
V1350OUT	Carnaman SR Outlet	4940219	11/07/2024 07:53	Total - Residual disinfectant	mg Cl/l	0.41	
V1350OUT	Carnaman SR Outlet	4940219	11/07/2024 07:53	Total Coliforms	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4940193	11/07/2024 08:13	Colony Counts 22	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4940193	11/07/2024 08:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4940193	11/07/2024 08:13	E. coli	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4940193	11/07/2024 08:13	Free - Residual disinfectant	mg Cl/l	0.65	
V4539OUT	Erganagh SR Outlet	4940193	11/07/2024 08:13	Total - Residual disinfectant	mg Cl/l	0.77	
V4539OUT	Erganagh SR Outlet	4940193	11/07/2024 08:13	Total Coliforms	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4940013	11/07/2024 08:22	Colony Counts 22	CFU/1 ml	0	
V1711OUT	Sconce Hill SR Outlet	4940013	11/07/2024 08:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1711OUT	Sconce Hill SR Outlet	4940013	11/07/2024 08:22	E. coli	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4940013	11/07/2024 08:22	Free - Residual disinfectant	mg Cl/l	0.47	
V1711OUT	Sconce Hill SR Outlet	4940013	11/07/2024 08:22	Total - Residual disinfectant	mg Cl/l	0.55	
V1711OUT	Sconce Hill SR Outlet	4940013	11/07/2024 08:22	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4940011	11/07/2024 08:37	Colony Counts 22	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4940011	11/07/2024 08:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4940011	11/07/2024 08:37	E. coli	CFU/100 ml	0	0

V1704OUT	Castlerock Downhill SR Outlet	4940011	11/07/2024 08:37	Free - Residual disinfectant	mg Cl/l	0.43	
V1704OUT	Castlerock Downhill SR Outlet	4940011	11/07/2024 08:37	Total - Residual disinfectant	mg Cl/l	0.55	
V1704OUT	Castlerock Downhill SR Outlet	4940011	11/07/2024 08:37	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4940212	11/07/2024 08:54	Colony Counts 22	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4940212	11/07/2024 08:54	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4940212	11/07/2024 08:54	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4940212	11/07/2024 08:54	Free - Residual disinfectant	mg Cl/l	0.6	
V1360OUT	Windmill Hill SR Outlet	4940212	11/07/2024 08:54	Total - Residual disinfectant	mg Cl/l	0.75	
V1360OUT	Windmill Hill SR Outlet	4940212	11/07/2024 08:54	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4954258	11/07/2024 08:55	Turbidity	NTU	<0.09	4
V1344OUT	Craigs Cookstown SR Outlet	4940227	11/07/2024 09:05	Colony Counts 22	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4940227	11/07/2024 09:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4940227	11/07/2024 09:05	E. coli	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4940227	11/07/2024 09:05	Free - Residual disinfectant	mg Cl/l	0.51	
V1344OUT	Craigs Cookstown SR Outlet	4940227	11/07/2024 09:05	Total - Residual disinfectant	mg Cl/l	0.55	
V1344OUT	Craigs Cookstown SR Outlet	4940227	11/07/2024 09:05	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4940223	11/07/2024 09:18	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4940223	11/07/2024 09:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4940223	11/07/2024 09:18	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4940223	11/07/2024 09:18	Free - Residual disinfectant	mg Cl/l	0.98	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4940223	11/07/2024 09:18	Total - Residual disinfectant	mg Cl/l	1.1	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4940223	11/07/2024 09:18	Total Coliforms	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4940191	11/07/2024 09:18	Colony Counts 22	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4940191	11/07/2024 09:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4940191	11/07/2024 09:18	E. coli	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4940191	11/07/2024 09:18	Free - Residual disinfectant	mg Cl/l	0.95	
V4538OUT	Killyclogher SR Outlet	4940191	11/07/2024 09:18	Total - Residual disinfectant	mg Cl/l	1.04	
V4538OUT	Killyclogher SR Outlet	4940191	11/07/2024 09:18	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4954261	11/07/2024 09:20	Turbidity	NTU	<0.09	4
V1362OUT	Unagh SR Outlet	4940213	11/07/2024 09:20	Colony Counts 22	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4940213	11/07/2024 09:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4940213	11/07/2024 09:20	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4940213	11/07/2024 09:20	Free - Residual disinfectant	mg Cl/l	0.38	
V1362OUT	Unagh SR Outlet	4940213	11/07/2024 09:20	Total - Residual disinfectant	mg Cl/l	0.42	
V1362OUT	Unagh SR Outlet	4940213	11/07/2024 09:20	Total Coliforms	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4940224	11/07/2024 09:45	Colony Counts 22	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4940224	11/07/2024 09:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4940224	11/07/2024 09:45	E. coli	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4940224	11/07/2024 09:45	Free - Residual disinfectant	mg Cl/l	0.75	
V1339OUT	Corvanaghan High SR Outlet	4940224	11/07/2024 09:45	Total - Residual disinfectant	mg Cl/l	0.82	

V1339OUT	Corvanaghan High SR Outlet	4940224	11/07/2024 09:45	Total Coliforms	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4940225	11/07/2024 09:58	Colony Counts 22	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4940225	11/07/2024 09:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4940225	11/07/2024 09:58	E. coli	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4940225	11/07/2024 09:58	Free - Residual disinfectant	mg Cl/l	0.65	
V1340OUT	Craigballyharkey SR Outlet	4940225	11/07/2024 09:58	Total - Residual disinfectant	mg Cl/l	0.7	
V1340OUT	Craigballyharkey SR Outlet	4940225	11/07/2024 09:58	Total Coliforms	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4939784	11/07/2024 10:03	Colony Counts 22	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4939784	11/07/2024 10:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4939784	11/07/2024 10:03	E. coli	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4939784	11/07/2024 10:03	Free - Residual disinfectant	mg Cl/l	0.72	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4939784	11/07/2024 10:03	Total - Residual disinfectant	mg Cl/l	0.79	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4939784	11/07/2024 10:03	Total Coliforms	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4940228	11/07/2024 10:11	Colony Counts 22	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4940228	11/07/2024 10:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4940228	11/07/2024 10:11	E. coli	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4940228	11/07/2024 10:11	Free - Residual disinfectant	mg Cl/l	0.54	
V1346OUT	Gortaclady Evishanoran SR Outlet	4940228	11/07/2024 10:11	Total - Residual disinfectant	mg Cl/l	0.61	
V1346OUT	Gortaclady Evishanoran SR Outlet	4940228	11/07/2024 10:11	Total Coliforms	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4940200	11/07/2024 10:57	Colony Counts 22	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4940200	11/07/2024 10:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4940200	11/07/2024 10:57	E. coli	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4940200	11/07/2024 10:57	Free - Residual disinfectant	mg Cl/l	1.09	
V4536OUT	Lough Macrory North SR Outlet	4940200	11/07/2024 10:57	Total - Residual disinfectant	mg Cl/l	1.17	
V4536OUT	Lough Macrory North SR Outlet	4940200	11/07/2024 10:57	Total Coliforms	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4940190	11/07/2024 11:28	Colony Counts 22	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4940190	11/07/2024 11:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4940190	11/07/2024 11:28	E. coli	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4940190	11/07/2024 11:28	Free - Residual disinfectant	mg Cl/l	1.06	
V4526OUT	Black Lough Pomeroy SR Outlet	4940190	11/07/2024 11:28	Total - Residual disinfectant	mg Cl/l	1.21	
V4526OUT	Black Lough Pomeroy SR Outlet	4940190	11/07/2024 11:28	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4942749	16/07/2024 07:12	Colony Counts 22	CFU/1 ml	17	
V1354OUT	Knockoneill SR Outlet	4942749	16/07/2024 07:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4942749	16/07/2024 07:12	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4942749	16/07/2024 07:12	Free - Residual disinfectant	mg Cl/l	0.26	
V1354OUT	Knockoneill SR Outlet	4942749	16/07/2024 07:12	Total - Residual disinfectant	mg Cl/l	0.32	
V1354OUT	Knockoneill SR Outlet	4942749	16/07/2024 07:12	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4942749	16/07/2024 07:12	Odour	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4942749	16/07/2024 07:12	Odour - Nature		No odour	
V1354OUT	Knockoneill SR Outlet	4942749	16/07/2024 07:12	Taste	Diln No	0	0

V1354OUT	Knockoneill SR Outlet	4942749	16/07/2024 07:12	Taste - Nature		No taste	
V1358OUT	Slaughtneil SR Outlet	4942751	16/07/2024 07:29	Colony Counts 22	CFU/1 ml	1	
V1358OUT	Slaughtneil SR Outlet	4942751	16/07/2024 07:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4942751	16/07/2024 07:29	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4942751	16/07/2024 07:29	Free - Residual disinfectant	mg Cl/l	0.42	
V1358OUT	Slaughtneil SR Outlet	4942751	16/07/2024 07:29	Total - Residual disinfectant	mg Cl/l	0.54	
V1358OUT	Slaughtneil SR Outlet	4942751	16/07/2024 07:29	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4942743	16/07/2024 07:47	Colony Counts 22	CFU/1 ml	190	
V1349OUT	Ballyknock Magherafelt SR Outlet	4942743	16/07/2024 07:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4942743	16/07/2024 07:47	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4942743	16/07/2024 07:47	Free - Residual disinfectant	mg Cl/l	0.31	
V1349OUT	Ballyknock Magherafelt SR Outlet	4942743	16/07/2024 07:47	Total - Residual disinfectant	mg Cl/l	0.56	
V1349OUT	Ballyknock Magherafelt SR Outlet	4942743	16/07/2024 07:47	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4942844	16/07/2024 08:22	Colony Counts 22	CFU/1 ml	7	
V1348OUT	Moydamlaght Draperstown SR Outlet	4942844	16/07/2024 08:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4942844	16/07/2024 08:22	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4942844	16/07/2024 08:22	Free - Residual disinfectant	mg Cl/l	<0.05	
V1348OUT	Moydamlaght Draperstown SR Outlet	4942844	16/07/2024 08:22	Total - Residual disinfectant	mg Cl/l	0.22	
V1348OUT	Moydamlaght Draperstown SR Outlet	4942844	16/07/2024 08:22	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4942849	16/07/2024 08:47	Colony Counts 22	CFU/1 ml	2	
V1356OUT	Mormeal SR Outlet	4942849	16/07/2024 08:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4942849	16/07/2024 08:47	E. coli	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4942849	16/07/2024 08:47	Free - Residual disinfectant	mg Cl/l	0.35	
V1356OUT	Mormeal SR Outlet	4942849	16/07/2024 08:47	Total - Residual disinfectant	mg Cl/l	0.6	
V1356OUT	Mormeal SR Outlet	4942849	16/07/2024 08:47	Total Coliforms	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4942832	16/07/2024 09:57	Colony Counts 22	CFU/1 ml	1	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4942832	16/07/2024 09:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4942832	16/07/2024 09:57	E. coli	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4942832	16/07/2024 09:57	Free - Residual disinfectant	mg Cl/l	0.77	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4942832	16/07/2024 09:57	Total - Residual disinfectant	mg Cl/l	0.8	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4942832	16/07/2024 09:57	Total Coliforms	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4942850	16/07/2024 10:06	Colony Counts 22	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4942850	16/07/2024 10:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4942850	16/07/2024 10:06	E. coli	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4942850	16/07/2024 10:06	Free - Residual disinfectant	mg Cl/l	0.48	
V4537OUT	Sixmilecross SR Outlet	4942850	16/07/2024 10:06	Total - Residual disinfectant	mg Cl/l	0.56	
V4537OUT	Sixmilecross SR Outlet	4942850	16/07/2024 10:06	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4942806	16/07/2024 10:16	Colony Counts 22	CFU/1 ml	1	
V2301OUT	Ballydougan Command SR Outlet	4942806	16/07/2024 10:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4942806	16/07/2024 10:16	E. coli	CFU/100 ml	0	0

V2301OUT	Ballydougan Command SR Outlet	4942806	16/07/2024 10:16	Free - Residual disinfectant	mg Cl/l	0.83	
V2301OUT	Ballydougan Command SR Outlet	4942806	16/07/2024 10:16	Total - Residual disinfectant	mg Cl/l	0.91	
V2301OUT	Ballydougan Command SR Outlet	4942806	16/07/2024 10:16	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4942806	16/07/2024 10:16	Odour	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4942806	16/07/2024 10:16	Odour - Nature		No odour	
V2301OUT	Ballydougan Command SR Outlet	4942806	16/07/2024 10:16	Taste	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4942806	16/07/2024 10:16	Taste - Nature		No taste	
V4531OUT	Foremass SR Outlet	4942847	16/07/2024 10:20	Colony Counts 22	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4942847	16/07/2024 10:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4942847	16/07/2024 10:20	E. coli	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4942847	16/07/2024 10:20	Free - Residual disinfectant	mg Cl/l	0.55	
V4531OUT	Foremass SR Outlet	4942847	16/07/2024 10:20	Total - Residual disinfectant	mg Cl/l	0.66	
V4531OUT	Foremass SR Outlet	4942847	16/07/2024 10:20	Total Coliforms	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4942807	16/07/2024 10:35	Colony Counts 22	CFU/1 ml	13	
V2302OUT	Ballyhannon SR Outlet	4942807	16/07/2024 10:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4942807	16/07/2024 10:35	E. coli	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4942807	16/07/2024 10:35	Free - Residual disinfectant	mg Cl/l	0.6	
V2302OUT	Ballyhannon SR Outlet	4942807	16/07/2024 10:35	Total - Residual disinfectant	mg Cl/l	0.65	
V2302OUT	Ballyhannon SR Outlet	4942807	16/07/2024 10:35	Total Coliforms	CFU/100 ml	1	0
V4540OUT	Radergan SR Outlet	4942821	16/07/2024 10:35	Colony Counts 22	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4942821	16/07/2024 10:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4942821	16/07/2024 10:35	E. coli	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4942821	16/07/2024 10:35	Free - Residual disinfectant	mg Cl/l	0.52	
V4540OUT	Radergan SR Outlet	4942821	16/07/2024 10:35	Total - Residual disinfectant	mg Cl/l	0.67	
V4540OUT	Radergan SR Outlet	4942821	16/07/2024 10:35	Total Coliforms	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4942855	16/07/2024 11:09	Colony Counts 22	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4942855	16/07/2024 11:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4942855	16/07/2024 11:09	E. coli	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4942855	16/07/2024 11:09	Free - Residual disinfectant	mg Cl/l	0.5	
V4528OUT	Crocknabohil SR Outlet	4942855	16/07/2024 11:09	Total - Residual disinfectant	mg Cl/l	0.61	
V4528OUT	Crocknabohil SR Outlet	4942855	16/07/2024 11:09	Total Coliforms	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4943101	17/07/2024 07:26	Colony Counts 22	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4943101	17/07/2024 07:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4943101	17/07/2024 07:26	E. coli	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4943101	17/07/2024 07:26	Free - Residual disinfectant	mg Cl/l	0.88	
V1702OUT	Cam SR Outlet	4943101	17/07/2024 07:26	Total - Residual disinfectant	mg Cl/l	0.96	
V1702OUT	Cam SR Outlet	4943101	17/07/2024 07:26	Total Coliforms	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4943099	17/07/2024 07:54	Colony Counts 22	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4943099	17/07/2024 07:54	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4943099	17/07/2024 07:54	E. coli	CFU/100 ml	0	0

V1706OUT	Killeague SR Outlet	4943099	17/07/2024 07:54	Free - Residual disinfectant	mg Cl/l	0.5	
V1706OUT	Killeague SR Outlet	4943099	17/07/2024 07:54	Total - Residual disinfectant	mg Cl/l	0.75	
V1706OUT	Killeague SR Outlet	4943099	17/07/2024 07:54	Total Coliforms	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4943102	17/07/2024 08:22	Colony Counts 22	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4943102	17/07/2024 08:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4943102	17/07/2024 08:22	E. coli	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4943102	17/07/2024 08:22	Free - Residual disinfectant	mg Cl/l	0.4	
V1708OUT	North Garvagh SR Outlet	4943102	17/07/2024 08:22	Total - Residual disinfectant	mg Cl/l	0.49	
V1708OUT	North Garvagh SR Outlet	4943102	17/07/2024 08:22	Total Coliforms	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4939506	17/07/2024 08:31	Colony Counts 22	CFU/1 ml	27	
V4527OUT	Carryglass SR Outlet	4939506	17/07/2024 08:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4939506	17/07/2024 08:31	E. coli	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4939506	17/07/2024 08:31	Free - Residual disinfectant	mg Cl/l	0.45	
V4527OUT	Carryglass SR Outlet	4939506	17/07/2024 08:31	Total - Residual disinfectant	mg Cl/l	0.53	
V4527OUT	Carryglass SR Outlet	4939506	17/07/2024 08:31	Total Coliforms	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4942754	17/07/2024 08:32	Colony Counts 22	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4942754	17/07/2024 08:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4942754	17/07/2024 08:32	E. coli	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4942754	17/07/2024 08:32	Free - Residual disinfectant	mg Cl/l	0.49	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4942754	17/07/2024 08:32	Total - Residual disinfectant	mg Cl/l	0.54	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4942754	17/07/2024 08:32	Total Coliforms	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4943106	17/07/2024 08:49	Colony Counts 22	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4943106	17/07/2024 08:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4943106	17/07/2024 08:49	E. coli	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4943106	17/07/2024 08:49	Free - Residual disinfectant	mg Cl/l	0.3	
V1713OUT	Trienaltenagh SR Outlet	4943106	17/07/2024 08:49	Total - Residual disinfectant	mg Cl/l	0.5	
V1713OUT	Trienaltenagh SR Outlet	4943106	17/07/2024 08:49	Total Coliforms	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4942726	17/07/2024 08:53	Colony Counts 22	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4942726	17/07/2024 08:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4942726	17/07/2024 08:53	E. coli	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4942726	17/07/2024 08:53	Free - Residual disinfectant	mg Cl/l	0.93	
V2501OUT	Altmore River SR Outlet	4942726	17/07/2024 08:53	Total - Residual disinfectant	mg Cl/l	1.03	
V2501OUT	Altmore River SR Outlet	4942726	17/07/2024 08:53	Total Coliforms	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4939526	17/07/2024 08:53	Colony Counts 22	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4939526	17/07/2024 08:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4939526	17/07/2024 08:53	E. coli	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4939526	17/07/2024 08:53	Free - Residual disinfectant	mg Cl/l	0.94	
V4707OUT	Sidaire SR Outlet	4939526	17/07/2024 08:53	Total - Residual disinfectant	mg Cl/l	1.03	
V4707OUT	Sidaire SR Outlet	4939526	17/07/2024 08:53	Total Coliforms	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4942707	17/07/2024 09:09	Colony Counts 22	CFU/1 ml	0	

V2507OUT	Cappagh SR Outlet	4942707	17/07/2024 09:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4942707	17/07/2024 09:09	E. coli	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4942707	17/07/2024 09:09	Free - Residual disinfectant	mg Cl/l	0.69	
V2507OUT	Cappagh SR Outlet	4942707	17/07/2024 09:09	Total - Residual disinfectant	mg Cl/l	0.73	
V2507OUT	Cappagh SR Outlet	4942707	17/07/2024 09:09	Total Coliforms	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4943118	17/07/2024 09:14	Colony Counts 22	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4943118	17/07/2024 09:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4943118	17/07/2024 09:14	E. coli	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4943118	17/07/2024 09:14	Free - Residual disinfectant	mg Cl/l	0.54	
V1343OUT	Ballybriest SR Outlet	4943118	17/07/2024 09:14	Total - Residual disinfectant	mg Cl/l	0.63	
V1343OUT	Ballybriest SR Outlet	4943118	17/07/2024 09:14	Total Coliforms	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4942706	17/07/2024 09:27	Colony Counts 22	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4942706	17/07/2024 09:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4942706	17/07/2024 09:27	E. coli	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4942706	17/07/2024 09:27	Free - Residual disinfectant	mg Cl/l	0.85	
V2505OUT	Cabragh Fasglashagh SR Outlet	4942706	17/07/2024 09:27	Total - Residual disinfectant	mg Cl/l	0.91	
V2505OUT	Cabragh Fasglashagh SR Outlet	4942706	17/07/2024 09:27	Total Coliforms	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4943095	17/07/2024 09:37	Colony Counts 22	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4943095	17/07/2024 09:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4943095	17/07/2024 09:37	E. coli	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4943095	17/07/2024 09:37	Free - Residual disinfectant	mg Cl/l	0.09	
V1352OUT	Cullion Desertmartin SR Outlet	4943095	17/07/2024 09:37	Total - Residual disinfectant	mg Cl/l	0.14	
V1352OUT	Cullion Desertmartin SR Outlet	4943095	17/07/2024 09:37	Total Coliforms	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4943094	17/07/2024 09:48	Colony Counts 22	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4943094	17/07/2024 09:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4943094	17/07/2024 09:48	E. coli	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4943094	17/07/2024 09:48	Free - Residual disinfectant	mg Cl/l	0.7	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4943094	17/07/2024 09:48	Total - Residual disinfectant	mg Cl/l	0.76	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4943094	17/07/2024 09:48	Total Coliforms	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4943107	17/07/2024 09:58	Colony Counts 22	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4943107	17/07/2024 09:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4943107	17/07/2024 09:58	E. coli	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4943107	17/07/2024 09:58	Free - Residual disinfectant	mg Cl/l	0.63	
V1351OUT	Cranny Moneymore SR Outlet	4943107	17/07/2024 09:58	Total - Residual disinfectant	mg Cl/l	0.65	
V1351OUT	Cranny Moneymore SR Outlet	4943107	17/07/2024 09:58	Total Coliforms	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4939537	17/07/2024 10:02	Colony Counts 22	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4939537	17/07/2024 10:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4939537	17/07/2024 10:02	E. coli	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4939537	17/07/2024 10:02	Free - Residual disinfectant	mg Cl/l	0.6	
V4535OUT	Lisnagardy SR Outlet	4939537	17/07/2024 10:02	Total - Residual disinfectant	mg Cl/l	0.68	

V4535OUT	Lisnagardy SR Outlet	4939537	17/07/2024 10:02	Total Coliforms	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4939527	17/07/2024 10:14	Colony Counts 22	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4939527	17/07/2024 10:14	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V4708OUT	Cavanacross Enniskillen SR Outlet	4939527	17/07/2024 10:14	E. coli	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4939527	17/07/2024 10:14	Free - Residual disinfectant	mg Cl/l	1.18	
V4708OUT	Cavanacross Enniskillen SR Outlet	4939527	17/07/2024 10:14	Total - Residual disinfectant	mg Cl/l	1.32	
V4708OUT	Cavanacross Enniskillen SR Outlet	4939527	17/07/2024 10:14	Total Coliforms	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4943077	17/07/2024 10:16	Colony Counts 22	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4943077	17/07/2024 10:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4943077	17/07/2024 10:16	E. coli	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4943077	17/07/2024 10:16	Free - Residual disinfectant	mg Cl/l	1.64	
V2521OUT	Mullaghanagh SR Outlet	4943077	17/07/2024 10:16	Total - Residual disinfectant	mg Cl/l	1.78	
V2521OUT	Mullaghanagh SR Outlet	4943077	17/07/2024 10:16	Total Coliforms	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4939536	17/07/2024 10:17	Colony Counts 22	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4939536	17/07/2024 10:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4939536	17/07/2024 10:17	E. coli	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4939536	17/07/2024 10:17	Free - Residual disinfectant	mg Cl/l	0.51	
V4530OUT	Dungoran SR Outlet	4939536	17/07/2024 10:17	Total - Residual disinfectant	mg Cl/l	0.65	
V4530OUT	Dungoran SR Outlet	4939536	17/07/2024 10:17	Total Coliforms	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4943056	17/07/2024 10:40	Colony Counts 22	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4943056	17/07/2024 10:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4943056	17/07/2024 10:40	E. coli	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4943056	17/07/2024 10:40	Free - Residual disinfectant	mg Cl/l	0.66	
V2509OUT	Castlehill Drumcoo SR Outlet	4943056	17/07/2024 10:40	Total - Residual disinfectant	mg Cl/l	0.71	
V2509OUT	Castlehill Drumcoo SR Outlet	4943056	17/07/2024 10:40	Total Coliforms	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4939538	17/07/2024 10:47	Colony Counts 22	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4939538	17/07/2024 10:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4939538	17/07/2024 10:47	E. coli	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4939538	17/07/2024 10:47	Free - Residual disinfectant	mg Cl/l	0.44	
V4719OUT	Glenchuil SR Outlet	4939538	17/07/2024 10:47	Total - Residual disinfectant	mg Cl/l	0.55	
V4719OUT	Glenchuil SR Outlet	4939538	17/07/2024 10:47	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4943055	17/07/2024 11:02	Colony Counts 22	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4943055	17/07/2024 11:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4943055	17/07/2024 11:02	E. coli	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4943055	17/07/2024 11:02	Free - Residual disinfectant	mg Cl/l	1.06	
V2508OUT	Carland SR Outlet	4943055	17/07/2024 11:02	Total - Residual disinfectant	mg Cl/l	1.2	
V2508OUT	Carland SR Outlet	4943055	17/07/2024 11:02	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4943055	17/07/2024 11:02	Odour	Diln No	0	0
V2508OUT	Carland SR Outlet	4943055	17/07/2024 11:02	Odour - Nature		No odour	
V2508OUT	Carland SR Outlet	4943055	17/07/2024 11:02	Taste	Diln No	0	0

V2508OUT	Carland SR Outlet	4943055	17/07/2024 11:02	Taste - Nature		No taste	
V2302OUT	Ballyhannon SR Outlet	4956657	17/07/2024 12:05	E. coli	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4956657	17/07/2024 12:05	Free - Residual disinfectant	mg Cl/l	0.54	
V2302OUT	Ballyhannon SR Outlet	4956657	17/07/2024 12:05	Total - Residual disinfectant	mg Cl/l	0.6	
V2302OUT	Ballyhannon SR Outlet	4956657	17/07/2024 12:05	Total Coliforms	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4956665	17/07/2024 12:15	E. coli	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4956665	17/07/2024 12:15	Free - Residual disinfectant	mg Cl/l	0.35	
V2302OUT	Ballyhannon SR Outlet	4956665	17/07/2024 12:15	Total - Residual disinfectant	mg Cl/l	0.4	
V2302OUT	Ballyhannon SR Outlet	4956665	17/07/2024 12:15	Total Coliforms	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4956666	17/07/2024 12:30	E. coli	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4956666	17/07/2024 12:30	Free - Residual disinfectant	mg Cl/l	0.34	
V2302OUT	Ballyhannon SR Outlet	4956666	17/07/2024 12:30	Total - Residual disinfectant	mg Cl/l	0.42	
V2302OUT	Ballyhannon SR Outlet	4956666	17/07/2024 12:30	Total Coliforms	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4943333	18/07/2024 07:24	Colony Counts 22	CFU/1 ml	8	
V1711OUT	Sconce Hill SR Outlet	4943333	18/07/2024 07:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1711OUT	Sconce Hill SR Outlet	4943333	18/07/2024 07:24	E. coli	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4943333	18/07/2024 07:24	Free - Residual disinfectant	mg Cl/l	0.4	
V1711OUT	Sconce Hill SR Outlet	4943333	18/07/2024 07:24	Total - Residual disinfectant	mg Cl/l	0.55	
V1711OUT	Sconce Hill SR Outlet	4943333	18/07/2024 07:24	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4943331	18/07/2024 07:56	Colony Counts 22	CFU/1 ml	1	
V1704OUT	Castlerock Downhill SR Outlet	4943331	18/07/2024 07:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4943331	18/07/2024 07:56	E. coli	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4943331	18/07/2024 07:56	Free - Residual disinfectant	mg Cl/l	0.43	
V1704OUT	Castlerock Downhill SR Outlet	4943331	18/07/2024 07:56	Total - Residual disinfectant	mg Cl/l	0.56	
V1704OUT	Castlerock Downhill SR Outlet	4943331	18/07/2024 07:56	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4943331	18/07/2024 07:56	Odour	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4943331	18/07/2024 07:56	Odour - Nature		No odour	
V1704OUT	Castlerock Downhill SR Outlet	4943331	18/07/2024 07:56	Taste	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4943331	18/07/2024 07:56	Taste - Nature		No taste	
V1338OUT	Coagh SR Outlet	4943341	18/07/2024 09:14	Colony Counts 22	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4943341	18/07/2024 09:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4943341	18/07/2024 09:14	E. coli	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4943341	18/07/2024 09:14	Free - Residual disinfectant	mg Cl/l	0.33	
V1338OUT	Coagh SR Outlet	4943341	18/07/2024 09:14	Total - Residual disinfectant	mg Cl/l	0.4	
V1338OUT	Coagh SR Outlet	4943341	18/07/2024 09:14	Total Coliforms	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4943340	18/07/2024 09:31	Colony Counts 22	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4943340	18/07/2024 09:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4943340	18/07/2024 09:31	E. coli	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4943340	18/07/2024 09:31	Free - Residual disinfectant	mg Cl/l	0.55	
V1335OUT	Brigh Quarry SR Outlet	4943340	18/07/2024 09:31	Total - Residual disinfectant	mg Cl/l	0.61	

V1335OUT	Brigh Quarry SR Outlet	4943340	18/07/2024 09:31	Total Coliforms	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4943344	18/07/2024 09:46	Colony Counts 22	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4943344	18/07/2024 09:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4943344	18/07/2024 09:46	E. coli	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4943344	18/07/2024 09:46	Free - Residual disinfectant	mg Cl/l	0.44	
V1342OUT	Dromore High SR Outlet	4943344	18/07/2024 09:46	Total - Residual disinfectant	mg Cl/l	0.48	
V1342OUT	Dromore High SR Outlet	4943344	18/07/2024 09:46	Total Coliforms	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4943311	18/07/2024 10:08	Colony Counts 22	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4943311	18/07/2024 10:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4943311	18/07/2024 10:08	E. coli	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4943311	18/07/2024 10:08	Free - Residual disinfectant	mg Cl/l	0.85	
V2518OUT	Lisnastrane SR Outlet	4943311	18/07/2024 10:08	Total - Residual disinfectant	mg Cl/l	0.93	
V2518OUT	Lisnastrane SR Outlet	4943311	18/07/2024 10:08	Total Coliforms	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4943105	18/07/2024 10:20	Colony Counts 22	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4943105	18/07/2024 10:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4943105	18/07/2024 10:20	E. coli	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4943105	18/07/2024 10:20	Free - Residual disinfectant	mg Cl/l	0.62	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4943105	18/07/2024 10:20	Total - Residual disinfectant	mg Cl/l	0.75	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4943105	18/07/2024 10:20	Total Coliforms	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4943337	18/07/2024 10:27	Colony Counts 22	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4943337	18/07/2024 10:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4943337	18/07/2024 10:27	E. coli	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4943337	18/07/2024 10:27	Free - Residual disinfectant	mg Cl/l	0.77	
V4533OUT	Inisclan SR Outlet	4943337	18/07/2024 10:27	Total - Residual disinfectant	mg Cl/l	0.84	
V4533OUT	Inisclan SR Outlet	4943337	18/07/2024 10:27	Total Coliforms	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4943302	18/07/2024 10:30	Colony Counts 22	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4943302	18/07/2024 10:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4943302	18/07/2024 10:30	E. coli	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4943302	18/07/2024 10:30	Free - Residual disinfectant	mg Cl/l	0.73	
V2511OUT	Corran Armagh SR Outlet	4943302	18/07/2024 10:30	Total - Residual disinfectant	mg Cl/l	0.94	
V2511OUT	Corran Armagh SR Outlet	4943302	18/07/2024 10:30	Total Coliforms	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4943103	18/07/2024 10:42	Colony Counts 22	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4943103	18/07/2024 10:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4943103	18/07/2024 10:42	E. coli	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4943103	18/07/2024 10:42	Free - Residual disinfectant	mg Cl/l	0.65	
V4742OUT	Tattinbar SR Outlet	4943103	18/07/2024 10:42	Total - Residual disinfectant	mg Cl/l	0.73	
V4742OUT	Tattinbar SR Outlet	4943103	18/07/2024 10:42	Total Coliforms	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4943301	18/07/2024 11:08	Colony Counts 22	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4943301	18/07/2024 11:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4943301	18/07/2024 11:08	E. coli	CFU/100 ml	0	0

V2510OUT	Calone SR Outlet	4943301	18/07/2024 11:08	Free - Residual disinfectant	mg Cl/l	0.46	
V2510OUT	Calone SR Outlet	4943301	18/07/2024 11:08	Total - Residual disinfectant	mg Cl/l	0.65	
V2510OUT	Calone SR Outlet	4943301	18/07/2024 11:08	Total Coliforms	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4943120	18/07/2024 11:12	Colony Counts 22	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4943120	18/07/2024 11:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4943120	18/07/2024 11:12	E. coli	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4943120	18/07/2024 11:12	Free - Residual disinfectant	mg Cl/l	0.62	
V4715OUT	Brookeborough High SR Outlet	4943120	18/07/2024 11:12	Total - Residual disinfectant	mg Cl/l	0.69	
V4715OUT	Brookeborough High SR Outlet	4943120	18/07/2024 11:12	Total Coliforms	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4943309	18/07/2024 11:25	Colony Counts 22	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4943309	18/07/2024 11:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4943309	18/07/2024 11:25	E. coli	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4943309	18/07/2024 11:25	Free - Residual disinfectant	mg Cl/l	0.66	
V2514OUT	Edenaveys Command SR Outlet	4943309	18/07/2024 11:25	Total - Residual disinfectant	mg Cl/l	0.87	
V2514OUT	Edenaveys Command SR Outlet	4943309	18/07/2024 11:25	Total Coliforms	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4943298	18/07/2024 11:42	Colony Counts 22	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4943298	18/07/2024 11:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4943298	18/07/2024 11:42	E. coli	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4943298	18/07/2024 11:42	Free - Residual disinfectant	mg Cl/l	0.89	
V2523OUT	Rough Fort SR Outlet	4943298	18/07/2024 11:42	Total - Residual disinfectant	mg Cl/l	1.11	
V2523OUT	Rough Fort SR Outlet	4943298	18/07/2024 11:42	Total Coliforms	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4943104	18/07/2024 11:58	Colony Counts 22	CFU/1 ml	2	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4943104	18/07/2024 11:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4943104	18/07/2024 11:58	E. coli	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4943104	18/07/2024 11:58	Free - Residual disinfectant	mg Cl/l	0.72	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4943104	18/07/2024 11:58	Total - Residual disinfectant	mg Cl/l	0.8	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4943104	18/07/2024 11:58	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4943543	19/07/2024 08:26	Colony Counts 22	CFU/1 ml	9	
V1360OUT	Windmill Hill SR Outlet	4943543	19/07/2024 08:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4943543	19/07/2024 08:26	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4943543	19/07/2024 08:26	Free - Residual disinfectant	mg Cl/l	0.41	
V1360OUT	Windmill Hill SR Outlet	4943543	19/07/2024 08:26	Total - Residual disinfectant	mg Cl/l	0.61	
V1360OUT	Windmill Hill SR Outlet	4943543	19/07/2024 08:26	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4943554	19/07/2024 08:49	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4943554	19/07/2024 08:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4943554	19/07/2024 08:49	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4943554	19/07/2024 08:49	Free - Residual disinfectant	mg Cl/l	0.9	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4943554	19/07/2024 08:49	Total - Residual disinfectant	mg Cl/l	0.98	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4943554	19/07/2024 08:49	Total Coliforms	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4943558	19/07/2024 08:54	Colony Counts 22	CFU/1 ml	0	

V1344OUT	Craigs Cookstown SR Outlet	4943558	19/07/2024 08:54	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4943558	19/07/2024 08:54	E. coli	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4943558	19/07/2024 08:54	Free - Residual disinfectant	mg Cl/l	0.3	
V1344OUT	Craigs Cookstown SR Outlet	4943558	19/07/2024 08:54	Total - Residual disinfectant	mg Cl/l	0.35	
V1344OUT	Craigs Cookstown SR Outlet	4943558	19/07/2024 08:54	Total Coliforms	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4943545	19/07/2024 09:07	Colony Counts 22	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4943545	19/07/2024 09:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4943545	19/07/2024 09:07	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4943545	19/07/2024 09:07	Free - Residual disinfectant	mg Cl/l	0.37	
V1362OUT	Unagh SR Outlet	4943545	19/07/2024 09:07	Total - Residual disinfectant	mg Cl/l	0.45	
V1362OUT	Unagh SR Outlet	4943545	19/07/2024 09:07	Total Coliforms	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4943555	19/07/2024 09:30	Colony Counts 22	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4943555	19/07/2024 09:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4943555	19/07/2024 09:30	E. coli	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4943555	19/07/2024 09:30	Free - Residual disinfectant	mg Cl/l	0.52	
V1339OUT	Corvanaghan High SR Outlet	4943555	19/07/2024 09:30	Total - Residual disinfectant	mg Cl/l	0.61	
V1339OUT	Corvanaghan High SR Outlet	4943555	19/07/2024 09:30	Total Coliforms	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4943347	19/07/2024 09:33	Colony Counts 22	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4943347	19/07/2024 09:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4943347	19/07/2024 09:33	E. coli	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4943347	19/07/2024 09:33	Free - Residual disinfectant	mg Cl/l	0.71	
V4713OUT	Knocknalosset SR Outlet	4943347	19/07/2024 09:33	Total - Residual disinfectant	mg Cl/l	0.76	
V4713OUT	Knocknalosset SR Outlet	4943347	19/07/2024 09:33	Total Coliforms	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4943524	19/07/2024 09:35	Colony Counts 22	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4943524	19/07/2024 09:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4943524	19/07/2024 09:35	E. coli	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4943524	19/07/2024 09:35	Free - Residual disinfectant	mg Cl/l	0.34	
V4539OUT	Erganagh SR Outlet	4943524	19/07/2024 09:35	Total - Residual disinfectant	mg Cl/l	0.53	
V4539OUT	Erganagh SR Outlet	4943524	19/07/2024 09:35	Total Coliforms	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4943556	19/07/2024 09:44	Colony Counts 22	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4943556	19/07/2024 09:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4943556	19/07/2024 09:44	E. coli	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4943556	19/07/2024 09:44	Free - Residual disinfectant	mg Cl/l	0.65	
V1340OUT	Craigballyharkey SR Outlet	4943556	19/07/2024 09:44	Total - Residual disinfectant	mg Cl/l	0.7	
V1340OUT	Craigballyharkey SR Outlet	4943556	19/07/2024 09:44	Total Coliforms	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4943345	19/07/2024 09:49	Colony Counts 22	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4943345	19/07/2024 09:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4943345	19/07/2024 09:49	E. coli	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4943345	19/07/2024 09:49	Free - Residual disinfectant	mg Cl/l	0.64	
V4712OUT	Corranny SR Outlet	4943345	19/07/2024 09:49	Total - Residual disinfectant	mg Cl/l	0.71	

V4712OUT	Corranny SR Outlet	4943345	19/07/2024 09:49	Total Coliforms	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4943559	19/07/2024 09:55	Colony Counts 22	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4943559	19/07/2024 09:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4943559	19/07/2024 09:55	E. coli	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4943559	19/07/2024 09:55	Free - Residual disinfectant	mg Cl/l	0.36	
V1346OUT	Gortaclady Evishanoran SR Outlet	4943559	19/07/2024 09:55	Total - Residual disinfectant	mg Cl/l	0.4	
V1346OUT	Gortaclady Evishanoran SR Outlet	4943559	19/07/2024 09:55	Total Coliforms	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4943522	19/07/2024 10:18	Colony Counts 22	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4943522	19/07/2024 10:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4943522	19/07/2024 10:18	E. coli	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4943522	19/07/2024 10:18	Free - Residual disinfectant	mg Cl/l	0.56	
V4538OUT	Killyclogher SR Outlet	4943522	19/07/2024 10:18	Total - Residual disinfectant	mg Cl/l	0.64	
V4538OUT	Killyclogher SR Outlet	4943522	19/07/2024 10:18	Total Coliforms	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4943531	19/07/2024 10:37	Colony Counts 22	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4943531	19/07/2024 10:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4943531	19/07/2024 10:37	E. coli	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4943531	19/07/2024 10:37	Free - Residual disinfectant	mg Cl/l	0.77	
V4536OUT	Lough Macrory North SR Outlet	4943531	19/07/2024 10:37	Total - Residual disinfectant	mg Cl/l	0.85	
V4536OUT	Lough Macrory North SR Outlet	4943531	19/07/2024 10:37	Total Coliforms	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4943520	19/07/2024 10:55	Colony Counts 22	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4943520	19/07/2024 10:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4943520	19/07/2024 10:55	E. coli	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4943520	19/07/2024 10:55	Free - Residual disinfectant	mg Cl/l	0.62	
V4526OUT	Black Lough Pomeroy SR Outlet	4943520	19/07/2024 10:55	Total - Residual disinfectant	mg Cl/l	0.69	
V4526OUT	Black Lough Pomeroy SR Outlet	4943520	19/07/2024 10:55	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4943550	19/07/2024 11:00	Colony Counts 22	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4943550	19/07/2024 11:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4943550	19/07/2024 11:00	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4943550	19/07/2024 11:00	Free - Residual disinfectant	mg Cl/l	0.13	
V1350OUT	Carnaman SR Outlet	4943550	19/07/2024 11:00	Total - Residual disinfectant	mg Cl/l	0.25	
V1350OUT	Carnaman SR Outlet	4943550	19/07/2024 11:00	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4946087	22/07/2024 07:54	Colony Counts 22	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4946087	22/07/2024 07:54	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4946087	22/07/2024 07:54	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4946087	22/07/2024 07:54	Free - Residual disinfectant	mg Cl/l	0.46	
V1360OUT	Windmill Hill SR Outlet	4946087	22/07/2024 07:54	Total - Residual disinfectant	mg Cl/l	0.69	
V1360OUT	Windmill Hill SR Outlet	4946087	22/07/2024 07:54	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4946098	22/07/2024 08:14	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4946098	22/07/2024 08:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4946098	22/07/2024 08:14	E. coli	CFU/100 ml	0	0

V1357OUT	Mullaghboy Magherafelt SR Outlet	4946098	22/07/2024 08:14	Free - Residual disinfectant	mg Cl/l	0.88	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4946098	22/07/2024 08:14	Total - Residual disinfectant	mg Cl/l	1	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4946098	22/07/2024 08:14	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4946098	22/07/2024 08:14	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4946098	22/07/2024 08:14	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4946098	22/07/2024 08:14	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4946098	22/07/2024 08:14	Taste - Nature		No taste	
V4707OUT	Sidaire SR Outlet	4942720	22/07/2024 08:58	Colony Counts 22	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4942720	22/07/2024 08:58	E. coli	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4942720	22/07/2024 08:58	Free - Residual disinfectant	mg Cl/l	0.72	
V4707OUT	Sidaire SR Outlet	4942720	22/07/2024 08:58	Total - Residual disinfectant	mg Cl/l	0.86	
V4707OUT	Sidaire SR Outlet	4942720	22/07/2024 08:58	Total Coliforms	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4942755	22/07/2024 08:58	Colony Counts 22	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4942755	22/07/2024 08:58	E. coli	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4942755	22/07/2024 08:58	Free - Residual disinfectant	mg Cl/l	1.07	
V4708OUT	Cavanacross Enniskillen SR Outlet	4942755	22/07/2024 08:58	Total - Residual disinfectant	mg Cl/l	1.2	
V4708OUT	Cavanacross Enniskillen SR Outlet	4942755	22/07/2024 08:58	Total Coliforms	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4946070	22/07/2024 09:30	Colony Counts 22	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4946070	22/07/2024 09:30	E. coli	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4946070	22/07/2024 09:30	Free - Residual disinfectant	mg Cl/l	0.31	
V4539OUT	Erganagh SR Outlet	4946070	22/07/2024 09:30	Total - Residual disinfectant	mg Cl/l	0.5	
V4539OUT	Erganagh SR Outlet	4946070	22/07/2024 09:30	Total Coliforms	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4946068	22/07/2024 09:44	Colony Counts 22	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4946068	22/07/2024 09:44	E. coli	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4946068	22/07/2024 09:44	Free - Residual disinfectant	mg Cl/l	0.58	
V4538OUT	Killyclogher SR Outlet	4946068	22/07/2024 09:44	Total - Residual disinfectant	mg Cl/l	0.65	
V4538OUT	Killyclogher SR Outlet	4946068	22/07/2024 09:44	Total Coliforms	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4946102	22/07/2024 09:52	Colony Counts 22	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4946102	22/07/2024 09:52	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V1344OUT	Craigs Cookstown SR Outlet	4946102	22/07/2024 09:52	E. coli	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4946102	22/07/2024 09:52	Free - Residual disinfectant	mg Cl/l	0.41	
V1344OUT	Craigs Cookstown SR Outlet	4946102	22/07/2024 09:52	Total - Residual disinfectant	mg Cl/l	0.45	
V1344OUT	Craigs Cookstown SR Outlet	4946102	22/07/2024 09:52	Total Coliforms	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4946089	22/07/2024 10:05	Colony Counts 22	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4946089	22/07/2024 10:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4946089	22/07/2024 10:05	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4946089	22/07/2024 10:05	Free - Residual disinfectant	mg Cl/l	0.36	
V1362OUT	Unagh SR Outlet	4946089	22/07/2024 10:05	Total - Residual disinfectant	mg Cl/l	0.4	
V1362OUT	Unagh SR Outlet	4946089	22/07/2024 10:05	Total Coliforms	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4946075	22/07/2024 10:12	Colony Counts 22	CFU/1 ml	0	

V4536OUT	Lough Macrory North SR Outlet	4946075	22/07/2024 10:12	E. coli	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4946075	22/07/2024 10:12	Free - Residual disinfectant	mg Cl/l	0.77	
V4536OUT	Lough Macrory North SR Outlet	4946075	22/07/2024 10:12	Total - Residual disinfectant	mg Cl/l	0.83	
V4536OUT	Lough Macrory North SR Outlet	4946075	22/07/2024 10:12	Total Coliforms	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4946099	22/07/2024 10:27	Colony Counts 22	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4946099	22/07/2024 10:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4946099	22/07/2024 10:27	E. coli	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4946099	22/07/2024 10:27	Free - Residual disinfectant	mg Cl/l	0.64	
V1339OUT	Corvanaghan High SR Outlet	4946099	22/07/2024 10:27	Total - Residual disinfectant	mg Cl/l	0.7	
V1339OUT	Corvanaghan High SR Outlet	4946099	22/07/2024 10:27	Total Coliforms	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4946067	22/07/2024 10:27	Colony Counts 22	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4946067	22/07/2024 10:27	E. coli	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4946067	22/07/2024 10:27	Free - Residual disinfectant	mg Cl/l	0.6	
V4526OUT	Black Lough Pomeroy SR Outlet	4946067	22/07/2024 10:27	Total - Residual disinfectant	mg Cl/l	0.7	
V4526OUT	Black Lough Pomeroy SR Outlet	4946067	22/07/2024 10:27	Total Coliforms	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4946100	22/07/2024 10:41	Colony Counts 22	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4946100	22/07/2024 10:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4946100	22/07/2024 10:41	E. coli	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4946100	22/07/2024 10:41	Free - Residual disinfectant	mg Cl/l	0.65	
V1340OUT	Craigballyharkey SR Outlet	4946100	22/07/2024 10:41	Total - Residual disinfectant	mg Cl/l	0.71	
V1340OUT	Craigballyharkey SR Outlet	4946100	22/07/2024 10:41	Total Coliforms	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4946103	22/07/2024 10:52	Colony Counts 22	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4946103	22/07/2024 10:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4946103	22/07/2024 10:52	E. coli	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4946103	22/07/2024 10:52	Free - Residual disinfectant	mg Cl/l	0.47	
V1346OUT	Gortaclady Evishanoran SR Outlet	4946103	22/07/2024 10:52	Total - Residual disinfectant	mg Cl/l	0.53	
V1346OUT	Gortaclady Evishanoran SR Outlet	4946103	22/07/2024 10:52	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4946339	23/07/2024 07:14	Colony Counts 22	CFU/1 ml	27	
V1354OUT	Knockoneill SR Outlet	4946339	23/07/2024 07:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4946339	23/07/2024 07:14	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4946339	23/07/2024 07:14	Free - Residual disinfectant	mg Cl/l	0.08	
V1354OUT	Knockoneill SR Outlet	4946339	23/07/2024 07:14	Total - Residual disinfectant	mg Cl/l	0.35	
V1354OUT	Knockoneill SR Outlet	4946339	23/07/2024 07:14	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4946339	23/07/2024 07:14	Odour	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4946339	23/07/2024 07:14	Odour - Nature		No odour	
V1354OUT	Knockoneill SR Outlet	4946339	23/07/2024 07:14	Taste	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4946339	23/07/2024 07:14	Taste - Nature		No taste	
V1715OUT	Ballystrone (Calvins) SR Outlet	4946336	23/07/2024 07:32	Colony Counts 22	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4946336	23/07/2024 07:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4946336	23/07/2024 07:32	E. coli	CFU/100 ml	0	0

V1715OUT	Ballystrone (Calvins) SR Outlet	4946336	23/07/2024 07:32	Free - Residual disinfectant	mg Cl/l	0.63	
V1715OUT	Ballystrone (Calvins) SR Outlet	4946336	23/07/2024 07:32	Total - Residual disinfectant	mg Cl/l	0.74	
V1715OUT	Ballystrone (Calvins) SR Outlet	4946336	23/07/2024 07:32	Total Coliforms	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4946341	23/07/2024 07:32	Colony Counts 22	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4946341	23/07/2024 07:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4946341	23/07/2024 07:32	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4946341	23/07/2024 07:32	Free - Residual disinfectant	mg Cl/l	0.39	
V1358OUT	Slaughtneil SR Outlet	4946341	23/07/2024 07:32	Total - Residual disinfectant	mg Cl/l	0.56	
V1358OUT	Slaughtneil SR Outlet	4946341	23/07/2024 07:32	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4946333	23/07/2024 07:55	Colony Counts 22	CFU/1 ml	174	
V1349OUT	Ballyknock Magherafelt SR Outlet	4946333	23/07/2024 07:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4946333	23/07/2024 07:55	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4946333	23/07/2024 07:55	Free - Residual disinfectant	mg Cl/l	0.3	
V1349OUT	Ballyknock Magherafelt SR Outlet	4946333	23/07/2024 07:55	Total - Residual disinfectant	mg Cl/l	0.47	
V1349OUT	Ballyknock Magherafelt SR Outlet	4946333	23/07/2024 07:55	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4946260	23/07/2024 08:01	Colony Counts 22	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4946260	23/07/2024 08:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4946260	23/07/2024 08:01	E. coli	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4946260	23/07/2024 08:01	Free - Residual disinfectant	mg Cl/l	0.9	
V1725OUT	Glenlough SR Outlet	4946260	23/07/2024 08:01	Total - Residual disinfectant	mg Cl/l	1.02	
V1725OUT	Glenlough SR Outlet	4946260	23/07/2024 08:01	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4946260	23/07/2024 08:01	Odour	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4946260	23/07/2024 08:01	Odour - Nature		No odour	
V1725OUT	Glenlough SR Outlet	4946260	23/07/2024 08:01	Taste	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4946260	23/07/2024 08:01	Taste - Nature		No taste	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4946344	23/07/2024 09:18	Colony Counts 22	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4946344	23/07/2024 09:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4946344	23/07/2024 09:18	E. coli	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4946344	23/07/2024 09:18	Free - Residual disinfectant	mg Cl/l	0.51	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4946344	23/07/2024 09:18	Total - Residual disinfectant	mg Cl/l	0.55	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4946344	23/07/2024 09:18	Total Coliforms	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4946316	23/07/2024 09:38	Colony Counts 22	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4946316	23/07/2024 09:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4946316	23/07/2024 09:38	E. coli	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4946316	23/07/2024 09:38	Free - Residual disinfectant	mg Cl/l	0.94	
V2501OUT	Altmore River SR Outlet	4946316	23/07/2024 09:38	Total - Residual disinfectant	mg Cl/l	1.05	
V2501OUT	Altmore River SR Outlet	4946316	23/07/2024 09:38	Total Coliforms	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4946248	23/07/2024 09:52	Colony Counts 22	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4946248	23/07/2024 09:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4946248	23/07/2024 09:52	E. coli	CFU/100 ml	0	0

V2507OUT	Cappagh SR Outlet	4946248	23/07/2024 09:52	Free - Residual disinfectant	mg Cl/l	0.72	
V2507OUT	Cappagh SR Outlet	4946248	23/07/2024 09:52	Total - Residual disinfectant	mg Cl/l	0.78	
V2507OUT	Cappagh SR Outlet	4946248	23/07/2024 09:52	Total Coliforms	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4946348	23/07/2024 10:00	Colony Counts 22	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4946348	23/07/2024 10:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4946348	23/07/2024 10:00	E. coli	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4946348	23/07/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.64	
V4530OUT	Dungoran SR Outlet	4946348	23/07/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.71	
V4530OUT	Dungoran SR Outlet	4946348	23/07/2024 10:00	Total Coliforms	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4946247	23/07/2024 10:10	Colony Counts 22	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4946247	23/07/2024 10:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4946247	23/07/2024 10:10	E. coli	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4946247	23/07/2024 10:10	Free - Residual disinfectant	mg Cl/l	0.82	
V2505OUT	Cabragh Fasglashagh SR Outlet	4946247	23/07/2024 10:10	Total - Residual disinfectant	mg Cl/l	0.92	
V2505OUT	Cabragh Fasglashagh SR Outlet	4946247	23/07/2024 10:10	Total Coliforms	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4946340	23/07/2024 10:10	Colony Counts 22	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4946340	23/07/2024 10:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4946340	23/07/2024 10:10	E. coli	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4946340	23/07/2024 10:10	Free - Residual disinfectant	mg Cl/l	0.54	
V4535OUT	Lisnagardy SR Outlet	4946340	23/07/2024 10:10	Total - Residual disinfectant	mg Cl/l	0.6	
V4535OUT	Lisnagardy SR Outlet	4946340	23/07/2024 10:10	Total Coliforms	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4946338	23/07/2024 10:34	Colony Counts 22	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4946338	23/07/2024 10:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4946338	23/07/2024 10:34	E. coli	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4946338	23/07/2024 10:34	Free - Residual disinfectant	mg Cl/l	0.27	
V4719OUT	Glenchuil SR Outlet	4946338	23/07/2024 10:34	Total - Residual disinfectant	mg Cl/l	0.4	
V4719OUT	Glenchuil SR Outlet	4946338	23/07/2024 10:34	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4946094	23/07/2024 10:52	Colony Counts 22	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4946094	23/07/2024 10:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4946094	23/07/2024 10:52	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4946094	23/07/2024 10:52	Free - Residual disinfectant	mg Cl/l	0.14	
V1350OUT	Carnaman SR Outlet	4946094	23/07/2024 10:52	Total - Residual disinfectant	mg Cl/l	0.31	
V1350OUT	Carnaman SR Outlet	4946094	23/07/2024 10:52	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4946094	23/07/2024 10:52	Odour	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4946094	23/07/2024 10:52	Odour - Nature		No odour	
V1350OUT	Carnaman SR Outlet	4946094	23/07/2024 10:52	Taste	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4946094	23/07/2024 10:52	Taste - Nature		No taste	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4946545	24/07/2024 08:46	Colony Counts 22	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4946545	24/07/2024 08:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4946545	24/07/2024 08:46	E. coli	CFU/100 ml	0	0

V1365OUT	Lough Fea North (Blacks) SR Outlet	4946545	24/07/2024 08:46	Free - Residual disinfectant	mg Cl/l	0.81	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4946545	24/07/2024 08:46	Total - Residual disinfectant	mg Cl/l	0.86	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4946545	24/07/2024 08:46	Total Coliforms	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4946305	24/07/2024 08:48	Colony Counts 22	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4946305	24/07/2024 08:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4946305	24/07/2024 08:48	E. coli	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4946305	24/07/2024 08:48	Free - Residual disinfectant	mg Cl/l	0.78	
V4707OUT	Sidaire SR Outlet	4946305	24/07/2024 08:48	Total - Residual disinfectant	mg Cl/l	0.85	
V4707OUT	Sidaire SR Outlet	4946305	24/07/2024 08:48	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4946558	24/07/2024 09:26	Colony Counts 22	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4946558	24/07/2024 09:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4946558	24/07/2024 09:26	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4946558	24/07/2024 09:26	Free - Residual disinfectant	mg Cl/l	0.24	
V1348OUT	Moydamlaght Draperstown SR Outlet	4946558	24/07/2024 09:26	Total - Residual disinfectant	mg Cl/l	0.42	
V1348OUT	Moydamlaght Draperstown SR Outlet	4946558	24/07/2024 09:26	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4946473	24/07/2024 09:39	Colony Counts 22	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4946473	24/07/2024 09:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4946473	24/07/2024 09:39	E. coli	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4946473	24/07/2024 09:39	Free - Residual disinfectant	mg Cl/l	0.89	
V2301OUT	Ballydougan Command SR Outlet	4946473	24/07/2024 09:39	Total - Residual disinfectant	mg Cl/l	0.98	
V2301OUT	Ballydougan Command SR Outlet	4946473	24/07/2024 09:39	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4946473	24/07/2024 09:39	Odour	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4946473	24/07/2024 09:39	Odour - Nature		No odour	
V2301OUT	Ballydougan Command SR Outlet	4946473	24/07/2024 09:39	Taste	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4946473	24/07/2024 09:39	Taste - Nature		No taste	
V4719OUT	Glenchuil SR Outlet	4942748	24/07/2024 09:45	Colony Counts 22	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4942748	24/07/2024 09:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4942748	24/07/2024 09:45	E. coli	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4942748	24/07/2024 09:45	Free - Residual disinfectant	mg Cl/l	0.31	
V4719OUT	Glenchuil SR Outlet	4942748	24/07/2024 09:45	Total - Residual disinfectant	mg Cl/l	0.45	
V4719OUT	Glenchuil SR Outlet	4942748	24/07/2024 09:45	Total Coliforms	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4946474	24/07/2024 09:55	Colony Counts 22	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4946474	24/07/2024 09:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4946474	24/07/2024 09:55	E. coli	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4946474	24/07/2024 09:55	Free - Residual disinfectant	mg Cl/l	0.78	
V2302OUT	Ballyhannon SR Outlet	4946474	24/07/2024 09:55	Total - Residual disinfectant	mg Cl/l	0.89	
V2302OUT	Ballyhannon SR Outlet	4946474	24/07/2024 09:55	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4946563	24/07/2024 09:56	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4946563	24/07/2024 09:56	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V1356OUT	Mormeal SR Outlet	4946563	24/07/2024 09:56	E. coli	CFU/100 ml	0	0

V1356OUT	Mormeal SR Outlet	4946563	24/07/2024 09:56	Free - Residual disinfectant	mg Cl/l	0.35	
V1356OUT	Mormeal SR Outlet	4946563	24/07/2024 09:56	Total - Residual disinfectant	mg Cl/l	0.45	
V1356OUT	Mormeal SR Outlet	4946563	24/07/2024 09:56	Total Coliforms	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4946536	24/07/2024 10:04	Colony Counts 22	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4946536	24/07/2024 10:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4946536	24/07/2024 10:04	E. coli	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4946536	24/07/2024 10:04	Free - Residual disinfectant	mg Cl/l	0.72	
V4540OUT	Radergan SR Outlet	4946536	24/07/2024 10:04	Total - Residual disinfectant	mg Cl/l	0.81	
V4540OUT	Radergan SR Outlet	4946536	24/07/2024 10:04	Total Coliforms	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4946561	24/07/2024 10:21	Colony Counts 22	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4946561	24/07/2024 10:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4946561	24/07/2024 10:21	E. coli	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4946561	24/07/2024 10:21	Free - Residual disinfectant	mg Cl/l	0.77	
V4531OUT	Foremass SR Outlet	4946561	24/07/2024 10:21	Total - Residual disinfectant	mg Cl/l	0.85	
V4531OUT	Foremass SR Outlet	4946561	24/07/2024 10:21	Total Coliforms	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4946564	24/07/2024 10:41	Colony Counts 22	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4946564	24/07/2024 10:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4946564	24/07/2024 10:41	E. coli	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4946564	24/07/2024 10:41	Free - Residual disinfectant	mg Cl/l	0.77	
V4537OUT	Sixmilecross SR Outlet	4946564	24/07/2024 10:41	Total - Residual disinfectant	mg Cl/l	0.86	
V4537OUT	Sixmilecross SR Outlet	4946564	24/07/2024 10:41	Total Coliforms	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4946568	24/07/2024 11:04	Colony Counts 22	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4946568	24/07/2024 11:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4946568	24/07/2024 11:04	E. coli	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4946568	24/07/2024 11:04	Free - Residual disinfectant	mg Cl/l	0.49	
V4528OUT	Crocknabohil SR Outlet	4946568	24/07/2024 11:04	Total - Residual disinfectant	mg Cl/l	0.63	
V4528OUT	Crocknabohil SR Outlet	4946568	24/07/2024 11:04	Total Coliforms	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4946310	24/07/2024 11:45	Colony Counts 22	CFU/1 ml	172	
V4527OUT	Carryglass SR Outlet	4946310	24/07/2024 11:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4946310	24/07/2024 11:45	E. coli	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4946310	24/07/2024 11:45	Free - Residual disinfectant	mg Cl/l	0.5	
V4527OUT	Carryglass SR Outlet	4946310	24/07/2024 11:45	Total - Residual disinfectant	mg Cl/l	0.63	
V4527OUT	Carryglass SR Outlet	4946310	24/07/2024 11:45	Total Coliforms	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4946747	25/07/2024 07:23	Colony Counts 22	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4946747	25/07/2024 07:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4946747	25/07/2024 07:23	E. coli	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4946747	25/07/2024 07:23	Free - Residual disinfectant	mg Cl/l	0.65	
V1702OUT	Cam SR Outlet	4946747	25/07/2024 07:23	Total - Residual disinfectant	mg Cl/l	0.8	
V1702OUT	Cam SR Outlet	4946747	25/07/2024 07:23	Total Coliforms	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4946745	25/07/2024 07:48	Colony Counts 22	CFU/1 ml	0	

V1706OUT	Killeague SR Outlet	4946745	25/07/2024 07:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4946745	25/07/2024 07:48	E. coli	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4946745	25/07/2024 07:48	Free - Residual disinfectant	mg Cl/l	0.54	
V1706OUT	Killeague SR Outlet	4946745	25/07/2024 07:48	Total - Residual disinfectant	mg Cl/l	0.68	
V1706OUT	Killeague SR Outlet	4946745	25/07/2024 07:48	Total Coliforms	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4946753	25/07/2024 07:58	Colony Counts 22	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4946753	25/07/2024 07:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4946753	25/07/2024 07:58	E. coli	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4946753	25/07/2024 07:58	Free - Residual disinfectant	mg Cl/l	0.64	
V1351OUT	Cranny Moneymore SR Outlet	4946753	25/07/2024 07:58	Total - Residual disinfectant	mg Cl/l	0.71	
V1351OUT	Cranny Moneymore SR Outlet	4946753	25/07/2024 07:58	Total Coliforms	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4946749	25/07/2024 08:13	Colony Counts 22	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4946749	25/07/2024 08:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4946749	25/07/2024 08:13	E. coli	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4946749	25/07/2024 08:13	Free - Residual disinfectant	mg Cl/l	0.37	
V1708OUT	North Garvagh SR Outlet	4946749	25/07/2024 08:13	Total - Residual disinfectant	mg Cl/l	0.48	
V1708OUT	North Garvagh SR Outlet	4946749	25/07/2024 08:13	Total Coliforms	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4946741	25/07/2024 08:20	Colony Counts 22	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4946741	25/07/2024 08:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4946741	25/07/2024 08:20	E. coli	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4946741	25/07/2024 08:20	Free - Residual disinfectant	mg Cl/l	0.14	
V1352OUT	Cullion Desertmartin SR Outlet	4946741	25/07/2024 08:20	Total - Residual disinfectant	mg Cl/l	0.24	
V1352OUT	Cullion Desertmartin SR Outlet	4946741	25/07/2024 08:20	Total Coliforms	CFU/100 ml	0	0
V1713OUT	Trientalenagh SR Outlet	4946752	25/07/2024 08:34	Colony Counts 22	CFU/1 ml	0	
V1713OUT	Trientalenagh SR Outlet	4946752	25/07/2024 08:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1713OUT	Trientalenagh SR Outlet	4946752	25/07/2024 08:34	E. coli	CFU/100 ml	0	0
V1713OUT	Trientalenagh SR Outlet	4946752	25/07/2024 08:34	Free - Residual disinfectant	mg Cl/l	0.35	
V1713OUT	Trientalenagh SR Outlet	4946752	25/07/2024 08:34	Total - Residual disinfectant	mg Cl/l	0.47	
V1713OUT	Trientalenagh SR Outlet	4946752	25/07/2024 08:34	Total Coliforms	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4946764	25/07/2024 08:42	Colony Counts 22	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4946764	25/07/2024 08:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4946764	25/07/2024 08:42	E. coli	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4946764	25/07/2024 08:42	Free - Residual disinfectant	mg Cl/l	0.63	
V1343OUT	Ballybriest SR Outlet	4946764	25/07/2024 08:42	Total - Residual disinfectant	mg Cl/l	0.74	
V1343OUT	Ballybriest SR Outlet	4946764	25/07/2024 08:42	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4942714	25/07/2024 09:05	Colony Counts 22	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4942714	25/07/2024 09:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4942714	25/07/2024 09:05	E. coli	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4942714	25/07/2024 09:05	Free - Residual disinfectant	mg Cl/l	0.52	
V1725OUT	Glenlough SR Outlet	4942714	25/07/2024 09:05	Total - Residual disinfectant	mg Cl/l	0.65	

V1725OUT	Glenlough SR Outlet	4942714	25/07/2024 09:05	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4942714	25/07/2024 09:05	Odour	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4942714	25/07/2024 09:05	Odour - Nature		No odour	
V1725OUT	Glenlough SR Outlet	4942714	25/07/2024 09:05	Taste	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4942714	25/07/2024 09:05	Taste - Nature		No taste	
V2508OUT	Carland SR Outlet	4946653	25/07/2024 09:20	Colony Counts 22	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4946653	25/07/2024 09:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4946653	25/07/2024 09:20	E. coli	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4946653	25/07/2024 09:20	Free - Residual disinfectant	mg Cl/l	0.96	
V2508OUT	Carland SR Outlet	4946653	25/07/2024 09:20	Total - Residual disinfectant	mg Cl/l	1.06	
V2508OUT	Carland SR Outlet	4946653	25/07/2024 09:20	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4946653	25/07/2024 09:20	Odour	Diln No	0	0
V2508OUT	Carland SR Outlet	4946653	25/07/2024 09:20	Odour - Nature		No odour	
V2508OUT	Carland SR Outlet	4946653	25/07/2024 09:20	Taste	Diln No	0	0
V2508OUT	Carland SR Outlet	4946653	25/07/2024 09:20	Taste - Nature		No taste	
V2509OUT	Castlehill Drumcoo SR Outlet	4946654	25/07/2024 09:45	Colony Counts 22	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4946654	25/07/2024 09:45	Colony Counts 37 (48hrs)	CFU/1 ml	16	
V2509OUT	Castlehill Drumcoo SR Outlet	4946654	25/07/2024 09:45	E. coli	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4946654	25/07/2024 09:45	Free - Residual disinfectant	mg Cl/l	0.62	
V2509OUT	Castlehill Drumcoo SR Outlet	4946654	25/07/2024 09:45	Total - Residual disinfectant	mg Cl/l	0.71	
V2509OUT	Castlehill Drumcoo SR Outlet	4946654	25/07/2024 09:45	Total Coliforms	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4946726	25/07/2024 10:05	Colony Counts 22	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4946726	25/07/2024 10:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4946726	25/07/2024 10:05	E. coli	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4946726	25/07/2024 10:05	Free - Residual disinfectant	mg Cl/l	1.1	
V2521OUT	Mullaghanagh SR Outlet	4946726	25/07/2024 10:05	Total - Residual disinfectant	mg Cl/l	1.25	
V2521OUT	Mullaghanagh SR Outlet	4946726	25/07/2024 10:05	Total Coliforms	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4946740	25/07/2024 10:45	Colony Counts 22	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4946740	25/07/2024 10:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4946740	25/07/2024 10:45	E. coli	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4946740	25/07/2024 10:45	Free - Residual disinfectant	mg Cl/l	0.72	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4946740	25/07/2024 10:45	Total - Residual disinfectant	mg Cl/l	0.79	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4946740	25/07/2024 10:45	Total Coliforms	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4946748	25/07/2024 11:01	Colony Counts 22	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4946748	25/07/2024 11:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4946748	25/07/2024 11:01	E. coli	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4946748	25/07/2024 11:01	Free - Residual disinfectant	mg Cl/l	0.9	
V4742OUT	Tattinbar SR Outlet	4946748	25/07/2024 11:01	Total - Residual disinfectant	mg Cl/l	1.02	
V4742OUT	Tattinbar SR Outlet	4946748	25/07/2024 11:01	Total Coliforms	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4946766	25/07/2024 11:24	Colony Counts 22	CFU/1 ml	0	

V4715OUT	Brookeborough High SR Outlet	4946766	25/07/2024 11:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4946766	25/07/2024 11:24	E. coli	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4946766	25/07/2024 11:24	Free - Residual disinfectant	mg Cl/l	0.81	
V4715OUT	Brookeborough High SR Outlet	4946766	25/07/2024 11:24	Total - Residual disinfectant	mg Cl/l	0.92	
V4715OUT	Brookeborough High SR Outlet	4946766	25/07/2024 11:24	Total Coliforms	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4942723	25/07/2024 11:43	Colony Counts 22	CFU/1 ml	70	
V4527OUT	Carryglass SR Outlet	4942723	25/07/2024 11:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4942723	25/07/2024 11:43	E. coli	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4942723	25/07/2024 11:43	Free - Residual disinfectant	mg Cl/l	0.38	
V4527OUT	Carryglass SR Outlet	4942723	25/07/2024 11:43	Total - Residual disinfectant	mg Cl/l	0.51	
V4527OUT	Carryglass SR Outlet	4942723	25/07/2024 11:43	Total Coliforms	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4942746	25/07/2024 11:45	Colony Counts 22	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4942746	25/07/2024 11:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4942746	25/07/2024 11:45	E. coli	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4942746	25/07/2024 11:45	Free - Residual disinfectant	mg Cl/l	0.73	
V1715OUT	Ballystrone (Calvins) SR Outlet	4942746	25/07/2024 11:45	Total - Residual disinfectant	mg Cl/l	0.85	
V1715OUT	Ballystrone (Calvins) SR Outlet	4942746	25/07/2024 11:45	Total Coliforms	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4946750	25/07/2024 11:55	Colony Counts 22	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4946750	25/07/2024 11:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4946750	25/07/2024 11:55	E. coli	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4946750	25/07/2024 11:55	Free - Residual disinfectant	mg Cl/l	0.67	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4946750	25/07/2024 11:55	Total - Residual disinfectant	mg Cl/l	0.75	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4946750	25/07/2024 11:55	Total Coliforms	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4946923	26/07/2024 08:51	Colony Counts 22	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4946923	26/07/2024 08:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4946923	26/07/2024 08:51	E. coli	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4946923	26/07/2024 08:51	Free - Residual disinfectant	mg Cl/l	0.35	
V1338OUT	Coagh SR Outlet	4946923	26/07/2024 08:51	Total - Residual disinfectant	mg Cl/l	0.41	
V1338OUT	Coagh SR Outlet	4946923	26/07/2024 08:51	Total Coliforms	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4946922	26/07/2024 09:10	Colony Counts 22	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4946922	26/07/2024 09:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4946922	26/07/2024 09:10	E. coli	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4946922	26/07/2024 09:10	Free - Residual disinfectant	mg Cl/l	0.55	
V1335OUT	Brigh Quarry SR Outlet	4946922	26/07/2024 09:10	Total - Residual disinfectant	mg Cl/l	0.64	
V1335OUT	Brigh Quarry SR Outlet	4946922	26/07/2024 09:10	Total Coliforms	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4946848	26/07/2024 09:12	Colony Counts 22	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4946848	26/07/2024 09:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4946848	26/07/2024 09:12	E. coli	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4946848	26/07/2024 09:12	Free - Residual disinfectant	mg Cl/l	0.81	
V2511OUT	Corran Armagh SR Outlet	4946848	26/07/2024 09:12	Total - Residual disinfectant	mg Cl/l	0.87	

V2511OUT	Corran Armagh SR Outlet	4946848	26/07/2024 09:12	Total Coliforms	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4946926	26/07/2024 09:32	Colony Counts 22	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4946926	26/07/2024 09:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4946926	26/07/2024 09:32	E. coli	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4946926	26/07/2024 09:32	Free - Residual disinfectant	mg Cl/l	0.56	
V1342OUT	Dromore High SR Outlet	4946926	26/07/2024 09:32	Total - Residual disinfectant	mg Cl/l	0.61	
V1342OUT	Dromore High SR Outlet	4946926	26/07/2024 09:32	Total Coliforms	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4946847	26/07/2024 09:33	Colony Counts 22	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4946847	26/07/2024 09:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4946847	26/07/2024 09:33	E. coli	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4946847	26/07/2024 09:33	Free - Residual disinfectant	mg Cl/l	0.3	
V2510OUT	Calone SR Outlet	4946847	26/07/2024 09:33	Total - Residual disinfectant	mg Cl/l	0.61	
V2510OUT	Calone SR Outlet	4946847	26/07/2024 09:33	Total Coliforms	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4946345	26/07/2024 09:38	Colony Counts 22	CFU/1 ml	2	
V4708OUT	Cavanacross Enniskillen SR Outlet	4946345	26/07/2024 09:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4946345	26/07/2024 09:38	E. coli	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4946345	26/07/2024 09:38	Free - Residual disinfectant	mg Cl/l	1.08	
V4708OUT	Cavanacross Enniskillen SR Outlet	4946345	26/07/2024 09:38	Total - Residual disinfectant	mg Cl/l	1.14	
V4708OUT	Cavanacross Enniskillen SR Outlet	4946345	26/07/2024 09:38	Total Coliforms	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4946887	26/07/2024 09:48	Colony Counts 22	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4946887	26/07/2024 09:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4946887	26/07/2024 09:48	E. coli	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4946887	26/07/2024 09:48	Free - Residual disinfectant	mg Cl/l	0.65	
V2514OUT	Edenaveys Command SR Outlet	4946887	26/07/2024 09:48	Total - Residual disinfectant	mg Cl/l	0.89	
V2514OUT	Edenaveys Command SR Outlet	4946887	26/07/2024 09:48	Total Coliforms	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4946888	26/07/2024 09:55	Colony Counts 22	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4946888	26/07/2024 09:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4946888	26/07/2024 09:55	E. coli	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4946888	26/07/2024 09:55	Free - Residual disinfectant	mg Cl/l	0.9	
V2518OUT	Lisnastrane SR Outlet	4946888	26/07/2024 09:55	Total - Residual disinfectant	mg Cl/l	0.95	
V2518OUT	Lisnastrane SR Outlet	4946888	26/07/2024 09:55	Total Coliforms	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4946919	26/07/2024 10:06	Colony Counts 22	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4946919	26/07/2024 10:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4946919	26/07/2024 10:06	E. coli	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4946919	26/07/2024 10:06	Free - Residual disinfectant	mg Cl/l	0.8	
V4533OUT	Inisclan SR Outlet	4946919	26/07/2024 10:06	Total - Residual disinfectant	mg Cl/l	0.87	
V4533OUT	Inisclan SR Outlet	4946919	26/07/2024 10:06	Total Coliforms	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4946844	26/07/2024 10:10	Colony Counts 22	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4946844	26/07/2024 10:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4946844	26/07/2024 10:10	E. coli	CFU/100 ml	0	0

V2523OUT	Rough Fort SR Outlet	4946844	26/07/2024 10:10	Free - Residual disinfectant	mg Cl/l	0.85	
V2523OUT	Rough Fort SR Outlet	4946844	26/07/2024 10:10	Total - Residual disinfectant	mg Cl/l	1.05	
V2523OUT	Rough Fort SR Outlet	4946844	26/07/2024 10:10	Total Coliforms	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4942758	26/07/2024 10:40	Colony Counts 22	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4942758	26/07/2024 10:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4942758	26/07/2024 10:40	E. coli	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4942758	26/07/2024 10:40	Free - Residual disinfectant	mg Cl/l	0.43	
V4530OUT	Dungoran SR Outlet	4942758	26/07/2024 10:40	Total - Residual disinfectant	mg Cl/l	0.6	
V4530OUT	Dungoran SR Outlet	4942758	26/07/2024 10:40	Total Coliforms	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4942750	26/07/2024 10:50	Colony Counts 22	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4942750	26/07/2024 10:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4942750	26/07/2024 10:50	E. coli	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4942750	26/07/2024 10:50	Free - Residual disinfectant	mg Cl/l	0.66	
V4535OUT	Lisnagardy SR Outlet	4942750	26/07/2024 10:50	Total - Residual disinfectant	mg Cl/l	0.73	
V4535OUT	Lisnagardy SR Outlet	4942750	26/07/2024 10:50	Total Coliforms	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4946751	26/07/2024 11:02	Colony Counts 22	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4946751	26/07/2024 11:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4946751	26/07/2024 11:02	E. coli	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4946751	26/07/2024 11:02	Free - Residual disinfectant	mg Cl/l	0.72	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4946751	26/07/2024 11:02	Total - Residual disinfectant	mg Cl/l	0.79	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4946751	26/07/2024 11:02	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4946914	26/07/2024 11:42	Colony Counts 22	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4946914	26/07/2024 11:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4946914	26/07/2024 11:42	E. coli	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4946914	26/07/2024 11:42	Free - Residual disinfectant	mg Cl/l	0.46	
V1704OUT	Castlerock Downhill SR Outlet	4946914	26/07/2024 11:42	Total - Residual disinfectant	mg Cl/l	0.58	
V1704OUT	Castlerock Downhill SR Outlet	4946914	26/07/2024 11:42	Total Coliforms	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4946915	26/07/2024 12:01	Colony Counts 22	CFU/1 ml	0	
V1711OUT	Sconce Hill SR Outlet	4946915	26/07/2024 12:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1711OUT	Sconce Hill SR Outlet	4946915	26/07/2024 12:01	E. coli	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4946915	26/07/2024 12:01	Free - Residual disinfectant	mg Cl/l	0.56	
V1711OUT	Sconce Hill SR Outlet	4946915	26/07/2024 12:01	Total - Residual disinfectant	mg Cl/l	0.67	
V1711OUT	Sconce Hill SR Outlet	4946915	26/07/2024 12:01	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4949229	29/07/2024 07:31	Colony Counts 22	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4949229	29/07/2024 07:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4949229	29/07/2024 07:31	E. coli	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4949229	29/07/2024 07:31	Free - Residual disinfectant	mg Cl/l	0.43	
V1704OUT	Castlerock Downhill SR Outlet	4949229	29/07/2024 07:31	Total - Residual disinfectant	mg Cl/l	0.58	
V1704OUT	Castlerock Downhill SR Outlet	4949229	29/07/2024 07:31	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4949229	29/07/2024 07:31	Odour	Diln No	0	0

V1704OUT	Castlerock Downhill SR Outlet	4949229	29/07/2024 07:31	Odour - Nature		No odour	
V1704OUT	Castlerock Downhill SR Outlet	4949229	29/07/2024 07:31	Taste	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4949229	29/07/2024 07:31	Taste - Nature		No taste	
V1711OUT	Sconce Hill SR Outlet	4949230	29/07/2024 07:51	Colony Counts 22	CFU/1 ml	1	
V1711OUT	Sconce Hill SR Outlet	4949230	29/07/2024 07:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1711OUT	Sconce Hill SR Outlet	4949230	29/07/2024 07:51	E. coli	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4949230	29/07/2024 07:51	Free - Residual disinfectant	mg Cl/l	0.59	
V1711OUT	Sconce Hill SR Outlet	4949230	29/07/2024 07:51	Total - Residual disinfectant	mg Cl/l	0.8	
V1711OUT	Sconce Hill SR Outlet	4949230	29/07/2024 07:51	Total Coliforms	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4949238	29/07/2024 09:05	Colony Counts 22	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4949238	29/07/2024 09:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4949238	29/07/2024 09:05	E. coli	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4949238	29/07/2024 09:05	Free - Residual disinfectant	mg Cl/l	0.35	
V1338OUT	Coagh SR Outlet	4949238	29/07/2024 09:05	Total - Residual disinfectant	mg Cl/l	0.42	
V1338OUT	Coagh SR Outlet	4949238	29/07/2024 09:05	Total Coliforms	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4949237	29/07/2024 09:23	Colony Counts 22	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4949237	29/07/2024 09:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4949237	29/07/2024 09:23	E. coli	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4949237	29/07/2024 09:23	Free - Residual disinfectant	mg Cl/l	0.53	
V1335OUT	Brigh Quarry SR Outlet	4949237	29/07/2024 09:23	Total - Residual disinfectant	mg Cl/l	0.58	
V1335OUT	Brigh Quarry SR Outlet	4949237	29/07/2024 09:23	Total Coliforms	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4946929	29/07/2024 09:25	Colony Counts 22	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4946929	29/07/2024 09:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4946929	29/07/2024 09:25	E. coli	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4946929	29/07/2024 09:25	Free - Residual disinfectant	mg Cl/l	0.51	
V4713OUT	Knocknalosset SR Outlet	4946929	29/07/2024 09:25	Total - Residual disinfectant	mg Cl/l	0.64	
V4713OUT	Knocknalosset SR Outlet	4946929	29/07/2024 09:25	Total Coliforms	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4949241	29/07/2024 09:38	Colony Counts 22	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4949241	29/07/2024 09:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4949241	29/07/2024 09:38	E. coli	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4949241	29/07/2024 09:38	Free - Residual disinfectant	mg Cl/l	0.49	
V1342OUT	Dromore High SR Outlet	4949241	29/07/2024 09:38	Total - Residual disinfectant	mg Cl/l	0.54	
V1342OUT	Dromore High SR Outlet	4949241	29/07/2024 09:38	Total Coliforms	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4946927	29/07/2024 09:41	Colony Counts 22	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4946927	29/07/2024 09:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4946927	29/07/2024 09:41	E. coli	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4946927	29/07/2024 09:41	Free - Residual disinfectant	mg Cl/l	0.62	
V4712OUT	Corranny SR Outlet	4946927	29/07/2024 09:41	Total - Residual disinfectant	mg Cl/l	0.7	
V4712OUT	Corranny SR Outlet	4946927	29/07/2024 09:41	Total Coliforms	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4949210	29/07/2024 10:00	Colony Counts 22	CFU/1 ml	0	

V2518OUT	Lisnastrane SR Outlet	4949210	29/07/2024 10:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4949210	29/07/2024 10:00	E. coli	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4949210	29/07/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.81	
V2518OUT	Lisnastrane SR Outlet	4949210	29/07/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.9	
V2518OUT	Lisnastrane SR Outlet	4949210	29/07/2024 10:00	Total Coliforms	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4949234	29/07/2024 10:11	Colony Counts 22	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4949234	29/07/2024 10:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4949234	29/07/2024 10:11	E. coli	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4949234	29/07/2024 10:11	Free - Residual disinfectant	mg Cl/l	0.64	
V4533OUT	Inisclan SR Outlet	4949234	29/07/2024 10:11	Total - Residual disinfectant	mg Cl/l	0.73	
V4533OUT	Inisclan SR Outlet	4949234	29/07/2024 10:11	Total Coliforms	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4949202	29/07/2024 10:14	Colony Counts 22	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4949202	29/07/2024 10:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4949202	29/07/2024 10:14	E. coli	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4949202	29/07/2024 10:14	Free - Residual disinfectant	mg Cl/l	0.77	
V2511OUT	Corran Armagh SR Outlet	4949202	29/07/2024 10:14	Total - Residual disinfectant	mg Cl/l	1	
V2511OUT	Corran Armagh SR Outlet	4949202	29/07/2024 10:14	Total Coliforms	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4949201	29/07/2024 10:57	Colony Counts 22	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4949201	29/07/2024 10:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4949201	29/07/2024 10:57	E. coli	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4949201	29/07/2024 10:57	Free - Residual disinfectant	mg Cl/l	0.41	
V2510OUT	Calone SR Outlet	4949201	29/07/2024 10:57	Total - Residual disinfectant	mg Cl/l	0.62	
V2510OUT	Calone SR Outlet	4949201	29/07/2024 10:57	Total Coliforms	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4949209	29/07/2024 11:14	Colony Counts 22	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4949209	29/07/2024 11:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4949209	29/07/2024 11:14	E. coli	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4949209	29/07/2024 11:14	Free - Residual disinfectant	mg Cl/l	0.66	
V2514OUT	Edenaveys Command SR Outlet	4949209	29/07/2024 11:14	Total - Residual disinfectant	mg Cl/l	0.92	
V2514OUT	Edenaveys Command SR Outlet	4949209	29/07/2024 11:14	Total Coliforms	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4949198	29/07/2024 11:38	Colony Counts 22	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4949198	29/07/2024 11:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4949198	29/07/2024 11:38	E. coli	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4949198	29/07/2024 11:38	Free - Residual disinfectant	mg Cl/l	0.85	
V2523OUT	Rough Fort SR Outlet	4949198	29/07/2024 11:38	Total - Residual disinfectant	mg Cl/l	1.09	
V2523OUT	Rough Fort SR Outlet	4949198	29/07/2024 11:38	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4949554	30/07/2024 08:25	Colony Counts 22	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4949554	30/07/2024 08:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4949554	30/07/2024 08:25	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4949554	30/07/2024 08:25	Free - Residual disinfectant	mg Cl/l	0.31	
V1350OUT	Carnaman SR Outlet	4949554	30/07/2024 08:25	Total - Residual disinfectant	mg Cl/l	0.39	

V1350OUT	Carnaman SR Outlet	4949554	30/07/2024 08:25	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4949554	30/07/2024 08:25	Odour	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4949554	30/07/2024 08:25	Odour - Nature		No odour	
V1350OUT	Carnaman SR Outlet	4949554	30/07/2024 08:25	Taste	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4949554	30/07/2024 08:25	Taste - Nature		No taste	
V1360OUT	Windmill Hill SR Outlet	4949547	30/07/2024 08:55	Colony Counts 22	CFU/1 ml	7	
V1360OUT	Windmill Hill SR Outlet	4949547	30/07/2024 08:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4949547	30/07/2024 08:55	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4949547	30/07/2024 08:55	Free - Residual disinfectant	mg Cl/l	0.65	
V1360OUT	Windmill Hill SR Outlet	4949547	30/07/2024 08:55	Total - Residual disinfectant	mg Cl/l	0.77	
V1360OUT	Windmill Hill SR Outlet	4949547	30/07/2024 08:55	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4949558	30/07/2024 09:16	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4949558	30/07/2024 09:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4949558	30/07/2024 09:16	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4949558	30/07/2024 09:16	Free - Residual disinfectant	mg Cl/l	0.75	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4949558	30/07/2024 09:16	Total - Residual disinfectant	mg Cl/l	0.87	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4949558	30/07/2024 09:16	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4949558	30/07/2024 09:16	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4949558	30/07/2024 09:16	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4949558	30/07/2024 09:16	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4949558	30/07/2024 09:16	Taste - Nature		No taste	
V1344OUT	Craigs Cookstown SR Outlet	4949562	30/07/2024 09:17	Colony Counts 22	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4949562	30/07/2024 09:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4949562	30/07/2024 09:17	E. coli	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4949562	30/07/2024 09:17	Free - Residual disinfectant	mg Cl/l	0.35	
V1344OUT	Craigs Cookstown SR Outlet	4949562	30/07/2024 09:17	Total - Residual disinfectant	mg Cl/l	0.4	
V1344OUT	Craigs Cookstown SR Outlet	4949562	30/07/2024 09:17	Total Coliforms	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4949549	30/07/2024 09:35	Colony Counts 22	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4949549	30/07/2024 09:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4949549	30/07/2024 09:35	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4949549	30/07/2024 09:35	Free - Residual disinfectant	mg Cl/l	0.27	
V1362OUT	Unagh SR Outlet	4949549	30/07/2024 09:35	Total - Residual disinfectant	mg Cl/l	0.34	
V1362OUT	Unagh SR Outlet	4949549	30/07/2024 09:35	Total Coliforms	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4949559	30/07/2024 09:57	Colony Counts 22	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4949559	30/07/2024 09:57	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V1339OUT	Corvanaghan High SR Outlet	4949559	30/07/2024 09:57	E. coli	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4949559	30/07/2024 09:57	Free - Residual disinfectant	mg Cl/l	0.62	
V1339OUT	Corvanaghan High SR Outlet	4949559	30/07/2024 09:57	Total - Residual disinfectant	mg Cl/l	0.67	
V1339OUT	Corvanaghan High SR Outlet	4949559	30/07/2024 09:57	Total Coliforms	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4949524	30/07/2024 10:04	Colony Counts 22	CFU/1 ml	0	

V4526OUT	Black Lough Pomeroy SR Outlet	4949524	30/07/2024 10:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4949524	30/07/2024 10:04	E. coli	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4949524	30/07/2024 10:04	Free - Residual disinfectant	mg Cl/l	0.55	
V4526OUT	Black Lough Pomeroy SR Outlet	4949524	30/07/2024 10:04	Total - Residual disinfectant	mg Cl/l	0.7	
V4526OUT	Black Lough Pomeroy SR Outlet	4949524	30/07/2024 10:04	Total Coliforms	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4949560	30/07/2024 10:11	Colony Counts 22	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4949560	30/07/2024 10:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4949560	30/07/2024 10:11	E. coli	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4949560	30/07/2024 10:11	Free - Residual disinfectant	mg Cl/l	0.65	
V1340OUT	Craigballyharkey SR Outlet	4949560	30/07/2024 10:11	Total - Residual disinfectant	mg Cl/l	0.7	
V1340OUT	Craigballyharkey SR Outlet	4949560	30/07/2024 10:11	Total Coliforms	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4949535	30/07/2024 10:23	Colony Counts 22	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4949535	30/07/2024 10:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4949535	30/07/2024 10:23	E. coli	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4949535	30/07/2024 10:23	Free - Residual disinfectant	mg Cl/l	0.81	
V4536OUT	Lough Macrory North SR Outlet	4949535	30/07/2024 10:23	Total - Residual disinfectant	mg Cl/l	0.88	
V4536OUT	Lough Macrory North SR Outlet	4949535	30/07/2024 10:23	Total Coliforms	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4949563	30/07/2024 10:26	Colony Counts 22	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4949563	30/07/2024 10:26	Colony Counts 37 (48hrs)	CFU/1 ml	2	
V1346OUT	Gortaclady Evishanoran SR Outlet	4949563	30/07/2024 10:26	E. coli	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4949563	30/07/2024 10:26	Free - Residual disinfectant	mg Cl/l	0.27	
V1346OUT	Gortaclady Evishanoran SR Outlet	4949563	30/07/2024 10:26	Total - Residual disinfectant	mg Cl/l	0.34	
V1346OUT	Gortaclady Evishanoran SR Outlet	4949563	30/07/2024 10:26	Total Coliforms	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4949525	30/07/2024 11:02	Colony Counts 22	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4949525	30/07/2024 11:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4949525	30/07/2024 11:02	E. coli	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4949525	30/07/2024 11:02	Free - Residual disinfectant	mg Cl/l	0.54	
V4538OUT	Killyclogher SR Outlet	4949525	30/07/2024 11:02	Total - Residual disinfectant	mg Cl/l	0.66	
V4538OUT	Killyclogher SR Outlet	4949525	30/07/2024 11:02	Total Coliforms	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4949527	30/07/2024 11:25	Colony Counts 22	CFU/1 ml	19	
V4539OUT	Erganagh SR Outlet	4949527	30/07/2024 11:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4949527	30/07/2024 11:25	E. coli	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4949527	30/07/2024 11:25	Free - Residual disinfectant	mg Cl/l	0.53	
V4539OUT	Erganagh SR Outlet	4949527	30/07/2024 11:25	Total - Residual disinfectant	mg Cl/l	0.59	
V4539OUT	Erganagh SR Outlet	4949527	30/07/2024 11:25	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4949742	31/07/2024 07:56	Colony Counts 22	CFU/1 ml	160	
V1349OUT	Ballyknock Magherafelt SR Outlet	4949742	31/07/2024 07:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4949742	31/07/2024 07:56	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4949742	31/07/2024 07:56	Free - Residual disinfectant	mg Cl/l	0.5	
V1349OUT	Ballyknock Magherafelt SR Outlet	4949742	31/07/2024 07:56	Total - Residual disinfectant	mg Cl/l	0.65	

V1349OUT	Ballyknock Magherafelt SR Outlet	4949742	31/07/2024 07:56	Total Coliforms	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4949753	31/07/2024 07:58	Colony Counts 22	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4949753	31/07/2024 07:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4949753	31/07/2024 07:58	E. coli	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4949753	31/07/2024 07:58	Free - Residual disinfectant	mg Cl/l	0.43	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4949753	31/07/2024 07:58	Total - Residual disinfectant	mg Cl/l	0.49	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4949753	31/07/2024 07:58	Total Coliforms	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4949750	31/07/2024 08:17	Colony Counts 22	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4949750	31/07/2024 08:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4949750	31/07/2024 08:17	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4949750	31/07/2024 08:17	Free - Residual disinfectant	mg Cl/l	0.67	
V1358OUT	Slaughtneil SR Outlet	4949750	31/07/2024 08:17	Total - Residual disinfectant	mg Cl/l	0.78	
V1358OUT	Slaughtneil SR Outlet	4949750	31/07/2024 08:17	Total Coliforms	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4949725	31/07/2024 08:17	Colony Counts 22	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4949725	31/07/2024 08:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4949725	31/07/2024 08:17	E. coli	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4949725	31/07/2024 08:17	Free - Residual disinfectant	mg Cl/l	1	
V2501OUT	Altmore River SR Outlet	4949725	31/07/2024 08:17	Total - Residual disinfectant	mg Cl/l	1.15	
V2501OUT	Altmore River SR Outlet	4949725	31/07/2024 08:17	Total Coliforms	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4949695	31/07/2024 08:29	Colony Counts 22	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4949695	31/07/2024 08:29	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V2507OUT	Cappagh SR Outlet	4949695	31/07/2024 08:29	E. coli	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4949695	31/07/2024 08:29	Free - Residual disinfectant	mg Cl/l	0.68	
V2507OUT	Cappagh SR Outlet	4949695	31/07/2024 08:29	Total - Residual disinfectant	mg Cl/l	0.72	
V2507OUT	Cappagh SR Outlet	4949695	31/07/2024 08:29	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4949748	31/07/2024 08:41	Colony Counts 22	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4949748	31/07/2024 08:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4949748	31/07/2024 08:41	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4949748	31/07/2024 08:41	Free - Residual disinfectant	mg Cl/l	0.25	
V1354OUT	Knockoneill SR Outlet	4949748	31/07/2024 08:41	Total - Residual disinfectant	mg Cl/l	0.31	
V1354OUT	Knockoneill SR Outlet	4949748	31/07/2024 08:41	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4949748	31/07/2024 08:41	Odour	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4949748	31/07/2024 08:41	Odour - Nature		No odour	
V1354OUT	Knockoneill SR Outlet	4949748	31/07/2024 08:41	Taste	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4949748	31/07/2024 08:41	Taste - Nature		No taste	
V2505OUT	Cabragh Fasglashagh SR Outlet	4949694	31/07/2024 08:47	Colony Counts 22	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4949694	31/07/2024 08:47	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V2505OUT	Cabragh Fasglashagh SR Outlet	4949694	31/07/2024 08:47	E. coli	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4949694	31/07/2024 08:47	Free - Residual disinfectant	mg Cl/l	0.81	
V2505OUT	Cabragh Fasglashagh SR Outlet	4949694	31/07/2024 08:47	Total - Residual disinfectant	mg Cl/l	0.87	

V2505OUT	Cabragh Fasglashagh SR Outlet	4949694	31/07/2024 08:47	Total Coliforms	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4949709	31/07/2024 08:48	Colony Counts 22	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4949709	31/07/2024 08:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4949709	31/07/2024 08:48	E. coli	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4949709	31/07/2024 08:48	Free - Residual disinfectant	mg Cl/l	0.69	
V4707OUT	Sidaire SR Outlet	4949709	31/07/2024 08:48	Total - Residual disinfectant	mg Cl/l	0.78	
V4707OUT	Sidaire SR Outlet	4949709	31/07/2024 08:48	Total Coliforms	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4949718	31/07/2024 09:30	Colony Counts 22	CFU/1 ml	112	
V4527OUT	Carryglass SR Outlet	4949718	31/07/2024 09:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4949718	31/07/2024 09:30	E. coli	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4949718	31/07/2024 09:30	Free - Residual disinfectant	mg Cl/l	0.44	
V4527OUT	Carryglass SR Outlet	4949718	31/07/2024 09:30	Total - Residual disinfectant	mg Cl/l	0.57	
V4527OUT	Carryglass SR Outlet	4949718	31/07/2024 09:30	Total Coliforms	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4949757	31/07/2024 09:44	Colony Counts 22	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4949757	31/07/2024 09:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4949757	31/07/2024 09:44	E. coli	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4949757	31/07/2024 09:44	Free - Residual disinfectant	mg Cl/l	0.31	
V4530OUT	Dungoran SR Outlet	4949757	31/07/2024 09:44	Total - Residual disinfectant	mg Cl/l	0.44	
V4530OUT	Dungoran SR Outlet	4949757	31/07/2024 09:44	Total Coliforms	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4949749	31/07/2024 09:55	Colony Counts 22	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4949749	31/07/2024 09:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4949749	31/07/2024 09:55	E. coli	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4949749	31/07/2024 09:55	Free - Residual disinfectant	mg Cl/l	0.49	
V4535OUT	Lisnagardy SR Outlet	4949749	31/07/2024 09:55	Total - Residual disinfectant	mg Cl/l	0.6	
V4535OUT	Lisnagardy SR Outlet	4949749	31/07/2024 09:55	Total Coliforms	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4949747	31/07/2024 10:25	Colony Counts 22	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4949747	31/07/2024 10:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4949747	31/07/2024 10:25	E. coli	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4949747	31/07/2024 10:25	Free - Residual disinfectant	mg Cl/l	0.5	
V4719OUT	Glenchuil SR Outlet	4949747	31/07/2024 10:25	Total - Residual disinfectant	mg Cl/l	0.6	
V4719OUT	Glenchuil SR Outlet	4949747	31/07/2024 10:25	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4949703	31/07/2024 10:58	Colony Counts 22	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4949703	31/07/2024 10:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4949703	31/07/2024 10:58	E. coli	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4949703	31/07/2024 10:58	Free - Residual disinfectant	mg Cl/l	0.38	
V1725OUT	Glenlough SR Outlet	4949703	31/07/2024 10:58	Total - Residual disinfectant	mg Cl/l	0.51	
V1725OUT	Glenlough SR Outlet	4949703	31/07/2024 10:58	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4949703	31/07/2024 10:58	Odour	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4949703	31/07/2024 10:58	Odour - Nature		No odour	
V1725OUT	Glenlough SR Outlet	4949703	31/07/2024 10:58	Taste	Diln No	0	0

V1725OUT	Glenlough SR Outlet	4949703	31/07/2024 10:58	Taste - Nature		No taste	
V4712OUT	Corranny SR Outlet	4949242	31/07/2024 11:43	Colony Counts 22	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4949242	31/07/2024 11:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4949242	31/07/2024 11:43	E. coli	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4949242	31/07/2024 11:43	Free - Residual disinfectant	mg Cl/l	0.51	
V4712OUT	Corranny SR Outlet	4949242	31/07/2024 11:43	Total - Residual disinfectant	mg Cl/l	0.62	
V4712OUT	Corranny SR Outlet	4949242	31/07/2024 11:43	Total Coliforms	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4949244	31/07/2024 11:56	Colony Counts 22	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4949244	31/07/2024 11:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4949244	31/07/2024 11:56	E. coli	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4949244	31/07/2024 11:56	Free - Residual disinfectant	mg Cl/l	0.48	
V4713OUT	Knocknalosset SR Outlet	4949244	31/07/2024 11:56	Total - Residual disinfectant	mg Cl/l	0.59	
V4713OUT	Knocknalosset SR Outlet	4949244	31/07/2024 11:56	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4949929	01/08/2024 08:14	Colony Counts 22	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4949929	01/08/2024 08:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4949929	01/08/2024 08:14	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4949929	01/08/2024 08:14	Free - Residual disinfectant	mg Cl/l	0.32	
V1348OUT	Moydamlaght Draperstown SR Outlet	4949929	01/08/2024 08:14	Total - Residual disinfectant	mg Cl/l	0.47	
V1348OUT	Moydamlaght Draperstown SR Outlet	4949929	01/08/2024 08:14	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4949934	01/08/2024 08:36	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4949934	01/08/2024 08:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4949934	01/08/2024 08:36	E. coli	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4949934	01/08/2024 08:36	Free - Residual disinfectant	mg Cl/l	0.42	
V1356OUT	Mormeal SR Outlet	4949934	01/08/2024 08:36	Total - Residual disinfectant	mg Cl/l	0.49	
V1356OUT	Mormeal SR Outlet	4949934	01/08/2024 08:36	Total Coliforms	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4949916	01/08/2024 09:25	Colony Counts 22	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4949916	01/08/2024 09:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4949916	01/08/2024 09:25	E. coli	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4949916	01/08/2024 09:25	Free - Residual disinfectant	mg Cl/l	0.91	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4949916	01/08/2024 09:25	Total - Residual disinfectant	mg Cl/l	0.99	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4949916	01/08/2024 09:25	Total Coliforms	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4949907	01/08/2024 09:45	Colony Counts 22	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4949907	01/08/2024 09:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4949907	01/08/2024 09:45	E. coli	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4949907	01/08/2024 09:45	Free - Residual disinfectant	mg Cl/l	0.56	
V4540OUT	Radergan SR Outlet	4949907	01/08/2024 09:45	Total - Residual disinfectant	mg Cl/l	0.65	
V4540OUT	Radergan SR Outlet	4949907	01/08/2024 09:45	Total Coliforms	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4949932	01/08/2024 10:02	Colony Counts 22	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4949932	01/08/2024 10:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4949932	01/08/2024 10:02	E. coli	CFU/100 ml	0	0

V4531OUT	Foremass SR Outlet	4949932	01/08/2024 10:02	Free - Residual disinfectant	mg Cl/l	0.61	
V4531OUT	Foremass SR Outlet	4949932	01/08/2024 10:02	Total - Residual disinfectant	mg Cl/l	0.73	
V4531OUT	Foremass SR Outlet	4949932	01/08/2024 10:02	Total Coliforms	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4949935	01/08/2024 10:23	Colony Counts 22	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4949935	01/08/2024 10:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4949935	01/08/2024 10:23	E. coli	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4949935	01/08/2024 10:23	Free - Residual disinfectant	mg Cl/l	0.61	
V4537OUT	Sixmilecross SR Outlet	4949935	01/08/2024 10:23	Total - Residual disinfectant	mg Cl/l	0.69	
V4537OUT	Sixmilecross SR Outlet	4949935	01/08/2024 10:23	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4949895	01/08/2024 10:25	Colony Counts 22	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4949895	01/08/2024 10:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4949895	01/08/2024 10:25	E. coli	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4949895	01/08/2024 10:25	Free - Residual disinfectant	mg Cl/l	0.86	
V2301OUT	Ballydougan Command SR Outlet	4949895	01/08/2024 10:25	Total - Residual disinfectant	mg Cl/l	0.96	
V2301OUT	Ballydougan Command SR Outlet	4949895	01/08/2024 10:25	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4949895	01/08/2024 10:25	Odour	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4949895	01/08/2024 10:25	Odour - Nature		No odour	
V2301OUT	Ballydougan Command SR Outlet	4949895	01/08/2024 10:25	Taste	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4949895	01/08/2024 10:25	Taste - Nature		No taste	
V4528OUT	Crocknabohil SR Outlet	4949939	01/08/2024 10:44	Colony Counts 22	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4949939	01/08/2024 10:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4949939	01/08/2024 10:44	E. coli	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4949939	01/08/2024 10:44	Free - Residual disinfectant	mg Cl/l	0.39	
V4528OUT	Crocknabohil SR Outlet	4949939	01/08/2024 10:44	Total - Residual disinfectant	mg Cl/l	0.45	
V4528OUT	Crocknabohil SR Outlet	4949939	01/08/2024 10:44	Total Coliforms	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4949896	01/08/2024 10:47	Colony Counts 22	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4949896	01/08/2024 10:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4949896	01/08/2024 10:47	E. coli	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4949896	01/08/2024 10:47	Free - Residual disinfectant	mg Cl/l	0.3	
V2302OUT	Ballyhannon SR Outlet	4949896	01/08/2024 10:47	Total - Residual disinfectant	mg Cl/l	0.38	
V2302OUT	Ballyhannon SR Outlet	4949896	01/08/2024 10:47	Total Coliforms	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4949745	01/08/2024 12:15	Colony Counts 22	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4949745	01/08/2024 12:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4949745	01/08/2024 12:15	E. coli	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4949745	01/08/2024 12:15	Free - Residual disinfectant	mg Cl/l	0.6	
V1715OUT	Ballystrone (Calvins) SR Outlet	4949745	01/08/2024 12:15	Total - Residual disinfectant	mg Cl/l	0.71	
V1715OUT	Ballystrone (Calvins) SR Outlet	4949745	01/08/2024 12:15	Total Coliforms	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4950064	02/08/2024 07:47	Colony Counts 22	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4950064	02/08/2024 07:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4950064	02/08/2024 07:47	E. coli	CFU/100 ml	0	0

V1352OUT	Cullion Desertmartin SR Outlet	4950064	02/08/2024 07:47	Free - Residual disinfectant	mg Cl/l	0.25	
V1352OUT	Cullion Desertmartin SR Outlet	4950064	02/08/2024 07:47	Total - Residual disinfectant	mg Cl/l	0.32	
V1352OUT	Cullion Desertmartin SR Outlet	4950064	02/08/2024 07:47	Total Coliforms	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4950076	02/08/2024 08:09	Colony Counts 22	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4950076	02/08/2024 08:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4950076	02/08/2024 08:09	E. coli	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4950076	02/08/2024 08:09	Free - Residual disinfectant	mg Cl/l	0.63	
V1351OUT	Cranny Moneymore SR Outlet	4950076	02/08/2024 08:09	Total - Residual disinfectant	mg Cl/l	0.82	
V1351OUT	Cranny Moneymore SR Outlet	4950076	02/08/2024 08:09	Total Coliforms	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4950087	02/08/2024 08:44	Colony Counts 22	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4950087	02/08/2024 08:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4950087	02/08/2024 08:44	E. coli	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4950087	02/08/2024 08:44	Free - Residual disinfectant	mg Cl/l	0.68	
V1343OUT	Ballybriest SR Outlet	4950087	02/08/2024 08:44	Total - Residual disinfectant	mg Cl/l	0.74	
V1343OUT	Ballybriest SR Outlet	4950087	02/08/2024 08:44	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4950034	02/08/2024 08:46	Colony Counts 22	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4950034	02/08/2024 08:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4950034	02/08/2024 08:46	E. coli	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4950034	02/08/2024 08:46	Free - Residual disinfectant	mg Cl/l	1.08	
V2508OUT	Carland SR Outlet	4950034	02/08/2024 08:46	Total - Residual disinfectant	mg Cl/l	1.2	
V2508OUT	Carland SR Outlet	4950034	02/08/2024 08:46	Total Coliforms	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4949754	02/08/2024 08:50	Colony Counts 22	CFU/1 ml	3	
V4708OUT	Cavanacross Enniskillen SR Outlet	4949754	02/08/2024 08:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4949754	02/08/2024 08:50	E. coli	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4949754	02/08/2024 08:50	Free - Residual disinfectant	mg Cl/l	1.11	
V4708OUT	Cavanacross Enniskillen SR Outlet	4949754	02/08/2024 08:50	Total - Residual disinfectant	mg Cl/l	1.18	
V4708OUT	Cavanacross Enniskillen SR Outlet	4949754	02/08/2024 08:50	Total Coliforms	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4950035	02/08/2024 09:10	Colony Counts 22	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4950035	02/08/2024 09:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4950035	02/08/2024 09:10	E. coli	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4950035	02/08/2024 09:10	Free - Residual disinfectant	mg Cl/l	0.65	
V2509OUT	Castlehill Drumcoo SR Outlet	4950035	02/08/2024 09:10	Total - Residual disinfectant	mg Cl/l	0.75	
V2509OUT	Castlehill Drumcoo SR Outlet	4950035	02/08/2024 09:10	Total Coliforms	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4950075	02/08/2024 09:19	Colony Counts 22	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4950075	02/08/2024 09:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4950075	02/08/2024 09:19	E. coli	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4950075	02/08/2024 09:19	Free - Residual disinfectant	mg Cl/l	0.25	
V1713OUT	Trienaltenagh SR Outlet	4950075	02/08/2024 09:19	Total - Residual disinfectant	mg Cl/l	0.4	
V1713OUT	Trienaltenagh SR Outlet	4950075	02/08/2024 09:19	Total Coliforms	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4950047	02/08/2024 09:26	Colony Counts 22	CFU/1 ml	0	

V2521OUT	Mullaghanagh SR Outlet	4950047	02/08/2024 09:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4950047	02/08/2024 09:26	E. coli	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4950047	02/08/2024 09:26	Free - Residual disinfectant	mg Cl/l	0.96	
V2521OUT	Mullaghanagh SR Outlet	4950047	02/08/2024 09:26	Total - Residual disinfectant	mg Cl/l	1.06	
V2521OUT	Mullaghanagh SR Outlet	4950047	02/08/2024 09:26	Total Coliforms	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4950072	02/08/2024 09:43	Colony Counts 22	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4950072	02/08/2024 09:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4950072	02/08/2024 09:43	E. coli	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4950072	02/08/2024 09:43	Free - Residual disinfectant	mg Cl/l	0.18	
V1708OUT	North Garvagh SR Outlet	4950072	02/08/2024 09:43	Total - Residual disinfectant	mg Cl/l	0.39	
V1708OUT	North Garvagh SR Outlet	4950072	02/08/2024 09:43	Total Coliforms	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4950063	02/08/2024 09:55	Colony Counts 22	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4950063	02/08/2024 09:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4950063	02/08/2024 09:55	E. coli	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4950063	02/08/2024 09:55	Free - Residual disinfectant	mg Cl/l	0.81	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4950063	02/08/2024 09:55	Total - Residual disinfectant	mg Cl/l	0.9	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4950063	02/08/2024 09:55	Total Coliforms	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4950074	02/08/2024 10:00	Colony Counts 22	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4950074	02/08/2024 10:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4950074	02/08/2024 10:00	E. coli	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4950074	02/08/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.56	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4950074	02/08/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.66	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4950074	02/08/2024 10:00	Total Coliforms	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4950068	02/08/2024 10:03	Colony Counts 22	CFU/1 ml	1	
V1706OUT	Killeague SR Outlet	4950068	02/08/2024 10:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4950068	02/08/2024 10:03	E. coli	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4950068	02/08/2024 10:03	Free - Residual disinfectant	mg Cl/l	0.41	
V1706OUT	Killeague SR Outlet	4950068	02/08/2024 10:03	Total - Residual disinfectant	mg Cl/l	0.63	
V1706OUT	Killeague SR Outlet	4950068	02/08/2024 10:03	Total Coliforms	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4950071	02/08/2024 10:21	Colony Counts 22	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4950071	02/08/2024 10:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4950071	02/08/2024 10:21	E. coli	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4950071	02/08/2024 10:21	Free - Residual disinfectant	mg Cl/l	0.63	
V4742OUT	Tattinbar SR Outlet	4950071	02/08/2024 10:21	Total - Residual disinfectant	mg Cl/l	0.68	
V4742OUT	Tattinbar SR Outlet	4950071	02/08/2024 10:21	Total Coliforms	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4950070	02/08/2024 10:22	Colony Counts 22	CFU/1 ml	4	
V1702OUT	Cam SR Outlet	4950070	02/08/2024 10:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4950070	02/08/2024 10:22	E. coli	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4950070	02/08/2024 10:22	Free - Residual disinfectant	mg Cl/l	0.49	
V1702OUT	Cam SR Outlet	4950070	02/08/2024 10:22	Total - Residual disinfectant	mg Cl/l	0.71	

V1702OUT	Cam SR Outlet	4950070	02/08/2024 10:22	Total Coliforms	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4950089	02/08/2024 10:49	Colony Counts 22	CFU/1 ml	1	
V4715OUT	Brookeborough High SR Outlet	4950089	02/08/2024 10:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4950089	02/08/2024 10:49	E. coli	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4950089	02/08/2024 10:49	Free - Residual disinfectant	mg Cl/l	0.71	
V4715OUT	Brookeborough High SR Outlet	4950089	02/08/2024 10:49	Total - Residual disinfectant	mg Cl/l	0.76	
V4715OUT	Brookeborough High SR Outlet	4950089	02/08/2024 10:49	Total Coliforms	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4950073	02/08/2024 11:19	Colony Counts 22	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4950073	02/08/2024 11:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4950073	02/08/2024 11:19	E. coli	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4950073	02/08/2024 11:19	Free - Residual disinfectant	mg Cl/l	0.52	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4950073	02/08/2024 11:19	Total - Residual disinfectant	mg Cl/l	0.65	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4950073	02/08/2024 11:19	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4952085	05/08/2024 09:09	Colony Counts 22	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4952085	05/08/2024 09:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4952085	05/08/2024 09:09	E. coli	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4952085	05/08/2024 09:09	Free - Residual disinfectant	mg Cl/l	1.03	
V2508OUT	Carland SR Outlet	4952085	05/08/2024 09:09	Total - Residual disinfectant	mg Cl/l	1.15	
V2508OUT	Carland SR Outlet	4952085	05/08/2024 09:09	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4952085	05/08/2024 09:09	Odour	Diln No	0	0
V2508OUT	Carland SR Outlet	4952085	05/08/2024 09:09	Odour - Nature		No odour	
V2508OUT	Carland SR Outlet	4952085	05/08/2024 09:09	Taste	Diln No	0	0
V2508OUT	Carland SR Outlet	4952085	05/08/2024 09:09	Taste - Nature		No taste	
V2509OUT	Castlehill Drumcoo SR Outlet	4952086	05/08/2024 09:32	Colony Counts 22	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4952086	05/08/2024 09:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4952086	05/08/2024 09:32	E. coli	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4952086	05/08/2024 09:32	Free - Residual disinfectant	mg Cl/l	0.59	
V2509OUT	Castlehill Drumcoo SR Outlet	4952086	05/08/2024 09:32	Total - Residual disinfectant	mg Cl/l	0.66	
V2509OUT	Castlehill Drumcoo SR Outlet	4952086	05/08/2024 09:32	Total Coliforms	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4952252	05/08/2024 09:37	Colony Counts 22	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4952252	05/08/2024 09:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4952252	05/08/2024 09:37	E. coli	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4952252	05/08/2024 09:37	Free - Residual disinfectant	mg Cl/l	0.52	
V4742OUT	Tattinbar SR Outlet	4952252	05/08/2024 09:37	Total - Residual disinfectant	mg Cl/l	0.77	
V4742OUT	Tattinbar SR Outlet	4952252	05/08/2024 09:37	Total Coliforms	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4952229	05/08/2024 09:49	Colony Counts 22	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4952229	05/08/2024 09:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4952229	05/08/2024 09:49	E. coli	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4952229	05/08/2024 09:49	Free - Residual disinfectant	mg Cl/l	0.97	
V2521OUT	Mullaghanagh SR Outlet	4952229	05/08/2024 09:49	Total - Residual disinfectant	mg Cl/l	1.17	

V2521OUT	Mullaghanagh SR Outlet	4952229	05/08/2024 09:49	Total Coliforms	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4952255	05/08/2024 10:06	Colony Counts 22	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4952255	05/08/2024 10:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4952255	05/08/2024 10:06	E. coli	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4952255	05/08/2024 10:06	Free - Residual disinfectant	mg Cl/l	0.6	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4952255	05/08/2024 10:06	Total - Residual disinfectant	mg Cl/l	0.73	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4952255	05/08/2024 10:06	Total Coliforms	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4952244	05/08/2024 10:14	Colony Counts 22	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4952244	05/08/2024 10:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4952244	05/08/2024 10:14	E. coli	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4952244	05/08/2024 10:14	Free - Residual disinfectant	mg Cl/l	0.76	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4952244	05/08/2024 10:14	Total - Residual disinfectant	mg Cl/l	0.83	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4952244	05/08/2024 10:14	Total Coliforms	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4952256	05/08/2024 10:30	Colony Counts 22	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4952256	05/08/2024 10:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4952256	05/08/2024 10:30	E. coli	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4952256	05/08/2024 10:30	Free - Residual disinfectant	mg Cl/l	0.31	
V1713OUT	Trienaltenagh SR Outlet	4952256	05/08/2024 10:30	Total - Residual disinfectant	mg Cl/l	0.43	
V1713OUT	Trienaltenagh SR Outlet	4952256	05/08/2024 10:30	Total Coliforms	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4952253	05/08/2024 10:53	Colony Counts 22	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4952253	05/08/2024 10:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4952253	05/08/2024 10:53	E. coli	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4952253	05/08/2024 10:53	Free - Residual disinfectant	mg Cl/l	0.08	
V1708OUT	North Garvagh SR Outlet	4952253	05/08/2024 10:53	Total - Residual disinfectant	mg Cl/l	0.24	
V1708OUT	North Garvagh SR Outlet	4952253	05/08/2024 10:53	Total Coliforms	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4952249	05/08/2024 11:12	Colony Counts 22	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4952249	05/08/2024 11:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4952249	05/08/2024 11:12	E. coli	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4952249	05/08/2024 11:12	Free - Residual disinfectant	mg Cl/l	0.59	
V1706OUT	Killeague SR Outlet	4952249	05/08/2024 11:12	Total - Residual disinfectant	mg Cl/l	0.74	
V1706OUT	Killeague SR Outlet	4952249	05/08/2024 11:12	Total Coliforms	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4952251	05/08/2024 11:25	Colony Counts 22	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4952251	05/08/2024 11:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4952251	05/08/2024 11:25	E. coli	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4952251	05/08/2024 11:25	Free - Residual disinfectant	mg Cl/l	0.65	
V1702OUT	Cam SR Outlet	4952251	05/08/2024 11:25	Total - Residual disinfectant	mg Cl/l	0.73	
V1702OUT	Cam SR Outlet	4952251	05/08/2024 11:25	Total Coliforms	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4952622	06/08/2024 09:03	Colony Counts 22	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4952622	06/08/2024 09:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4952622	06/08/2024 09:03	E. coli	CFU/100 ml	0	0

V1338OUT	Coagh SR Outlet	4952622	06/08/2024 09:03	Free - Residual disinfectant	mg Cl/l	0.29	
V1338OUT	Coagh SR Outlet	4952622	06/08/2024 09:03	Total - Residual disinfectant	mg Cl/l	0.37	
V1338OUT	Coagh SR Outlet	4952622	06/08/2024 09:03	Total Coliforms	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4952621	06/08/2024 09:21	Colony Counts 22	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4952621	06/08/2024 09:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4952621	06/08/2024 09:21	E. coli	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4952621	06/08/2024 09:21	Free - Residual disinfectant	mg Cl/l	0.48	
V1335OUT	Brigh Quarry SR Outlet	4952621	06/08/2024 09:21	Total - Residual disinfectant	mg Cl/l	0.54	
V1335OUT	Brigh Quarry SR Outlet	4952621	06/08/2024 09:21	Total Coliforms	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4952536	06/08/2024 09:31	Colony Counts 22	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4952536	06/08/2024 09:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4952536	06/08/2024 09:31	E. coli	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4952536	06/08/2024 09:31	Free - Residual disinfectant	mg Cl/l	0.67	
V2511OUT	Corran Armagh SR Outlet	4952536	06/08/2024 09:31	Total - Residual disinfectant	mg Cl/l	0.9	
V2511OUT	Corran Armagh SR Outlet	4952536	06/08/2024 09:31	Total Coliforms	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4952625	06/08/2024 09:38	Colony Counts 22	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4952625	06/08/2024 09:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4952625	06/08/2024 09:38	E. coli	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4952625	06/08/2024 09:38	Free - Residual disinfectant	mg Cl/l	0.37	
V1342OUT	Dromore High SR Outlet	4952625	06/08/2024 09:38	Total - Residual disinfectant	mg Cl/l	0.41	
V1342OUT	Dromore High SR Outlet	4952625	06/08/2024 09:38	Total Coliforms	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4952591	06/08/2024 09:59	Colony Counts 22	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4952591	06/08/2024 09:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4952591	06/08/2024 09:59	E. coli	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4952591	06/08/2024 09:59	Free - Residual disinfectant	mg Cl/l	0.9	
V2518OUT	Lisnastrane SR Outlet	4952591	06/08/2024 09:59	Total - Residual disinfectant	mg Cl/l	0.94	
V2518OUT	Lisnastrane SR Outlet	4952591	06/08/2024 09:59	Total Coliforms	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4952618	06/08/2024 10:06	Colony Counts 22	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4952618	06/08/2024 10:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4952618	06/08/2024 10:06	E. coli	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4952618	06/08/2024 10:06	Free - Residual disinfectant	mg Cl/l	0.66	
V4533OUT	Inisclan SR Outlet	4952618	06/08/2024 10:06	Total - Residual disinfectant	mg Cl/l	0.74	
V4533OUT	Inisclan SR Outlet	4952618	06/08/2024 10:06	Total Coliforms	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4952535	06/08/2024 10:14	Colony Counts 22	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4952535	06/08/2024 10:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4952535	06/08/2024 10:14	E. coli	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4952535	06/08/2024 10:14	Free - Residual disinfectant	mg Cl/l	0.37	
V2510OUT	Calone SR Outlet	4952535	06/08/2024 10:14	Total - Residual disinfectant	mg Cl/l	0.61	
V2510OUT	Calone SR Outlet	4952535	06/08/2024 10:14	Total Coliforms	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4952589	06/08/2024 10:31	Colony Counts 22	CFU/1 ml	0	

V2514OUT	Edenaveys Command SR Outlet	4952589	06/08/2024 10:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4952589	06/08/2024 10:31	E. coli	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4952589	06/08/2024 10:31	Free - Residual disinfectant	mg Cl/l	0.65	
V2514OUT	Edenaveys Command SR Outlet	4952589	06/08/2024 10:31	Total - Residual disinfectant	mg Cl/l	0.84	
V2514OUT	Edenaveys Command SR Outlet	4952589	06/08/2024 10:31	Total Coliforms	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4952532	06/08/2024 10:56	Colony Counts 22	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4952532	06/08/2024 10:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4952532	06/08/2024 10:56	E. coli	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4952532	06/08/2024 10:56	Free - Residual disinfectant	mg Cl/l	0.92	
V2523OUT	Rough Fort SR Outlet	4952532	06/08/2024 10:56	Total - Residual disinfectant	mg Cl/l	1.1	
V2523OUT	Rough Fort SR Outlet	4952532	06/08/2024 10:56	Total Coliforms	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4952270	06/08/2024 11:28	Colony Counts 22	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4952270	06/08/2024 11:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4952270	06/08/2024 11:28	E. coli	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4952270	06/08/2024 11:28	Free - Residual disinfectant	mg Cl/l	0.86	
V4715OUT	Brookeborough High SR Outlet	4952270	06/08/2024 11:28	Total - Residual disinfectant	mg Cl/l	1.01	
V4715OUT	Brookeborough High SR Outlet	4952270	06/08/2024 11:28	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4952614	06/08/2024 11:44	Colony Counts 22	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4952614	06/08/2024 11:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4952614	06/08/2024 11:44	E. coli	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4952614	06/08/2024 11:44	Free - Residual disinfectant	mg Cl/l	0.31	
V1704OUT	Castlerock Downhill SR Outlet	4952614	06/08/2024 11:44	Total - Residual disinfectant	mg Cl/l	0.58	
V1704OUT	Castlerock Downhill SR Outlet	4952614	06/08/2024 11:44	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4952614	06/08/2024 11:44	Odour	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4952614	06/08/2024 11:44	Odour - Nature		No odour	
V1704OUT	Castlerock Downhill SR Outlet	4952614	06/08/2024 11:44	Taste	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4952614	06/08/2024 11:44	Taste - Nature		No taste	
V1711OUT	Sconce Hill SR Outlet	4952615	06/08/2024 12:10	Colony Counts 22	CFU/1 ml	2	
V1711OUT	Sconce Hill SR Outlet	4952615	06/08/2024 12:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1711OUT	Sconce Hill SR Outlet	4952615	06/08/2024 12:10	E. coli	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4952615	06/08/2024 12:10	Free - Residual disinfectant	mg Cl/l	0.68	
V1711OUT	Sconce Hill SR Outlet	4952615	06/08/2024 12:10	Total - Residual disinfectant	mg Cl/l	0.75	
V1711OUT	Sconce Hill SR Outlet	4952615	06/08/2024 12:10	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4952836	07/08/2024 07:51	Colony Counts 22	CFU/1 ml	7	
V1360OUT	Windmill Hill SR Outlet	4952836	07/08/2024 07:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4952836	07/08/2024 07:51	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4952836	07/08/2024 07:51	Free - Residual disinfectant	mg Cl/l	0.44	
V1360OUT	Windmill Hill SR Outlet	4952836	07/08/2024 07:51	Total - Residual disinfectant	mg Cl/l	0.62	
V1360OUT	Windmill Hill SR Outlet	4952836	07/08/2024 07:51	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4952847	07/08/2024 08:12	Colony Counts 22	CFU/1 ml	0	

V1357OUT	Mullaghboy Magherafelt SR Outlet	4952847	07/08/2024 08:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4952847	07/08/2024 08:12	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4952847	07/08/2024 08:12	Free - Residual disinfectant	mg Cl/l	0.47	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4952847	07/08/2024 08:12	Total - Residual disinfectant	mg Cl/l	0.58	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4952847	07/08/2024 08:12	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4952847	07/08/2024 08:12	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4952847	07/08/2024 08:12	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4952847	07/08/2024 08:12	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4952847	07/08/2024 08:12	Taste - Nature		No taste	
V1351OUT	Cranny Moneymore SR Outlet	4952257	07/08/2024 08:38	Colony Counts 22	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4952257	07/08/2024 08:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4952257	07/08/2024 08:38	E. coli	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4952257	07/08/2024 08:38	Free - Residual disinfectant	mg Cl/l	0.58	
V1351OUT	Cranny Moneymore SR Outlet	4952257	07/08/2024 08:38	Total - Residual disinfectant	mg Cl/l	0.62	
V1351OUT	Cranny Moneymore SR Outlet	4952257	07/08/2024 08:38	Total Coliforms	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4952838	07/08/2024 08:43	Colony Counts 22	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4952838	07/08/2024 08:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4952838	07/08/2024 08:43	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4952838	07/08/2024 08:43	Free - Residual disinfectant	mg Cl/l	0.52	
V1362OUT	Unagh SR Outlet	4952838	07/08/2024 08:43	Total - Residual disinfectant	mg Cl/l	0.61	
V1362OUT	Unagh SR Outlet	4952838	07/08/2024 08:43	Total Coliforms	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4952851	07/08/2024 09:00	Colony Counts 22	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4952851	07/08/2024 09:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4952851	07/08/2024 09:00	E. coli	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4952851	07/08/2024 09:00	Free - Residual disinfectant	mg Cl/l	0.56	
V1344OUT	Craigs Cookstown SR Outlet	4952851	07/08/2024 09:00	Total - Residual disinfectant	mg Cl/l	0.67	
V1344OUT	Craigs Cookstown SR Outlet	4952851	07/08/2024 09:00	Total Coliforms	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4952245	07/08/2024 09:03	Colony Counts 22	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4952245	07/08/2024 09:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4952245	07/08/2024 09:03	E. coli	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4952245	07/08/2024 09:03	Free - Residual disinfectant	mg Cl/l	0.15	
V1352OUT	Cullion Desertmartin SR Outlet	4952245	07/08/2024 09:03	Total - Residual disinfectant	mg Cl/l	0.24	
V1352OUT	Cullion Desertmartin SR Outlet	4952245	07/08/2024 09:03	Total Coliforms	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4952848	07/08/2024 09:16	Colony Counts 22	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4952848	07/08/2024 09:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4952848	07/08/2024 09:16	E. coli	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4952848	07/08/2024 09:16	Free - Residual disinfectant	mg Cl/l	0.62	
V1339OUT	Corvanaghan High SR Outlet	4952848	07/08/2024 09:16	Total - Residual disinfectant	mg Cl/l	0.74	
V1339OUT	Corvanaghan High SR Outlet	4952848	07/08/2024 09:16	Total Coliforms	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4952268	07/08/2024 09:25	Colony Counts 22	CFU/1 ml	1	

V1343OUT	Ballybriest SR Outlet	4952268	07/08/2024 09:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4952268	07/08/2024 09:25	E. coli	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4952268	07/08/2024 09:25	Free - Residual disinfectant	mg Cl/l	0.58	
V1343OUT	Ballybriest SR Outlet	4952268	07/08/2024 09:25	Total - Residual disinfectant	mg Cl/l	0.62	
V1343OUT	Ballybriest SR Outlet	4952268	07/08/2024 09:25	Total Coliforms	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4952852	07/08/2024 09:45	Colony Counts 22	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4952852	07/08/2024 09:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4952852	07/08/2024 09:45	E. coli	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4952852	07/08/2024 09:45	Free - Residual disinfectant	mg Cl/l	0.58	
V1346OUT	Gortaclady Evishanoran SR Outlet	4952852	07/08/2024 09:45	Total - Residual disinfectant	mg Cl/l	0.66	
V1346OUT	Gortaclady Evishanoran SR Outlet	4952852	07/08/2024 09:45	Total Coliforms	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4952812	07/08/2024 09:55	Colony Counts 22	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4952812	07/08/2024 09:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4952812	07/08/2024 09:55	E. coli	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4952812	07/08/2024 09:55	Free - Residual disinfectant	mg Cl/l	0.65	
V4526OUT	Black Lough Pomeroy SR Outlet	4952812	07/08/2024 09:55	Total - Residual disinfectant	mg Cl/l	0.71	
V4526OUT	Black Lough Pomeroy SR Outlet	4952812	07/08/2024 09:55	Total Coliforms	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4952849	07/08/2024 10:00	Colony Counts 22	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4952849	07/08/2024 10:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4952849	07/08/2024 10:00	E. coli	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4952849	07/08/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.57	
V1340OUT	Craigballyharkey SR Outlet	4952849	07/08/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.67	
V1340OUT	Craigballyharkey SR Outlet	4952849	07/08/2024 10:00	Total Coliforms	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4952824	07/08/2024 10:08	Colony Counts 22	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4952824	07/08/2024 10:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4952824	07/08/2024 10:08	E. coli	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4952824	07/08/2024 10:08	Free - Residual disinfectant	mg Cl/l	0.81	
V4536OUT	Lough Macrory North SR Outlet	4952824	07/08/2024 10:08	Total - Residual disinfectant	mg Cl/l	0.87	
V4536OUT	Lough Macrory North SR Outlet	4952824	07/08/2024 10:08	Total Coliforms	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4952814	07/08/2024 10:41	Colony Counts 22	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4952814	07/08/2024 10:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4952814	07/08/2024 10:41	E. coli	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4952814	07/08/2024 10:41	Free - Residual disinfectant	mg Cl/l	0.53	
V4538OUT	Killyclogher SR Outlet	4952814	07/08/2024 10:41	Total - Residual disinfectant	mg Cl/l	0.64	
V4538OUT	Killyclogher SR Outlet	4952814	07/08/2024 10:41	Total Coliforms	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4952817	07/08/2024 11:00	Colony Counts 22	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4952817	07/08/2024 11:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4952817	07/08/2024 11:00	E. coli	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4952817	07/08/2024 11:00	Free - Residual disinfectant	mg Cl/l	0.32	
V4539OUT	Erganagh SR Outlet	4952817	07/08/2024 11:00	Total - Residual disinfectant	mg Cl/l	0.38	

V4539OUT	Erganagh SR Outlet	4952817	07/08/2024 11:00	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4952843	07/08/2024 11:29	Colony Counts 22	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4952843	07/08/2024 11:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4952843	07/08/2024 11:29	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4952843	07/08/2024 11:29	Free - Residual disinfectant	mg Cl/l	0.1	
V1350OUT	Carnaman SR Outlet	4952843	07/08/2024 11:29	Total - Residual disinfectant	mg Cl/l	0.22	
V1350OUT	Carnaman SR Outlet	4952843	07/08/2024 11:29	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4952843	07/08/2024 11:29	Odour	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4952843	07/08/2024 11:29	Odour - Nature		No odour	
V1350OUT	Carnaman SR Outlet	4952843	07/08/2024 11:29	Taste	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4952843	07/08/2024 11:29	Taste - Nature		No taste	
V1354OUT	Knockoneill SR Outlet	4953012	08/08/2024 07:32	Colony Counts 22	CFU/1 ml	28	
V1354OUT	Knockoneill SR Outlet	4953012	08/08/2024 07:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4953012	08/08/2024 07:32	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4953012	08/08/2024 07:32	Free - Residual disinfectant	mg Cl/l	0.11	
V1354OUT	Knockoneill SR Outlet	4953012	08/08/2024 07:32	Total - Residual disinfectant	mg Cl/l	0.26	
V1354OUT	Knockoneill SR Outlet	4953012	08/08/2024 07:32	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4953012	08/08/2024 07:32	Odour	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4953012	08/08/2024 07:32	Odour - Nature		No odour	
V1354OUT	Knockoneill SR Outlet	4953012	08/08/2024 07:32	Taste	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4953012	08/08/2024 07:32	Taste - Nature		No taste	
V1358OUT	Slaughtneil SR Outlet	4953014	08/08/2024 07:50	Colony Counts 22	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4953014	08/08/2024 07:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4953014	08/08/2024 07:50	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4953014	08/08/2024 07:50	Free - Residual disinfectant	mg Cl/l	0.46	
V1358OUT	Slaughtneil SR Outlet	4953014	08/08/2024 07:50	Total - Residual disinfectant	mg Cl/l	0.56	
V1358OUT	Slaughtneil SR Outlet	4953014	08/08/2024 07:50	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4953006	08/08/2024 08:09	Colony Counts 22	CFU/1 ml	>300	
V1349OUT	Ballyknock Magherafelt SR Outlet	4953006	08/08/2024 08:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4953006	08/08/2024 08:09	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4953006	08/08/2024 08:09	Free - Residual disinfectant	mg Cl/l	0.3	
V1349OUT	Ballyknock Magherafelt SR Outlet	4953006	08/08/2024 08:09	Total - Residual disinfectant	mg Cl/l	0.53	
V1349OUT	Ballyknock Magherafelt SR Outlet	4953006	08/08/2024 08:09	Total Coliforms	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4953017	08/08/2024 08:31	Colony Counts 22	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4953017	08/08/2024 08:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4953017	08/08/2024 08:31	E. coli	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4953017	08/08/2024 08:31	Free - Residual disinfectant	mg Cl/l	0.33	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4953017	08/08/2024 08:31	Total - Residual disinfectant	mg Cl/l	0.41	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4953017	08/08/2024 08:31	Total Coliforms	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4952989	08/08/2024 08:52	Colony Counts 22	CFU/1 ml	0	

V2501OUT	Altmore River SR Outlet	4952989	08/08/2024 08:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4952989	08/08/2024 08:52	E. coli	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4952989	08/08/2024 08:52	Free - Residual disinfectant	mg Cl/l	0.97	
V2501OUT	Altmore River SR Outlet	4952989	08/08/2024 08:52	Total - Residual disinfectant	mg Cl/l	1.03	
V2501OUT	Altmore River SR Outlet	4952989	08/08/2024 08:52	Total Coliforms	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4952931	08/08/2024 09:06	Colony Counts 22	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4952931	08/08/2024 09:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4952931	08/08/2024 09:06	E. coli	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4952931	08/08/2024 09:06	Free - Residual disinfectant	mg Cl/l	0.65	
V2507OUT	Cappagh SR Outlet	4952931	08/08/2024 09:06	Total - Residual disinfectant	mg Cl/l	0.7	
V2507OUT	Cappagh SR Outlet	4952931	08/08/2024 09:06	Total Coliforms	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4952979	08/08/2024 09:09	Colony Counts 22	CFU/1 ml	1	
V4707OUT	Sidaire SR Outlet	4952979	08/08/2024 09:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4952979	08/08/2024 09:09	E. coli	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4952979	08/08/2024 09:09	Free - Residual disinfectant	mg Cl/l	0.6	
V4707OUT	Sidaire SR Outlet	4952979	08/08/2024 09:09	Total - Residual disinfectant	mg Cl/l	0.98	
V4707OUT	Sidaire SR Outlet	4952979	08/08/2024 09:09	Total Coliforms	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4952930	08/08/2024 09:24	Colony Counts 22	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4952930	08/08/2024 09:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4952930	08/08/2024 09:24	E. coli	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4952930	08/08/2024 09:24	Free - Residual disinfectant	mg Cl/l	0.75	
V2505OUT	Cabragh Fasglashagh SR Outlet	4952930	08/08/2024 09:24	Total - Residual disinfectant	mg Cl/l	0.85	
V2505OUT	Cabragh Fasglashagh SR Outlet	4952930	08/08/2024 09:24	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4952939	08/08/2024 09:56	Colony Counts 22	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4952939	08/08/2024 09:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4952939	08/08/2024 09:56	E. coli	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4952939	08/08/2024 09:56	Free - Residual disinfectant	mg Cl/l	0.78	
V1725OUT	Glenlough SR Outlet	4952939	08/08/2024 09:56	Total - Residual disinfectant	mg Cl/l	0.85	
V1725OUT	Glenlough SR Outlet	4952939	08/08/2024 09:56	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4952939	08/08/2024 09:56	Odour	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4952939	08/08/2024 09:56	Odour - Nature		No odour	
V1725OUT	Glenlough SR Outlet	4952939	08/08/2024 09:56	Taste	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4952939	08/08/2024 09:56	Taste - Nature		No taste	
V4719OUT	Glenchuil SR Outlet	4953011	08/08/2024 10:19	Colony Counts 22	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4953011	08/08/2024 10:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4953011	08/08/2024 10:19	E. coli	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4953011	08/08/2024 10:19	Free - Residual disinfectant	mg Cl/l	0.59	
V4719OUT	Glenchuil SR Outlet	4953011	08/08/2024 10:19	Total - Residual disinfectant	mg Cl/l	0.7	
V4719OUT	Glenchuil SR Outlet	4953011	08/08/2024 10:19	Total Coliforms	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4953018	08/08/2024 10:36	Colony Counts 22	CFU/1 ml	0	

V4708OUT	Cavanacross Enniskillen SR Outlet	4953018	08/08/2024 10:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4953018	08/08/2024 10:36	E. coli	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4953018	08/08/2024 10:36	Free - Residual disinfectant	mg Cl/l	1.09	
V4708OUT	Cavanacross Enniskillen SR Outlet	4953018	08/08/2024 10:36	Total - Residual disinfectant	mg Cl/l	1.15	
V4708OUT	Cavanacross Enniskillen SR Outlet	4953018	08/08/2024 10:36	Total Coliforms	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4953021	08/08/2024 10:49	Colony Counts 22	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4953021	08/08/2024 10:49	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V4530OUT	Dungoran SR Outlet	4953021	08/08/2024 10:49	E. coli	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4953021	08/08/2024 10:49	Free - Residual disinfectant	mg Cl/l	0.41	
V4530OUT	Dungoran SR Outlet	4953021	08/08/2024 10:49	Total - Residual disinfectant	mg Cl/l	0.53	
V4530OUT	Dungoran SR Outlet	4953021	08/08/2024 10:49	Total Coliforms	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4952984	08/08/2024 10:57	Colony Counts 22	CFU/1 ml	2	
V4527OUT	Carryglass SR Outlet	4952984	08/08/2024 10:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4952984	08/08/2024 10:57	E. coli	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4952984	08/08/2024 10:57	Free - Residual disinfectant	mg Cl/l	0.21	
V4527OUT	Carryglass SR Outlet	4952984	08/08/2024 10:57	Total - Residual disinfectant	mg Cl/l	0.31	
V4527OUT	Carryglass SR Outlet	4952984	08/08/2024 10:57	Total Coliforms	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4953013	08/08/2024 11:01	Colony Counts 22	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4953013	08/08/2024 11:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4953013	08/08/2024 11:01	E. coli	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4953013	08/08/2024 11:01	Free - Residual disinfectant	mg Cl/l	0.49	
V4535OUT	Lisnagardy SR Outlet	4953013	08/08/2024 11:01	Total - Residual disinfectant	mg Cl/l	0.6	
V4535OUT	Lisnagardy SR Outlet	4953013	08/08/2024 11:01	Total Coliforms	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4952254	08/08/2024 11:28	Colony Counts 22	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4952254	08/08/2024 11:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4952254	08/08/2024 11:28	E. coli	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4952254	08/08/2024 11:28	Free - Residual disinfectant	mg Cl/l	0.82	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4952254	08/08/2024 11:28	Total - Residual disinfectant	mg Cl/l	0.9	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4952254	08/08/2024 11:28	Total Coliforms	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4953009	08/08/2024 11:55	Colony Counts 22	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4953009	08/08/2024 11:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4953009	08/08/2024 11:55	E. coli	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4953009	08/08/2024 11:55	Free - Residual disinfectant	mg Cl/l	0.61	
V1715OUT	Ballystrone (Calvins) SR Outlet	4953009	08/08/2024 11:55	Total - Residual disinfectant	mg Cl/l	0.73	
V1715OUT	Ballystrone (Calvins) SR Outlet	4953009	08/08/2024 11:55	Total Coliforms	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4953136	09/08/2024 08:04	Colony Counts 22	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4953136	09/08/2024 08:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4953136	09/08/2024 08:04	E. coli	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4953136	09/08/2024 08:04	Free - Residual disinfectant	mg Cl/l	0.81	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4953136	09/08/2024 08:04	Total - Residual disinfectant	mg Cl/l	0.87	

V1365OUT	Lough Fea North (Blacks) SR Outlet	4953136	09/08/2024 08:04	Total Coliforms	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4952628	09/08/2024 08:31	Colony Counts 22	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4952628	09/08/2024 08:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4952628	09/08/2024 08:31	E. coli	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4952628	09/08/2024 08:31	Free - Residual disinfectant	mg Cl/l	0.75	
V4713OUT	Knocknalosset SR Outlet	4952628	09/08/2024 08:31	Total - Residual disinfectant	mg Cl/l	0.9	
V4713OUT	Knocknalosset SR Outlet	4952628	09/08/2024 08:31	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4953149	09/08/2024 08:46	Colony Counts 22	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4953149	09/08/2024 08:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4953149	09/08/2024 08:46	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4953149	09/08/2024 08:46	Free - Residual disinfectant	mg Cl/l	0.28	
V1348OUT	Moydamlaght Draperstown SR Outlet	4953149	09/08/2024 08:46	Total - Residual disinfectant	mg Cl/l	0.38	
V1348OUT	Moydamlaght Draperstown SR Outlet	4953149	09/08/2024 08:46	Total Coliforms	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4952626	09/08/2024 08:47	Colony Counts 22	CFU/1 ml	1	
V4712OUT	Corranny SR Outlet	4952626	09/08/2024 08:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4952626	09/08/2024 08:47	E. coli	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4952626	09/08/2024 08:47	Free - Residual disinfectant	mg Cl/l	0.67	
V4712OUT	Corranny SR Outlet	4952626	09/08/2024 08:47	Total - Residual disinfectant	mg Cl/l	0.82	
V4712OUT	Corranny SR Outlet	4952626	09/08/2024 08:47	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4953154	09/08/2024 09:10	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4953154	09/08/2024 09:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4953154	09/08/2024 09:10	E. coli	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4953154	09/08/2024 09:10	Free - Residual disinfectant	mg Cl/l	0.43	
V1356OUT	Mormeal SR Outlet	4953154	09/08/2024 09:10	Total - Residual disinfectant	mg Cl/l	0.61	
V1356OUT	Mormeal SR Outlet	4953154	09/08/2024 09:10	Total Coliforms	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4953159	09/08/2024 09:42	Colony Counts 22	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4953159	09/08/2024 09:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4953159	09/08/2024 09:42	E. coli	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4953159	09/08/2024 09:42	Free - Residual disinfectant	mg Cl/l	0.19	
V4528OUT	Crocknabohil SR Outlet	4953159	09/08/2024 09:42	Total - Residual disinfectant	mg Cl/l	0.26	
V4528OUT	Crocknabohil SR Outlet	4953159	09/08/2024 09:42	Total Coliforms	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4953155	09/08/2024 10:06	Colony Counts 22	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4953155	09/08/2024 10:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4953155	09/08/2024 10:06	E. coli	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4953155	09/08/2024 10:06	Free - Residual disinfectant	mg Cl/l	0.54	
V4537OUT	Sixmilecross SR Outlet	4953155	09/08/2024 10:06	Total - Residual disinfectant	mg Cl/l	0.62	
V4537OUT	Sixmilecross SR Outlet	4953155	09/08/2024 10:06	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4953099	09/08/2024 10:17	Colony Counts 22	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4953099	09/08/2024 10:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4953099	09/08/2024 10:17	E. coli	CFU/100 ml	0	0

V2301OUT	Ballydougan Command SR Outlet	4953099	09/08/2024 10:17	Free - Residual disinfectant	mg Cl/l	0.89	
V2301OUT	Ballydougan Command SR Outlet	4953099	09/08/2024 10:17	Total - Residual disinfectant	mg Cl/l	1.01	
V2301OUT	Ballydougan Command SR Outlet	4953099	09/08/2024 10:17	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4953099	09/08/2024 10:17	Odour	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4953099	09/08/2024 10:17	Odour - Nature		No odour	
V2301OUT	Ballydougan Command SR Outlet	4953099	09/08/2024 10:17	Taste	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4953099	09/08/2024 10:17	Taste - Nature		No taste	
V4531OUT	Foremass SR Outlet	4953152	09/08/2024 10:30	Colony Counts 22	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4953152	09/08/2024 10:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4953152	09/08/2024 10:30	E. coli	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4953152	09/08/2024 10:30	Free - Residual disinfectant	mg Cl/l	0.39	
V4531OUT	Foremass SR Outlet	4953152	09/08/2024 10:30	Total - Residual disinfectant	mg Cl/l	0.56	
V4531OUT	Foremass SR Outlet	4953152	09/08/2024 10:30	Total Coliforms	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4953100	09/08/2024 10:41	Colony Counts 22	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4953100	09/08/2024 10:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4953100	09/08/2024 10:41	E. coli	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4953100	09/08/2024 10:41	Free - Residual disinfectant	mg Cl/l	0.38	
V2302OUT	Ballyhannon SR Outlet	4953100	09/08/2024 10:41	Total - Residual disinfectant	mg Cl/l	0.42	
V2302OUT	Ballyhannon SR Outlet	4953100	09/08/2024 10:41	Total Coliforms	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4953127	09/08/2024 10:45	Colony Counts 22	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4953127	09/08/2024 10:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4953127	09/08/2024 10:45	E. coli	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4953127	09/08/2024 10:45	Free - Residual disinfectant	mg Cl/l	0.29	
V4540OUT	Radergan SR Outlet	4953127	09/08/2024 10:45	Total - Residual disinfectant	mg Cl/l	0.48	
V4540OUT	Radergan SR Outlet	4953127	09/08/2024 10:45	Total Coliforms	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4954970	12/08/2024 08:06	Colony Counts 22	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4954970	12/08/2024 08:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4954970	12/08/2024 08:06	E. coli	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4954970	12/08/2024 08:06	Free - Residual disinfectant	mg Cl/l	0.72	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4954970	12/08/2024 08:06	Total - Residual disinfectant	mg Cl/l	0.82	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4954970	12/08/2024 08:06	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4954983	12/08/2024 08:57	Colony Counts 22	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4954983	12/08/2024 08:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4954983	12/08/2024 08:57	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4954983	12/08/2024 08:57	Free - Residual disinfectant	mg Cl/l	0.25	
V1348OUT	Moydamlaght Draperstown SR Outlet	4954983	12/08/2024 08:57	Total - Residual disinfectant	mg Cl/l	0.42	
V1348OUT	Moydamlaght Draperstown SR Outlet	4954983	12/08/2024 08:57	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4954988	12/08/2024 09:33	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4954988	12/08/2024 09:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4954988	12/08/2024 09:33	E. coli	CFU/100 ml	0	0

V1356OUT	Mormeal SR Outlet	4954988	12/08/2024 09:33	Free - Residual disinfectant	mg Cl/l	0.12	
V1356OUT	Mormeal SR Outlet	4954988	12/08/2024 09:33	Total - Residual disinfectant	mg Cl/l	0.35	
V1356OUT	Mormeal SR Outlet	4954988	12/08/2024 09:33	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4954951	12/08/2024 10:17	Colony Counts 22	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4954951	12/08/2024 10:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4954951	12/08/2024 10:17	E. coli	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4954951	12/08/2024 10:17	Free - Residual disinfectant	mg Cl/l	0.88	
V2301OUT	Ballydougan Command SR Outlet	4954951	12/08/2024 10:17	Total - Residual disinfectant	mg Cl/l	0.98	
V2301OUT	Ballydougan Command SR Outlet	4954951	12/08/2024 10:17	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4954951	12/08/2024 10:17	Odour	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4954951	12/08/2024 10:17	Odour - Nature		No odour	
V2301OUT	Ballydougan Command SR Outlet	4954951	12/08/2024 10:17	Taste	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4954951	12/08/2024 10:17	Taste - Nature		No taste	
V4540OUT	Radergan SR Outlet	4954963	12/08/2024 10:37	Colony Counts 22	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4954963	12/08/2024 10:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4954963	12/08/2024 10:37	E. coli	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4954963	12/08/2024 10:37	Free - Residual disinfectant	mg Cl/l	0.49	
V4540OUT	Radergan SR Outlet	4954963	12/08/2024 10:37	Total - Residual disinfectant	mg Cl/l	0.56	
V4540OUT	Radergan SR Outlet	4954963	12/08/2024 10:37	Total Coliforms	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4954952	12/08/2024 10:40	Colony Counts 22	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4954952	12/08/2024 10:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4954952	12/08/2024 10:40	E. coli	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4954952	12/08/2024 10:40	Free - Residual disinfectant	mg Cl/l	0.33	
V2302OUT	Ballyhannon SR Outlet	4954952	12/08/2024 10:40	Total - Residual disinfectant	mg Cl/l	0.4	
V2302OUT	Ballyhannon SR Outlet	4954952	12/08/2024 10:40	Total Coliforms	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4954986	12/08/2024 10:49	Colony Counts 22	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4954986	12/08/2024 10:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4954986	12/08/2024 10:49	E. coli	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4954986	12/08/2024 10:49	Free - Residual disinfectant	mg Cl/l	0.55	
V4531OUT	Foremass SR Outlet	4954986	12/08/2024 10:49	Total - Residual disinfectant	mg Cl/l	0.63	
V4531OUT	Foremass SR Outlet	4954986	12/08/2024 10:49	Total Coliforms	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4954989	12/08/2024 11:03	Colony Counts 22	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4954989	12/08/2024 11:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4954989	12/08/2024 11:03	E. coli	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4954989	12/08/2024 11:03	Free - Residual disinfectant	mg Cl/l	0.55	
V4537OUT	Sixmilecross SR Outlet	4954989	12/08/2024 11:03	Total - Residual disinfectant	mg Cl/l	0.64	
V4537OUT	Sixmilecross SR Outlet	4954989	12/08/2024 11:03	Total Coliforms	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4954993	12/08/2024 11:20	Colony Counts 22	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4954993	12/08/2024 11:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4954993	12/08/2024 11:20	E. coli	CFU/100 ml	0	0

V4528OUT	Crocknabohil SR Outlet	4954993	12/08/2024 11:20	Free - Residual disinfectant	mg Cl/l	0.31	
V4528OUT	Crocknabohil SR Outlet	4954993	12/08/2024 11:20	Total - Residual disinfectant	mg Cl/l	0.39	
V4528OUT	Crocknabohil SR Outlet	4954993	12/08/2024 11:20	Total Coliforms	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4955293	13/08/2024 08:08	Colony Counts 22	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4955293	13/08/2024 08:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4955293	13/08/2024 08:08	E. coli	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4955293	13/08/2024 08:08	Free - Residual disinfectant	mg Cl/l	0.56	
V1351OUT	Cranny Moneymore SR Outlet	4955293	13/08/2024 08:08	Total - Residual disinfectant	mg Cl/l	0.66	
V1351OUT	Cranny Moneymore SR Outlet	4955293	13/08/2024 08:08	Total Coliforms	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4955281	13/08/2024 08:30	Colony Counts 22	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4955281	13/08/2024 08:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4955281	13/08/2024 08:30	E. coli	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4955281	13/08/2024 08:30	Free - Residual disinfectant	mg Cl/l	0.29	
V1352OUT	Cullion Desertmartin SR Outlet	4955281	13/08/2024 08:30	Total - Residual disinfectant	mg Cl/l	0.33	
V1352OUT	Cullion Desertmartin SR Outlet	4955281	13/08/2024 08:30	Total Coliforms	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4955304	13/08/2024 08:52	Colony Counts 22	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4955304	13/08/2024 08:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4955304	13/08/2024 08:52	E. coli	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4955304	13/08/2024 08:52	Free - Residual disinfectant	mg Cl/l	0.65	
V1343OUT	Ballybriest SR Outlet	4955304	13/08/2024 08:52	Total - Residual disinfectant	mg Cl/l	0.71	
V1343OUT	Ballybriest SR Outlet	4955304	13/08/2024 08:52	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4955252	13/08/2024 09:02	Colony Counts 22	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4955252	13/08/2024 09:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4955252	13/08/2024 09:02	E. coli	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4955252	13/08/2024 09:02	Free - Residual disinfectant	mg Cl/l	0.73	
V2508OUT	Carland SR Outlet	4955252	13/08/2024 09:02	Total - Residual disinfectant	mg Cl/l	0.82	
V2508OUT	Carland SR Outlet	4955252	13/08/2024 09:02	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4955252	13/08/2024 09:02	Odour	Diln No	0	0
V2508OUT	Carland SR Outlet	4955252	13/08/2024 09:02	Odour - Nature		No odour	
V2508OUT	Carland SR Outlet	4955252	13/08/2024 09:02	Taste	Diln No	0	0
V2508OUT	Carland SR Outlet	4955252	13/08/2024 09:02	Taste - Nature		No taste	
V2509OUT	Castlehill Drumcoo SR Outlet	4955253	13/08/2024 09:59	Colony Counts 22	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4955253	13/08/2024 09:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4955253	13/08/2024 09:59	E. coli	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4955253	13/08/2024 09:59	Free - Residual disinfectant	mg Cl/l	0.56	
V2509OUT	Castlehill Drumcoo SR Outlet	4955253	13/08/2024 09:59	Total - Residual disinfectant	mg Cl/l	0.66	
V2509OUT	Castlehill Drumcoo SR Outlet	4955253	13/08/2024 09:59	Total Coliforms	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4955291	13/08/2024 10:06	Colony Counts 22	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4955291	13/08/2024 10:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4955291	13/08/2024 10:06	E. coli	CFU/100 ml	0	0

V4745OUT	Glasdrumman Lisnaskea SR Outlet	4955291	13/08/2024 10:06	Free - Residual disinfectant	mg Cl/l	0.57	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4955291	13/08/2024 10:06	Total - Residual disinfectant	mg Cl/l	0.66	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4955291	13/08/2024 10:06	Total Coliforms	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4955292	13/08/2024 10:10	Colony Counts 22	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4955292	13/08/2024 10:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4955292	13/08/2024 10:10	E. coli	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4955292	13/08/2024 10:10	Free - Residual disinfectant	mg Cl/l	0.37	
V1713OUT	Trienaltenagh SR Outlet	4955292	13/08/2024 10:10	Total - Residual disinfectant	mg Cl/l	0.56	
V1713OUT	Trienaltenagh SR Outlet	4955292	13/08/2024 10:10	Total Coliforms	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4955266	13/08/2024 10:15	Colony Counts 22	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4955266	13/08/2024 10:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4955266	13/08/2024 10:15	E. coli	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4955266	13/08/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.99	
V2521OUT	Mullaghanagh SR Outlet	4955266	13/08/2024 10:15	Total - Residual disinfectant	mg Cl/l	1.06	
V2521OUT	Mullaghanagh SR Outlet	4955266	13/08/2024 10:15	Total Coliforms	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4955289	13/08/2024 10:25	Colony Counts 22	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4955289	13/08/2024 10:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4955289	13/08/2024 10:25	E. coli	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4955289	13/08/2024 10:25	Free - Residual disinfectant	mg Cl/l	0.09	
V1708OUT	North Garvagh SR Outlet	4955289	13/08/2024 10:25	Total - Residual disinfectant	mg Cl/l	0.25	
V1708OUT	North Garvagh SR Outlet	4955289	13/08/2024 10:25	Total Coliforms	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4955288	13/08/2024 10:33	Colony Counts 22	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4955288	13/08/2024 10:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4955288	13/08/2024 10:33	E. coli	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4955288	13/08/2024 10:33	Free - Residual disinfectant	mg Cl/l	0.66	
V4742OUT	Tattinbar SR Outlet	4955288	13/08/2024 10:33	Total - Residual disinfectant	mg Cl/l	0.73	
V4742OUT	Tattinbar SR Outlet	4955288	13/08/2024 10:33	Total Coliforms	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4955280	13/08/2024 10:41	Colony Counts 22	CFU/1 ml	1	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4955280	13/08/2024 10:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4955280	13/08/2024 10:41	E. coli	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4955280	13/08/2024 10:41	Free - Residual disinfectant	mg Cl/l	0.75	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4955280	13/08/2024 10:41	Total - Residual disinfectant	mg Cl/l	0.81	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4955280	13/08/2024 10:41	Total Coliforms	CFU/100 ml	0	0
V1361OUT	Moneymore Tamnadoey SR Outlet	4966966	13/08/2024 10:53	Colony Counts 22	CFU/1 ml	0	
V1361OUT	Moneymore Tamnadoey SR Outlet	4966966	13/08/2024 10:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1361OUT	Moneymore Tamnadoey SR Outlet	4966966	13/08/2024 10:53	E. coli	CFU/100 ml	0	0
V1361OUT	Moneymore Tamnadoey SR Outlet	4966966	13/08/2024 10:53	Free - Residual disinfectant	mg Cl/l	0.22	
V1361OUT	Moneymore Tamnadoey SR Outlet	4966966	13/08/2024 10:53	Total - Residual disinfectant	mg Cl/l	0.46	
V1361OUT	Moneymore Tamnadoey SR Outlet	4966966	13/08/2024 10:53	Total Coliforms	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4955285	13/08/2024 11:00	Colony Counts 22	CFU/1 ml	0	

V1706OUT	Killeague SR Outlet	4955285	13/08/2024 11:00	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V1706OUT	Killeague SR Outlet	4955285	13/08/2024 11:00	E. coli	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4955285	13/08/2024 11:00	Free - Residual disinfectant	mg Cl/l	0.59	
V1706OUT	Killeague SR Outlet	4955285	13/08/2024 11:00	Total - Residual disinfectant	mg Cl/l	0.69	
V1706OUT	Killeague SR Outlet	4955285	13/08/2024 11:00	Total Coliforms	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4955306	13/08/2024 11:03	Colony Counts 22	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4955306	13/08/2024 11:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4955306	13/08/2024 11:03	E. coli	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4955306	13/08/2024 11:03	Free - Residual disinfectant	mg Cl/l	0.71	
V4715OUT	Brookeborough High SR Outlet	4955306	13/08/2024 11:03	Total - Residual disinfectant	mg Cl/l	0.76	
V4715OUT	Brookeborough High SR Outlet	4955306	13/08/2024 11:03	Total Coliforms	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4955287	13/08/2024 11:20	Colony Counts 22	CFU/1 ml	2	
V1702OUT	Cam SR Outlet	4955287	13/08/2024 11:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4955287	13/08/2024 11:20	E. coli	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4955287	13/08/2024 11:20	Free - Residual disinfectant	mg Cl/l	<0.05	
V1702OUT	Cam SR Outlet	4955287	13/08/2024 11:20	Total - Residual disinfectant	mg Cl/l	0.1	
V1702OUT	Cam SR Outlet	4955287	13/08/2024 11:20	Total Coliforms	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4955290	13/08/2024 11:31	Colony Counts 22	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4955290	13/08/2024 11:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4955290	13/08/2024 11:31	E. coli	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4955290	13/08/2024 11:31	Free - Residual disinfectant	mg Cl/l	0.59	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4955290	13/08/2024 11:31	Total - Residual disinfectant	mg Cl/l	0.68	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4955290	13/08/2024 11:31	Total Coliforms	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4955550	14/08/2024 09:02	Colony Counts 22	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4955550	14/08/2024 09:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4955550	14/08/2024 09:02	E. coli	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4955550	14/08/2024 09:02	Free - Residual disinfectant	mg Cl/l	0.2	
V1338OUT	Coagh SR Outlet	4955550	14/08/2024 09:02	Total - Residual disinfectant	mg Cl/l	0.26	
V1338OUT	Coagh SR Outlet	4955550	14/08/2024 09:02	Total Coliforms	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4969227	14/08/2024 09:07	Cryptosporidium Oocysts	Oocyst/10l	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4969227	14/08/2024 09:07	Oocysts per volume filtered	Oocyst	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4969227	14/08/2024 09:07	Pellet Size	ml	<0.5	
V4708OUT	Cavanacross Enniskillen SR Outlet	4969227	14/08/2024 09:07	Sample Volume	l	10	
V1335OUT	Brigh Quarry SR Outlet	4955549	14/08/2024 09:37	Colony Counts 22	CFU/1 ml	3	
V1335OUT	Brigh Quarry SR Outlet	4955549	14/08/2024 09:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4955549	14/08/2024 09:37	E. coli	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4955549	14/08/2024 09:37	Free - Residual disinfectant	mg Cl/l	0.41	
V1335OUT	Brigh Quarry SR Outlet	4955549	14/08/2024 09:37	Total - Residual disinfectant	mg Cl/l	0.48	
V1335OUT	Brigh Quarry SR Outlet	4955549	14/08/2024 09:37	Total Coliforms	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4955503	14/08/2024 09:37	Colony Counts 22	CFU/1 ml	0	

V2511OUT	Corran Armagh SR Outlet	4955503	14/08/2024 09:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4955503	14/08/2024 09:37	E. coli	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4955503	14/08/2024 09:37	Free - Residual disinfectant	mg Cl/l	0.76	
V2511OUT	Corran Armagh SR Outlet	4955503	14/08/2024 09:37	Total - Residual disinfectant	mg Cl/l	0.97	
V2511OUT	Corran Armagh SR Outlet	4955503	14/08/2024 09:37	Total Coliforms	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4969232	14/08/2024 09:43	Cryptosporidium Oocysts	Oocyst/10l	0	
V4742OUT	Tattinbar SR Outlet	4969232	14/08/2024 09:43	Oocysts per volume filtered	Oocyst	0	
V4742OUT	Tattinbar SR Outlet	4969232	14/08/2024 09:43	Pellet Size	ml	<0.5	
V4742OUT	Tattinbar SR Outlet	4969232	14/08/2024 09:43	Sample Volume	l	10	
V1342OUT	Dromore High SR Outlet	4955553	14/08/2024 09:53	Colony Counts 22	CFU/1 ml	9	
V1342OUT	Dromore High SR Outlet	4955553	14/08/2024 09:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4955553	14/08/2024 09:53	E. coli	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4955553	14/08/2024 09:53	Free - Residual disinfectant	mg Cl/l	0.4	
V1342OUT	Dromore High SR Outlet	4955553	14/08/2024 09:53	Total - Residual disinfectant	mg Cl/l	0.45	
V1342OUT	Dromore High SR Outlet	4955553	14/08/2024 09:53	Total Coliforms	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4955546	14/08/2024 10:08	Colony Counts 22	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4955546	14/08/2024 10:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4955546	14/08/2024 10:08	E. coli	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4955546	14/08/2024 10:08	Free - Residual disinfectant	mg Cl/l	0.55	
V4533OUT	Inisclan SR Outlet	4955546	14/08/2024 10:08	Total - Residual disinfectant	mg Cl/l	0.67	
V4533OUT	Inisclan SR Outlet	4955546	14/08/2024 10:08	Total Coliforms	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4955502	14/08/2024 10:15	Colony Counts 22	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4955502	14/08/2024 10:15	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V2510OUT	Calone SR Outlet	4955502	14/08/2024 10:15	E. coli	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4955502	14/08/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.45	
V2510OUT	Calone SR Outlet	4955502	14/08/2024 10:15	Total - Residual disinfectant	mg Cl/l	0.67	
V2510OUT	Calone SR Outlet	4955502	14/08/2024 10:15	Total Coliforms	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4955514	14/08/2024 10:16	Colony Counts 22	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4955514	14/08/2024 10:16	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V2518OUT	Lisnastrane SR Outlet	4955514	14/08/2024 10:16	E. coli	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4955514	14/08/2024 10:16	Free - Residual disinfectant	mg Cl/l	0.9	
V2518OUT	Lisnastrane SR Outlet	4955514	14/08/2024 10:16	Total - Residual disinfectant	mg Cl/l	0.97	
V2518OUT	Lisnastrane SR Outlet	4955514	14/08/2024 10:16	Total Coliforms	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4955513	14/08/2024 10:37	Colony Counts 22	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4955513	14/08/2024 10:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4955513	14/08/2024 10:37	E. coli	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4955513	14/08/2024 10:37	Free - Residual disinfectant	mg Cl/l	0.68	
V2514OUT	Edenaveys Command SR Outlet	4955513	14/08/2024 10:37	Total - Residual disinfectant	mg Cl/l	0.91	
V2514OUT	Edenaveys Command SR Outlet	4955513	14/08/2024 10:37	Total Coliforms	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4955499	14/08/2024 11:02	Colony Counts 22	CFU/1 ml	90	

V2523OUT	Rough Fort SR Outlet	4955499	14/08/2024 11:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4955499	14/08/2024 11:02	E. coli	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4955499	14/08/2024 11:02	Free - Residual disinfectant	mg Cl/l	0.93	
V2523OUT	Rough Fort SR Outlet	4955499	14/08/2024 11:02	Total - Residual disinfectant	mg Cl/l	1.17	
V2523OUT	Rough Fort SR Outlet	4955499	14/08/2024 11:02	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4955542	14/08/2024 11:33	Colony Counts 22	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4955542	14/08/2024 11:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4955542	14/08/2024 11:33	E. coli	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4955542	14/08/2024 11:33	Free - Residual disinfectant	mg Cl/l	0.09	
V1704OUT	Castlerock Downhill SR Outlet	4955542	14/08/2024 11:33	Total - Residual disinfectant	mg Cl/l	0.15	
V1704OUT	Castlerock Downhill SR Outlet	4955542	14/08/2024 11:33	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4955542	14/08/2024 11:33	Odour	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4955542	14/08/2024 11:33	Odour - Nature		No odour	
V1704OUT	Castlerock Downhill SR Outlet	4955542	14/08/2024 11:33	Taste	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4955542	14/08/2024 11:33	Taste - Nature		No taste	
V1711OUT	Sconce Hill SR Outlet	4955543	14/08/2024 12:00	Colony Counts 22	CFU/1 ml	>300	
V1711OUT	Sconce Hill SR Outlet	4955543	14/08/2024 12:00	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V1711OUT	Sconce Hill SR Outlet	4955543	14/08/2024 12:00	E. coli	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4955543	14/08/2024 12:00	Free - Residual disinfectant	mg Cl/l	0.1	
V1711OUT	Sconce Hill SR Outlet	4955543	14/08/2024 12:00	Total - Residual disinfectant	mg Cl/l	0.22	
V1711OUT	Sconce Hill SR Outlet	4955543	14/08/2024 12:00	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4955756	15/08/2024 08:06	Colony Counts 22	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4955756	15/08/2024 08:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4955756	15/08/2024 08:06	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4955756	15/08/2024 08:06	Free - Residual disinfectant	mg Cl/l	0.46	
V1360OUT	Windmill Hill SR Outlet	4955756	15/08/2024 08:06	Total - Residual disinfectant	mg Cl/l	0.57	
V1360OUT	Windmill Hill SR Outlet	4955756	15/08/2024 08:06	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4955767	15/08/2024 08:25	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4955767	15/08/2024 08:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4955767	15/08/2024 08:25	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4955767	15/08/2024 08:25	Free - Residual disinfectant	mg Cl/l	0.74	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4955767	15/08/2024 08:25	Total - Residual disinfectant	mg Cl/l	1.02	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4955767	15/08/2024 08:25	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4955767	15/08/2024 08:25	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4955767	15/08/2024 08:25	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4955767	15/08/2024 08:25	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4955767	15/08/2024 08:25	Taste - Nature		No taste	
V4708OUT	Cavanacross Enniskillen SR Outlet	4969603	15/08/2024 08:59	Cryptosporidium Oocysts	Oocyst/10l	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4969603	15/08/2024 08:59	Oocysts per volume filtered	Oocyst	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4969603	15/08/2024 08:59	Pellet Size	ml	<0.5	

V4708OUT	Cavanacross Enniskillen SR Outlet	4969603	15/08/2024 08:59	Sample Volume	l	10	
V1344OUT	Craigs Cookstown SR Outlet	4955771	15/08/2024 08:59	Colony Counts 22	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4955771	15/08/2024 08:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4955771	15/08/2024 08:59	E. coli	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4955771	15/08/2024 08:59	Free - Residual disinfectant	mg Cl/l	0.35	
V1344OUT	Craigs Cookstown SR Outlet	4955771	15/08/2024 08:59	Total - Residual disinfectant	mg Cl/l	0.4	
V1344OUT	Craigs Cookstown SR Outlet	4955771	15/08/2024 08:59	Total Coliforms	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4955758	15/08/2024 09:17	Colony Counts 22	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4955758	15/08/2024 09:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4955758	15/08/2024 09:17	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4955758	15/08/2024 09:17	Free - Residual disinfectant	mg Cl/l	0.2	
V1362OUT	Unagh SR Outlet	4955758	15/08/2024 09:17	Total - Residual disinfectant	mg Cl/l	0.27	
V1362OUT	Unagh SR Outlet	4955758	15/08/2024 09:17	Total Coliforms	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4969601	15/08/2024 09:35	Cryptosporidium Oocysts	Oocyst/10l	0	
V4742OUT	Tattinbar SR Outlet	4969601	15/08/2024 09:35	Oocysts per volume filtered	Oocyst	0	
V4742OUT	Tattinbar SR Outlet	4969601	15/08/2024 09:35	Pellet Size	ml	<0.5	
V4742OUT	Tattinbar SR Outlet	4969601	15/08/2024 09:35	Sample Volume	l	10	
V1339OUT	Corvanaghan High SR Outlet	4955768	15/08/2024 09:37	Colony Counts 22	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4955768	15/08/2024 09:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4955768	15/08/2024 09:37	E. coli	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4955768	15/08/2024 09:37	Free - Residual disinfectant	mg Cl/l	0.66	
V1339OUT	Corvanaghan High SR Outlet	4955768	15/08/2024 09:37	Total - Residual disinfectant	mg Cl/l	0.72	
V1339OUT	Corvanaghan High SR Outlet	4955768	15/08/2024 09:37	Total Coliforms	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4955872	15/08/2024 09:37	Colony Counts 22	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4955872	15/08/2024 09:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4955872	15/08/2024 09:37	E. coli	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4955872	15/08/2024 09:37	Free - Residual disinfectant	mg Cl/l	0.21	
V4539OUT	Erganagh SR Outlet	4955872	15/08/2024 09:37	Total - Residual disinfectant	mg Cl/l	0.3	
V4539OUT	Erganagh SR Outlet	4955872	15/08/2024 09:37	Total Coliforms	CFU/100 ml	0	0
V4538OUT	Killiclogher SR Outlet	4955736	15/08/2024 09:52	Colony Counts 22	CFU/1 ml	0	
V4538OUT	Killiclogher SR Outlet	4955736	15/08/2024 09:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4538OUT	Killiclogher SR Outlet	4955736	15/08/2024 09:52	E. coli	CFU/100 ml	0	0
V4538OUT	Killiclogher SR Outlet	4955736	15/08/2024 09:52	Free - Residual disinfectant	mg Cl/l	0.38	
V4538OUT	Killiclogher SR Outlet	4955736	15/08/2024 09:52	Total - Residual disinfectant	mg Cl/l	0.45	
V4538OUT	Killiclogher SR Outlet	4955736	15/08/2024 09:52	Total Coliforms	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4955769	15/08/2024 09:57	Colony Counts 22	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4955769	15/08/2024 09:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4955769	15/08/2024 09:57	E. coli	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4955769	15/08/2024 09:57	Free - Residual disinfectant	mg Cl/l	0.66	
V1340OUT	Craigballyharkey SR Outlet	4955769	15/08/2024 09:57	Total - Residual disinfectant	mg Cl/l	0.72	

V1340OUT	Craigballyharkey SR Outlet	4955769	15/08/2024 09:57	Total Coliforms	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4955772	15/08/2024 10:11	Colony Counts 22	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4955772	15/08/2024 10:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4955772	15/08/2024 10:11	E. coli	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4955772	15/08/2024 10:11	Free - Residual disinfectant	mg Cl/l	0.22	
V1346OUT	Gortaclady Evishanoran SR Outlet	4955772	15/08/2024 10:11	Total - Residual disinfectant	mg Cl/l	0.26	
V1346OUT	Gortaclady Evishanoran SR Outlet	4955772	15/08/2024 10:11	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4955763	15/08/2024 10:18	Colony Counts 22	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4955763	15/08/2024 10:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4955763	15/08/2024 10:18	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4955763	15/08/2024 10:18	Free - Residual disinfectant	mg Cl/l	0.11	
V1350OUT	Carnaman SR Outlet	4955763	15/08/2024 10:18	Total - Residual disinfectant	mg Cl/l	0.27	
V1350OUT	Carnaman SR Outlet	4955763	15/08/2024 10:18	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4955763	15/08/2024 10:18	Odour	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4955763	15/08/2024 10:18	Odour - Nature		No odour	
V1350OUT	Carnaman SR Outlet	4955763	15/08/2024 10:18	Taste	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4955763	15/08/2024 10:18	Taste - Nature		No taste	
V4536OUT	Lough Macrory North SR Outlet	4955744	15/08/2024 10:47	Colony Counts 22	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4955744	15/08/2024 10:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4955744	15/08/2024 10:47	E. coli	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4955744	15/08/2024 10:47	Free - Residual disinfectant	mg Cl/l	0.68	
V4536OUT	Lough Macrory North SR Outlet	4955744	15/08/2024 10:47	Total - Residual disinfectant	mg Cl/l	0.8	
V4536OUT	Lough Macrory North SR Outlet	4955744	15/08/2024 10:47	Total Coliforms	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4955735	15/08/2024 11:05	Colony Counts 22	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4955735	15/08/2024 11:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4955735	15/08/2024 11:05	E. coli	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4955735	15/08/2024 11:05	Free - Residual disinfectant	mg Cl/l	0.42	
V4526OUT	Black Lough Pomeroy SR Outlet	4955735	15/08/2024 11:05	Total - Residual disinfectant	mg Cl/l	0.48	
V4526OUT	Black Lough Pomeroy SR Outlet	4955735	15/08/2024 11:05	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4955946	16/08/2024 07:27	Colony Counts 22	CFU/1 ml	13	
V1354OUT	Knockoneill SR Outlet	4955946	16/08/2024 07:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4955946	16/08/2024 07:27	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4955946	16/08/2024 07:27	Free - Residual disinfectant	mg Cl/l	0.1	
V1354OUT	Knockoneill SR Outlet	4955946	16/08/2024 07:27	Total - Residual disinfectant	mg Cl/l	0.56	
V1354OUT	Knockoneill SR Outlet	4955946	16/08/2024 07:27	Total Coliforms	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4955948	16/08/2024 07:50	Colony Counts 22	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4955948	16/08/2024 07:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4955948	16/08/2024 07:50	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4955948	16/08/2024 07:50	Free - Residual disinfectant	mg Cl/l	0.49	
V1358OUT	Slaughtneil SR Outlet	4955948	16/08/2024 07:50	Total - Residual disinfectant	mg Cl/l	0.56	

V1358OUT	Slaughtneil SR Outlet	4955948	16/08/2024 07:50	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4955903	16/08/2024 07:55	Colony Counts 22	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4955903	16/08/2024 07:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4955903	16/08/2024 07:55	E. coli	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4955903	16/08/2024 07:55	Free - Residual disinfectant	mg Cl/l	0.71	
V1725OUT	Glenlough SR Outlet	4955903	16/08/2024 07:55	Total - Residual disinfectant	mg Cl/l	1.02	
V1725OUT	Glenlough SR Outlet	4955903	16/08/2024 07:55	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4955940	16/08/2024 08:12	Colony Counts 22	CFU/1 ml	241	
V1349OUT	Ballyknock Magherafelt SR Outlet	4955940	16/08/2024 08:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4955940	16/08/2024 08:12	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4955940	16/08/2024 08:12	Free - Residual disinfectant	mg Cl/l	0.24	
V1349OUT	Ballyknock Magherafelt SR Outlet	4955940	16/08/2024 08:12	Total - Residual disinfectant	mg Cl/l	0.5	
V1349OUT	Ballyknock Magherafelt SR Outlet	4955940	16/08/2024 08:12	Total Coliforms	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4955951	16/08/2024 09:01	Colony Counts 22	CFU/1 ml	16	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4955951	16/08/2024 09:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4955951	16/08/2024 09:01	E. coli	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4955951	16/08/2024 09:01	Free - Residual disinfectant	mg Cl/l	0.26	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4955951	16/08/2024 09:01	Total - Residual disinfectant	mg Cl/l	0.3	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4955951	16/08/2024 09:01	Total Coliforms	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4955923	16/08/2024 09:21	Colony Counts 22	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4955923	16/08/2024 09:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4955923	16/08/2024 09:21	E. coli	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4955923	16/08/2024 09:21	Free - Residual disinfectant	mg Cl/l	0.93	
V2501OUT	Altmore River SR Outlet	4955923	16/08/2024 09:21	Total - Residual disinfectant	mg Cl/l	1.01	
V2501OUT	Altmore River SR Outlet	4955923	16/08/2024 09:21	Total Coliforms	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4955897	16/08/2024 09:33	Colony Counts 22	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4955897	16/08/2024 09:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4955897	16/08/2024 09:33	E. coli	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4955897	16/08/2024 09:33	Free - Residual disinfectant	mg Cl/l	0.68	
V2507OUT	Cappagh SR Outlet	4955897	16/08/2024 09:33	Total - Residual disinfectant	mg Cl/l	0.72	
V2507OUT	Cappagh SR Outlet	4955897	16/08/2024 09:33	Total Coliforms	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4955896	16/08/2024 09:51	Colony Counts 22	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4955896	16/08/2024 09:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4955896	16/08/2024 09:51	E. coli	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4955896	16/08/2024 09:51	Free - Residual disinfectant	mg Cl/l	0.74	
V2505OUT	Cabragh Fasglashagh SR Outlet	4955896	16/08/2024 09:51	Total - Residual disinfectant	mg Cl/l	0.84	
V2505OUT	Cabragh Fasglashagh SR Outlet	4955896	16/08/2024 09:51	Total Coliforms	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4955945	16/08/2024 09:52	Colony Counts 22	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4955945	16/08/2024 09:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4955945	16/08/2024 09:52	E. coli	CFU/100 ml	0	0

V4719OUT	Glenchuil SR Outlet	4955945	16/08/2024 09:52	Free - Residual disinfectant	mg Cl/l	0.39	
V4719OUT	Glenchuil SR Outlet	4955945	16/08/2024 09:52	Total - Residual disinfectant	mg Cl/l	0.5	
V4719OUT	Glenchuil SR Outlet	4955945	16/08/2024 09:52	Total Coliforms	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4955955	16/08/2024 10:27	Colony Counts 22	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4955955	16/08/2024 10:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4955955	16/08/2024 10:27	E. coli	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4955955	16/08/2024 10:27	Free - Residual disinfectant	mg Cl/l	0.21	
V4530OUT	Dungoran SR Outlet	4955955	16/08/2024 10:27	Total - Residual disinfectant	mg Cl/l	0.38	
V4530OUT	Dungoran SR Outlet	4955955	16/08/2024 10:27	Total Coliforms	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4955952	16/08/2024 10:30	Colony Counts 22	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4955952	16/08/2024 10:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4955952	16/08/2024 10:30	E. coli	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4955952	16/08/2024 10:30	Free - Residual disinfectant	mg Cl/l	1.02	
V4708OUT	Cavanacross Enniskillen SR Outlet	4955952	16/08/2024 10:30	Total - Residual disinfectant	mg Cl/l	1.11	
V4708OUT	Cavanacross Enniskillen SR Outlet	4955952	16/08/2024 10:30	Total Coliforms	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4955947	16/08/2024 10:39	Colony Counts 22	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4955947	16/08/2024 10:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4955947	16/08/2024 10:39	E. coli	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4955947	16/08/2024 10:39	Free - Residual disinfectant	mg Cl/l	0.35	
V4535OUT	Lisnagardy SR Outlet	4955947	16/08/2024 10:39	Total - Residual disinfectant	mg Cl/l	0.44	
V4535OUT	Lisnagardy SR Outlet	4955947	16/08/2024 10:39	Total Coliforms	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4955909	16/08/2024 11:07	Colony Counts 22	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4955909	16/08/2024 11:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4955909	16/08/2024 11:07	E. coli	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4955909	16/08/2024 11:07	Free - Residual disinfectant	mg Cl/l	0.72	
V4707OUT	Sidaire SR Outlet	4955909	16/08/2024 11:07	Total - Residual disinfectant	mg Cl/l	0.8	
V4707OUT	Sidaire SR Outlet	4955909	16/08/2024 11:07	Total Coliforms	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4955943	16/08/2024 11:10	Colony Counts 22	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4955943	16/08/2024 11:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4955943	16/08/2024 11:10	E. coli	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4955943	16/08/2024 11:10	Free - Residual disinfectant	mg Cl/l	<0.05	
V1715OUT	Ballystrone (Calvins) SR Outlet	4955943	16/08/2024 11:10	Total - Residual disinfectant	mg Cl/l	0.11	
V1715OUT	Ballystrone (Calvins) SR Outlet	4955943	16/08/2024 11:10	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4958084	19/08/2024 08:08	Colony Counts 22	CFU/1 ml	35	
V1354OUT	Knockoneill SR Outlet	4958084	19/08/2024 08:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4958084	19/08/2024 08:08	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4958084	19/08/2024 08:08	Free - Residual disinfectant	mg Cl/l	0.08	
V1354OUT	Knockoneill SR Outlet	4958084	19/08/2024 08:08	Total - Residual disinfectant	mg Cl/l	0.22	
V1354OUT	Knockoneill SR Outlet	4958084	19/08/2024 08:08	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4958084	19/08/2024 08:08	Odour	Diln No	0	0

V1354OUT	Knockoneill SR Outlet	4958084	19/08/2024 08:08	Odour - Nature		No odour	
V1354OUT	Knockoneill SR Outlet	4958084	19/08/2024 08:08	Taste	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4958084	19/08/2024 08:08	Taste - Nature		No taste	
V1358OUT	Slaughtneil SR Outlet	4958086	19/08/2024 08:26	Colony Counts 22	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4958086	19/08/2024 08:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4958086	19/08/2024 08:26	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4958086	19/08/2024 08:26	Free - Residual disinfectant	mg Cl/l	0.51	
V1358OUT	Slaughtneil SR Outlet	4958086	19/08/2024 08:26	Total - Residual disinfectant	mg Cl/l	0.71	
V1358OUT	Slaughtneil SR Outlet	4958086	19/08/2024 08:26	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4958078	19/08/2024 08:46	Colony Counts 22	CFU/1 ml	274	
V1349OUT	Ballyknock Magherafelt SR Outlet	4958078	19/08/2024 08:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4958078	19/08/2024 08:46	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4958078	19/08/2024 08:46	Free - Residual disinfectant	mg Cl/l	0.28	
V1349OUT	Ballyknock Magherafelt SR Outlet	4958078	19/08/2024 08:46	Total - Residual disinfectant	mg Cl/l	0.5	
V1349OUT	Ballyknock Magherafelt SR Outlet	4958078	19/08/2024 08:46	Total Coliforms	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4958089	19/08/2024 09:10	Colony Counts 22	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4958089	19/08/2024 09:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4958089	19/08/2024 09:10	E. coli	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4958089	19/08/2024 09:10	Free - Residual disinfectant	mg Cl/l	0.25	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4958089	19/08/2024 09:10	Total - Residual disinfectant	mg Cl/l	0.31	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4958089	19/08/2024 09:10	Total Coliforms	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4958061	19/08/2024 09:35	Colony Counts 22	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4958061	19/08/2024 09:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4958061	19/08/2024 09:35	E. coli	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4958061	19/08/2024 09:35	Free - Residual disinfectant	mg Cl/l	0.9	
V2501OUT	Altmore River SR Outlet	4958061	19/08/2024 09:35	Total - Residual disinfectant	mg Cl/l	1.01	
V2501OUT	Altmore River SR Outlet	4958061	19/08/2024 09:35	Total Coliforms	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4958093	19/08/2024 09:49	Colony Counts 22	CFU/1 ml	1	
V4530OUT	Dungoran SR Outlet	4958093	19/08/2024 09:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4958093	19/08/2024 09:49	E. coli	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4958093	19/08/2024 09:49	Free - Residual disinfectant	mg Cl/l	0.24	
V4530OUT	Dungoran SR Outlet	4958093	19/08/2024 09:49	Total - Residual disinfectant	mg Cl/l	0.4	
V4530OUT	Dungoran SR Outlet	4958093	19/08/2024 09:49	Total Coliforms	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4958041	19/08/2024 09:55	Colony Counts 22	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4958041	19/08/2024 09:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4958041	19/08/2024 09:55	E. coli	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4958041	19/08/2024 09:55	Free - Residual disinfectant	mg Cl/l	0.6	
V2507OUT	Cappagh SR Outlet	4958041	19/08/2024 09:55	Total - Residual disinfectant	mg Cl/l	0.65	
V2507OUT	Cappagh SR Outlet	4958041	19/08/2024 09:55	Total Coliforms	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4955554	19/08/2024 10:03	Colony Counts 22	CFU/1 ml	0	

V4712OUT	Corranny SR Outlet	4955554	19/08/2024 10:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4955554	19/08/2024 10:03	E. coli	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4955554	19/08/2024 10:03	Free - Residual disinfectant	mg Cl/l	0.42	
V4712OUT	Corranny SR Outlet	4955554	19/08/2024 10:03	Total - Residual disinfectant	mg Cl/l	0.46	
V4712OUT	Corranny SR Outlet	4955554	19/08/2024 10:03	Total Coliforms	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4958085	19/08/2024 10:05	Colony Counts 22	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4958085	19/08/2024 10:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4958085	19/08/2024 10:05	E. coli	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4958085	19/08/2024 10:05	Free - Residual disinfectant	mg Cl/l	0.33	
V4535OUT	Lisnagardy SR Outlet	4958085	19/08/2024 10:05	Total - Residual disinfectant	mg Cl/l	0.41	
V4535OUT	Lisnagardy SR Outlet	4958085	19/08/2024 10:05	Total Coliforms	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4958040	19/08/2024 10:15	Colony Counts 22	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4958040	19/08/2024 10:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4958040	19/08/2024 10:15	E. coli	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4958040	19/08/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.87	
V2505OUT	Cabragh Fasglashagh SR Outlet	4958040	19/08/2024 10:15	Total - Residual disinfectant	mg Cl/l	0.92	
V2505OUT	Cabragh Fasglashagh SR Outlet	4958040	19/08/2024 10:15	Total Coliforms	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4958058	19/08/2024 10:32	Colony Counts 22	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4958058	19/08/2024 10:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4958058	19/08/2024 10:32	E. coli	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4958058	19/08/2024 10:32	Free - Residual disinfectant	mg Cl/l	0.11	
V4527OUT	Carryglass SR Outlet	4958058	19/08/2024 10:32	Total - Residual disinfectant	mg Cl/l	0.2	
V4527OUT	Carryglass SR Outlet	4958058	19/08/2024 10:32	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4958047	19/08/2024 10:45	Colony Counts 22	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4958047	19/08/2024 10:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4958047	19/08/2024 10:45	E. coli	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4958047	19/08/2024 10:45	Free - Residual disinfectant	mg Cl/l	0.2	
V1725OUT	Glenlough SR Outlet	4958047	19/08/2024 10:45	Total - Residual disinfectant	mg Cl/l	0.4	
V1725OUT	Glenlough SR Outlet	4958047	19/08/2024 10:45	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4958047	19/08/2024 10:45	Odour	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4958047	19/08/2024 10:45	Odour - Nature		No odour	
V1725OUT	Glenlough SR Outlet	4958047	19/08/2024 10:45	Taste	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4958047	19/08/2024 10:45	Taste - Nature		No taste	
V4713OUT	Knocknalosset SR Outlet	4955558	19/08/2024 10:54	Colony Counts 22	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4955558	19/08/2024 10:54	Colony Counts 37 (48hrs)	CFU/1 ml	2	
V4713OUT	Knocknalosset SR Outlet	4955558	19/08/2024 10:54	E. coli	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4955558	19/08/2024 10:54	Free - Residual disinfectant	mg Cl/l	0.52	
V4713OUT	Knocknalosset SR Outlet	4955558	19/08/2024 10:54	Total - Residual disinfectant	mg Cl/l	0.6	
V4713OUT	Knocknalosset SR Outlet	4955558	19/08/2024 10:54	Total Coliforms	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4958081	19/08/2024 12:10	Colony Counts 22	CFU/1 ml	2	

V1715OUT	Ballystrone (Calvins) SR Outlet	4958081	19/08/2024 12:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4958081	19/08/2024 12:10	E. coli	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4958081	19/08/2024 12:10	Free - Residual disinfectant	mg Cl/l	<0.05	
V1715OUT	Ballystrone (Calvins) SR Outlet	4958081	19/08/2024 12:10	Total - Residual disinfectant	mg Cl/l	0.13	
V1715OUT	Ballystrone (Calvins) SR Outlet	4958081	19/08/2024 12:10	Total Coliforms	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4958361	20/08/2024 08:31	Colony Counts 22	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4958361	20/08/2024 08:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4958361	20/08/2024 08:31	E. coli	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4958361	20/08/2024 08:31	Free - Residual disinfectant	mg Cl/l	0.68	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4958361	20/08/2024 08:31	Total - Residual disinfectant	mg Cl/l	0.8	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4958361	20/08/2024 08:31	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4958374	20/08/2024 09:02	Colony Counts 22	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4958374	20/08/2024 09:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4958374	20/08/2024 09:02	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4958374	20/08/2024 09:02	Free - Residual disinfectant	mg Cl/l	0.3	
V1348OUT	Moydamlaght Draperstown SR Outlet	4958374	20/08/2024 09:02	Total - Residual disinfectant	mg Cl/l	0.42	
V1348OUT	Moydamlaght Draperstown SR Outlet	4958374	20/08/2024 09:02	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4958379	20/08/2024 09:28	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4958379	20/08/2024 09:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4958379	20/08/2024 09:28	E. coli	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4958379	20/08/2024 09:28	Free - Residual disinfectant	mg Cl/l	0.4	
V1356OUT	Mormeal SR Outlet	4958379	20/08/2024 09:28	Total - Residual disinfectant	mg Cl/l	0.63	
V1356OUT	Mormeal SR Outlet	4958379	20/08/2024 09:28	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4958338	20/08/2024 10:59	Colony Counts 22	CFU/1 ml	1	
V2301OUT	Ballydougan Command SR Outlet	4958338	20/08/2024 10:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4958338	20/08/2024 10:59	E. coli	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4958338	20/08/2024 10:59	Free - Residual disinfectant	mg Cl/l	0.9	
V2301OUT	Ballydougan Command SR Outlet	4958338	20/08/2024 10:59	Total - Residual disinfectant	mg Cl/l	0.96	
V2301OUT	Ballydougan Command SR Outlet	4958338	20/08/2024 10:59	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4958338	20/08/2024 10:59	Odour	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4958338	20/08/2024 10:59	Odour - Nature		No odour	
V2301OUT	Ballydougan Command SR Outlet	4958338	20/08/2024 10:59	Taste	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4958338	20/08/2024 10:59	Taste - Nature		No taste	
V4537OUT	Sixmilecross SR Outlet	4958380	20/08/2024 11:03	Colony Counts 22	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4958380	20/08/2024 11:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4958380	20/08/2024 11:03	E. coli	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4958380	20/08/2024 11:03	Free - Residual disinfectant	mg Cl/l	0.28	
V4537OUT	Sixmilecross SR Outlet	4958380	20/08/2024 11:03	Total - Residual disinfectant	mg Cl/l	0.41	
V4537OUT	Sixmilecross SR Outlet	4958380	20/08/2024 11:03	Total Coliforms	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4958339	20/08/2024 11:16	Colony Counts 22	CFU/1 ml	0	

V2302OUT	Ballyhannon SR Outlet	4958339	20/08/2024 11:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4958339	20/08/2024 11:16	E. coli	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4958339	20/08/2024 11:16	Free - Residual disinfectant	mg Cl/l	0.34	
V2302OUT	Ballyhannon SR Outlet	4958339	20/08/2024 11:16	Total - Residual disinfectant	mg Cl/l	0.4	
V2302OUT	Ballyhannon SR Outlet	4958339	20/08/2024 11:16	Total Coliforms	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4958377	20/08/2024 11:16	Colony Counts 22	CFU/1 ml	1	
V4531OUT	Foremass SR Outlet	4958377	20/08/2024 11:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4958377	20/08/2024 11:16	E. coli	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4958377	20/08/2024 11:16	Free - Residual disinfectant	mg Cl/l	0.24	
V4531OUT	Foremass SR Outlet	4958377	20/08/2024 11:16	Total - Residual disinfectant	mg Cl/l	0.38	
V4531OUT	Foremass SR Outlet	4958377	20/08/2024 11:16	Total Coliforms	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4958352	20/08/2024 11:29	Colony Counts 22	CFU/1 ml	2	
V4540OUT	Radergan SR Outlet	4958352	20/08/2024 11:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4958352	20/08/2024 11:29	E. coli	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4958352	20/08/2024 11:29	Free - Residual disinfectant	mg Cl/l	0.34	
V4540OUT	Radergan SR Outlet	4958352	20/08/2024 11:29	Total - Residual disinfectant	mg Cl/l	0.47	
V4540OUT	Radergan SR Outlet	4958352	20/08/2024 11:29	Total Coliforms	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4958083	20/08/2024 11:49	Colony Counts 22	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4958083	20/08/2024 11:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4958083	20/08/2024 11:49	E. coli	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4958083	20/08/2024 11:49	Free - Residual disinfectant	mg Cl/l	0.4	
V4719OUT	Glenchuil SR Outlet	4958083	20/08/2024 11:49	Total - Residual disinfectant	mg Cl/l	0.48	
V4719OUT	Glenchuil SR Outlet	4958083	20/08/2024 11:49	Total Coliforms	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4958384	21/08/2024 00:00	Colony Counts 22	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4958384	21/08/2024 00:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4958384	21/08/2024 00:00	E. coli	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4958384	21/08/2024 00:00	Free - Residual disinfectant	mg Cl/l	0.39	
V4528OUT	Crocknabohil SR Outlet	4958384	21/08/2024 00:00	Total - Residual disinfectant	mg Cl/l	0.45	
V4528OUT	Crocknabohil SR Outlet	4958384	21/08/2024 00:00	Total Coliforms	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4958577	21/08/2024 07:55	Colony Counts 22	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4958577	21/08/2024 07:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4958577	21/08/2024 07:55	E. coli	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4958577	21/08/2024 07:55	Free - Residual disinfectant	mg Cl/l	0.13	
V1708OUT	North Garvagh SR Outlet	4958577	21/08/2024 07:55	Total - Residual disinfectant	mg Cl/l	0.14	
V1708OUT	North Garvagh SR Outlet	4958577	21/08/2024 07:55	Total Coliforms	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4955917	21/08/2024 08:00	Colony Counts 22	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4955917	21/08/2024 08:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4955917	21/08/2024 08:00	E. coli	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4955917	21/08/2024 08:00	Free - Residual disinfectant	mg Cl/l	0.09	
V4527OUT	Carryglass SR Outlet	4955917	21/08/2024 08:00	Total - Residual disinfectant	mg Cl/l	0.16	

V4527OUT	Carryglass SR Outlet	4955917	21/08/2024 08:00	Total Coliforms	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4958581	21/08/2024 08:09	Colony Counts 22	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4958581	21/08/2024 08:09	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V1351OUT	Cranny Moneymore SR Outlet	4958581	21/08/2024 08:09	E. coli	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4958581	21/08/2024 08:09	Free - Residual disinfectant	mg Cl/l	0.52	
V1351OUT	Cranny Moneymore SR Outlet	4958581	21/08/2024 08:09	Total - Residual disinfectant	mg Cl/l	0.7	
V1351OUT	Cranny Moneymore SR Outlet	4958581	21/08/2024 08:09	Total Coliforms	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4958580	21/08/2024 08:17	Colony Counts 22	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4958580	21/08/2024 08:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4958580	21/08/2024 08:17	E. coli	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4958580	21/08/2024 08:17	Free - Residual disinfectant	mg Cl/l	0.06	
V1713OUT	Trienaltenagh SR Outlet	4958580	21/08/2024 08:17	Total - Residual disinfectant	mg Cl/l	0.13	
V1713OUT	Trienaltenagh SR Outlet	4958580	21/08/2024 08:17	Total Coliforms	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4958569	21/08/2024 08:33	Colony Counts 22	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4958569	21/08/2024 08:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4958569	21/08/2024 08:33	E. coli	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4958569	21/08/2024 08:33	Free - Residual disinfectant	mg Cl/l	0.36	
V1352OUT	Cullion Desertmartin SR Outlet	4958569	21/08/2024 08:33	Total - Residual disinfectant	mg Cl/l	0.42	
V1352OUT	Cullion Desertmartin SR Outlet	4958569	21/08/2024 08:33	Total Coliforms	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4958592	21/08/2024 08:56	Colony Counts 22	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4958592	21/08/2024 08:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4958592	21/08/2024 08:56	E. coli	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4958592	21/08/2024 08:56	Free - Residual disinfectant	mg Cl/l	0.56	
V1343OUT	Ballybriest SR Outlet	4958592	21/08/2024 08:56	Total - Residual disinfectant	mg Cl/l	0.65	
V1343OUT	Ballybriest SR Outlet	4958592	21/08/2024 08:56	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4958537	21/08/2024 08:57	Colony Counts 22	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4958537	21/08/2024 08:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4958537	21/08/2024 08:57	E. coli	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4958537	21/08/2024 08:57	Free - Residual disinfectant	mg Cl/l	1.05	
V2508OUT	Carland SR Outlet	4958537	21/08/2024 08:57	Total - Residual disinfectant	mg Cl/l	1.18	
V2508OUT	Carland SR Outlet	4958537	21/08/2024 08:57	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4958537	21/08/2024 08:57	Odour	Diln No	0	0
V2508OUT	Carland SR Outlet	4958537	21/08/2024 08:57	Odour - Nature		No odour	
V2508OUT	Carland SR Outlet	4958537	21/08/2024 08:57	Taste	Diln No	0	0
V2508OUT	Carland SR Outlet	4958537	21/08/2024 08:57	Taste - Nature		No taste	
V2509OUT	Castlehill Drumcoo SR Outlet	4958538	21/08/2024 09:14	Colony Counts 22	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4958538	21/08/2024 09:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4958538	21/08/2024 09:14	E. coli	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4958538	21/08/2024 09:14	Free - Residual disinfectant	mg Cl/l	0.59	
V2509OUT	Castlehill Drumcoo SR Outlet	4958538	21/08/2024 09:14	Total - Residual disinfectant	mg Cl/l	0.74	

V2509OUT	Castlehill Drumcoo SR Outlet	4958538	21/08/2024 09:14	Total Coliforms	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4958551	21/08/2024 09:30	Colony Counts 22	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4958551	21/08/2024 09:30	Colony Counts 37 (48hrs)	CFU/1 ml	2	
V2521OUT	Mullaghanagh SR Outlet	4958551	21/08/2024 09:30	E. coli	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4958551	21/08/2024 09:30	Free - Residual disinfectant	mg Cl/l	1.01	
V2521OUT	Mullaghanagh SR Outlet	4958551	21/08/2024 09:30	Total - Residual disinfectant	mg Cl/l	1.09	
V2521OUT	Mullaghanagh SR Outlet	4958551	21/08/2024 09:30	Total Coliforms	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4958568	21/08/2024 09:58	Colony Counts 22	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4958568	21/08/2024 09:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4958568	21/08/2024 09:58	E. coli	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4958568	21/08/2024 09:58	Free - Residual disinfectant	mg Cl/l	0.63	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4958568	21/08/2024 09:58	Total - Residual disinfectant	mg Cl/l	0.77	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4958568	21/08/2024 09:58	Total Coliforms	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4958090	21/08/2024 10:04	Colony Counts 22	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4958090	21/08/2024 10:04	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V4708OUT	Cavanacross Enniskillen SR Outlet	4958090	21/08/2024 10:04	E. coli	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4958090	21/08/2024 10:04	Free - Residual disinfectant	mg Cl/l	0.97	
V4708OUT	Cavanacross Enniskillen SR Outlet	4958090	21/08/2024 10:04	Total - Residual disinfectant	mg Cl/l	1.04	
V4708OUT	Cavanacross Enniskillen SR Outlet	4958090	21/08/2024 10:04	Total Coliforms	CFU/100 ml	0	0
V1361OUT	Moneymore Tamnadoey SR Outlet	4967305	21/08/2024 10:22	Colony Counts 22	CFU/1 ml	0	
V1361OUT	Moneymore Tamnadoey SR Outlet	4967305	21/08/2024 10:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1361OUT	Moneymore Tamnadoey SR Outlet	4967305	21/08/2024 10:22	E. coli	CFU/100 ml	0	0
V1361OUT	Moneymore Tamnadoey SR Outlet	4967305	21/08/2024 10:22	Free - Residual disinfectant	mg Cl/l	0.25	
V1361OUT	Moneymore Tamnadoey SR Outlet	4967305	21/08/2024 10:22	Total - Residual disinfectant	mg Cl/l	0.44	
V1361OUT	Moneymore Tamnadoey SR Outlet	4967305	21/08/2024 10:22	Total Coliforms	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4958573	21/08/2024 10:35	Colony Counts 22	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4958573	21/08/2024 10:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4958573	21/08/2024 10:35	E. coli	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4958573	21/08/2024 10:35	Free - Residual disinfectant	mg Cl/l	<0.05	
V1706OUT	Killeague SR Outlet	4958573	21/08/2024 10:35	Total - Residual disinfectant	mg Cl/l	0.12	
V1706OUT	Killeague SR Outlet	4958573	21/08/2024 10:35	Total Coliforms	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4958575	21/08/2024 11:15	Colony Counts 22	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4958575	21/08/2024 11:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4958575	21/08/2024 11:15	E. coli	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4958575	21/08/2024 11:15	Free - Residual disinfectant	mg Cl/l	0.06	
V1702OUT	Cam SR Outlet	4958575	21/08/2024 11:15	Total - Residual disinfectant	mg Cl/l	0.19	
V1702OUT	Cam SR Outlet	4958575	21/08/2024 11:15	Total Coliforms	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4958055	21/08/2024 11:17	Colony Counts 22	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4958055	21/08/2024 11:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4958055	21/08/2024 11:17	E. coli	CFU/100 ml	0	0

V4707OUT	Sidaire SR Outlet	4958055	21/08/2024 11:17	Free - Residual disinfectant	mg Cl/l	0.72	
V4707OUT	Sidaire SR Outlet	4958055	21/08/2024 11:17	Total - Residual disinfectant	mg Cl/l	0.8	
V4707OUT	Sidaire SR Outlet	4958055	21/08/2024 11:17	Total Coliforms	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4958792	22/08/2024 09:00	Colony Counts 22	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4958792	22/08/2024 09:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4958792	22/08/2024 09:00	E. coli	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4958792	22/08/2024 09:00	Free - Residual disinfectant	mg Cl/l	0.25	
V1338OUT	Coagh SR Outlet	4958792	22/08/2024 09:00	Total - Residual disinfectant	mg Cl/l	0.34	
V1338OUT	Coagh SR Outlet	4958792	22/08/2024 09:00	Total Coliforms	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4958791	22/08/2024 09:19	Colony Counts 22	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4958791	22/08/2024 09:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4958791	22/08/2024 09:19	E. coli	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4958791	22/08/2024 09:19	Free - Residual disinfectant	mg Cl/l	0.41	
V1335OUT	Brigh Quarry SR Outlet	4958791	22/08/2024 09:19	Total - Residual disinfectant	mg Cl/l	0.47	
V1335OUT	Brigh Quarry SR Outlet	4958791	22/08/2024 09:19	Total Coliforms	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4958752	22/08/2024 09:27	Colony Counts 22	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4958752	22/08/2024 09:27	Colony Counts 37 (48hrs)	CFU/1 ml	3	
V2511OUT	Corran Armagh SR Outlet	4958752	22/08/2024 09:27	E. coli	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4958752	22/08/2024 09:27	Free - Residual disinfectant	mg Cl/l	0.75	
V2511OUT	Corran Armagh SR Outlet	4958752	22/08/2024 09:27	Total - Residual disinfectant	mg Cl/l	1.02	
V2511OUT	Corran Armagh SR Outlet	4958752	22/08/2024 09:27	Total Coliforms	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4958795	22/08/2024 09:37	Colony Counts 22	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4958795	22/08/2024 09:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4958795	22/08/2024 09:37	E. coli	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4958795	22/08/2024 09:37	Free - Residual disinfectant	mg Cl/l	0.38	
V1342OUT	Dromore High SR Outlet	4958795	22/08/2024 09:37	Total - Residual disinfectant	mg Cl/l	0.46	
V1342OUT	Dromore High SR Outlet	4958795	22/08/2024 09:37	Total Coliforms	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4958579	22/08/2024 09:41	Colony Counts 22	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4958579	22/08/2024 09:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4958579	22/08/2024 09:41	E. coli	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4958579	22/08/2024 09:41	Free - Residual disinfectant	mg Cl/l	0.52	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4958579	22/08/2024 09:41	Total - Residual disinfectant	mg Cl/l	0.61	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4958579	22/08/2024 09:41	Total Coliforms	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4958762	22/08/2024 10:04	Colony Counts 22	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4958762	22/08/2024 10:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4958762	22/08/2024 10:04	E. coli	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4958762	22/08/2024 10:04	Free - Residual disinfectant	mg Cl/l	0.7	
V2518OUT	Lisnastrane SR Outlet	4958762	22/08/2024 10:04	Total - Residual disinfectant	mg Cl/l	0.75	
V2518OUT	Lisnastrane SR Outlet	4958762	22/08/2024 10:04	Total Coliforms	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4958796	22/08/2024 10:05	Colony Counts 22	CFU/1 ml	0	

V4712OUT	Corranny SR Outlet	4958796	22/08/2024 10:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4958796	22/08/2024 10:05	E. coli	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4958796	22/08/2024 10:05	Free - Residual disinfectant	mg Cl/l	0.49	
V4712OUT	Corranny SR Outlet	4958796	22/08/2024 10:05	Total - Residual disinfectant	mg Cl/l	0.61	
V4712OUT	Corranny SR Outlet	4958796	22/08/2024 10:05	Total Coliforms	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4958751	22/08/2024 10:08	Colony Counts 22	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4958751	22/08/2024 10:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4958751	22/08/2024 10:08	E. coli	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4958751	22/08/2024 10:08	Free - Residual disinfectant	mg Cl/l	0.35	
V2510OUT	Calone SR Outlet	4958751	22/08/2024 10:08	Total - Residual disinfectant	mg Cl/l	0.36	
V2510OUT	Calone SR Outlet	4958751	22/08/2024 10:08	Total Coliforms	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4958788	22/08/2024 10:15	Colony Counts 22	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4958788	22/08/2024 10:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4958788	22/08/2024 10:15	E. coli	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4958788	22/08/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.39	
V4533OUT	Inisclan SR Outlet	4958788	22/08/2024 10:15	Total - Residual disinfectant	mg Cl/l	0.54	
V4533OUT	Inisclan SR Outlet	4958788	22/08/2024 10:15	Total Coliforms	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4958800	22/08/2024 10:18	Colony Counts 22	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4958800	22/08/2024 10:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4958800	22/08/2024 10:18	E. coli	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4958800	22/08/2024 10:18	Free - Residual disinfectant	mg Cl/l	0.74	
V4713OUT	Knocknalosset SR Outlet	4958800	22/08/2024 10:18	Total - Residual disinfectant	mg Cl/l	0.79	
V4713OUT	Knocknalosset SR Outlet	4958800	22/08/2024 10:18	Total Coliforms	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4958760	22/08/2024 10:24	Colony Counts 22	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4958760	22/08/2024 10:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4958760	22/08/2024 10:24	E. coli	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4958760	22/08/2024 10:24	Free - Residual disinfectant	mg Cl/l	0.6	
V2514OUT	Edenaveys Command SR Outlet	4958760	22/08/2024 10:24	Total - Residual disinfectant	mg Cl/l	0.84	
V2514OUT	Edenaveys Command SR Outlet	4958760	22/08/2024 10:24	Total Coliforms	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4958576	22/08/2024 10:36	Colony Counts 22	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4958576	22/08/2024 10:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4958576	22/08/2024 10:36	E. coli	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4958576	22/08/2024 10:36	Free - Residual disinfectant	mg Cl/l	0.89	
V4742OUT	Tattinbar SR Outlet	4958576	22/08/2024 10:36	Total - Residual disinfectant	mg Cl/l	1.01	
V4742OUT	Tattinbar SR Outlet	4958576	22/08/2024 10:36	Total Coliforms	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4958748	22/08/2024 10:46	Colony Counts 22	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4958748	22/08/2024 10:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4958748	22/08/2024 10:46	E. coli	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4958748	22/08/2024 10:46	Free - Residual disinfectant	mg Cl/l	0.91	
V2523OUT	Rough Fort SR Outlet	4958748	22/08/2024 10:46	Total - Residual disinfectant	mg Cl/l	1.19	

V2523OUT	Rough Fort SR Outlet	4958748	22/08/2024 10:46	Total Coliforms	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4958594	22/08/2024 11:03	Colony Counts 22	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4958594	22/08/2024 11:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4958594	22/08/2024 11:03	E. coli	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4958594	22/08/2024 11:03	Free - Residual disinfectant	mg Cl/l	0.91	
V4715OUT	Brookeborough High SR Outlet	4958594	22/08/2024 11:03	Total - Residual disinfectant	mg Cl/l	0.96	
V4715OUT	Brookeborough High SR Outlet	4958594	22/08/2024 11:03	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4958784	22/08/2024 11:27	Colony Counts 22	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4958784	22/08/2024 11:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4958784	22/08/2024 11:27	E. coli	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4958784	22/08/2024 11:27	Free - Residual disinfectant	mg Cl/l	<0.05	
V1704OUT	Castlerock Downhill SR Outlet	4958784	22/08/2024 11:27	Total - Residual disinfectant	mg Cl/l	0.13	
V1704OUT	Castlerock Downhill SR Outlet	4958784	22/08/2024 11:27	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4958784	22/08/2024 11:27	Odour	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4958784	22/08/2024 11:27	Odour - Nature		No odour	
V1704OUT	Castlerock Downhill SR Outlet	4958784	22/08/2024 11:27	Taste	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4958784	22/08/2024 11:27	Taste - Nature		No taste	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4958578	22/08/2024 11:34	Colony Counts 22	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4958578	22/08/2024 11:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4958578	22/08/2024 11:34	E. coli	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4958578	22/08/2024 11:34	Free - Residual disinfectant	mg Cl/l	0.52	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4958578	22/08/2024 11:34	Total - Residual disinfectant	mg Cl/l	0.6	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4958578	22/08/2024 11:34	Total Coliforms	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4958785	22/08/2024 11:55	Colony Counts 22	CFU/1 ml	>300	
V1711OUT	Sconce Hill SR Outlet	4958785	22/08/2024 11:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1711OUT	Sconce Hill SR Outlet	4958785	22/08/2024 11:55	E. coli	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4958785	22/08/2024 11:55	Free - Residual disinfectant	mg Cl/l	0.2	
V1711OUT	Sconce Hill SR Outlet	4958785	22/08/2024 11:55	Total - Residual disinfectant	mg Cl/l	1.7	
V1711OUT	Sconce Hill SR Outlet	4958785	22/08/2024 11:55	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4958956	23/08/2024 08:15	Colony Counts 22	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4958956	23/08/2024 08:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4958956	23/08/2024 08:15	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4958956	23/08/2024 08:15	Free - Residual disinfectant	mg Cl/l	0.58	
V1360OUT	Windmill Hill SR Outlet	4958956	23/08/2024 08:15	Total - Residual disinfectant	mg Cl/l	0.6	
V1360OUT	Windmill Hill SR Outlet	4958956	23/08/2024 08:15	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4958967	23/08/2024 08:35	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4958967	23/08/2024 08:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4958967	23/08/2024 08:35	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4958967	23/08/2024 08:35	Free - Residual disinfectant	mg Cl/l	0.9	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4958967	23/08/2024 08:35	Total - Residual disinfectant	mg Cl/l	1.05	

V1357OUT	Mullaghboy Magherafelt SR Outlet	4958967	23/08/2024 08:35	Total Coliforms	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4958971	23/08/2024 09:30	Colony Counts 22	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4958971	23/08/2024 09:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4958971	23/08/2024 09:30	E. coli	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4958971	23/08/2024 09:30	Free - Residual disinfectant	mg Cl/l	0.5	
V1344OUT	Craigs Cookstown SR Outlet	4958971	23/08/2024 09:30	Total - Residual disinfectant	mg Cl/l	0.55	
V1344OUT	Craigs Cookstown SR Outlet	4958971	23/08/2024 09:30	Total Coliforms	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4958958	23/08/2024 09:45	Colony Counts 22	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4958958	23/08/2024 09:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4958958	23/08/2024 09:45	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4958958	23/08/2024 09:45	Free - Residual disinfectant	mg Cl/l	0.34	
V1362OUT	Unagh SR Outlet	4958958	23/08/2024 09:45	Total - Residual disinfectant	mg Cl/l	0.4	
V1362OUT	Unagh SR Outlet	4958958	23/08/2024 09:45	Total Coliforms	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4958968	23/08/2024 10:05	Colony Counts 22	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4958968	23/08/2024 10:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4958968	23/08/2024 10:05	E. coli	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4958968	23/08/2024 10:05	Free - Residual disinfectant	mg Cl/l	0.7	
V1339OUT	Corvanaghan High SR Outlet	4958968	23/08/2024 10:05	Total - Residual disinfectant	mg Cl/l	0.77	
V1339OUT	Corvanaghan High SR Outlet	4958968	23/08/2024 10:05	Total Coliforms	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4958933	23/08/2024 10:12	Colony Counts 22	CFU/1 ml	14	
V4526OUT	Black Lough Pomeroy SR Outlet	4958933	23/08/2024 10:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4958933	23/08/2024 10:12	Free - Residual disinfectant	mg Cl/l	0.42	
V4526OUT	Black Lough Pomeroy SR Outlet	4958933	23/08/2024 10:12	Total - Residual disinfectant	mg Cl/l	0.55	
V1340OUT	Craigballyharkey SR Outlet	4958969	23/08/2024 10:20	Colony Counts 22	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4958969	23/08/2024 10:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4958969	23/08/2024 10:20	E. coli	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4958969	23/08/2024 10:20	Free - Residual disinfectant	mg Cl/l	0.65	
V1340OUT	Craigballyharkey SR Outlet	4958969	23/08/2024 10:20	Total - Residual disinfectant	mg Cl/l	0.7	
V1340OUT	Craigballyharkey SR Outlet	4958969	23/08/2024 10:20	Total Coliforms	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4958944	23/08/2024 10:37	Colony Counts 22	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4958944	23/08/2024 10:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4958944	23/08/2024 10:37	Free - Residual disinfectant	mg Cl/l	0.6	
V4536OUT	Lough Macrory North SR Outlet	4958944	23/08/2024 10:37	Total - Residual disinfectant	mg Cl/l	0.73	
V1346OUT	Gortaclady Evishanoran SR Outlet	4958972	23/08/2024 10:40	Colony Counts 22	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4958972	23/08/2024 10:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4958972	23/08/2024 10:40	E. coli	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4958972	23/08/2024 10:40	Free - Residual disinfectant	mg Cl/l	0.35	
V1346OUT	Gortaclady Evishanoran SR Outlet	4958972	23/08/2024 10:40	Total - Residual disinfectant	mg Cl/l	0.4	
V1346OUT	Gortaclady Evishanoran SR Outlet	4958972	23/08/2024 10:40	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4958963	23/08/2024 10:40	Colony Counts 22	CFU/1 ml	0	

V1350OUT	Carnaman SR Outlet	4958963	23/08/2024 10:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4958963	23/08/2024 10:40	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4958963	23/08/2024 10:40	Free - Residual disinfectant	mg Cl/l	0.16	
V1350OUT	Carnaman SR Outlet	4958963	23/08/2024 10:40	Total - Residual disinfectant	mg Cl/l	0.26	
V1350OUT	Carnaman SR Outlet	4958963	23/08/2024 10:40	Total Coliforms	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4958934	23/08/2024 11:28	Colony Counts 22	CFU/1 ml	19	
V4538OUT	Killyclogher SR Outlet	4958934	23/08/2024 11:28	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V4538OUT	Killyclogher SR Outlet	4958934	23/08/2024 11:28	Free - Residual disinfectant	mg Cl/l	0.42	
V4538OUT	Killyclogher SR Outlet	4958934	23/08/2024 11:28	Total - Residual disinfectant	mg Cl/l	0.55	
V4539OUT	Erganagh SR Outlet	4958937	23/08/2024 11:51	Colony Counts 22	CFU/1 ml	17	
V4539OUT	Erganagh SR Outlet	4958937	23/08/2024 11:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4958937	23/08/2024 11:51	Free - Residual disinfectant	mg Cl/l	0.38	
V4539OUT	Erganagh SR Outlet	4958937	23/08/2024 11:51	Total - Residual disinfectant	mg Cl/l	0.49	
V1360OUT	Windmill Hill SR Outlet	4961099	27/08/2024 07:36	Colony Counts 22	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4961099	27/08/2024 07:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4961099	27/08/2024 07:36	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4961099	27/08/2024 07:36	Free - Residual disinfectant	mg Cl/l	0.41	
V1360OUT	Windmill Hill SR Outlet	4961099	27/08/2024 07:36	Total - Residual disinfectant	mg Cl/l	0.62	
V1360OUT	Windmill Hill SR Outlet	4961099	27/08/2024 07:36	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4961110	27/08/2024 07:59	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4961110	27/08/2024 07:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4961110	27/08/2024 07:59	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4961110	27/08/2024 07:59	Free - Residual disinfectant	mg Cl/l	0.73	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4961110	27/08/2024 07:59	Total - Residual disinfectant	mg Cl/l	0.85	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4961110	27/08/2024 07:59	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4961110	27/08/2024 07:59	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4961110	27/08/2024 07:59	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4961110	27/08/2024 07:59	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4961110	27/08/2024 07:59	Taste - Nature		No taste	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4961225	27/08/2024 09:08	Colony Counts 22	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4961225	27/08/2024 09:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4961225	27/08/2024 09:08	E. coli	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4961225	27/08/2024 09:08	Free - Residual disinfectant	mg Cl/l	0.58	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4961225	27/08/2024 09:08	Total - Residual disinfectant	mg Cl/l	0.64	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4961225	27/08/2024 09:08	Total Coliforms	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4961197	27/08/2024 09:46	Colony Counts 22	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4961197	27/08/2024 09:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4961197	27/08/2024 09:46	E. coli	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4961197	27/08/2024 09:46	Free - Residual disinfectant	mg Cl/l	0.64	
V2501OUT	Altmore River SR Outlet	4961197	27/08/2024 09:46	Total - Residual disinfectant	mg Cl/l	0.74	

V2501OUT	Altmore River SR Outlet	4961197	27/08/2024 09:46	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4961178	27/08/2024 09:55	Colony Counts 22	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4961178	27/08/2024 09:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4961178	27/08/2024 09:55	E. coli	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4961178	27/08/2024 09:55	Free - Residual disinfectant	mg Cl/l	0.05	
V1725OUT	Glenlough SR Outlet	4961178	27/08/2024 09:55	Total - Residual disinfectant	mg Cl/l	0.17	
V1725OUT	Glenlough SR Outlet	4961178	27/08/2024 09:55	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4961178	27/08/2024 09:55	Odour	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4961178	27/08/2024 09:55	Odour - Nature		No odour	
V1725OUT	Glenlough SR Outlet	4961178	27/08/2024 09:55	Taste	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4961178	27/08/2024 09:55	Taste - Nature		No taste	
V2507OUT	Cappagh SR Outlet	4961170	27/08/2024 09:59	Colony Counts 22	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4961170	27/08/2024 09:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4961170	27/08/2024 09:59	E. coli	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4961170	27/08/2024 09:59	Free - Residual disinfectant	mg Cl/l	0.57	
V2507OUT	Cappagh SR Outlet	4961170	27/08/2024 09:59	Total - Residual disinfectant	mg Cl/l	0.66	
V2507OUT	Cappagh SR Outlet	4961170	27/08/2024 09:59	Total Coliforms	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4961229	27/08/2024 10:04	Colony Counts 22	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4961229	27/08/2024 10:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4961229	27/08/2024 10:04	E. coli	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4961229	27/08/2024 10:04	Free - Residual disinfectant	mg Cl/l	0.22	
V4530OUT	Dungoran SR Outlet	4961229	27/08/2024 10:04	Total - Residual disinfectant	mg Cl/l	0.35	
V4530OUT	Dungoran SR Outlet	4961229	27/08/2024 10:04	Total Coliforms	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4961221	27/08/2024 10:14	Colony Counts 22	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4961221	27/08/2024 10:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4961221	27/08/2024 10:14	E. coli	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4961221	27/08/2024 10:14	Free - Residual disinfectant	mg Cl/l	0.77	
V4535OUT	Lisnagardy SR Outlet	4961221	27/08/2024 10:14	Total - Residual disinfectant	mg Cl/l	0.39	
V4535OUT	Lisnagardy SR Outlet	4961221	27/08/2024 10:14	Total Coliforms	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4961169	27/08/2024 10:23	Colony Counts 22	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4961169	27/08/2024 10:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4961169	27/08/2024 10:23	E. coli	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4961169	27/08/2024 10:23	Free - Residual disinfectant	mg Cl/l	0.69	
V2505OUT	Cabragh Fasglashagh SR Outlet	4961169	27/08/2024 10:23	Total - Residual disinfectant	mg Cl/l	0.78	
V2505OUT	Cabragh Fasglashagh SR Outlet	4961169	27/08/2024 10:23	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4961106	27/08/2024 10:24	Colony Counts 22	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4961106	27/08/2024 10:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4961106	27/08/2024 10:24	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4961106	27/08/2024 10:24	Free - Residual disinfectant	mg Cl/l	0.17	
V1350OUT	Carnaman SR Outlet	4961106	27/08/2024 10:24	Total - Residual disinfectant	mg Cl/l	0.26	

V1350OUT	Carnaman SR Outlet	4961106	27/08/2024 10:24	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4961106	27/08/2024 10:24	Odour	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4961106	27/08/2024 10:24	Odour - Nature		No odour	
V1350OUT	Carnaman SR Outlet	4961106	27/08/2024 10:24	Taste	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4961106	27/08/2024 10:24	Taste - Nature		No taste	
V4527OUT	Carryglass SR Outlet	4961191	27/08/2024 10:30	Colony Counts 22	CFU/1 ml	65	
V4527OUT	Carryglass SR Outlet	4961191	27/08/2024 10:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4961191	27/08/2024 10:30	E. coli	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4961191	27/08/2024 10:30	Free - Residual disinfectant	mg Cl/l	0.19	
V4527OUT	Carryglass SR Outlet	4961191	27/08/2024 10:30	Total - Residual disinfectant	mg Cl/l	0.32	
V4527OUT	Carryglass SR Outlet	4961191	27/08/2024 10:30	Total Coliforms	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4961219	27/08/2024 10:36	Colony Counts 22	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4961219	27/08/2024 10:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4961219	27/08/2024 10:36	E. coli	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4961219	27/08/2024 10:36	Free - Residual disinfectant	mg Cl/l	0.53	
V4719OUT	Glenchuil SR Outlet	4961219	27/08/2024 10:36	Total - Residual disinfectant	mg Cl/l	0.61	
V4719OUT	Glenchuil SR Outlet	4961219	27/08/2024 10:36	Total Coliforms	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4961186	27/08/2024 11:15	Colony Counts 22	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4961186	27/08/2024 11:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4961186	27/08/2024 11:15	E. coli	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4961186	27/08/2024 11:15	Free - Residual disinfectant	mg Cl/l	0.79	
V4707OUT	Sidaire SR Outlet	4961186	27/08/2024 11:15	Total - Residual disinfectant	mg Cl/l	0.85	
V4707OUT	Sidaire SR Outlet	4961186	27/08/2024 11:15	Total Coliforms	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4961217	27/08/2024 12:20	Colony Counts 22	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4961217	27/08/2024 12:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4961217	27/08/2024 12:20	E. coli	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4961217	27/08/2024 12:20	Free - Residual disinfectant	mg Cl/l	0.05	
V1715OUT	Ballystrone (Calvins) SR Outlet	4961217	27/08/2024 12:20	Total - Residual disinfectant	mg Cl/l	0.12	
V1715OUT	Ballystrone (Calvins) SR Outlet	4961217	27/08/2024 12:20	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4961220	28/08/2024 07:20	Colony Counts 22	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4961220	28/08/2024 07:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4961220	28/08/2024 07:20	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4961220	28/08/2024 07:20	Free - Residual disinfectant	mg Cl/l	0.44	
V1354OUT	Knockoneill SR Outlet	4961220	28/08/2024 07:20	Total - Residual disinfectant	mg Cl/l	0.58	
V1354OUT	Knockoneill SR Outlet	4961220	28/08/2024 07:20	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4961220	28/08/2024 07:20	Odour	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4961220	28/08/2024 07:20	Odour - Nature		No odour	
V1354OUT	Knockoneill SR Outlet	4961220	28/08/2024 07:20	Taste	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4961220	28/08/2024 07:20	Taste - Nature		No taste	
V1358OUT	Slaughtneil SR Outlet	4961222	28/08/2024 07:39	Colony Counts 22	CFU/1 ml	0	

V1358OUT	Slaughtneil SR Outlet	4961222	28/08/2024 07:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4961222	28/08/2024 07:39	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4961222	28/08/2024 07:39	Free - Residual disinfectant	mg Cl/l	0.68	
V1358OUT	Slaughtneil SR Outlet	4961222	28/08/2024 07:39	Total - Residual disinfectant	mg Cl/l	0.82	
V1358OUT	Slaughtneil SR Outlet	4961222	28/08/2024 07:39	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4961214	28/08/2024 07:57	Colony Counts 22	CFU/1 ml	63	
V1349OUT	Ballyknock Magherafelt SR Outlet	4961214	28/08/2024 07:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4961214	28/08/2024 07:57	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4961214	28/08/2024 07:57	Free - Residual disinfectant	mg Cl/l	0.31	
V1349OUT	Ballyknock Magherafelt SR Outlet	4961214	28/08/2024 07:57	Total - Residual disinfectant	mg Cl/l	0.46	
V1349OUT	Ballyknock Magherafelt SR Outlet	4961214	28/08/2024 07:57	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4961505	28/08/2024 08:28	Colony Counts 22	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4961505	28/08/2024 08:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4961505	28/08/2024 08:28	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4961505	28/08/2024 08:28	Free - Residual disinfectant	mg Cl/l	0.21	
V1348OUT	Moydamlaght Draperstown SR Outlet	4961505	28/08/2024 08:28	Total - Residual disinfectant	mg Cl/l	0.39	
V1348OUT	Moydamlaght Draperstown SR Outlet	4961505	28/08/2024 08:28	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4961510	28/08/2024 08:53	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4961510	28/08/2024 08:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4961510	28/08/2024 08:53	E. coli	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4961510	28/08/2024 08:53	Free - Residual disinfectant	mg Cl/l	0.34	
V1356OUT	Mormeal SR Outlet	4961510	28/08/2024 08:53	Total - Residual disinfectant	mg Cl/l	0.6	
V1356OUT	Mormeal SR Outlet	4961510	28/08/2024 08:53	Total Coliforms	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4961226	28/08/2024 09:20	Colony Counts 22	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4961226	28/08/2024 09:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4961226	28/08/2024 09:20	E. coli	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4961226	28/08/2024 09:20	Free - Residual disinfectant	mg Cl/l	0.94	
V4708OUT	Cavanacross Enniskillen SR Outlet	4961226	28/08/2024 09:20	Total - Residual disinfectant	mg Cl/l	1.03	
V4708OUT	Cavanacross Enniskillen SR Outlet	4961226	28/08/2024 09:20	Total Coliforms	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4961492	28/08/2024 09:21	Colony Counts 22	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4961492	28/08/2024 09:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4961492	28/08/2024 09:21	E. coli	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4961492	28/08/2024 09:21	Free - Residual disinfectant	mg Cl/l	0.72	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4961492	28/08/2024 09:21	Total - Residual disinfectant	mg Cl/l	0.81	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4961492	28/08/2024 09:21	Total Coliforms	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4961483	28/08/2024 10:00	Colony Counts 22	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4961483	28/08/2024 10:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4961483	28/08/2024 10:00	E. coli	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4961483	28/08/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.29	
V4540OUT	Radergan SR Outlet	4961483	28/08/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.4	

V4540OUT	Radergan SR Outlet	4961483	28/08/2024 10:00	Total Coliforms	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4961508	28/08/2024 10:15	Colony Counts 22	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4961508	28/08/2024 10:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4961508	28/08/2024 10:15	E. coli	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4961508	28/08/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.35	
V4531OUT	Foremass SR Outlet	4961508	28/08/2024 10:15	Total - Residual disinfectant	mg Cl/l	0.5	
V4531OUT	Foremass SR Outlet	4961508	28/08/2024 10:15	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4961463	28/08/2024 10:31	Colony Counts 22	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4961463	28/08/2024 10:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4961463	28/08/2024 10:31	E. coli	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4961463	28/08/2024 10:31	Free - Residual disinfectant	mg Cl/l	0.76	
V2301OUT	Ballydougan Command SR Outlet	4961463	28/08/2024 10:31	Total - Residual disinfectant	mg Cl/l	0.88	
V2301OUT	Ballydougan Command SR Outlet	4961463	28/08/2024 10:31	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4961463	28/08/2024 10:31	Odour	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4961463	28/08/2024 10:31	Odour - Nature		No odour	
V2301OUT	Ballydougan Command SR Outlet	4961463	28/08/2024 10:31	Taste	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4961463	28/08/2024 10:31	Taste - Nature		No taste	
V4537OUT	Sixmilecross SR Outlet	4961511	28/08/2024 10:32	Colony Counts 22	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4961511	28/08/2024 10:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4961511	28/08/2024 10:32	E. coli	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4961511	28/08/2024 10:32	Free - Residual disinfectant	mg Cl/l	0.38	
V4537OUT	Sixmilecross SR Outlet	4961511	28/08/2024 10:32	Total - Residual disinfectant	mg Cl/l	0.49	
V4537OUT	Sixmilecross SR Outlet	4961511	28/08/2024 10:32	Total Coliforms	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4961464	28/08/2024 10:49	Colony Counts 22	CFU/1 ml	59	
V2302OUT	Ballyhannon SR Outlet	4961464	28/08/2024 10:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4961464	28/08/2024 10:49	E. coli	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4961464	28/08/2024 10:49	Free - Residual disinfectant	mg Cl/l	0.54	
V2302OUT	Ballyhannon SR Outlet	4961464	28/08/2024 10:49	Total - Residual disinfectant	mg Cl/l	0.65	
V2302OUT	Ballyhannon SR Outlet	4961464	28/08/2024 10:49	Total Coliforms	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4961515	28/08/2024 10:55	Colony Counts 22	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4961515	28/08/2024 10:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4961515	28/08/2024 10:55	E. coli	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4961515	28/08/2024 10:55	Free - Residual disinfectant	mg Cl/l	0.23	
V4528OUT	Crocknabohil SR Outlet	4961515	28/08/2024 10:55	Total - Residual disinfectant	mg Cl/l	0.31	
V4528OUT	Crocknabohil SR Outlet	4961515	28/08/2024 10:55	Total Coliforms	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4961717	29/08/2024 07:50	Colony Counts 22	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4961717	29/08/2024 07:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4961717	29/08/2024 07:50	E. coli	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4961717	29/08/2024 07:50	Free - Residual disinfectant	mg Cl/l	0.59	
V1351OUT	Cranny Moneymore SR Outlet	4961717	29/08/2024 07:50	Total - Residual disinfectant	mg Cl/l	0.69	

V1351OUT	Cranny Moneymore SR Outlet	4961717	29/08/2024 07:50	Total Coliforms	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4961705	29/08/2024 08:13	Colony Counts 22	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4961705	29/08/2024 08:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4961705	29/08/2024 08:13	E. coli	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4961705	29/08/2024 08:13	Free - Residual disinfectant	mg Cl/l	0.51	
V1352OUT	Cullion Desertmartin SR Outlet	4961705	29/08/2024 08:13	Total - Residual disinfectant	mg Cl/l	0.54	
V1352OUT	Cullion Desertmartin SR Outlet	4961705	29/08/2024 08:13	Total Coliforms	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4961101	29/08/2024 08:21	Colony Counts 22	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4961101	29/08/2024 08:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4961101	29/08/2024 08:21	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4961101	29/08/2024 08:21	Free - Residual disinfectant	mg Cl/l	0.48	
V1362OUT	Unagh SR Outlet	4961101	29/08/2024 08:21	Total - Residual disinfectant	mg Cl/l	0.57	
V1362OUT	Unagh SR Outlet	4961101	29/08/2024 08:21	Total Coliforms	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4961728	29/08/2024 08:34	Colony Counts 22	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4961728	29/08/2024 08:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4961728	29/08/2024 08:34	E. coli	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4961728	29/08/2024 08:34	Free - Residual disinfectant	mg Cl/l	0.71	
V1343OUT	Ballybriest SR Outlet	4961728	29/08/2024 08:34	Total - Residual disinfectant	mg Cl/l	0.79	
V1343OUT	Ballybriest SR Outlet	4961728	29/08/2024 08:34	Total Coliforms	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4961114	29/08/2024 08:39	Colony Counts 22	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4961114	29/08/2024 08:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4961114	29/08/2024 08:39	E. coli	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4961114	29/08/2024 08:39	Free - Residual disinfectant	mg Cl/l	0.51	
V1344OUT	Craigs Cookstown SR Outlet	4961114	29/08/2024 08:39	Total - Residual disinfectant	mg Cl/l	0.61	
V1344OUT	Craigs Cookstown SR Outlet	4961114	29/08/2024 08:39	Total Coliforms	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4961714	29/08/2024 08:45	Colony Counts 22	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4961714	29/08/2024 08:45	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4961714	29/08/2024 08:45	E. coli	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4961714	29/08/2024 08:45	Free - Residual disinfectant	mg Cl/l	0.83	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4961714	29/08/2024 08:45	Total - Residual disinfectant	mg Cl/l	0.92	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4961714	29/08/2024 08:45	Total Coliforms	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4961111	29/08/2024 09:01	Colony Counts 22	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4961111	29/08/2024 09:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4961111	29/08/2024 09:01	E. coli	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4961111	29/08/2024 09:01	Free - Residual disinfectant	mg Cl/l	0.53	
V1339OUT	Corvanaghan High SR Outlet	4961111	29/08/2024 09:01	Total - Residual disinfectant	mg Cl/l	0.62	
V1339OUT	Corvanaghan High SR Outlet	4961111	29/08/2024 09:01	Total Coliforms	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4961115	29/08/2024 09:22	Colony Counts 22	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4961115	29/08/2024 09:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4961115	29/08/2024 09:22	E. coli	CFU/100 ml	0	0

V1346OUT	Gortaclady Evishanoran SR Outlet	4961115	29/08/2024 09:22	Free - Residual disinfectant	mg Cl/l	0.46	
V1346OUT	Gortaclady Evishanoran SR Outlet	4961115	29/08/2024 09:22	Total - Residual disinfectant	mg Cl/l	0.55	
V1346OUT	Gortaclady Evishanoran SR Outlet	4961115	29/08/2024 09:22	Total Coliforms	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4961112	29/08/2024 09:36	Colony Counts 22	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4961112	29/08/2024 09:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4961112	29/08/2024 09:36	E. coli	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4961112	29/08/2024 09:36	Free - Residual disinfectant	mg Cl/l	0.51	
V1340OUT	Craigballyharkey SR Outlet	4961112	29/08/2024 09:36	Total - Residual disinfectant	mg Cl/l	0.59	
V1340OUT	Craigballyharkey SR Outlet	4961112	29/08/2024 09:36	Total Coliforms	CFU/100 ml	0	0
V1361OUT	Moneymore Tamnadoey SR Outlet	4967310	29/08/2024 10:07	Colony Counts 22	CFU/1 ml	0	
V1361OUT	Moneymore Tamnadoey SR Outlet	4967310	29/08/2024 10:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1361OUT	Moneymore Tamnadoey SR Outlet	4967310	29/08/2024 10:07	E. coli	CFU/100 ml	0	0
V1361OUT	Moneymore Tamnadoey SR Outlet	4967310	29/08/2024 10:07	Free - Residual disinfectant	mg Cl/l	0.15	
V1361OUT	Moneymore Tamnadoey SR Outlet	4967310	29/08/2024 10:07	Total - Residual disinfectant	mg Cl/l	0.37	
V1361OUT	Moneymore Tamnadoey SR Outlet	4967310	29/08/2024 10:07	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4961679	29/08/2024 10:11	Colony Counts 22	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4961679	29/08/2024 10:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4961679	29/08/2024 10:11	E. coli	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4961679	29/08/2024 10:11	Free - Residual disinfectant	mg Cl/l	0.98	
V2508OUT	Carland SR Outlet	4961679	29/08/2024 10:11	Total - Residual disinfectant	mg Cl/l	1.11	
V2508OUT	Carland SR Outlet	4961679	29/08/2024 10:11	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4961679	29/08/2024 10:11	Odour	Diln No	0	0
V2508OUT	Carland SR Outlet	4961679	29/08/2024 10:11	Odour - Nature		No odour	
V2508OUT	Carland SR Outlet	4961679	29/08/2024 10:11	Taste	Diln No	0	0
V2508OUT	Carland SR Outlet	4961679	29/08/2024 10:11	Taste - Nature		No taste	
V1713OUT	Trienaltenagh SR Outlet	4961716	29/08/2024 10:23	Colony Counts 22	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4961716	29/08/2024 10:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4961716	29/08/2024 10:23	E. coli	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4961716	29/08/2024 10:23	Free - Residual disinfectant	mg Cl/l	0.31	
V1713OUT	Trienaltenagh SR Outlet	4961716	29/08/2024 10:23	Total - Residual disinfectant	mg Cl/l	0.32	
V1713OUT	Trienaltenagh SR Outlet	4961716	29/08/2024 10:23	Total Coliforms	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4961680	29/08/2024 10:33	Colony Counts 22	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4961680	29/08/2024 10:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4961680	29/08/2024 10:33	E. coli	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4961680	29/08/2024 10:33	Free - Residual disinfectant	mg Cl/l	0.61	
V2509OUT	Castlehill Drumcoo SR Outlet	4961680	29/08/2024 10:33	Total - Residual disinfectant	mg Cl/l	0.72	
V2509OUT	Castlehill Drumcoo SR Outlet	4961680	29/08/2024 10:33	Total Coliforms	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4961730	29/08/2024 10:36	Colony Counts 22	CFU/1 ml	1	
V4715OUT	Brookeborough High SR Outlet	4961730	29/08/2024 10:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4961730	29/08/2024 10:36	E. coli	CFU/100 ml	0	0

V4715OUT	Brookeborough High SR Outlet	4961730	29/08/2024 10:36	Free - Residual disinfectant	mg Cl/l	1.02	
V4715OUT	Brookeborough High SR Outlet	4961730	29/08/2024 10:36	Total - Residual disinfectant	mg Cl/l	1.15	
V4715OUT	Brookeborough High SR Outlet	4961730	29/08/2024 10:36	Total Coliforms	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4961691	29/08/2024 10:52	Colony Counts 22	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4961691	29/08/2024 10:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4961691	29/08/2024 10:52	E. coli	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4961691	29/08/2024 10:52	Free - Residual disinfectant	mg Cl/l	0.74	
V2521OUT	Mullaghanagh SR Outlet	4961691	29/08/2024 10:52	Total - Residual disinfectant	mg Cl/l	0.85	
V2521OUT	Mullaghanagh SR Outlet	4961691	29/08/2024 10:52	Total Coliforms	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4961713	29/08/2024 11:18	Colony Counts 22	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4961713	29/08/2024 11:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4961713	29/08/2024 11:18	E. coli	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4961713	29/08/2024 11:18	Free - Residual disinfectant	mg Cl/l	0.29	
V1708OUT	North Garvagh SR Outlet	4961713	29/08/2024 11:18	Total - Residual disinfectant	mg Cl/l	0.38	
V1708OUT	North Garvagh SR Outlet	4961713	29/08/2024 11:18	Total Coliforms	CFU/100 ml	0	0
V2522OUT	Rehaghy Aghnacloy SR Outlet	4961704	29/08/2024 11:19	Colony Counts 22	CFU/1 ml	0	
V2522OUT	Rehaghy Aghnacloy SR Outlet	4961704	29/08/2024 11:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2522OUT	Rehaghy Aghnacloy SR Outlet	4961704	29/08/2024 11:19	E. coli	CFU/100 ml	0	0
V2522OUT	Rehaghy Aghnacloy SR Outlet	4961704	29/08/2024 11:19	Free - Residual disinfectant	mg Cl/l	0.67	
V2522OUT	Rehaghy Aghnacloy SR Outlet	4961704	29/08/2024 11:19	Total - Residual disinfectant	mg Cl/l	0.77	
V2522OUT	Rehaghy Aghnacloy SR Outlet	4961704	29/08/2024 11:19	Total Coliforms	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4961709	29/08/2024 11:42	Colony Counts 22	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4961709	29/08/2024 11:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4961709	29/08/2024 11:42	E. coli	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4961709	29/08/2024 11:42	Free - Residual disinfectant	mg Cl/l	0.51	
V1706OUT	Killeague SR Outlet	4961709	29/08/2024 11:42	Total - Residual disinfectant	mg Cl/l	0.67	
V1706OUT	Killeague SR Outlet	4961709	29/08/2024 11:42	Total Coliforms	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4961711	29/08/2024 12:08	Colony Counts 22	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4961711	29/08/2024 12:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4961711	29/08/2024 12:08	E. coli	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4961711	29/08/2024 12:08	Free - Residual disinfectant	mg Cl/l	0.55	
V1702OUT	Cam SR Outlet	4961711	29/08/2024 12:08	Total - Residual disinfectant	mg Cl/l	0.8	
V1702OUT	Cam SR Outlet	4961711	29/08/2024 12:08	Total Coliforms	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4975327	29/08/2024 12:30	Cryptosporidium Oocysts	Oocyst/10l	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4975327	29/08/2024 12:30	Oocysts per volume filtered	Oocyst	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4975327	29/08/2024 12:30	Pellet Size	ml	<0.5	
V4708OUT	Cavanacross Enniskillen SR Outlet	4975327	29/08/2024 12:30	Sample Volume	l	10	
V4742OUT	Tattinbar SR Outlet	4975325	29/08/2024 13:10	Cryptosporidium Oocysts	Oocyst/10l	0	
V4742OUT	Tattinbar SR Outlet	4975325	29/08/2024 13:10	Oocysts per volume filtered	Oocyst	0	
V4742OUT	Tattinbar SR Outlet	4975325	29/08/2024 13:10	Pellet Size	ml	<0.5	

V4742OUT	Tattinbar SR Outlet	4975325	29/08/2024 13:10	Sample Volume	l	10	
V2523OUT	Rough Fort SR Outlet	4961850	30/08/2024 07:15	Colony Counts 22	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4961850	30/08/2024 07:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4961850	30/08/2024 07:15	E. coli	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4961850	30/08/2024 07:15	Free - Residual disinfectant	mg Cl/l	0.97	
V2523OUT	Rough Fort SR Outlet	4961850	30/08/2024 07:15	Total - Residual disinfectant	mg Cl/l	1.02	
V2523OUT	Rough Fort SR Outlet	4961850	30/08/2024 07:15	Total Coliforms	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4961858	30/08/2024 07:35	Colony Counts 22	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4961858	30/08/2024 07:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4961858	30/08/2024 07:35	E. coli	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4961858	30/08/2024 07:35	Free - Residual disinfectant	mg Cl/l	0.75	
V2514OUT	Edenaveys Command SR Outlet	4961858	30/08/2024 07:35	Total - Residual disinfectant	mg Cl/l	0.85	
V2514OUT	Edenaveys Command SR Outlet	4961858	30/08/2024 07:35	Total Coliforms	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4961853	30/08/2024 07:48	Colony Counts 22	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4961853	30/08/2024 07:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4961853	30/08/2024 07:48	E. coli	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4961853	30/08/2024 07:48	Free - Residual disinfectant	mg Cl/l	0.55	
V2510OUT	Calone SR Outlet	4961853	30/08/2024 07:48	Total - Residual disinfectant	mg Cl/l	0.66	
V2510OUT	Calone SR Outlet	4961853	30/08/2024 07:48	Total Coliforms	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4961854	30/08/2024 08:06	Colony Counts 22	CFU/1 ml	7	
V2511OUT	Corran Armagh SR Outlet	4961854	30/08/2024 08:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4961854	30/08/2024 08:06	E. coli	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4961854	30/08/2024 08:06	Free - Residual disinfectant	mg Cl/l	0.77	
V2511OUT	Corran Armagh SR Outlet	4961854	30/08/2024 08:06	Total - Residual disinfectant	mg Cl/l	0.84	
V2511OUT	Corran Armagh SR Outlet	4961854	30/08/2024 08:06	Total Coliforms	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4961712	30/08/2024 08:45	Colony Counts 22	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4961712	30/08/2024 08:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4961712	30/08/2024 08:45	E. coli	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4961712	30/08/2024 08:45	Free - Residual disinfectant	mg Cl/l	0.58	
V4742OUT	Tattinbar SR Outlet	4961712	30/08/2024 08:45	Total - Residual disinfectant	mg Cl/l	0.69	
V4742OUT	Tattinbar SR Outlet	4961712	30/08/2024 08:45	Total Coliforms	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4975546	30/08/2024 08:45	Cryptosporidium Oocysts	Oocyst/10l	0	
V4742OUT	Tattinbar SR Outlet	4975546	30/08/2024 08:45	Oocysts per volume filtered	Oocyst	0	
V4742OUT	Tattinbar SR Outlet	4975546	30/08/2024 08:45	Pellet Size	ml	<0.5	
V4742OUT	Tattinbar SR Outlet	4975546	30/08/2024 08:45	Sample Volume	l	10	
V1338OUT	Coagh SR Outlet	4961893	30/08/2024 08:47	Colony Counts 22	CFU/1 ml	1	
V1338OUT	Coagh SR Outlet	4961893	30/08/2024 08:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4961893	30/08/2024 08:47	E. coli	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4961893	30/08/2024 08:47	Free - Residual disinfectant	mg Cl/l	0.46	
V1338OUT	Coagh SR Outlet	4961893	30/08/2024 08:47	Total - Residual disinfectant	mg Cl/l	0.54	

V1338OUT	Coagh SR Outlet	4961893	30/08/2024 08:47	Total Coliforms	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4961901	30/08/2024 08:58	Colony Counts 22	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4961901	30/08/2024 08:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4961901	30/08/2024 08:58	E. coli	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4961901	30/08/2024 08:58	Free - Residual disinfectant	mg Cl/l	0.95	
V4713OUT	Knocknalosset SR Outlet	4961901	30/08/2024 08:58	Total - Residual disinfectant	mg Cl/l	1.09	
V4713OUT	Knocknalosset SR Outlet	4961901	30/08/2024 08:58	Total Coliforms	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4961896	30/08/2024 09:11	Colony Counts 22	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4961896	30/08/2024 09:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4961896	30/08/2024 09:11	E. coli	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4961896	30/08/2024 09:11	Free - Residual disinfectant	mg Cl/l	0.52	
V1342OUT	Dromore High SR Outlet	4961896	30/08/2024 09:11	Total - Residual disinfectant	mg Cl/l	0.61	
V1342OUT	Dromore High SR Outlet	4961896	30/08/2024 09:11	Total Coliforms	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4961897	30/08/2024 09:15	Colony Counts 22	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4961897	30/08/2024 09:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4961897	30/08/2024 09:15	E. coli	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4961897	30/08/2024 09:15	Free - Residual disinfectant	mg Cl/l	0.65	
V4712OUT	Corranny SR Outlet	4961897	30/08/2024 09:15	Total - Residual disinfectant	mg Cl/l	0.81	
V4712OUT	Corranny SR Outlet	4961897	30/08/2024 09:15	Total Coliforms	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4961892	30/08/2024 09:31	Colony Counts 22	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4961892	30/08/2024 09:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4961892	30/08/2024 09:31	E. coli	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4961892	30/08/2024 09:31	Free - Residual disinfectant	mg Cl/l	0.58	
V1335OUT	Brigh Quarry SR Outlet	4961892	30/08/2024 09:31	Total - Residual disinfectant	mg Cl/l	0.67	
V1335OUT	Brigh Quarry SR Outlet	4961892	30/08/2024 09:31	Total Coliforms	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4961715	30/08/2024 09:44	Colony Counts 22	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4961715	30/08/2024 09:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4961715	30/08/2024 09:44	E. coli	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4961715	30/08/2024 09:44	Free - Residual disinfectant	mg Cl/l	0.71	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4961715	30/08/2024 09:44	Total - Residual disinfectant	mg Cl/l	1.01	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4961715	30/08/2024 09:44	Total Coliforms	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4961859	30/08/2024 10:06	Colony Counts 22	CFU/1 ml	4	
V2518OUT	Lisnastrane SR Outlet	4961859	30/08/2024 10:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4961859	30/08/2024 10:06	E. coli	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4961859	30/08/2024 10:06	Free - Residual disinfectant	mg Cl/l	0.49	
V2518OUT	Lisnastrane SR Outlet	4961859	30/08/2024 10:06	Total - Residual disinfectant	mg Cl/l	0.61	
V2518OUT	Lisnastrane SR Outlet	4961859	30/08/2024 10:06	Total Coliforms	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4975549	30/08/2024 10:40	Cryptosporidium Oocysts	Oocyst/10l	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4975549	30/08/2024 10:40	Oocysts per volume filtered	Oocyst	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4975549	30/08/2024 10:40	Pellet Size	ml	<0.5	

V4708OUT	Cavanacross Enniskillen SR Outlet	4975549	30/08/2024 10:40	Sample Volume	l	10	
V4533OUT	Inisclan SR Outlet	4961889	30/08/2024 10:52	Colony Counts 22	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4961889	30/08/2024 10:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4961889	30/08/2024 10:52	E. coli	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4961889	30/08/2024 10:52	Free - Residual disinfectant	mg Cl/l	0.53	
V4533OUT	Inisclan SR Outlet	4961889	30/08/2024 10:52	Total - Residual disinfectant	mg Cl/l	0.66	
V4533OUT	Inisclan SR Outlet	4961889	30/08/2024 10:52	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4961885	30/08/2024 11:14	Colony Counts 22	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4961885	30/08/2024 11:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4961885	30/08/2024 11:14	E. coli	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4961885	30/08/2024 11:14	Free - Residual disinfectant	mg Cl/l	<0.05	
V1704OUT	Castlerock Downhill SR Outlet	4961885	30/08/2024 11:14	Total - Residual disinfectant	mg Cl/l	0.35	
V1704OUT	Castlerock Downhill SR Outlet	4961885	30/08/2024 11:14	Total Coliforms	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4961886	30/08/2024 11:52	Colony Counts 22	CFU/1 ml	26	
V1711OUT	Sconce Hill SR Outlet	4961886	30/08/2024 11:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1711OUT	Sconce Hill SR Outlet	4961886	30/08/2024 11:52	E. coli	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4961886	30/08/2024 11:52	Free - Residual disinfectant	mg Cl/l	<0.05	
V1711OUT	Sconce Hill SR Outlet	4961886	30/08/2024 11:52	Total - Residual disinfectant	mg Cl/l	0.22	
V1711OUT	Sconce Hill SR Outlet	4961886	30/08/2024 11:52	Total Coliforms	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4975766	31/08/2024 08:14	Cryptosporidium Oocysts	Oocyst/10l	0	
V4742OUT	Tattinbar SR Outlet	4975766	31/08/2024 08:14	Oocysts per volume filtered	Oocyst	0	
V4742OUT	Tattinbar SR Outlet	4975766	31/08/2024 08:14	Pellet Size	ml	<0.5	
V4742OUT	Tattinbar SR Outlet	4975766	31/08/2024 08:14	Sample Volume	l	10	
V4708OUT	Cavanacross Enniskillen SR Outlet	4975767	31/08/2024 08:45	Cryptosporidium Oocysts	Oocyst/10l	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4975767	31/08/2024 08:45	Oocysts per volume filtered	Oocyst	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4975767	31/08/2024 08:45	Pellet Size	ml	<0.5	
V4708OUT	Cavanacross Enniskillen SR Outlet	4975767	31/08/2024 08:45	Sample Volume	l	10	
V4742OUT	Tattinbar SR Outlet	4975835	01/09/2024 08:06	Cryptosporidium Oocysts	Oocyst/10l	0	
V4742OUT	Tattinbar SR Outlet	4975835	01/09/2024 08:06	Oocysts per volume filtered	Oocyst	0	
V4742OUT	Tattinbar SR Outlet	4975835	01/09/2024 08:06	Pellet Size	ml	<0.5	
V4742OUT	Tattinbar SR Outlet	4975835	01/09/2024 08:06	Sample Volume	l	10	
V4708OUT	Cavanacross Enniskillen SR Outlet	4975836	01/09/2024 08:41	Cryptosporidium Oocysts	Oocyst/10l	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4975836	01/09/2024 08:41	Oocysts per volume filtered	Oocyst	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4975836	01/09/2024 08:41	Pellet Size	ml	<0.5	
V4708OUT	Cavanacross Enniskillen SR Outlet	4975836	01/09/2024 08:41	Sample Volume	l	10	
V1338OUT	Coagh SR Outlet	4964092	02/09/2024 08:46	Colony Counts 22	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4964092	02/09/2024 08:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4964092	02/09/2024 08:46	E. coli	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4964092	02/09/2024 08:46	Free - Residual disinfectant	mg Cl/l	0.47	
V1338OUT	Coagh SR Outlet	4964092	02/09/2024 08:46	Total - Residual disinfectant	mg Cl/l	0.56	

V1338OUT	Coagh SR Outlet	4964092	02/09/2024 08:46	Total Coliforms	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4964100	02/09/2024 08:47	Colony Counts 22	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4964100	02/09/2024 08:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4964100	02/09/2024 08:47	E. coli	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4964100	02/09/2024 08:47	Free - Residual disinfectant	mg Cl/l	0.8	
V4713OUT	Knocknalosset SR Outlet	4964100	02/09/2024 08:47	Total - Residual disinfectant	mg Cl/l	0.91	
V4713OUT	Knocknalosset SR Outlet	4964100	02/09/2024 08:47	Total Coliforms	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4976065	02/09/2024 08:55	Cryptosporidium Oocysts	Oocyst/10l	0	
V4742OUT	Tattinbar SR Outlet	4976065	02/09/2024 08:55	Oocysts per volume filtered	Oocyst	0	
V4742OUT	Tattinbar SR Outlet	4976065	02/09/2024 08:55	Pellet Size	ml	<0.5	
V4742OUT	Tattinbar SR Outlet	4976065	02/09/2024 08:55	Sample Volume	l	10	
V1342OUT	Dromore High SR Outlet	4964095	02/09/2024 09:05	Colony Counts 22	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4964095	02/09/2024 09:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4964095	02/09/2024 09:05	E. coli	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4964095	02/09/2024 09:05	Free - Residual disinfectant	mg Cl/l	0.58	
V1342OUT	Dromore High SR Outlet	4964095	02/09/2024 09:05	Total - Residual disinfectant	mg Cl/l	0.69	
V1342OUT	Dromore High SR Outlet	4964095	02/09/2024 09:05	Total Coliforms	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4964096	02/09/2024 09:06	Colony Counts 22	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4964096	02/09/2024 09:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4964096	02/09/2024 09:06	E. coli	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4964096	02/09/2024 09:06	Free - Residual disinfectant	mg Cl/l	0.38	
V4712OUT	Corranny SR Outlet	4964096	02/09/2024 09:06	Total - Residual disinfectant	mg Cl/l	0.65	
V4712OUT	Corranny SR Outlet	4964096	02/09/2024 09:06	Total Coliforms	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4964091	02/09/2024 09:21	Colony Counts 22	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4964091	02/09/2024 09:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4964091	02/09/2024 09:21	E. coli	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4964091	02/09/2024 09:21	Free - Residual disinfectant	mg Cl/l	0.54	
V1335OUT	Brigh Quarry SR Outlet	4964091	02/09/2024 09:21	Total - Residual disinfectant	mg Cl/l	0.64	
V1335OUT	Brigh Quarry SR Outlet	4964091	02/09/2024 09:21	Total Coliforms	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4964056	02/09/2024 09:54	Colony Counts 22	CFU/1 ml	6	
V2518OUT	Lisnastrane SR Outlet	4964056	02/09/2024 09:54	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4964056	02/09/2024 09:54	E. coli	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4964056	02/09/2024 09:54	Free - Residual disinfectant	mg Cl/l	0.57	
V2518OUT	Lisnastrane SR Outlet	4964056	02/09/2024 09:54	Total - Residual disinfectant	mg Cl/l	0.69	
V2518OUT	Lisnastrane SR Outlet	4964056	02/09/2024 09:54	Total Coliforms	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4964088	02/09/2024 10:09	Colony Counts 22	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4964088	02/09/2024 10:09	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V4533OUT	Inisclan SR Outlet	4964088	02/09/2024 10:09	E. coli	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4964088	02/09/2024 10:09	Free - Residual disinfectant	mg Cl/l	0.65	
V4533OUT	Inisclan SR Outlet	4964088	02/09/2024 10:09	Total - Residual disinfectant	mg Cl/l	0.8	

V4533OUT	Inisclan SR Outlet	4964088	02/09/2024 10:09	Total Coliforms	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4964034	02/09/2024 10:23	Colony Counts 22	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4964034	02/09/2024 10:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4964034	02/09/2024 10:23	E. coli	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4964034	02/09/2024 10:23	Free - Residual disinfectant	mg Cl/l	0.7	
V2511OUT	Corran Armagh SR Outlet	4964034	02/09/2024 10:23	Total - Residual disinfectant	mg Cl/l	1.02	
V2511OUT	Corran Armagh SR Outlet	4964034	02/09/2024 10:23	Total Coliforms	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4964033	02/09/2024 11:01	Colony Counts 22	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4964033	02/09/2024 11:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4964033	02/09/2024 11:01	E. coli	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4964033	02/09/2024 11:01	Free - Residual disinfectant	mg Cl/l	0.37	
V2510OUT	Calone SR Outlet	4964033	02/09/2024 11:01	Total - Residual disinfectant	mg Cl/l	0.66	
V2510OUT	Calone SR Outlet	4964033	02/09/2024 11:01	Total Coliforms	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4976069	02/09/2024 11:10	Cryptosporidium Oocysts	Oocyst/10l	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4976069	02/09/2024 11:10	Oocysts per volume filtered	Oocyst	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4976069	02/09/2024 11:10	Pellet Size	ml	<0.5	
V4708OUT	Cavanacross Enniskillen SR Outlet	4976069	02/09/2024 11:10	Sample Volume	l	10	
V2514OUT	Edenaveys Command SR Outlet	4964055	02/09/2024 11:16	Colony Counts 22	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4964055	02/09/2024 11:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4964055	02/09/2024 11:16	E. coli	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4964055	02/09/2024 11:16	Free - Residual disinfectant	mg Cl/l	0.67	
V2514OUT	Edenaveys Command SR Outlet	4964055	02/09/2024 11:16	Total - Residual disinfectant	mg Cl/l	0.92	
V2514OUT	Edenaveys Command SR Outlet	4964055	02/09/2024 11:16	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4964084	02/09/2024 11:43	Colony Counts 22	CFU/1 ml	35	
V1704OUT	Castlerock Downhill SR Outlet	4964084	02/09/2024 11:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4964084	02/09/2024 11:43	E. coli	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4964084	02/09/2024 11:43	Free - Residual disinfectant	mg Cl/l	<0.05	
V1704OUT	Castlerock Downhill SR Outlet	4964084	02/09/2024 11:43	Total - Residual disinfectant	mg Cl/l	0.21	
V1704OUT	Castlerock Downhill SR Outlet	4964084	02/09/2024 11:43	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4964084	02/09/2024 11:43	Odour	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4964084	02/09/2024 11:43	Odour - Nature		No odour	
V1704OUT	Castlerock Downhill SR Outlet	4964084	02/09/2024 11:43	Taste	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4964084	02/09/2024 11:43	Taste - Nature		No taste	
V1711OUT	Sconce Hill SR Outlet	4964085	02/09/2024 12:02	Colony Counts 22	CFU/1 ml	24	
V1711OUT	Sconce Hill SR Outlet	4964085	02/09/2024 12:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1711OUT	Sconce Hill SR Outlet	4964085	02/09/2024 12:02	E. coli	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4964085	02/09/2024 12:02	Free - Residual disinfectant	mg Cl/l	0.1	
V1711OUT	Sconce Hill SR Outlet	4964085	02/09/2024 12:02	Total - Residual disinfectant	mg Cl/l	0.2	
V1711OUT	Sconce Hill SR Outlet	4964085	02/09/2024 12:02	Total Coliforms	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4964030	02/09/2024 12:07	Colony Counts 22	CFU/1 ml	0	

V2523OUT	Rough Fort SR Outlet	4964030	02/09/2024 12:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4964030	02/09/2024 12:07	E. coli	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4964030	02/09/2024 12:07	Free - Residual disinfectant	mg Cl/l	0.81	
V2523OUT	Rough Fort SR Outlet	4964030	02/09/2024 12:07	Total - Residual disinfectant	mg Cl/l	1.11	
V2523OUT	Rough Fort SR Outlet	4964030	02/09/2024 12:07	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4964557	03/09/2024 07:31	Colony Counts 22	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4964557	03/09/2024 07:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4964557	03/09/2024 07:31	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4964557	03/09/2024 07:31	Free - Residual disinfectant	mg Cl/l	0.76	
V1360OUT	Windmill Hill SR Outlet	4964557	03/09/2024 07:31	Total - Residual disinfectant	mg Cl/l	0.87	
V1360OUT	Windmill Hill SR Outlet	4964557	03/09/2024 07:31	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4964568	03/09/2024 07:49	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4964568	03/09/2024 07:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4964568	03/09/2024 07:49	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4964568	03/09/2024 07:49	Free - Residual disinfectant	mg Cl/l	0.87	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4964568	03/09/2024 07:49	Total - Residual disinfectant	mg Cl/l	0.95	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4964568	03/09/2024 07:49	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4964568	03/09/2024 07:49	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4964568	03/09/2024 07:49	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4964568	03/09/2024 07:49	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4964568	03/09/2024 07:49	Taste - Nature		No taste	
V1362OUT	Unagh SR Outlet	4964559	03/09/2024 09:15	Colony Counts 22	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4964559	03/09/2024 09:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4964559	03/09/2024 09:15	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4964559	03/09/2024 09:15	Free - Residual disinfectant	mg Cl/l	0.48	
V1362OUT	Unagh SR Outlet	4964559	03/09/2024 09:15	Total - Residual disinfectant	mg Cl/l	0.58	
V1362OUT	Unagh SR Outlet	4964559	03/09/2024 09:15	Total Coliforms	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4964572	03/09/2024 09:39	Colony Counts 22	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4964572	03/09/2024 09:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4964572	03/09/2024 09:39	E. coli	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4964572	03/09/2024 09:39	Free - Residual disinfectant	mg Cl/l	0.55	
V1344OUT	Craigs Cookstown SR Outlet	4964572	03/09/2024 09:39	Total - Residual disinfectant	mg Cl/l	0.64	
V1344OUT	Craigs Cookstown SR Outlet	4964572	03/09/2024 09:39	Total Coliforms	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4964569	03/09/2024 10:00	Colony Counts 22	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4964569	03/09/2024 10:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4964569	03/09/2024 10:00	E. coli	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4964569	03/09/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.53	
V1339OUT	Corvanaghan High SR Outlet	4964569	03/09/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.64	
V1339OUT	Corvanaghan High SR Outlet	4964569	03/09/2024 10:00	Total Coliforms	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4964534	03/09/2024 10:01	Colony Counts 22	CFU/1 ml	41	

V4526OUT	Black Lough Pomeroy SR Outlet	4964534	03/09/2024 10:01	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V4526OUT	Black Lough Pomeroy SR Outlet	4964534	03/09/2024 10:01	E. coli	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4964534	03/09/2024 10:01	Free - Residual disinfectant	mg Cl/l	0.39	
V4526OUT	Black Lough Pomeroy SR Outlet	4964534	03/09/2024 10:01	Total - Residual disinfectant	mg Cl/l	0.45	
V4526OUT	Black Lough Pomeroy SR Outlet	4964534	03/09/2024 10:01	Total Coliforms	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4964570	03/09/2024 10:15	Colony Counts 22	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4964570	03/09/2024 10:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4964570	03/09/2024 10:15	E. coli	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4964570	03/09/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.56	
V1340OUT	Craigballyharkey SR Outlet	4964570	03/09/2024 10:15	Total - Residual disinfectant	mg Cl/l	0.67	
V1340OUT	Craigballyharkey SR Outlet	4964570	03/09/2024 10:15	Total Coliforms	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4964545	03/09/2024 10:17	Colony Counts 22	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4964545	03/09/2024 10:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4964545	03/09/2024 10:17	E. coli	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4964545	03/09/2024 10:17	Free - Residual disinfectant	mg Cl/l	0.69	
V4536OUT	Lough Macrory North SR Outlet	4964545	03/09/2024 10:17	Total - Residual disinfectant	mg Cl/l	0.77	
V4536OUT	Lough Macrory North SR Outlet	4964545	03/09/2024 10:17	Total Coliforms	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4964573	03/09/2024 10:29	Colony Counts 22	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4964573	03/09/2024 10:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4964573	03/09/2024 10:29	E. coli	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4964573	03/09/2024 10:29	Free - Residual disinfectant	mg Cl/l	0.58	
V1346OUT	Gortaclady Evishanoran SR Outlet	4964573	03/09/2024 10:29	Total - Residual disinfectant	mg Cl/l	0.69	
V1346OUT	Gortaclady Evishanoran SR Outlet	4964573	03/09/2024 10:29	Total Coliforms	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4964535	03/09/2024 10:53	Colony Counts 22	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4964535	03/09/2024 10:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4964535	03/09/2024 10:53	E. coli	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4964535	03/09/2024 10:53	Free - Residual disinfectant	mg Cl/l	0.41	
V4538OUT	Killyclogher SR Outlet	4964535	03/09/2024 10:53	Total - Residual disinfectant	mg Cl/l	0.49	
V4538OUT	Killyclogher SR Outlet	4964535	03/09/2024 10:53	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4964564	03/09/2024 11:19	Colony Counts 22	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4964564	03/09/2024 11:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4964564	03/09/2024 11:19	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4964564	03/09/2024 11:19	Free - Residual disinfectant	mg Cl/l	0.35	
V1350OUT	Carnaman SR Outlet	4964564	03/09/2024 11:19	Total - Residual disinfectant	mg Cl/l	0.52	
V1350OUT	Carnaman SR Outlet	4964564	03/09/2024 11:19	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4964564	03/09/2024 11:19	Odour	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4964564	03/09/2024 11:19	Odour - Nature		No odour	
V1350OUT	Carnaman SR Outlet	4964564	03/09/2024 11:19	Taste	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4964564	03/09/2024 11:19	Taste - Nature		No taste	
V4539OUT	Erganagh SR Outlet	4964537	03/09/2024 11:48	Colony Counts 22	CFU/1 ml	15	

V4539OUT	Erganagh SR Outlet	4964537	03/09/2024 11:48	Colony Counts 37 (48hrs)	CFU/1 ml	5	
V4539OUT	Erganagh SR Outlet	4964537	03/09/2024 11:48	E. coli	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4964537	03/09/2024 11:48	Free - Residual disinfectant	mg Cl/l	0.11	
V4539OUT	Erganagh SR Outlet	4964537	03/09/2024 11:48	Total - Residual disinfectant	mg Cl/l	0.15	
V4539OUT	Erganagh SR Outlet	4964537	03/09/2024 11:48	Total Coliforms	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4964708	04/09/2024 08:28	Colony Counts 22	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4964708	04/09/2024 08:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4964708	04/09/2024 08:28	E. coli	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4964708	04/09/2024 08:28	Free - Residual disinfectant	mg Cl/l	0.63	
V2505OUT	Cabragh Fasglashagh SR Outlet	4964708	04/09/2024 08:28	Total - Residual disinfectant	mg Cl/l	0.74	
V2505OUT	Cabragh Fasglashagh SR Outlet	4964708	04/09/2024 08:28	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4964755	04/09/2024 08:39	Colony Counts 22	CFU/1 ml	64	
V1349OUT	Ballyknock Magherafelt SR Outlet	4964755	04/09/2024 08:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4964755	04/09/2024 08:39	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4964755	04/09/2024 08:39	Free - Residual disinfectant	mg Cl/l	0.38	
V1349OUT	Ballyknock Magherafelt SR Outlet	4964755	04/09/2024 08:39	Total - Residual disinfectant	mg Cl/l	0.47	
V1349OUT	Ballyknock Magherafelt SR Outlet	4964755	04/09/2024 08:39	Total Coliforms	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4964722	04/09/2024 08:49	Colony Counts 22	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4964722	04/09/2024 08:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4964722	04/09/2024 08:49	E. coli	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4964722	04/09/2024 08:49	Free - Residual disinfectant	mg Cl/l	0.62	
V4707OUT	Sidaire SR Outlet	4964722	04/09/2024 08:49	Total - Residual disinfectant	mg Cl/l	0.73	
V4707OUT	Sidaire SR Outlet	4964722	04/09/2024 08:49	Total Coliforms	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4964709	04/09/2024 08:59	Colony Counts 22	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4964709	04/09/2024 08:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4964709	04/09/2024 08:59	E. coli	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4964709	04/09/2024 08:59	Free - Residual disinfectant	mg Cl/l	0.58	
V2507OUT	Cappagh SR Outlet	4964709	04/09/2024 08:59	Total - Residual disinfectant	mg Cl/l	0.67	
V2507OUT	Cappagh SR Outlet	4964709	04/09/2024 08:59	Total Coliforms	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4964763	04/09/2024 08:59	Colony Counts 22	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4964763	04/09/2024 08:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4964763	04/09/2024 08:59	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4964763	04/09/2024 08:59	Free - Residual disinfectant	mg Cl/l	0.67	
V1358OUT	Slaughtneil SR Outlet	4964763	04/09/2024 08:59	Total - Residual disinfectant	mg Cl/l	0.84	
V1358OUT	Slaughtneil SR Outlet	4964763	04/09/2024 08:59	Total Coliforms	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4964738	04/09/2024 09:09	Colony Counts 22	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4964738	04/09/2024 09:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4964738	04/09/2024 09:09	E. coli	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4964738	04/09/2024 09:09	Free - Residual disinfectant	mg Cl/l	0.84	
V2501OUT	Altmore River SR Outlet	4964738	04/09/2024 09:09	Total - Residual disinfectant	mg Cl/l	0.95	

V2501OUT	Altmore River SR Outlet	4964738	04/09/2024 09:09	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4964761	04/09/2024 09:21	Colony Counts 22	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4964761	04/09/2024 09:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4964761	04/09/2024 09:21	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4964761	04/09/2024 09:21	Free - Residual disinfectant	mg Cl/l	0.21	
V1354OUT	Knockoneill SR Outlet	4964761	04/09/2024 09:21	Total - Residual disinfectant	mg Cl/l	0.39	
V1354OUT	Knockoneill SR Outlet	4964761	04/09/2024 09:21	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4964761	04/09/2024 09:21	Odour	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4964761	04/09/2024 09:21	Odour - Nature		No odour	
V1354OUT	Knockoneill SR Outlet	4964761	04/09/2024 09:21	Taste	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4964761	04/09/2024 09:21	Taste - Nature		No taste	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4964766	04/09/2024 09:41	Colony Counts 22	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4964766	04/09/2024 09:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4964766	04/09/2024 09:41	E. coli	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4964766	04/09/2024 09:41	Free - Residual disinfectant	mg Cl/l	0.52	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4964766	04/09/2024 09:41	Total - Residual disinfectant	mg Cl/l	0.61	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4964766	04/09/2024 09:41	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4964710	04/09/2024 09:45	Colony Counts 22	CFU/1 ml	1	
V1725OUT	Glenlough SR Outlet	4964710	04/09/2024 09:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4964710	04/09/2024 09:45	E. coli	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4964710	04/09/2024 09:45	Free - Residual disinfectant	mg Cl/l	0.39	
V1725OUT	Glenlough SR Outlet	4964710	04/09/2024 09:45	Total - Residual disinfectant	mg Cl/l	0.71	
V1725OUT	Glenlough SR Outlet	4964710	04/09/2024 09:45	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4964710	04/09/2024 09:45	Odour	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4964710	04/09/2024 09:45	Odour - Nature		No odour	
V1725OUT	Glenlough SR Outlet	4964710	04/09/2024 09:45	Taste	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4964710	04/09/2024 09:45	Taste - Nature		No taste	
V4708OUT	Cavanacross Enniskillen SR Outlet	4964767	04/09/2024 09:49	Colony Counts 22	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4964767	04/09/2024 09:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4964767	04/09/2024 09:49	E. coli	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4964767	04/09/2024 09:49	Free - Residual disinfectant	mg Cl/l	1.26	
V4708OUT	Cavanacross Enniskillen SR Outlet	4964767	04/09/2024 09:49	Total - Residual disinfectant	mg Cl/l	1.39	
V4708OUT	Cavanacross Enniskillen SR Outlet	4964767	04/09/2024 09:49	Total Coliforms	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4961079	04/09/2024 09:50	Colony Counts 22	CFU/1 ml	5	
V4526OUT	Black Lough Pomeroy SR Outlet	4961079	04/09/2024 09:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4961079	04/09/2024 09:50	E. coli	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4961079	04/09/2024 09:50	Free - Residual disinfectant	mg Cl/l	0.49	
V4526OUT	Black Lough Pomeroy SR Outlet	4961079	04/09/2024 09:50	Total - Residual disinfectant	mg Cl/l	0.56	
V4526OUT	Black Lough Pomeroy SR Outlet	4961079	04/09/2024 09:50	Total Coliforms	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4961087	04/09/2024 10:02	Colony Counts 22	CFU/1 ml	0	

V4536OUT	Lough Macrory North SR Outlet	4961087	04/09/2024 10:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4961087	04/09/2024 10:02	E. coli	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4961087	04/09/2024 10:02	Free - Residual disinfectant	mg Cl/l	0.61	
V4536OUT	Lough Macrory North SR Outlet	4961087	04/09/2024 10:02	Total - Residual disinfectant	mg Cl/l	0.69	
V4536OUT	Lough Macrory North SR Outlet	4961087	04/09/2024 10:02	Total Coliforms	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4964731	04/09/2024 10:45	Colony Counts 22	CFU/1 ml	17	
V4527OUT	Carryglass SR Outlet	4964731	04/09/2024 10:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4964731	04/09/2024 10:45	E. coli	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4964731	04/09/2024 10:45	Free - Residual disinfectant	mg Cl/l	0.17	
V4527OUT	Carryglass SR Outlet	4964731	04/09/2024 10:45	Total - Residual disinfectant	mg Cl/l	0.32	
V4527OUT	Carryglass SR Outlet	4964731	04/09/2024 10:45	Total Coliforms	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4964760	04/09/2024 10:47	Colony Counts 22	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4964760	04/09/2024 10:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4964760	04/09/2024 10:47	E. coli	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4964760	04/09/2024 10:47	Free - Residual disinfectant	mg Cl/l	0.53	
V4719OUT	Glenchuil SR Outlet	4964760	04/09/2024 10:47	Total - Residual disinfectant	mg Cl/l	0.6	
V4719OUT	Glenchuil SR Outlet	4964760	04/09/2024 10:47	Total Coliforms	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4964770	04/09/2024 11:16	Colony Counts 22	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4964770	04/09/2024 11:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4964770	04/09/2024 11:16	E. coli	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4964770	04/09/2024 11:16	Free - Residual disinfectant	mg Cl/l	0.09	
V4530OUT	Dungoran SR Outlet	4964770	04/09/2024 11:16	Total - Residual disinfectant	mg Cl/l	0.14	
V4530OUT	Dungoran SR Outlet	4964770	04/09/2024 11:16	Total Coliforms	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4964762	04/09/2024 11:27	Colony Counts 22	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4964762	04/09/2024 11:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4964762	04/09/2024 11:27	E. coli	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4964762	04/09/2024 11:27	Free - Residual disinfectant	mg Cl/l	0.43	
V4535OUT	Lisnagardy SR Outlet	4964762	04/09/2024 11:27	Total - Residual disinfectant	mg Cl/l	0.49	
V4535OUT	Lisnagardy SR Outlet	4964762	04/09/2024 11:27	Total Coliforms	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4964758	04/09/2024 11:45	Colony Counts 22	CFU/1 ml	1	
V1715OUT	Ballystrone (Calvins) SR Outlet	4964758	04/09/2024 11:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4964758	04/09/2024 11:45	E. coli	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4964758	04/09/2024 11:45	Free - Residual disinfectant	mg Cl/l	0.15	
V1715OUT	Ballystrone (Calvins) SR Outlet	4964758	04/09/2024 11:45	Total - Residual disinfectant	mg Cl/l	0.32	
V1715OUT	Ballystrone (Calvins) SR Outlet	4964758	04/09/2024 11:45	Total Coliforms	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4961080	04/09/2024 11:47	Colony Counts 22	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4961080	04/09/2024 11:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4961080	04/09/2024 11:47	E. coli	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4961080	04/09/2024 11:47	Free - Residual disinfectant	mg Cl/l	0.36	
V4538OUT	Killyclogher SR Outlet	4961080	04/09/2024 11:47	Total - Residual disinfectant	mg Cl/l	0.45	

V4538OUT	Killiclogher SR Outlet	4961080	04/09/2024 11:47	Total Coliforms	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4961082	04/09/2024 12:05	Colony Counts 22	CFU/1 ml	36	
V4539OUT	Erganagh SR Outlet	4961082	04/09/2024 12:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4961082	04/09/2024 12:05	E. coli	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4961082	04/09/2024 12:05	Free - Residual disinfectant	mg Cl/l	0.18	
V4539OUT	Erganagh SR Outlet	4961082	04/09/2024 12:05	Total - Residual disinfectant	mg Cl/l	0.26	
V4539OUT	Erganagh SR Outlet	4961082	04/09/2024 12:05	Total Coliforms	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4964919	05/09/2024 08:18	Colony Counts 22	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4964919	05/09/2024 08:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4964919	05/09/2024 08:18	E. coli	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4964919	05/09/2024 08:18	Free - Residual disinfectant	mg Cl/l	0.8	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4964919	05/09/2024 08:18	Total - Residual disinfectant	mg Cl/l	0.94	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4964919	05/09/2024 08:18	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4964932	05/09/2024 09:04	Colony Counts 22	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4964932	05/09/2024 09:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4964932	05/09/2024 09:04	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4964932	05/09/2024 09:04	Free - Residual disinfectant	mg Cl/l	0.26	
V1348OUT	Moydamlaght Draperstown SR Outlet	4964932	05/09/2024 09:04	Total - Residual disinfectant	mg Cl/l	0.41	
V1348OUT	Moydamlaght Draperstown SR Outlet	4964932	05/09/2024 09:04	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4978052	05/09/2024 09:05	Free - Residual disinfectant	mg Cl/l	0.26	
V1348OUT	Moydamlaght Draperstown SR Outlet	4978052	05/09/2024 09:05	Total - Residual disinfectant	mg Cl/l	0.41	
V1348OUT	Moydamlaght Draperstown SR Outlet	4978052	05/09/2024 09:05	Aluminium	ug Al/l	27	200
V1348OUT	Moydamlaght Draperstown SR Outlet	4978052	05/09/2024 09:05	Iron	ug/l Fe	38	200
V1348OUT	Moydamlaght Draperstown SR Outlet	4978052	05/09/2024 09:05	Manganese	ug Mn/l	0.98	50
V2301OUT	Ballydougan Command SR Outlet	4964898	05/09/2024 09:24	Colony Counts 22	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4964898	05/09/2024 09:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4964898	05/09/2024 09:24	E. coli	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4964898	05/09/2024 09:24	Free - Residual disinfectant	mg Cl/l	0.98	
V2301OUT	Ballydougan Command SR Outlet	4964898	05/09/2024 09:24	Total - Residual disinfectant	mg Cl/l	1.05	
V2301OUT	Ballydougan Command SR Outlet	4964898	05/09/2024 09:24	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4964898	05/09/2024 09:24	Odour	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4964898	05/09/2024 09:24	Odour - Nature		No odour	
V2301OUT	Ballydougan Command SR Outlet	4964898	05/09/2024 09:24	Taste	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4964898	05/09/2024 09:24	Taste - Nature		No taste	
V2302OUT	Ballyhannon SR Outlet	4964899	05/09/2024 09:42	Colony Counts 22	CFU/1 ml	90	
V2302OUT	Ballyhannon SR Outlet	4964899	05/09/2024 09:42	Colony Counts 37 (48hrs)	CFU/1 ml	165	
V2302OUT	Ballyhannon SR Outlet	4964899	05/09/2024 09:42	E. coli	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4964899	05/09/2024 09:42	Free - Residual disinfectant	mg Cl/l	0.55	
V2302OUT	Ballyhannon SR Outlet	4964899	05/09/2024 09:42	Total - Residual disinfectant	mg Cl/l	0.65	
V2302OUT	Ballyhannon SR Outlet	4964899	05/09/2024 09:42	Total Coliforms	CFU/100 ml	0	0

V1356OUT	Mormeal SR Outlet	4964937	05/09/2024 10:15	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4964937	05/09/2024 10:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4964937	05/09/2024 10:15	E. coli	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4964937	05/09/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.45	
V1356OUT	Mormeal SR Outlet	4964937	05/09/2024 10:15	Total - Residual disinfectant	mg Cl/l	0.61	
V1356OUT	Mormeal SR Outlet	4964937	05/09/2024 10:15	Total Coliforms	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4964910	05/09/2024 10:40	Colony Counts 22	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4964910	05/09/2024 10:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4964910	05/09/2024 10:40	E. coli	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4964910	05/09/2024 10:40	Free - Residual disinfectant	mg Cl/l	0.47	
V4540OUT	Radergan SR Outlet	4964910	05/09/2024 10:40	Total - Residual disinfectant	mg Cl/l	0.6	
V4540OUT	Radergan SR Outlet	4964910	05/09/2024 10:40	Total Coliforms	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4964935	05/09/2024 10:56	Colony Counts 22	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4964935	05/09/2024 10:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4964935	05/09/2024 10:56	E. coli	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4964935	05/09/2024 10:56	Free - Residual disinfectant	mg Cl/l	0.49	
V4531OUT	Foremass SR Outlet	4964935	05/09/2024 10:56	Total - Residual disinfectant	mg Cl/l	0.63	
V4531OUT	Foremass SR Outlet	4964935	05/09/2024 10:56	Total Coliforms	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4964938	05/09/2024 11:10	Colony Counts 22	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4964938	05/09/2024 11:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4964938	05/09/2024 11:10	E. coli	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4964938	05/09/2024 11:10	Free - Residual disinfectant	mg Cl/l	0.44	
V4537OUT	Sixmilecross SR Outlet	4964938	05/09/2024 11:10	Total - Residual disinfectant	mg Cl/l	0.56	
V4537OUT	Sixmilecross SR Outlet	4964938	05/09/2024 11:10	Total Coliforms	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4964942	05/09/2024 11:26	Colony Counts 22	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4964942	05/09/2024 11:26	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V4528OUT	Crocknabohil SR Outlet	4964942	05/09/2024 11:26	E. coli	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4964942	05/09/2024 11:26	Free - Residual disinfectant	mg Cl/l	0.31	
V4528OUT	Crocknabohil SR Outlet	4964942	05/09/2024 11:26	Total - Residual disinfectant	mg Cl/l	0.45	
V4528OUT	Crocknabohil SR Outlet	4964942	05/09/2024 11:26	Total Coliforms	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4965129	06/09/2024 07:19	Colony Counts 22	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4965129	06/09/2024 07:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4965129	06/09/2024 07:19	E. coli	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4965129	06/09/2024 07:19	Free - Residual disinfectant	mg Cl/l	0.63	
V1351OUT	Cranny Moneymore SR Outlet	4965129	06/09/2024 07:19	Total - Residual disinfectant	mg Cl/l	0.73	
V1351OUT	Cranny Moneymore SR Outlet	4965129	06/09/2024 07:19	Total Coliforms	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4965117	06/09/2024 07:40	Colony Counts 22	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4965117	06/09/2024 07:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4965117	06/09/2024 07:40	E. coli	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4965117	06/09/2024 07:40	Free - Residual disinfectant	mg Cl/l	0.4	

V1352OUT	Cullion Desertmartin SR Outlet	4965117	06/09/2024 07:40	Total - Residual disinfectant	mg Cl/l	0.5	
V1352OUT	Cullion Desertmartin SR Outlet	4965117	06/09/2024 07:40	Total Coliforms	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4965140	06/09/2024 08:03	Colony Counts 22	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4965140	06/09/2024 08:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4965140	06/09/2024 08:03	E. coli	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4965140	06/09/2024 08:03	Free - Residual disinfectant	mg Cl/l	0.7	
V1343OUT	Ballybriest SR Outlet	4965140	06/09/2024 08:03	Total - Residual disinfectant	mg Cl/l	0.76	
V1343OUT	Ballybriest SR Outlet	4965140	06/09/2024 08:03	Total Coliforms	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4965128	06/09/2024 08:05	Colony Counts 22	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4965128	06/09/2024 08:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4965128	06/09/2024 08:05	E. coli	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4965128	06/09/2024 08:05	Free - Residual disinfectant	mg Cl/l	0.45	
V1713OUT	Trienaltenagh SR Outlet	4965128	06/09/2024 08:05	Total - Residual disinfectant	mg Cl/l	0.56	
V1713OUT	Trienaltenagh SR Outlet	4965128	06/09/2024 08:05	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4965087	06/09/2024 08:39	Colony Counts 22	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4965087	06/09/2024 08:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4965087	06/09/2024 08:39	E. coli	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4965087	06/09/2024 08:39	Free - Residual disinfectant	mg Cl/l	1.12	
V2508OUT	Carland SR Outlet	4965087	06/09/2024 08:39	Total - Residual disinfectant	mg Cl/l	1.2	
V2508OUT	Carland SR Outlet	4965087	06/09/2024 08:39	Total Coliforms	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4965125	06/09/2024 08:45	Colony Counts 22	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4965125	06/09/2024 08:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4965125	06/09/2024 08:45	E. coli	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4965125	06/09/2024 08:45	Free - Residual disinfectant	mg Cl/l	0.07	
V1708OUT	North Garvagh SR Outlet	4965125	06/09/2024 08:45	Total - Residual disinfectant	mg Cl/l	0.2	
V1708OUT	North Garvagh SR Outlet	4965125	06/09/2024 08:45	Total Coliforms	CFU/100 ml	0	0
V1361OUT	Moneymore Tamnadoey SR Outlet	4967317	06/09/2024 08:48	Colony Counts 22	CFU/1 ml	0	
V1361OUT	Moneymore Tamnadoey SR Outlet	4967317	06/09/2024 08:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1361OUT	Moneymore Tamnadoey SR Outlet	4967317	06/09/2024 08:48	E. coli	CFU/100 ml	0	0
V1361OUT	Moneymore Tamnadoey SR Outlet	4967317	06/09/2024 08:48	Free - Residual disinfectant	mg Cl/l	0.18	
V1361OUT	Moneymore Tamnadoey SR Outlet	4967317	06/09/2024 08:48	Total - Residual disinfectant	mg Cl/l	0.39	
V1361OUT	Moneymore Tamnadoey SR Outlet	4967317	06/09/2024 08:48	Total Coliforms	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4965088	06/09/2024 08:59	Colony Counts 22	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4965088	06/09/2024 08:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4965088	06/09/2024 08:59	E. coli	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4965088	06/09/2024 08:59	Free - Residual disinfectant	mg Cl/l	0.65	
V2509OUT	Castlehill Drumcoo SR Outlet	4965088	06/09/2024 08:59	Total - Residual disinfectant	mg Cl/l	0.71	
V2509OUT	Castlehill Drumcoo SR Outlet	4965088	06/09/2024 08:59	Total Coliforms	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4965121	06/09/2024 09:05	Colony Counts 22	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4965121	06/09/2024 09:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	

V1706OUT	Killeague SR Outlet	4965121	06/09/2024 09:05	E. coli	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4965121	06/09/2024 09:05	Free - Residual disinfectant	mg Cl/l	<0.05	
V1706OUT	Killeague SR Outlet	4965121	06/09/2024 09:05	Total - Residual disinfectant	mg Cl/l	<0.05	
V1706OUT	Killeague SR Outlet	4965121	06/09/2024 09:05	Total Coliforms	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4965100	06/09/2024 09:13	Colony Counts 22	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4965100	06/09/2024 09:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4965100	06/09/2024 09:13	E. coli	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4965100	06/09/2024 09:13	Free - Residual disinfectant	mg Cl/l	0.85	
V2521OUT	Mullaghanagh SR Outlet	4965100	06/09/2024 09:13	Total - Residual disinfectant	mg Cl/l	0.89	
V2521OUT	Mullaghanagh SR Outlet	4965100	06/09/2024 09:13	Total Coliforms	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4965123	06/09/2024 09:30	Colony Counts 22	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4965123	06/09/2024 09:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4965123	06/09/2024 09:30	E. coli	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4965123	06/09/2024 09:30	Free - Residual disinfectant	mg Cl/l	0.13	
V1702OUT	Cam SR Outlet	4965123	06/09/2024 09:30	Total - Residual disinfectant	mg Cl/l	0.14	
V1702OUT	Cam SR Outlet	4965123	06/09/2024 09:30	Total Coliforms	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4965116	06/09/2024 09:38	Colony Counts 22	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4965116	06/09/2024 09:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4965116	06/09/2024 09:38	E. coli	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4965116	06/09/2024 09:38	Free - Residual disinfectant	mg Cl/l	0.65	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4965116	06/09/2024 09:38	Total - Residual disinfectant	mg Cl/l	0.7	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4965116	06/09/2024 09:38	Total Coliforms	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4965127	06/09/2024 09:49	Colony Counts 22	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4965127	06/09/2024 09:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4965127	06/09/2024 09:49	E. coli	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4965127	06/09/2024 09:49	Free - Residual disinfectant	mg Cl/l	0.69	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4965127	06/09/2024 09:49	Total - Residual disinfectant	mg Cl/l	0.8	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4965127	06/09/2024 09:49	Total Coliforms	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4965124	06/09/2024 10:09	Colony Counts 22	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4965124	06/09/2024 10:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4965124	06/09/2024 10:09	E. coli	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4965124	06/09/2024 10:09	Free - Residual disinfectant	mg Cl/l	1.04	
V4742OUT	Tattinbar SR Outlet	4965124	06/09/2024 10:09	Total - Residual disinfectant	mg Cl/l	1.11	
V4742OUT	Tattinbar SR Outlet	4965124	06/09/2024 10:09	Total Coliforms	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4965142	06/09/2024 10:32	Colony Counts 22	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4965142	06/09/2024 10:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4965142	06/09/2024 10:32	E. coli	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4965142	06/09/2024 10:32	Free - Residual disinfectant	mg Cl/l	0.91	
V4715OUT	Brookeborough High SR Outlet	4965142	06/09/2024 10:32	Total - Residual disinfectant	mg Cl/l	1.02	
V4715OUT	Brookeborough High SR Outlet	4965142	06/09/2024 10:32	Total Coliforms	CFU/100 ml	0	0

V4744OUT	Altaveedan Crockacleaven SR Outlet	4965126	06/09/2024 11:00	Colony Counts 22	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4965126	06/09/2024 11:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4965126	06/09/2024 11:00	E. coli	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4965126	06/09/2024 11:00	Free - Residual disinfectant	mg Cl/l	0.57	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4965126	06/09/2024 11:00	Total - Residual disinfectant	mg Cl/l	0.65	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4965126	06/09/2024 11:00	Total Coliforms	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4967369	09/09/2024 08:02	Colony Counts 22	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4967369	09/09/2024 08:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4967369	09/09/2024 08:02	E. coli	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4967369	09/09/2024 08:02	Free - Residual disinfectant	mg Cl/l	0.67	
V1351OUT	Cranny Moneymore SR Outlet	4967369	09/09/2024 08:02	Total - Residual disinfectant	mg Cl/l	0.72	
V1351OUT	Cranny Moneymore SR Outlet	4967369	09/09/2024 08:02	Total Coliforms	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4967357	09/09/2024 08:23	Colony Counts 22	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4967357	09/09/2024 08:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4967357	09/09/2024 08:23	E. coli	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4967357	09/09/2024 08:23	Free - Residual disinfectant	mg Cl/l	0.23	
V1352OUT	Cullion Desertmartin SR Outlet	4967357	09/09/2024 08:23	Total - Residual disinfectant	mg Cl/l	0.47	
V1352OUT	Cullion Desertmartin SR Outlet	4967357	09/09/2024 08:23	Total Coliforms	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4967380	09/09/2024 08:45	Colony Counts 22	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4967380	09/09/2024 08:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4967380	09/09/2024 08:45	E. coli	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4967380	09/09/2024 08:45	Free - Residual disinfectant	mg Cl/l	0.69	
V1343OUT	Ballybriest SR Outlet	4967380	09/09/2024 08:45	Total - Residual disinfectant	mg Cl/l	0.82	
V1343OUT	Ballybriest SR Outlet	4967380	09/09/2024 08:45	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4967333	09/09/2024 09:19	Colony Counts 22	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4967333	09/09/2024 09:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4967333	09/09/2024 09:19	E. coli	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4967333	09/09/2024 09:19	Free - Residual disinfectant	mg Cl/l	1.02	
V2508OUT	Carland SR Outlet	4967333	09/09/2024 09:19	Total - Residual disinfectant	mg Cl/l	1.1	
V2508OUT	Carland SR Outlet	4967333	09/09/2024 09:19	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4967333	09/09/2024 09:19	Odour	Diln No	0	0
V2508OUT	Carland SR Outlet	4967333	09/09/2024 09:19	Odour - Nature		No odour	
V2508OUT	Carland SR Outlet	4967333	09/09/2024 09:19	Taste	Diln No	0	0
V2508OUT	Carland SR Outlet	4967333	09/09/2024 09:19	Taste - Nature		No taste	
V1702OUT	Cam SR Outlet	4967363	09/09/2024 09:24	Colony Counts 22	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4967363	09/09/2024 09:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4967363	09/09/2024 09:24	E. coli	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4967363	09/09/2024 09:24	Free - Residual disinfectant	mg Cl/l	0.48	
V1702OUT	Cam SR Outlet	4967363	09/09/2024 09:24	Total - Residual disinfectant	mg Cl/l	0.63	
V1702OUT	Cam SR Outlet	4967363	09/09/2024 09:24	Total Coliforms	CFU/100 ml	0	0

V1361OUT	Money more Tamnadoey SR Outlet	4967490	09/09/2024 09:33	Colony Counts 22	CFU/1 ml	0	
V1361OUT	Money more Tamnadoey SR Outlet	4967490	09/09/2024 09:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1361OUT	Money more Tamnadoey SR Outlet	4967490	09/09/2024 09:33	E. coli	CFU/100 ml	0	0
V1361OUT	Money more Tamnadoey SR Outlet	4967490	09/09/2024 09:33	Free - Residual disinfectant	mg Cl/l	0.1	
V1361OUT	Money more Tamnadoey SR Outlet	4967490	09/09/2024 09:33	Total - Residual disinfectant	mg Cl/l	0.36	
V1361OUT	Money more Tamnadoey SR Outlet	4967490	09/09/2024 09:33	Total Coliforms	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4967361	09/09/2024 09:38	Colony Counts 22	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4967361	09/09/2024 09:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4967361	09/09/2024 09:38	E. coli	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4967361	09/09/2024 09:38	Free - Residual disinfectant	mg Cl/l	0.43	
V1706OUT	Killeague SR Outlet	4967361	09/09/2024 09:38	Total - Residual disinfectant	mg Cl/l	0.6	
V1706OUT	Killeague SR Outlet	4967361	09/09/2024 09:38	Total Coliforms	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4967334	09/09/2024 09:38	Colony Counts 22	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4967334	09/09/2024 09:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4967334	09/09/2024 09:38	E. coli	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4967334	09/09/2024 09:38	Free - Residual disinfectant	mg Cl/l	0.48	
V2509OUT	Castlehill Drumcoo SR Outlet	4967334	09/09/2024 09:38	Total - Residual disinfectant	mg Cl/l	0.58	
V2509OUT	Castlehill Drumcoo SR Outlet	4967334	09/09/2024 09:38	Total Coliforms	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4967365	09/09/2024 09:52	Colony Counts 22	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4967365	09/09/2024 09:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4967365	09/09/2024 09:52	E. coli	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4967365	09/09/2024 09:52	Free - Residual disinfectant	mg Cl/l	0.37	
V1708OUT	North Garvagh SR Outlet	4967365	09/09/2024 09:52	Total - Residual disinfectant	mg Cl/l	0.54	
V1708OUT	North Garvagh SR Outlet	4967365	09/09/2024 09:52	Total Coliforms	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4967366	09/09/2024 09:58	Colony Counts 22	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4967366	09/09/2024 09:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4967366	09/09/2024 09:58	E. coli	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4967366	09/09/2024 09:58	Free - Residual disinfectant	mg Cl/l	0.82	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4967366	09/09/2024 09:58	Total - Residual disinfectant	mg Cl/l	0.91	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4967366	09/09/2024 09:58	Total Coliforms	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4967345	09/09/2024 09:59	Colony Counts 22	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4967345	09/09/2024 09:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4967345	09/09/2024 09:59	E. coli	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4967345	09/09/2024 09:59	Free - Residual disinfectant	mg Cl/l	0.48	
V2521OUT	Mullaghanagh SR Outlet	4967345	09/09/2024 09:59	Total - Residual disinfectant	mg Cl/l	0.59	
V2521OUT	Mullaghanagh SR Outlet	4967345	09/09/2024 09:59	Total Coliforms	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4967368	09/09/2024 10:08	Colony Counts 22	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4967368	09/09/2024 10:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4967368	09/09/2024 10:08	E. coli	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4967368	09/09/2024 10:08	Free - Residual disinfectant	mg Cl/l	0.39	

V1713OUT	Trienaltenagh SR Outlet	4967368	09/09/2024 10:08	Total - Residual disinfectant	mg Cl/l	0.5	
V1713OUT	Trienaltenagh SR Outlet	4967368	09/09/2024 10:08	Total Coliforms	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4967382	09/09/2024 10:32	Colony Counts 22	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4967382	09/09/2024 10:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4967382	09/09/2024 10:32	E. coli	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4967382	09/09/2024 10:32	Free - Residual disinfectant	mg Cl/l	0.92	
V4715OUT	Brookeborough High SR Outlet	4967382	09/09/2024 10:32	Total - Residual disinfectant	mg Cl/l	1	
V4715OUT	Brookeborough High SR Outlet	4967382	09/09/2024 10:32	Total Coliforms	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4967356	09/09/2024 10:45	Colony Counts 22	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4967356	09/09/2024 10:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4967356	09/09/2024 10:45	E. coli	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4967356	09/09/2024 10:45	Free - Residual disinfectant	mg Cl/l	0.75	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4967356	09/09/2024 10:45	Total - Residual disinfectant	mg Cl/l	0.86	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4967356	09/09/2024 10:45	Total Coliforms	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4967364	09/09/2024 10:54	Colony Counts 22	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4967364	09/09/2024 10:54	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4967364	09/09/2024 10:54	E. coli	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4967364	09/09/2024 10:54	Free - Residual disinfectant	mg Cl/l	0.91	
V4742OUT	Tattinbar SR Outlet	4967364	09/09/2024 10:54	Total - Residual disinfectant	mg Cl/l	1.08	
V4742OUT	Tattinbar SR Outlet	4967364	09/09/2024 10:54	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979077	09/09/2024 14:30	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979077	09/09/2024 14:30	Free - Residual disinfectant	mg Cl/l	0.71	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979077	09/09/2024 14:30	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979077	09/09/2024 14:30	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979077	09/09/2024 14:30	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979077	09/09/2024 14:30	Taste - Nature		No taste	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979077	09/09/2024 14:30	Total - Residual disinfectant	mg Cl/l	0.83	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979077	09/09/2024 14:30	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4979074	09/09/2024 15:35	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4979074	09/09/2024 15:35	Free - Residual disinfectant	mg Cl/l	0.24	
V1348OUT	Moydamlaght Draperstown SR Outlet	4979074	09/09/2024 15:35	Odour	Diln No	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4979074	09/09/2024 15:35	Odour - Nature		No odour	
V1348OUT	Moydamlaght Draperstown SR Outlet	4979074	09/09/2024 15:35	Taste	Diln No	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4979074	09/09/2024 15:35	Taste - Nature		No taste	
V1348OUT	Moydamlaght Draperstown SR Outlet	4979074	09/09/2024 15:35	Total - Residual disinfectant	mg Cl/l	0.36	
V1348OUT	Moydamlaght Draperstown SR Outlet	4979074	09/09/2024 15:35	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4979075	09/09/2024 16:05	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4979075	09/09/2024 16:05	Free - Residual disinfectant	mg Cl/l	0.27	
V1349OUT	Ballyknock Magherafelt SR Outlet	4979075	09/09/2024 16:05	Odour	Diln No	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4979075	09/09/2024 16:05	Odour - Nature		No odour	

V1349OUT	Ballyknock Magherafelt SR Outlet	4979075	09/09/2024 16:05	Taste	Diln No	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4979075	09/09/2024 16:05	Taste - Nature		No taste	
V1349OUT	Ballyknock Magherafelt SR Outlet	4979075	09/09/2024 16:05	Total - Residual disinfectant	mg Cl/l	0.43	
V1349OUT	Ballyknock Magherafelt SR Outlet	4979075	09/09/2024 16:05	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4979073	09/09/2024 16:20	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4979073	09/09/2024 16:20	Free - Residual disinfectant	mg Cl/l	0.33	
V1350OUT	Carnaman SR Outlet	4979073	09/09/2024 16:20	Odour	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4979073	09/09/2024 16:20	Odour - Nature		No odour	
V1350OUT	Carnaman SR Outlet	4979073	09/09/2024 16:20	Taste	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4979073	09/09/2024 16:20	Taste - Nature		No taste	
V1350OUT	Carnaman SR Outlet	4979073	09/09/2024 16:20	Total - Residual disinfectant	mg Cl/l	0.52	
V1350OUT	Carnaman SR Outlet	4979073	09/09/2024 16:20	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4968164	10/09/2024 07:35	Colony Counts 22	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4968164	10/09/2024 07:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4968164	10/09/2024 07:35	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4968164	10/09/2024 07:35	Free - Residual disinfectant	mg Cl/l	0.29	
V1354OUT	Knockoneill SR Outlet	4968164	10/09/2024 07:35	Total - Residual disinfectant	mg Cl/l	0.37	
V1354OUT	Knockoneill SR Outlet	4968164	10/09/2024 07:35	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4968164	10/09/2024 07:35	Odour	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4968164	10/09/2024 07:35	Odour - Nature		No odour	
V1354OUT	Knockoneill SR Outlet	4968164	10/09/2024 07:35	Taste	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4968164	10/09/2024 07:35	Taste - Nature		No taste	
V1358OUT	Slaughtneil SR Outlet	4968166	10/09/2024 07:55	Colony Counts 22	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4968166	10/09/2024 07:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4968166	10/09/2024 07:55	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4968166	10/09/2024 07:55	Free - Residual disinfectant	mg Cl/l	0.68	
V1358OUT	Slaughtneil SR Outlet	4968166	10/09/2024 07:55	Total - Residual disinfectant	mg Cl/l	0.77	
V1358OUT	Slaughtneil SR Outlet	4968166	10/09/2024 07:55	Total Coliforms	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4968166	10/09/2024 07:55	Odour	Diln No	0	0
V1358OUT	Slaughtneil SR Outlet	4968166	10/09/2024 07:55	Odour - Nature		No odour	
V1358OUT	Slaughtneil SR Outlet	4968166	10/09/2024 07:55	Taste	Diln No	0	0
V1358OUT	Slaughtneil SR Outlet	4968166	10/09/2024 07:55	Taste - Nature		No taste	
V1711OUT	Sconce Hill SR Outlet	4967713	10/09/2024 08:34	Colony Counts 22	CFU/1 ml	0	
V1711OUT	Sconce Hill SR Outlet	4967713	10/09/2024 08:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1711OUT	Sconce Hill SR Outlet	4967713	10/09/2024 08:34	E. coli	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4967713	10/09/2024 08:34	Free - Residual disinfectant	mg Cl/l	0.36	
V1711OUT	Sconce Hill SR Outlet	4967713	10/09/2024 08:34	Total - Residual disinfectant	mg Cl/l	0.45	
V1711OUT	Sconce Hill SR Outlet	4967713	10/09/2024 08:34	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4968350	10/09/2024 08:40	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4968350	10/09/2024 08:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	

V1356OUT	Mormeal SR Outlet	4968350	10/09/2024 08:40	E. coli	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4968350	10/09/2024 08:40	Free - Residual disinfectant	mg Cl/l	0.11	
V1356OUT	Mormeal SR Outlet	4968350	10/09/2024 08:40	Total - Residual disinfectant	mg Cl/l	0.3	
V1356OUT	Mormeal SR Outlet	4968350	10/09/2024 08:40	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4968350	10/09/2024 08:40	Odour	Diln No	0	0
V1356OUT	Mormeal SR Outlet	4968350	10/09/2024 08:40	Odour - Nature		No odour	
V1356OUT	Mormeal SR Outlet	4968350	10/09/2024 08:40	Taste	Diln No	0	0
V1356OUT	Mormeal SR Outlet	4968350	10/09/2024 08:40	Taste - Nature		No taste	
V1704OUT	Castlerock Downhill SR Outlet	4967712	10/09/2024 08:49	Colony Counts 22	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4967712	10/09/2024 08:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4967712	10/09/2024 08:49	E. coli	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4967712	10/09/2024 08:49	Free - Residual disinfectant	mg Cl/l	0.4	
V1704OUT	Castlerock Downhill SR Outlet	4967712	10/09/2024 08:49	Total - Residual disinfectant	mg Cl/l	0.54	
V1704OUT	Castlerock Downhill SR Outlet	4967712	10/09/2024 08:49	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4967712	10/09/2024 08:49	Odour	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4967712	10/09/2024 08:49	Odour - Nature		No odour	
V1704OUT	Castlerock Downhill SR Outlet	4967712	10/09/2024 08:49	Taste	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4967712	10/09/2024 08:49	Taste - Nature		No taste	
V1338OUT	Coagh SR Outlet	4967720	10/09/2024 09:25	Colony Counts 22	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4967720	10/09/2024 09:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4967720	10/09/2024 09:25	E. coli	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4967720	10/09/2024 09:25	Free - Residual disinfectant	mg Cl/l	0.32	
V1338OUT	Coagh SR Outlet	4967720	10/09/2024 09:25	Total - Residual disinfectant	mg Cl/l	0.4	
V1338OUT	Coagh SR Outlet	4967720	10/09/2024 09:25	Total Coliforms	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4967728	10/09/2024 09:25	Colony Counts 22	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4967728	10/09/2024 09:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4967728	10/09/2024 09:25	E. coli	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4967728	10/09/2024 09:25	Free - Residual disinfectant	mg Cl/l	0.82	
V4713OUT	Knocknalosset SR Outlet	4967728	10/09/2024 09:25	Total - Residual disinfectant	mg Cl/l	0.9	
V4713OUT	Knocknalosset SR Outlet	4967728	10/09/2024 09:25	Total Coliforms	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4967681	10/09/2024 09:29	Colony Counts 22	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4967681	10/09/2024 09:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4967681	10/09/2024 09:29	E. coli	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4967681	10/09/2024 09:29	Free - Residual disinfectant	mg Cl/l	0.67	
V2511OUT	Corran Armagh SR Outlet	4967681	10/09/2024 09:29	Total - Residual disinfectant	mg Cl/l	0.96	
V2511OUT	Corran Armagh SR Outlet	4967681	10/09/2024 09:29	Total Coliforms	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4967724	10/09/2024 09:39	Colony Counts 22	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4967724	10/09/2024 09:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4967724	10/09/2024 09:39	E. coli	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4967724	10/09/2024 09:39	Free - Residual disinfectant	mg Cl/l	0.74	

V4712OUT	Corranny SR Outlet	4967724	10/09/2024 09:39	Total - Residual disinfectant	mg Cl/l	0.82	
V4712OUT	Corranny SR Outlet	4967724	10/09/2024 09:39	Total Coliforms	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4967719	10/09/2024 09:43	Colony Counts 22	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4967719	10/09/2024 09:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4967719	10/09/2024 09:43	E. coli	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4967719	10/09/2024 09:43	Free - Residual disinfectant	mg Cl/l	0.45	
V1335OUT	Brigh Quarry SR Outlet	4967719	10/09/2024 09:43	Total - Residual disinfectant	mg Cl/l	0.49	
V1335OUT	Brigh Quarry SR Outlet	4967719	10/09/2024 09:43	Total Coliforms	CFU/100 ml	0	0
V1361OUT	Money more Tamnadoey SR Outlet	4979043	10/09/2024 09:46	Colony Counts 22	CFU/1 ml	0	
V1361OUT	Money more Tamnadoey SR Outlet	4979043	10/09/2024 09:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1361OUT	Money more Tamnadoey SR Outlet	4979043	10/09/2024 09:46	E. coli	CFU/100 ml	0	0
V1361OUT	Money more Tamnadoey SR Outlet	4979043	10/09/2024 09:46	Free - Residual disinfectant	mg Cl/l	0.36	
V1361OUT	Money more Tamnadoey SR Outlet	4979043	10/09/2024 09:46	Odour	Diln No	0	0
V1361OUT	Money more Tamnadoey SR Outlet	4979043	10/09/2024 09:46	Odour - Nature		No odour	
V1361OUT	Money more Tamnadoey SR Outlet	4979043	10/09/2024 09:46	Taste	Diln No	0	0
V1361OUT	Money more Tamnadoey SR Outlet	4979043	10/09/2024 09:46	Taste - Nature		No taste	
V1361OUT	Money more Tamnadoey SR Outlet	4979043	10/09/2024 09:46	Total - Residual disinfectant	mg Cl/l	0.5	
V1361OUT	Money more Tamnadoey SR Outlet	4979043	10/09/2024 09:46	Total Coliforms	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4967680	10/09/2024 09:59	Colony Counts 22	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4967680	10/09/2024 09:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4967680	10/09/2024 09:59	E. coli	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4967680	10/09/2024 09:59	Free - Residual disinfectant	mg Cl/l	0.24	
V2510OUT	Calone SR Outlet	4967680	10/09/2024 09:59	Total - Residual disinfectant	mg Cl/l	0.46	
V2510OUT	Calone SR Outlet	4967680	10/09/2024 09:59	Total Coliforms	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4967723	10/09/2024 10:00	Colony Counts 22	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4967723	10/09/2024 10:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4967723	10/09/2024 10:00	E. coli	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4967723	10/09/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.45	
V1342OUT	Dromore High SR Outlet	4967723	10/09/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.53	
V1342OUT	Dromore High SR Outlet	4967723	10/09/2024 10:00	Total Coliforms	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4967367	10/09/2024 10:03	Colony Counts 22	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4967367	10/09/2024 10:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4967367	10/09/2024 10:03	E. coli	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4967367	10/09/2024 10:03	Free - Residual disinfectant	mg Cl/l	0.62	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4967367	10/09/2024 10:03	Total - Residual disinfectant	mg Cl/l	0.75	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4967367	10/09/2024 10:03	Total Coliforms	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4967687	10/09/2024 10:15	Colony Counts 22	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4967687	10/09/2024 10:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4967687	10/09/2024 10:15	E. coli	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4967687	10/09/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.62	

V2514OUT	Edenaveys Command SR Outlet	4967687	10/09/2024 10:15	Total - Residual disinfectant	mg Cl/l	1	
V2514OUT	Edenaveys Command SR Outlet	4967687	10/09/2024 10:15	Total Coliforms	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4967689	10/09/2024 10:23	Colony Counts 22	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4967689	10/09/2024 10:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4967689	10/09/2024 10:23	E. coli	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4967689	10/09/2024 10:23	Free - Residual disinfectant	mg Cl/l	0.66	
V2518OUT	Lisnastrane SR Outlet	4967689	10/09/2024 10:23	Total - Residual disinfectant	mg Cl/l	0.76	
V2518OUT	Lisnastrane SR Outlet	4967689	10/09/2024 10:23	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4967951	10/09/2024 10:23	Colony Counts 22	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4967951	10/09/2024 10:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4967951	10/09/2024 10:23	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4967951	10/09/2024 10:23	Free - Residual disinfectant	mg Cl/l	0.43	
V1360OUT	Windmill Hill SR Outlet	4967951	10/09/2024 10:23	Total - Residual disinfectant	mg Cl/l	0.63	
V1360OUT	Windmill Hill SR Outlet	4967951	10/09/2024 10:23	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4967951	10/09/2024 10:23	Odour	Diln No	0	0
V1360OUT	Windmill Hill SR Outlet	4967951	10/09/2024 10:23	Odour - Nature		No odour	
V1360OUT	Windmill Hill SR Outlet	4967951	10/09/2024 10:23	Taste	Diln No	0	0
V1360OUT	Windmill Hill SR Outlet	4967951	10/09/2024 10:23	Taste - Nature		No taste	
V2523OUT	Rough Fort SR Outlet	4967677	10/09/2024 10:37	Colony Counts 22	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4967677	10/09/2024 10:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4967677	10/09/2024 10:37	E. coli	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4967677	10/09/2024 10:37	Free - Residual disinfectant	mg Cl/l	0.88	
V2523OUT	Rough Fort SR Outlet	4967677	10/09/2024 10:37	Total - Residual disinfectant	mg Cl/l	1.15	
V2523OUT	Rough Fort SR Outlet	4967677	10/09/2024 10:37	Total Coliforms	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4967716	10/09/2024 10:41	Colony Counts 22	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4967716	10/09/2024 10:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4967716	10/09/2024 10:41	E. coli	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4967716	10/09/2024 10:41	Free - Residual disinfectant	mg Cl/l	0.43	
V4533OUT	Inisclan SR Outlet	4967716	10/09/2024 10:41	Total - Residual disinfectant	mg Cl/l	0.61	
V4533OUT	Inisclan SR Outlet	4967716	10/09/2024 10:41	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4967962	11/09/2024 08:08	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4967962	11/09/2024 08:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4967962	11/09/2024 08:08	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4967962	11/09/2024 08:08	Free - Residual disinfectant	mg Cl/l	0.75	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4967962	11/09/2024 08:08	Total - Residual disinfectant	mg Cl/l	0.91	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4967962	11/09/2024 08:08	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4967962	11/09/2024 08:08	Odour	Diln No	6	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4967962	11/09/2024 08:08	Odour - Nature		Earthy	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4967962	11/09/2024 08:08	Taste	Diln No	6	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4967962	11/09/2024 08:08	Taste - Nature		Earthy	

V1362OUT	Unagh SR Outlet	4967953	11/09/2024 09:10	Colony Counts 22	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4967953	11/09/2024 09:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4967953	11/09/2024 09:10	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4967953	11/09/2024 09:10	Free - Residual disinfectant	mg Cl/l	0.49	
V1362OUT	Unagh SR Outlet	4967953	11/09/2024 09:10	Total - Residual disinfectant	mg Cl/l	0.58	
V1362OUT	Unagh SR Outlet	4967953	11/09/2024 09:10	Total Coliforms	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4967953	11/09/2024 09:10	Odour	Diln No	0	0
V1362OUT	Unagh SR Outlet	4967953	11/09/2024 09:10	Odour - Nature		No odour	
V1362OUT	Unagh SR Outlet	4967953	11/09/2024 09:10	Taste	Diln No	0	0
V1362OUT	Unagh SR Outlet	4967953	11/09/2024 09:10	Taste - Nature		No taste	
V1344OUT	Craigs Cookstown SR Outlet	4967966	11/09/2024 09:32	Colony Counts 22	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4967966	11/09/2024 09:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4967966	11/09/2024 09:32	E. coli	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4967966	11/09/2024 09:32	Free - Residual disinfectant	mg Cl/l	0.46	
V1344OUT	Craigs Cookstown SR Outlet	4967966	11/09/2024 09:32	Total - Residual disinfectant	mg Cl/l	0.54	
V1344OUT	Craigs Cookstown SR Outlet	4967966	11/09/2024 09:32	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4968345	11/09/2024 09:48	Colony Counts 22	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4968345	11/09/2024 09:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4968345	11/09/2024 09:48	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4968345	11/09/2024 09:48	Free - Residual disinfectant	mg Cl/l	0.38	
V1348OUT	Moydamlaght Draperstown SR Outlet	4968345	11/09/2024 09:48	Total - Residual disinfectant	mg Cl/l	0.4	
V1348OUT	Moydamlaght Draperstown SR Outlet	4968345	11/09/2024 09:48	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4968345	11/09/2024 09:48	Odour	Diln No	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4968345	11/09/2024 09:48	Odour - Nature		No odour	
V1348OUT	Moydamlaght Draperstown SR Outlet	4968345	11/09/2024 09:48	Taste	Diln No	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4968345	11/09/2024 09:48	Taste - Nature		No taste	
V1339OUT	Corvanaghan High SR Outlet	4967963	11/09/2024 09:55	Colony Counts 22	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4967963	11/09/2024 09:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4967963	11/09/2024 09:55	E. coli	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4967963	11/09/2024 09:55	Free - Residual disinfectant	mg Cl/l	0.52	
V1339OUT	Corvanaghan High SR Outlet	4967963	11/09/2024 09:55	Total - Residual disinfectant	mg Cl/l	0.61	
V1339OUT	Corvanaghan High SR Outlet	4967963	11/09/2024 09:55	Total Coliforms	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4967932	11/09/2024 09:59	Colony Counts 22	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4967932	11/09/2024 09:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4967932	11/09/2024 09:59	E. coli	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4967932	11/09/2024 09:59	Free - Residual disinfectant	mg Cl/l	0.26	
V4539OUT	Erganagh SR Outlet	4967932	11/09/2024 09:59	Total - Residual disinfectant	mg Cl/l	0.4	
V4539OUT	Erganagh SR Outlet	4967932	11/09/2024 09:59	Total Coliforms	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4967964	11/09/2024 10:14	Colony Counts 22	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4967964	11/09/2024 10:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	

V1340OUT	Craigballyharkey SR Outlet	4967964	11/09/2024 10:14	E. coli	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4967964	11/09/2024 10:14	Free - Residual disinfectant	mg Cl/l	0.56	
V1340OUT	Craigballyharkey SR Outlet	4967964	11/09/2024 10:14	Total - Residual disinfectant	mg Cl/l	0.65	
V1340OUT	Craigballyharkey SR Outlet	4967964	11/09/2024 10:14	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4968158	11/09/2024 10:20	Colony Counts 22	CFU/1 ml	66	
V1349OUT	Ballyknock Magherafelt SR Outlet	4968158	11/09/2024 10:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4968158	11/09/2024 10:20	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4968158	11/09/2024 10:20	Free - Residual disinfectant	mg Cl/l	0.38	
V1349OUT	Ballyknock Magherafelt SR Outlet	4968158	11/09/2024 10:20	Total - Residual disinfectant	mg Cl/l	0.4	
V1349OUT	Ballyknock Magherafelt SR Outlet	4968158	11/09/2024 10:20	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4968158	11/09/2024 10:20	Odour	Diln No	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4968158	11/09/2024 10:20	Odour - Nature		No odour	
V1349OUT	Ballyknock Magherafelt SR Outlet	4968158	11/09/2024 10:20	Taste	Diln No	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4968158	11/09/2024 10:20	Taste - Nature		No taste	
V1346OUT	Gortaclady Evishanoran SR Outlet	4967967	11/09/2024 10:49	Colony Counts 22	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4967967	11/09/2024 10:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4967967	11/09/2024 10:49	E. coli	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4967967	11/09/2024 10:49	Free - Residual disinfectant	mg Cl/l	0.51	
V1346OUT	Gortaclady Evishanoran SR Outlet	4967967	11/09/2024 10:49	Total - Residual disinfectant	mg Cl/l	0.59	
V1346OUT	Gortaclady Evishanoran SR Outlet	4967967	11/09/2024 10:49	Total Coliforms	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4967928	11/09/2024 10:49	Colony Counts 22	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4967928	11/09/2024 10:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4967928	11/09/2024 10:49	E. coli	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4967928	11/09/2024 10:49	Free - Residual disinfectant	mg Cl/l	0.4	
V4538OUT	Killyclogher SR Outlet	4967928	11/09/2024 10:49	Total - Residual disinfectant	mg Cl/l	0.51	
V4538OUT	Killyclogher SR Outlet	4967928	11/09/2024 10:49	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4967958	11/09/2024 10:57	Colony Counts 22	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4967958	11/09/2024 10:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4967958	11/09/2024 10:57	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4967958	11/09/2024 10:57	Free - Residual disinfectant	mg Cl/l	0.28	
V1350OUT	Carnaman SR Outlet	4967958	11/09/2024 10:57	Total - Residual disinfectant	mg Cl/l	0.29	
V1350OUT	Carnaman SR Outlet	4967958	11/09/2024 10:57	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4967958	11/09/2024 10:57	Odour	Diln No	7	0
V1350OUT	Carnaman SR Outlet	4967958	11/09/2024 10:57	Odour - Nature		Earthy	
V1350OUT	Carnaman SR Outlet	4967958	11/09/2024 10:57	Taste	Diln No	7	0
V1350OUT	Carnaman SR Outlet	4967958	11/09/2024 10:57	Taste - Nature		Earthy	
V4536OUT	Lough Macrory North SR Outlet	4967939	11/09/2024 11:28	Colony Counts 22	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4967939	11/09/2024 11:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4967939	11/09/2024 11:28	E. coli	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4967939	11/09/2024 11:28	Free - Residual disinfectant	mg Cl/l	0.69	

V4536OUT	Lough Macrory North SR Outlet	4967939	11/09/2024 11:28	Total - Residual disinfectant	mg Cl/l	0.8	
V4536OUT	Lough Macrory North SR Outlet	4967939	11/09/2024 11:28	Total Coliforms	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4967927	11/09/2024 11:45	Colony Counts 22	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4967927	11/09/2024 11:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4967927	11/09/2024 11:45	E. coli	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4967927	11/09/2024 11:45	Free - Residual disinfectant	mg Cl/l	0.29	
V4526OUT	Black Lough Pomeroy SR Outlet	4967927	11/09/2024 11:45	Total - Residual disinfectant	mg Cl/l	0.35	
V4526OUT	Black Lough Pomeroy SR Outlet	4967927	11/09/2024 11:45	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4979983	12/09/2024 07:36	Colony Counts 22	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4979983	12/09/2024 07:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4979983	12/09/2024 07:36	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4979983	12/09/2024 07:36	Free - Residual disinfectant	mg Cl/l	0.47	
V1360OUT	Windmill Hill SR Outlet	4979983	12/09/2024 07:36	Odour	Diln No	0	0
V1360OUT	Windmill Hill SR Outlet	4979983	12/09/2024 07:36	Odour - Nature		No odour	
V1360OUT	Windmill Hill SR Outlet	4979983	12/09/2024 07:36	Taste	Diln No	0	0
V1360OUT	Windmill Hill SR Outlet	4979983	12/09/2024 07:36	Taste - Nature		No taste	
V1360OUT	Windmill Hill SR Outlet	4979983	12/09/2024 07:36	Total - Residual disinfectant	mg Cl/l	0.93	
V1360OUT	Windmill Hill SR Outlet	4979983	12/09/2024 07:36	Total Coliforms	CFU/100 ml	0	0
V1361OUT	Money more Tamnadoey SR Outlet	4979984	12/09/2024 08:05	Colony Counts 22	CFU/1 ml	0	
V1361OUT	Money more Tamnadoey SR Outlet	4979984	12/09/2024 08:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1361OUT	Money more Tamnadoey SR Outlet	4979984	12/09/2024 08:05	Colour	mg/l Pt/Co	<4.56	20
V1361OUT	Money more Tamnadoey SR Outlet	4979984	12/09/2024 08:05	Conductivity	uS/cm 20 C	380	2500
V1361OUT	Money more Tamnadoey SR Outlet	4979984	12/09/2024 08:05	E. coli	CFU/100 ml	0	0
V1361OUT	Money more Tamnadoey SR Outlet	4979984	12/09/2024 08:05	Free - Residual disinfectant	mg Cl/l	0.44	
V1361OUT	Money more Tamnadoey SR Outlet	4979984	12/09/2024 08:05	Hydrogen Ion	pH value	7.7	9.5
V1361OUT	Money more Tamnadoey SR Outlet	4979984	12/09/2024 08:05	Odour	Diln No	0	0
V1361OUT	Money more Tamnadoey SR Outlet	4979984	12/09/2024 08:05	Odour - Nature		No odour	
V1361OUT	Money more Tamnadoey SR Outlet	4979984	12/09/2024 08:05	Taste	Diln No	0	0
V1361OUT	Money more Tamnadoey SR Outlet	4979984	12/09/2024 08:05	Taste - Nature		No taste	
V1361OUT	Money more Tamnadoey SR Outlet	4979984	12/09/2024 08:05	Total - Residual disinfectant	mg Cl/l	0.6	
V1361OUT	Money more Tamnadoey SR Outlet	4979984	12/09/2024 08:05	Total Coliforms	CFU/100 ml	0	0
V1361OUT	Money more Tamnadoey SR Outlet	4979984	12/09/2024 08:05	Turbidity	NTU	<0.09	4
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4968169	12/09/2024 08:36	Colony Counts 22	CFU/1 ml	1	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4968169	12/09/2024 08:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4968169	12/09/2024 08:36	E. coli	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4968169	12/09/2024 08:36	Free - Residual disinfectant	mg Cl/l	0.22	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4968169	12/09/2024 08:36	Total - Residual disinfectant	mg Cl/l	0.27	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4968169	12/09/2024 08:36	Total Coliforms	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4968136	12/09/2024 08:53	Colony Counts 22	CFU/1 ml	79	
V4527OUT	Carryglass SR Outlet	4968136	12/09/2024 08:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	

V4527OUT	Carryglass SR Outlet	4968136	12/09/2024 08:53	E. coli	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4968136	12/09/2024 08:53	Free - Residual disinfectant	mg Cl/l	0.21	
V4527OUT	Carryglass SR Outlet	4968136	12/09/2024 08:53	Total - Residual disinfectant	mg Cl/l	0.37	
V4527OUT	Carryglass SR Outlet	4968136	12/09/2024 08:53	Total Coliforms	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4968141	12/09/2024 08:56	Colony Counts 22	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4968141	12/09/2024 08:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4968141	12/09/2024 08:56	E. coli	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4968141	12/09/2024 08:56	Free - Residual disinfectant	mg Cl/l	0.95	
V2501OUT	Altmore River SR Outlet	4968141	12/09/2024 08:56	Total - Residual disinfectant	mg Cl/l	1.07	
V2501OUT	Altmore River SR Outlet	4968141	12/09/2024 08:56	Total Coliforms	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4968131	12/09/2024 09:01	Colony Counts 22	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4968131	12/09/2024 09:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4968131	12/09/2024 09:01	E. coli	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4968131	12/09/2024 09:01	Free - Residual disinfectant	mg Cl/l	0.69	
V4707OUT	Sidaire SR Outlet	4968131	12/09/2024 09:01	Total - Residual disinfectant	mg Cl/l	0.91	
V4707OUT	Sidaire SR Outlet	4968131	12/09/2024 09:01	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4968118	12/09/2024 09:12	Colony Counts 22	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4968118	12/09/2024 09:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4968118	12/09/2024 09:12	E. coli	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4968118	12/09/2024 09:12	Free - Residual disinfectant	mg Cl/l	0.58	
V1725OUT	Glenlough SR Outlet	4968118	12/09/2024 09:12	Total - Residual disinfectant	mg Cl/l	0.66	
V1725OUT	Glenlough SR Outlet	4968118	12/09/2024 09:12	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4968118	12/09/2024 09:12	Odour	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4968118	12/09/2024 09:12	Odour - Nature		No odour	
V1725OUT	Glenlough SR Outlet	4968118	12/09/2024 09:12	Taste	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4968118	12/09/2024 09:12	Taste - Nature		No taste	
V2507OUT	Cappagh SR Outlet	4968117	12/09/2024 09:13	Colony Counts 22	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4968117	12/09/2024 09:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4968117	12/09/2024 09:13	E. coli	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4968117	12/09/2024 09:13	Free - Residual disinfectant	mg Cl/l	0.65	
V2507OUT	Cappagh SR Outlet	4968117	12/09/2024 09:13	Total - Residual disinfectant	mg Cl/l	0.7	
V2507OUT	Cappagh SR Outlet	4968117	12/09/2024 09:13	Total Coliforms	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4968116	12/09/2024 09:37	Colony Counts 22	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4968116	12/09/2024 09:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4968116	12/09/2024 09:37	E. coli	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4968116	12/09/2024 09:37	Free - Residual disinfectant	mg Cl/l	0.72	
V2505OUT	Cabragh Fasglashagh SR Outlet	4968116	12/09/2024 09:37	Total - Residual disinfectant	mg Cl/l	0.82	
V2505OUT	Cabragh Fasglashagh SR Outlet	4968116	12/09/2024 09:37	Total Coliforms	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4968170	12/09/2024 10:15	Colony Counts 22	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4968170	12/09/2024 10:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	

V4708OUT	Cavanacross Enniskillen SR Outlet	4968170	12/09/2024 10:15	E. coli	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4968170	12/09/2024 10:15	Free - Residual disinfectant	mg Cl/l	1.11	
V4708OUT	Cavanacross Enniskillen SR Outlet	4968170	12/09/2024 10:15	Total - Residual disinfectant	mg Cl/l	1.23	
V4708OUT	Cavanacross Enniskillen SR Outlet	4968170	12/09/2024 10:15	Total Coliforms	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4968173	12/09/2024 10:32	Colony Counts 22	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4968173	12/09/2024 10:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4968173	12/09/2024 10:32	E. coli	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4968173	12/09/2024 10:32	Free - Residual disinfectant	mg Cl/l	0.34	
V4530OUT	Dungoran SR Outlet	4968173	12/09/2024 10:32	Total - Residual disinfectant	mg Cl/l	0.41	
V4530OUT	Dungoran SR Outlet	4968173	12/09/2024 10:32	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4979982	12/09/2024 10:37	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4979982	12/09/2024 10:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4979982	12/09/2024 10:37	Colour	mg/l Pt/Co	<4.56	20
V1356OUT	Mormeal SR Outlet	4979982	12/09/2024 10:37	Conductivity	uS/cm 20 C	350	2500
V1356OUT	Mormeal SR Outlet	4979982	12/09/2024 10:37	E. coli	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4979982	12/09/2024 10:37	Free - Residual disinfectant	mg Cl/l	0.21	
V1356OUT	Mormeal SR Outlet	4979982	12/09/2024 10:37	Hydrogen Ion	pH value	7.6	9.5
V1356OUT	Mormeal SR Outlet	4979982	12/09/2024 10:37	Odour	Diln No	0	0
V1356OUT	Mormeal SR Outlet	4979982	12/09/2024 10:37	Odour - Nature		No odour	
V1356OUT	Mormeal SR Outlet	4979982	12/09/2024 10:37	Taste	Diln No	0	0
V1356OUT	Mormeal SR Outlet	4979982	12/09/2024 10:37	Taste - Nature		No taste	
V1356OUT	Mormeal SR Outlet	4979982	12/09/2024 10:37	Total - Residual disinfectant	mg Cl/l	0.45	
V1356OUT	Mormeal SR Outlet	4979982	12/09/2024 10:37	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4979982	12/09/2024 10:37	Turbidity	NTU	<0.09	4
V4535OUT	Lisnagardy SR Outlet	4968165	12/09/2024 10:46	Colony Counts 22	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4968165	12/09/2024 10:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4968165	12/09/2024 10:46	E. coli	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4968165	12/09/2024 10:46	Free - Residual disinfectant	mg Cl/l	0.42	
V4535OUT	Lisnagardy SR Outlet	4968165	12/09/2024 10:46	Total - Residual disinfectant	mg Cl/l	0.51	
V4535OUT	Lisnagardy SR Outlet	4968165	12/09/2024 10:46	Total Coliforms	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4979998	12/09/2024 12:28	Colony Counts 22	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4979998	12/09/2024 12:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4979998	12/09/2024 12:28	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4979998	12/09/2024 12:28	Free - Residual disinfectant	mg Cl/l	0.61	
V1358OUT	Slaughtneil SR Outlet	4979998	12/09/2024 12:28	Odour	Diln No	0	0
V1358OUT	Slaughtneil SR Outlet	4979998	12/09/2024 12:28	Odour - Nature		No odour	
V1358OUT	Slaughtneil SR Outlet	4979998	12/09/2024 12:28	Taste	Diln No	0	0
V1358OUT	Slaughtneil SR Outlet	4979998	12/09/2024 12:28	Taste - Nature		No taste	
V1358OUT	Slaughtneil SR Outlet	4979998	12/09/2024 12:28	Total - Residual disinfectant	mg Cl/l	0.83	
V1358OUT	Slaughtneil SR Outlet	4979998	12/09/2024 12:28	Total Coliforms	CFU/100 ml	0	0

V1354OUT	Knockoneill SR Outlet	4979981	12/09/2024 12:58	Colony Counts 22	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4979981	12/09/2024 12:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4979981	12/09/2024 12:58	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4979981	12/09/2024 12:58	Free - Residual disinfectant	mg Cl/l	0.23	
V1354OUT	Knockoneill SR Outlet	4979981	12/09/2024 12:58	Odour	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4979981	12/09/2024 12:58	Odour - Nature		No odour	
V1354OUT	Knockoneill SR Outlet	4979981	12/09/2024 12:58	Taste	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4979981	12/09/2024 12:58	Taste - Nature		No taste	
V1354OUT	Knockoneill SR Outlet	4979981	12/09/2024 12:58	Total - Residual disinfectant	mg Cl/l	0.33	
V1354OUT	Knockoneill SR Outlet	4979981	12/09/2024 12:58	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979986	13/09/2024 07:14	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979986	13/09/2024 07:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979986	13/09/2024 07:14	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979986	13/09/2024 07:14	Free - Residual disinfectant	mg Cl/l	0.42	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979986	13/09/2024 07:14	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979986	13/09/2024 07:14	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979986	13/09/2024 07:14	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979986	13/09/2024 07:14	Taste - Nature		No taste	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979986	13/09/2024 07:14	Total - Residual disinfectant	mg Cl/l	1.02	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4979986	13/09/2024 07:14	Total Coliforms	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4979985	13/09/2024 09:17	Colony Counts 22	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4979985	13/09/2024 09:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4979985	13/09/2024 09:17	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4979985	13/09/2024 09:17	Free - Residual disinfectant	mg Cl/l	0.36	
V1362OUT	Unagh SR Outlet	4979985	13/09/2024 09:17	Odour	Diln No	0	0
V1362OUT	Unagh SR Outlet	4979985	13/09/2024 09:17	Odour - Nature		No odour	
V1362OUT	Unagh SR Outlet	4979985	13/09/2024 09:17	Taste	Diln No	0	0
V1362OUT	Unagh SR Outlet	4979985	13/09/2024 09:17	Taste - Nature		No taste	
V1362OUT	Unagh SR Outlet	4979985	13/09/2024 09:17	Total - Residual disinfectant	mg Cl/l	0.45	
V1362OUT	Unagh SR Outlet	4979985	13/09/2024 09:17	Total Coliforms	CFU/100 ml	0	0
V1361OUT	Money more Tamnadoey SR Outlet	4980669	13/09/2024 09:35	Colony Counts 22	CFU/1 ml	0	
V1361OUT	Money more Tamnadoey SR Outlet	4980669	13/09/2024 09:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1361OUT	Money more Tamnadoey SR Outlet	4980669	13/09/2024 09:35	E. coli	CFU/100 ml	0	0
V1361OUT	Money more Tamnadoey SR Outlet	4980669	13/09/2024 09:35	Free - Residual disinfectant	mg Cl/l	0.37	
V1361OUT	Money more Tamnadoey SR Outlet	4980669	13/09/2024 09:35	Odour	Diln No	0	0
V1361OUT	Money more Tamnadoey SR Outlet	4980669	13/09/2024 09:35	Odour - Nature		No odour	
V1361OUT	Money more Tamnadoey SR Outlet	4980669	13/09/2024 09:35	Taste	Diln No	0	0
V1361OUT	Money more Tamnadoey SR Outlet	4980669	13/09/2024 09:35	Taste - Nature		No taste	
V1361OUT	Money more Tamnadoey SR Outlet	4980669	13/09/2024 09:35	Total - Residual disinfectant	mg Cl/l	0.46	
V1361OUT	Money more Tamnadoey SR Outlet	4980669	13/09/2024 09:35	Total Coliforms	CFU/100 ml	0	0

V4719OUT	Glenchuil SR Outlet	4968163	13/09/2024 10:18	Colony Counts 22	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4968163	13/09/2024 10:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4968163	13/09/2024 10:18	E. coli	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4968163	13/09/2024 10:18	Free - Residual disinfectant	mg Cl/l	0.65	
V4719OUT	Glenchuil SR Outlet	4968163	13/09/2024 10:18	Total - Residual disinfectant	mg Cl/l	0.71	
V4719OUT	Glenchuil SR Outlet	4968163	13/09/2024 10:18	Total Coliforms	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4968332	13/09/2024 10:26	Colony Counts 22	CFU/1 ml	1	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4968332	13/09/2024 10:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4968332	13/09/2024 10:26	E. coli	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4968332	13/09/2024 10:26	Free - Residual disinfectant	mg Cl/l	0.98	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4968332	13/09/2024 10:26	Total - Residual disinfectant	mg Cl/l	1.05	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4968332	13/09/2024 10:26	Total Coliforms	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4968323	13/09/2024 10:38	Colony Counts 22	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4968323	13/09/2024 10:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4968323	13/09/2024 10:38	E. coli	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4968323	13/09/2024 10:38	Free - Residual disinfectant	mg Cl/l	0.33	
V4540OUT	Radergan SR Outlet	4968323	13/09/2024 10:38	Total - Residual disinfectant	mg Cl/l	0.41	
V4540OUT	Radergan SR Outlet	4968323	13/09/2024 10:38	Total Coliforms	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4968348	13/09/2024 10:52	Colony Counts 22	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4968348	13/09/2024 10:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4968348	13/09/2024 10:52	E. coli	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4968348	13/09/2024 10:52	Free - Residual disinfectant	mg Cl/l	0.39	
V4531OUT	Foremass SR Outlet	4968348	13/09/2024 10:52	Total - Residual disinfectant	mg Cl/l	0.47	
V4531OUT	Foremass SR Outlet	4968348	13/09/2024 10:52	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4968307	13/09/2024 10:59	Colony Counts 22	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4968307	13/09/2024 10:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4968307	13/09/2024 10:59	E. coli	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4968307	13/09/2024 10:59	Free - Residual disinfectant	mg Cl/l	0.85	
V2301OUT	Ballydougan Command SR Outlet	4968307	13/09/2024 10:59	Total - Residual disinfectant	mg Cl/l	0.99	
V2301OUT	Ballydougan Command SR Outlet	4968307	13/09/2024 10:59	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4968307	13/09/2024 10:59	Odour	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4968307	13/09/2024 10:59	Odour - Nature		No odour	
V2301OUT	Ballydougan Command SR Outlet	4968307	13/09/2024 10:59	Taste	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4968307	13/09/2024 10:59	Taste - Nature		No taste	
V4537OUT	Sixmilecross SR Outlet	4968351	13/09/2024 11:08	Colony Counts 22	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4968351	13/09/2024 11:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4968351	13/09/2024 11:08	E. coli	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4968351	13/09/2024 11:08	Free - Residual disinfectant	mg Cl/l	0.49	
V4537OUT	Sixmilecross SR Outlet	4968351	13/09/2024 11:08	Total - Residual disinfectant	mg Cl/l	0.56	
V4537OUT	Sixmilecross SR Outlet	4968351	13/09/2024 11:08	Total Coliforms	CFU/100 ml	0	0

V2302OUT	Ballyhannon SR Outlet	4968308	13/09/2024 11:16	Colony Counts 22	CFU/1 ml	240	
V2302OUT	Ballyhannon SR Outlet	4968308	13/09/2024 11:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4968308	13/09/2024 11:16	E. coli	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4968308	13/09/2024 11:16	Free - Residual disinfectant	mg Cl/l	0.53	
V2302OUT	Ballyhannon SR Outlet	4968308	13/09/2024 11:16	Total - Residual disinfectant	mg Cl/l	0.58	
V2302OUT	Ballyhannon SR Outlet	4968308	13/09/2024 11:16	Total Coliforms	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4968355	13/09/2024 11:23	Colony Counts 22	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4968355	13/09/2024 11:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4968355	13/09/2024 11:23	E. coli	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4968355	13/09/2024 11:23	Free - Residual disinfectant	mg Cl/l	0.23	
V4528OUT	Crocknabohil SR Outlet	4968355	13/09/2024 11:23	Total - Residual disinfectant	mg Cl/l	0.31	
V4528OUT	Crocknabohil SR Outlet	4968355	13/09/2024 11:23	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4979987	13/09/2024 11:30	Colony Counts 22	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4979987	13/09/2024 11:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4979987	13/09/2024 11:30	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4979987	13/09/2024 11:30	Free - Residual disinfectant	mg Cl/l	0.35	
V1348OUT	Moydamlaght Draperstown SR Outlet	4979987	13/09/2024 11:30	Odour	Diln No	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4979987	13/09/2024 11:30	Odour - Nature		No odour	
V1348OUT	Moydamlaght Draperstown SR Outlet	4979987	13/09/2024 11:30	Taste	Diln No	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4979987	13/09/2024 11:30	Taste - Nature		No taste	
V1348OUT	Moydamlaght Draperstown SR Outlet	4979987	13/09/2024 11:30	Total - Residual disinfectant	mg Cl/l	0.45	
V1348OUT	Moydamlaght Draperstown SR Outlet	4979987	13/09/2024 11:30	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4979988	13/09/2024 12:01	Colony Counts 22	CFU/1 ml	40	
V1349OUT	Ballyknock Magherafelt SR Outlet	4979988	13/09/2024 12:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4979988	13/09/2024 12:01	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4979988	13/09/2024 12:01	Free - Residual disinfectant	mg Cl/l	0.36	
V1349OUT	Ballyknock Magherafelt SR Outlet	4979988	13/09/2024 12:01	Odour	Diln No	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4979988	13/09/2024 12:01	Odour - Nature		No odour	
V1349OUT	Ballyknock Magherafelt SR Outlet	4979988	13/09/2024 12:01	Taste	Diln No	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4979988	13/09/2024 12:01	Taste - Nature		No taste	
V1349OUT	Ballyknock Magherafelt SR Outlet	4979988	13/09/2024 12:01	Total - Residual disinfectant	mg Cl/l	0.5	
V1349OUT	Ballyknock Magherafelt SR Outlet	4979988	13/09/2024 12:01	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4979989	13/09/2024 12:42	Colony Counts 22	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4979989	13/09/2024 12:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4979989	13/09/2024 12:42	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4979989	13/09/2024 12:42	Free - Residual disinfectant	mg Cl/l	0.36	
V1350OUT	Carnaman SR Outlet	4979989	13/09/2024 12:42	Odour	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4979989	13/09/2024 12:42	Odour - Nature		No odour	
V1350OUT	Carnaman SR Outlet	4979989	13/09/2024 12:42	Taste	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4979989	13/09/2024 12:42	Taste - Nature		No taste	

V1350OUT	Carnaman SR Outlet	4979989	13/09/2024 12:42	Total - Residual disinfectant	mg Cl/l	0.44	
V1350OUT	Carnaman SR Outlet	4979989	13/09/2024 12:42	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4980491	14/09/2024 08:35	Colony Counts 22	CFU/1 ml	1	
V1360OUT	Windmill Hill SR Outlet	4980491	14/09/2024 08:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4980491	14/09/2024 08:35	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4980491	14/09/2024 08:35	Free - Residual disinfectant	mg Cl/l	0.5	
V1360OUT	Windmill Hill SR Outlet	4980491	14/09/2024 08:35	Odour	Diln No	0	0
V1360OUT	Windmill Hill SR Outlet	4980491	14/09/2024 08:35	Odour - Nature		No odour	
V1360OUT	Windmill Hill SR Outlet	4980491	14/09/2024 08:35	Taste	Diln No	0	0
V1360OUT	Windmill Hill SR Outlet	4980491	14/09/2024 08:35	Taste - Nature		No taste	
V1360OUT	Windmill Hill SR Outlet	4980491	14/09/2024 08:35	Total - Residual disinfectant	mg Cl/l	0.7	
V1360OUT	Windmill Hill SR Outlet	4980491	14/09/2024 08:35	Total Coliforms	CFU/100 ml	0	0
V1361OUT	Money more Tamnadoey SR Outlet	4980492	14/09/2024 08:57	Colony Counts 22	CFU/1 ml	0	
V1361OUT	Money more Tamnadoey SR Outlet	4980492	14/09/2024 08:57	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V1361OUT	Money more Tamnadoey SR Outlet	4980492	14/09/2024 08:57	E. coli	CFU/100 ml	0	0
V1361OUT	Money more Tamnadoey SR Outlet	4980492	14/09/2024 08:57	Free - Residual disinfectant	mg Cl/l	0.4	
V1361OUT	Money more Tamnadoey SR Outlet	4980492	14/09/2024 08:57	Odour	Diln No	0	0
V1361OUT	Money more Tamnadoey SR Outlet	4980492	14/09/2024 08:57	Odour - Nature		No odour	
V1361OUT	Money more Tamnadoey SR Outlet	4980492	14/09/2024 08:57	Taste	Diln No	0	0
V1361OUT	Money more Tamnadoey SR Outlet	4980492	14/09/2024 08:57	Taste - Nature		No taste	
V1361OUT	Money more Tamnadoey SR Outlet	4980492	14/09/2024 08:57	Total - Residual disinfectant	mg Cl/l	0.59	
V1361OUT	Money more Tamnadoey SR Outlet	4980492	14/09/2024 08:57	Total Coliforms	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4980490	14/09/2024 11:01	Colony Counts 22	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4980490	14/09/2024 11:01	Colony Counts 37 (48hrs)	CFU/1 ml	14	
V1358OUT	Slaughtneil SR Outlet	4980490	14/09/2024 11:01	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4980490	14/09/2024 11:01	Free - Residual disinfectant	mg Cl/l	0.66	
V1358OUT	Slaughtneil SR Outlet	4980490	14/09/2024 11:01	Odour	Diln No	0	0
V1358OUT	Slaughtneil SR Outlet	4980490	14/09/2024 11:01	Odour - Nature		No odour	
V1358OUT	Slaughtneil SR Outlet	4980490	14/09/2024 11:01	Taste	Diln No	0	0
V1358OUT	Slaughtneil SR Outlet	4980490	14/09/2024 11:01	Taste - Nature		No taste	
V1358OUT	Slaughtneil SR Outlet	4980490	14/09/2024 11:01	Total - Residual disinfectant	mg Cl/l	0.85	
V1358OUT	Slaughtneil SR Outlet	4980490	14/09/2024 11:01	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4980488	14/09/2024 11:18	Colony Counts 22	CFU/1 ml	3	
V1354OUT	Knockoneill SR Outlet	4980488	14/09/2024 11:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4980488	14/09/2024 11:18	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4980488	14/09/2024 11:18	Free - Residual disinfectant	mg Cl/l	0.31	
V1354OUT	Knockoneill SR Outlet	4980488	14/09/2024 11:18	Odour	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4980488	14/09/2024 11:18	Odour - Nature		No odour	
V1354OUT	Knockoneill SR Outlet	4980488	14/09/2024 11:18	Taste	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4980488	14/09/2024 11:18	Taste - Nature		No taste	

V1354OUT	Knockoneill SR Outlet	4980488	14/09/2024 11:18	Total - Residual disinfectant	mg Cl/l	0.45	
V1354OUT	Knockoneill SR Outlet	4980488	14/09/2024 11:18	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4980494	15/09/2024 08:40	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4980494	15/09/2024 08:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4980494	15/09/2024 08:40	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4980494	15/09/2024 08:40	Free - Residual disinfectant	mg Cl/l	0.95	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4980494	15/09/2024 08:40	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4980494	15/09/2024 08:40	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4980494	15/09/2024 08:40	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4980494	15/09/2024 08:40	Taste - Nature		No taste	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4980494	15/09/2024 08:40	Total - Residual disinfectant	mg Cl/l	1.03	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4980494	15/09/2024 08:40	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4980497	15/09/2024 09:13	Colony Counts 22	CFU/1 ml	9	
V1350OUT	Carnaman SR Outlet	4980497	15/09/2024 09:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4980497	15/09/2024 09:13	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4980497	15/09/2024 09:13	Free - Residual disinfectant	mg Cl/l	0.46	
V1350OUT	Carnaman SR Outlet	4980497	15/09/2024 09:13	Odour	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4980497	15/09/2024 09:13	Odour - Nature		No odour	
V1350OUT	Carnaman SR Outlet	4980497	15/09/2024 09:13	Taste	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4980497	15/09/2024 09:13	Taste - Nature		No taste	
V1350OUT	Carnaman SR Outlet	4980497	15/09/2024 09:13	Total - Residual disinfectant	mg Cl/l	0.58	
V1350OUT	Carnaman SR Outlet	4980497	15/09/2024 09:13	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4980496	15/09/2024 09:39	Colony Counts 22	CFU/1 ml	100	
V1349OUT	Ballyknock Magherafelt SR Outlet	4980496	15/09/2024 09:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4980496	15/09/2024 09:39	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4980496	15/09/2024 09:39	Free - Residual disinfectant	mg Cl/l	0.45	
V1349OUT	Ballyknock Magherafelt SR Outlet	4980496	15/09/2024 09:39	Odour	Diln No	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4980496	15/09/2024 09:39	Odour - Nature		No odour	
V1349OUT	Ballyknock Magherafelt SR Outlet	4980496	15/09/2024 09:39	Taste	Diln No	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4980496	15/09/2024 09:39	Taste - Nature		No taste	
V1349OUT	Ballyknock Magherafelt SR Outlet	4980496	15/09/2024 09:39	Total - Residual disinfectant	mg Cl/l	0.56	
V1349OUT	Ballyknock Magherafelt SR Outlet	4980496	15/09/2024 09:39	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4980495	15/09/2024 10:04	Colony Counts 22	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4980495	15/09/2024 10:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4980495	15/09/2024 10:04	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4980495	15/09/2024 10:04	Free - Residual disinfectant	mg Cl/l	0.41	
V1348OUT	Moydamlaght Draperstown SR Outlet	4980495	15/09/2024 10:04	Odour	Diln No	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4980495	15/09/2024 10:04	Odour - Nature		No odour	
V1348OUT	Moydamlaght Draperstown SR Outlet	4980495	15/09/2024 10:04	Taste	Diln No	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4980495	15/09/2024 10:04	Taste - Nature		No taste	

V1348OUT	Moydamlaght Draperstown SR Outlet	4980495	15/09/2024 10:04	Total - Residual disinfectant	mg Cl/l	0.57	
V1348OUT	Moydamlaght Draperstown SR Outlet	4980495	15/09/2024 10:04	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4980489	15/09/2024 10:30	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4980489	15/09/2024 10:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4980489	15/09/2024 10:30	E. coli	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4980489	15/09/2024 10:30	Free - Residual disinfectant	mg Cl/l	0.06	
V1356OUT	Mormeal SR Outlet	4980489	15/09/2024 10:30	Odour	Diln No	0	0
V1356OUT	Mormeal SR Outlet	4980489	15/09/2024 10:30	Odour - Nature		No odour	
V1356OUT	Mormeal SR Outlet	4980489	15/09/2024 10:30	Taste	Diln No	0	0
V1356OUT	Mormeal SR Outlet	4980489	15/09/2024 10:30	Taste - Nature		No taste	
V1356OUT	Mormeal SR Outlet	4980489	15/09/2024 10:30	Total - Residual disinfectant	mg Cl/l	0.11	
V1356OUT	Mormeal SR Outlet	4980489	15/09/2024 10:30	Total Coliforms	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4980493	15/09/2024 11:25	Colony Counts 22	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4980493	15/09/2024 11:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4980493	15/09/2024 11:25	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4980493	15/09/2024 11:25	Free - Residual disinfectant	mg Cl/l	0.43	
V1362OUT	Unagh SR Outlet	4980493	15/09/2024 11:25	Odour	Diln No	0	0
V1362OUT	Unagh SR Outlet	4980493	15/09/2024 11:25	Odour - Nature		No odour	
V1362OUT	Unagh SR Outlet	4980493	15/09/2024 11:25	Taste	Diln No	0	0
V1362OUT	Unagh SR Outlet	4980493	15/09/2024 11:25	Taste - Nature		No taste	
V1362OUT	Unagh SR Outlet	4980493	15/09/2024 11:25	Total - Residual disinfectant	mg Cl/l	0.53	
V1362OUT	Unagh SR Outlet	4980493	15/09/2024 11:25	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4971610	16/09/2024 07:20	Colony Counts 22	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4971610	16/09/2024 07:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4971610	16/09/2024 07:20	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4971610	16/09/2024 07:20	Free - Residual disinfectant	mg Cl/l	0.36	
V1354OUT	Knockoneill SR Outlet	4971610	16/09/2024 07:20	Total - Residual disinfectant	mg Cl/l	0.53	
V1354OUT	Knockoneill SR Outlet	4971610	16/09/2024 07:20	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4971610	16/09/2024 07:20	Odour	Diln No	10	0
V1354OUT	Knockoneill SR Outlet	4971610	16/09/2024 07:20	Odour - Nature		Musty/Earthy	
V1354OUT	Knockoneill SR Outlet	4971610	16/09/2024 07:20	Taste	Diln No	10	0
V1354OUT	Knockoneill SR Outlet	4971610	16/09/2024 07:20	Taste - Nature		Musty/Earthy	
V1358OUT	Slaughtneil SR Outlet	4971612	16/09/2024 07:41	Colony Counts 22	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4971612	16/09/2024 07:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4971612	16/09/2024 07:41	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4971612	16/09/2024 07:41	Free - Residual disinfectant	mg Cl/l	0.56	
V1358OUT	Slaughtneil SR Outlet	4971612	16/09/2024 07:41	Total - Residual disinfectant	mg Cl/l	0.68	
V1358OUT	Slaughtneil SR Outlet	4971612	16/09/2024 07:41	Total Coliforms	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4971612	16/09/2024 07:41	Odour	Diln No	10	0
V1358OUT	Slaughtneil SR Outlet	4971612	16/09/2024 07:41	Odour - Nature		Musty/Earthy	

V1358OUT	Slaughtneil SR Outlet	4971612	16/09/2024 07:41	Taste	Diln No	10	0
V1358OUT	Slaughtneil SR Outlet	4971612	16/09/2024 07:41	Taste - Nature		Musty/Earthy	
V1356OUT	Mormeal SR Outlet	4970745	16/09/2024 08:26	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4970745	16/09/2024 08:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4970745	16/09/2024 08:26	E. coli	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4970745	16/09/2024 08:26	Free - Residual disinfectant	mg Cl/l	0.53	
V1356OUT	Mormeal SR Outlet	4970745	16/09/2024 08:26	Total - Residual disinfectant	mg Cl/l	0.73	
V1356OUT	Mormeal SR Outlet	4970745	16/09/2024 08:26	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4970745	16/09/2024 08:26	Odour	Diln No	7	0
V1356OUT	Mormeal SR Outlet	4970745	16/09/2024 08:26	Odour - Nature		Musty/Earthy	
V1356OUT	Mormeal SR Outlet	4970745	16/09/2024 08:26	Taste	Diln No	0	0
V1356OUT	Mormeal SR Outlet	4970745	16/09/2024 08:26	Taste - Nature		No taste	
V2301OUT	Ballydougan Command SR Outlet	4970709	16/09/2024 08:49	Colony Counts 22	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4970709	16/09/2024 08:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4970709	16/09/2024 08:49	E. coli	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4970709	16/09/2024 08:49	Free - Residual disinfectant	mg Cl/l	0.94	
V2301OUT	Ballydougan Command SR Outlet	4970709	16/09/2024 08:49	Total - Residual disinfectant	mg Cl/l	1.01	
V2301OUT	Ballydougan Command SR Outlet	4970709	16/09/2024 08:49	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4970709	16/09/2024 08:49	Odour	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4970709	16/09/2024 08:49	Odour - Nature		No odour	
V2301OUT	Ballydougan Command SR Outlet	4970709	16/09/2024 08:49	Taste	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4970709	16/09/2024 08:49	Taste - Nature		No taste	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4970727	16/09/2024 09:06	Colony Counts 22	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4970727	16/09/2024 09:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4970727	16/09/2024 09:06	E. coli	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4970727	16/09/2024 09:06	Free - Residual disinfectant	mg Cl/l	0.75	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4970727	16/09/2024 09:06	Total - Residual disinfectant	mg Cl/l	0.91	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4970727	16/09/2024 09:06	Total Coliforms	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4970710	16/09/2024 09:09	Colony Counts 22	CFU/1 ml	18	
V2302OUT	Ballyhannon SR Outlet	4970710	16/09/2024 09:09	Colony Counts 37 (48hrs)	CFU/1 ml	248	
V2302OUT	Ballyhannon SR Outlet	4970710	16/09/2024 09:09	E. coli	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4970710	16/09/2024 09:09	Free - Residual disinfectant	mg Cl/l	0.51	
V2302OUT	Ballyhannon SR Outlet	4970710	16/09/2024 09:09	Total - Residual disinfectant	mg Cl/l	0.61	
V2302OUT	Ballyhannon SR Outlet	4970710	16/09/2024 09:09	Total Coliforms	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4970720	16/09/2024 10:22	Colony Counts 22	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4970720	16/09/2024 10:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4970720	16/09/2024 10:22	E. coli	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4970720	16/09/2024 10:22	Free - Residual disinfectant	mg Cl/l	0.4	
V4540OUT	Radergan SR Outlet	4970720	16/09/2024 10:22	Total - Residual disinfectant	mg Cl/l	0.48	
V4540OUT	Radergan SR Outlet	4970720	16/09/2024 10:22	Total Coliforms	CFU/100 ml	0	0

V1361OUT	Money more Tamnadoey SR Outlet	4971097	16/09/2024 10:34	Colony Counts 22	CFU/1 ml	0	
V1361OUT	Money more Tamnadoey SR Outlet	4971097	16/09/2024 10:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1361OUT	Money more Tamnadoey SR Outlet	4971097	16/09/2024 10:34	E. coli	CFU/100 ml	0	0
V1361OUT	Money more Tamnadoey SR Outlet	4971097	16/09/2024 10:34	Free - Residual disinfectant	mg Cl/l	0.26	
V1361OUT	Money more Tamnadoey SR Outlet	4971097	16/09/2024 10:34	Total - Residual disinfectant	mg Cl/l	0.57	
V1361OUT	Money more Tamnadoey SR Outlet	4971097	16/09/2024 10:34	Total Coliforms	CFU/100 ml	0	0
V1361OUT	Money more Tamnadoey SR Outlet	4971097	16/09/2024 10:34	Odour	Diln No	0	0
V1361OUT	Money more Tamnadoey SR Outlet	4971097	16/09/2024 10:34	Odour - Nature		No odour	
V1361OUT	Money more Tamnadoey SR Outlet	4971097	16/09/2024 10:34	Taste	Diln No	0	0
V1361OUT	Money more Tamnadoey SR Outlet	4971097	16/09/2024 10:34	Taste - Nature		No taste	
V1360OUT	Windmill Hill SR Outlet	4971430	16/09/2024 11:01	Colony Counts 22	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4971430	16/09/2024 11:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4971430	16/09/2024 11:01	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4971430	16/09/2024 11:01	Free - Residual disinfectant	mg Cl/l	0.5	
V1360OUT	Windmill Hill SR Outlet	4971430	16/09/2024 11:01	Total - Residual disinfectant	mg Cl/l	0.66	
V1360OUT	Windmill Hill SR Outlet	4971430	16/09/2024 11:01	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4971430	16/09/2024 11:01	Odour	Diln No	10	0
V1360OUT	Windmill Hill SR Outlet	4971430	16/09/2024 11:01	Odour - Nature		Musty/Earthy	
V1360OUT	Windmill Hill SR Outlet	4971430	16/09/2024 11:01	Taste	Diln No	10	0
V1360OUT	Windmill Hill SR Outlet	4971430	16/09/2024 11:01	Taste - Nature		Musty	
V4531OUT	Foremass SR Outlet	4970743	16/09/2024 11:03	Colony Counts 22	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4970743	16/09/2024 11:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4970743	16/09/2024 11:03	E. coli	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4970743	16/09/2024 11:03	Free - Residual disinfectant	mg Cl/l	0.48	
V4531OUT	Foremass SR Outlet	4970743	16/09/2024 11:03	Total - Residual disinfectant	mg Cl/l	0.57	
V4531OUT	Foremass SR Outlet	4970743	16/09/2024 11:03	Total Coliforms	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4970746	16/09/2024 11:18	Colony Counts 22	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4970746	16/09/2024 11:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4970746	16/09/2024 11:18	E. coli	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4970746	16/09/2024 11:18	Free - Residual disinfectant	mg Cl/l	0.39	
V4537OUT	Sixmilecross SR Outlet	4970746	16/09/2024 11:18	Total - Residual disinfectant	mg Cl/l	0.45	
V4537OUT	Sixmilecross SR Outlet	4970746	16/09/2024 11:18	Total Coliforms	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4970750	16/09/2024 11:35	Colony Counts 22	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4970750	16/09/2024 11:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4970750	16/09/2024 11:35	E. coli	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4970750	16/09/2024 11:35	Free - Residual disinfectant	mg Cl/l	0.26	
V4528OUT	Crocknabohil SR Outlet	4970750	16/09/2024 11:35	Total - Residual disinfectant	mg Cl/l	0.4	
V4528OUT	Crocknabohil SR Outlet	4970750	16/09/2024 11:35	Total Coliforms	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4968161	16/09/2024 12:08	Colony Counts 22	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4968161	16/09/2024 12:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	

V1715OUT	Ballystrone (Calvins) SR Outlet	4968161	16/09/2024 12:08	E. coli	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4968161	16/09/2024 12:08	Free - Residual disinfectant	mg Cl/l	0.28	
V1715OUT	Ballystrone (Calvins) SR Outlet	4968161	16/09/2024 12:08	Total - Residual disinfectant	mg Cl/l	0.37	
V1715OUT	Ballystrone (Calvins) SR Outlet	4968161	16/09/2024 12:08	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4971441	17/09/2024 07:36	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4971441	17/09/2024 07:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4971441	17/09/2024 07:36	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4971441	17/09/2024 07:36	Free - Residual disinfectant	mg Cl/l	0.5	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4971441	17/09/2024 07:36	Total - Residual disinfectant	mg Cl/l	0.63	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4971441	17/09/2024 07:36	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4971441	17/09/2024 07:36	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4971441	17/09/2024 07:36	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4971441	17/09/2024 07:36	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4971441	17/09/2024 07:36	Taste - Nature		No taste	
V1348OUT	Moydamlaght Draperstown SR Outlet	4970740	17/09/2024 08:53	Colony Counts 22	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4970740	17/09/2024 08:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4970740	17/09/2024 08:53	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4970740	17/09/2024 08:53	Free - Residual disinfectant	mg Cl/l	0.49	
V1348OUT	Moydamlaght Draperstown SR Outlet	4970740	17/09/2024 08:53	Total - Residual disinfectant	mg Cl/l	0.66	
V1348OUT	Moydamlaght Draperstown SR Outlet	4970740	17/09/2024 08:53	Total Coliforms	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4971432	17/09/2024 09:40	Colony Counts 22	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4971432	17/09/2024 09:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4971432	17/09/2024 09:40	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4971432	17/09/2024 09:40	Free - Residual disinfectant	mg Cl/l	0.43	
V1362OUT	Unagh SR Outlet	4971432	17/09/2024 09:40	Total - Residual disinfectant	mg Cl/l	0.48	
V1362OUT	Unagh SR Outlet	4971432	17/09/2024 09:40	Total Coliforms	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4971432	17/09/2024 09:40	Odour	Diln No	0	0
V1362OUT	Unagh SR Outlet	4971432	17/09/2024 09:40	Odour - Nature		No odour	
V1362OUT	Unagh SR Outlet	4971432	17/09/2024 09:40	Taste	Diln No	0	0
V1362OUT	Unagh SR Outlet	4971432	17/09/2024 09:40	Taste - Nature		No taste	
V1349OUT	Ballyknock Magherafelt SR Outlet	4971604	17/09/2024 09:40	Colony Counts 22	CFU/1 ml	49	
V1349OUT	Ballyknock Magherafelt SR Outlet	4971604	17/09/2024 09:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4971604	17/09/2024 09:40	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4971604	17/09/2024 09:40	Free - Residual disinfectant	mg Cl/l	0.38	
V1349OUT	Ballyknock Magherafelt SR Outlet	4971604	17/09/2024 09:40	Total - Residual disinfectant	mg Cl/l	0.52	
V1349OUT	Ballyknock Magherafelt SR Outlet	4971604	17/09/2024 09:40	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4971604	17/09/2024 09:40	Odour	Diln No	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4971604	17/09/2024 09:40	Odour - Nature		No odour	
V1349OUT	Ballyknock Magherafelt SR Outlet	4971604	17/09/2024 09:40	Taste	Diln No	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4971604	17/09/2024 09:40	Taste - Nature		No taste	

V1350OUT	Carnaman SR Outlet	4971437	17/09/2024 10:26	Colony Counts 22	CFU/1 ml	4	
V1350OUT	Carnaman SR Outlet	4971437	17/09/2024 10:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4971437	17/09/2024 10:26	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4971437	17/09/2024 10:26	Free - Residual disinfectant	mg Cl/l	0.48	
V1350OUT	Carnaman SR Outlet	4971437	17/09/2024 10:26	Total - Residual disinfectant	mg Cl/l	0.56	
V1350OUT	Carnaman SR Outlet	4971437	17/09/2024 10:26	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4971437	17/09/2024 10:26	Odour	Diln No	10	0
V1350OUT	Carnaman SR Outlet	4971437	17/09/2024 10:26	Odour - Nature		Earthy/Musty	
V1350OUT	Carnaman SR Outlet	4971437	17/09/2024 10:26	Taste	Diln No	10	0
V1350OUT	Carnaman SR Outlet	4971437	17/09/2024 10:26	Taste - Nature		Earthy/Musty	
V2508OUT	Carland SR Outlet	4970969	17/09/2024 10:28	Colony Counts 22	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4970969	17/09/2024 10:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4970969	17/09/2024 10:28	E. coli	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4970969	17/09/2024 10:28	Free - Residual disinfectant	mg Cl/l	1.01	
V2508OUT	Carland SR Outlet	4970969	17/09/2024 10:28	Total - Residual disinfectant	mg Cl/l	1.08	
V2508OUT	Carland SR Outlet	4970969	17/09/2024 10:28	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4970969	17/09/2024 10:28	Odour	Diln No	0	0
V2508OUT	Carland SR Outlet	4970969	17/09/2024 10:28	Odour - Nature		No odour	
V2508OUT	Carland SR Outlet	4970969	17/09/2024 10:28	Taste	Diln No	0	0
V2508OUT	Carland SR Outlet	4970969	17/09/2024 10:28	Taste - Nature		No taste	
V2509OUT	Castlehill Drumcoo SR Outlet	4970970	17/09/2024 10:47	Colony Counts 22	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4970970	17/09/2024 10:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4970970	17/09/2024 10:47	E. coli	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4970970	17/09/2024 10:47	Free - Residual disinfectant	mg Cl/l	0.8	
V2509OUT	Castlehill Drumcoo SR Outlet	4970970	17/09/2024 10:47	Total - Residual disinfectant	mg Cl/l	0.9	
V2509OUT	Castlehill Drumcoo SR Outlet	4970970	17/09/2024 10:47	Total Coliforms	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4970985	17/09/2024 11:02	Colony Counts 22	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4970985	17/09/2024 11:02	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4970985	17/09/2024 11:02	E. coli	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4970985	17/09/2024 11:02	Free - Residual disinfectant	mg Cl/l	0.93	
V2521OUT	Mullaghanagh SR Outlet	4970985	17/09/2024 11:02	Total - Residual disinfectant	mg Cl/l	1.01	
V2521OUT	Mullaghanagh SR Outlet	4970985	17/09/2024 11:02	Total Coliforms	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4971009	17/09/2024 11:19	Colony Counts 22	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4971009	17/09/2024 11:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4971009	17/09/2024 11:19	Free - Residual disinfectant	mg Cl/l	0.53	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4971009	17/09/2024 11:19	Total - Residual disinfectant	mg Cl/l	0.72	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4970999	17/09/2024 11:25	Colony Counts 22	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4970999	17/09/2024 11:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4970999	17/09/2024 11:25	E. coli	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4970999	17/09/2024 11:25	Free - Residual disinfectant	mg Cl/l	0.31	

V2522OUT	Rehaghy Aughnacloy SR Outlet	4970999	17/09/2024 11:25	Total - Residual disinfectant	mg Cl/l	0.41	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4970999	17/09/2024 11:25	Total Coliforms	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4971025	18/09/2024 08:48	Colony Counts 22	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4971025	18/09/2024 08:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4971025	18/09/2024 08:48	E. coli	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4971025	18/09/2024 08:48	Free - Residual disinfectant	mg Cl/l	0.92	
V4715OUT	Brookeborough High SR Outlet	4971025	18/09/2024 08:48	Total - Residual disinfectant	mg Cl/l	1.06	
V4715OUT	Brookeborough High SR Outlet	4971025	18/09/2024 08:48	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4982204	18/09/2024 09:00	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4982204	18/09/2024 09:00	Free - Residual disinfectant	mg Cl/l	0.56	
V1360OUT	Windmill Hill SR Outlet	4982204	18/09/2024 09:00	Odour	Diln No	0	0
V1360OUT	Windmill Hill SR Outlet	4982204	18/09/2024 09:00	Odour - Nature		No odour	
V1360OUT	Windmill Hill SR Outlet	4982204	18/09/2024 09:00	Taste	Diln No	0	0
V1360OUT	Windmill Hill SR Outlet	4982204	18/09/2024 09:00	Taste - Nature		No taste	
V1360OUT	Windmill Hill SR Outlet	4982204	18/09/2024 09:00	Total - Residual disinfectant	mg Cl/l	0.93	
V1360OUT	Windmill Hill SR Outlet	4982204	18/09/2024 09:00	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4981624	18/09/2024 09:05	Colony Counts 22	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4981624	18/09/2024 09:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4981624	18/09/2024 09:05	E. coli	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4981624	18/09/2024 09:05	Free - Residual disinfectant	mg Cl/l	0.92	
V2301OUT	Ballydougan Command SR Outlet	4981624	18/09/2024 09:05	Odour	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4981624	18/09/2024 09:05	Odour - Nature		No odour	
V2301OUT	Ballydougan Command SR Outlet	4981624	18/09/2024 09:05	Taste	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4981624	18/09/2024 09:05	Taste - Nature		No taste	
V2301OUT	Ballydougan Command SR Outlet	4981624	18/09/2024 09:05	Total - Residual disinfectant	mg Cl/l	1.01	
V2301OUT	Ballydougan Command SR Outlet	4981624	18/09/2024 09:05	Total Coliforms	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4971007	18/09/2024 09:10	Colony Counts 22	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4971007	18/09/2024 09:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4971007	18/09/2024 09:10	E. coli	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4971007	18/09/2024 09:10	Free - Residual disinfectant	mg Cl/l	0.97	
V4742OUT	Tattinbar SR Outlet	4971007	18/09/2024 09:10	Total - Residual disinfectant	mg Cl/l	1.04	
V4742OUT	Tattinbar SR Outlet	4971007	18/09/2024 09:10	Total Coliforms	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4971216	18/09/2024 09:14	Colony Counts 22	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4971216	18/09/2024 09:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4971216	18/09/2024 09:14	E. coli	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4971216	18/09/2024 09:14	Free - Residual disinfectant	mg Cl/l	0.76	
V2511OUT	Corran Armagh SR Outlet	4971216	18/09/2024 09:14	Total - Residual disinfectant	mg Cl/l	1.09	
V2511OUT	Corran Armagh SR Outlet	4971216	18/09/2024 09:14	Total Coliforms	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4971266	18/09/2024 09:33	Colony Counts 22	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4971266	18/09/2024 09:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	

V4713OUT	Knocknalosset SR Outlet	4971266	18/09/2024 09:33	E. coli	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4971266	18/09/2024 09:33	Free - Residual disinfectant	mg Cl/l	0.72	
V4713OUT	Knocknalosset SR Outlet	4971266	18/09/2024 09:33	Total - Residual disinfectant	mg Cl/l	0.8	
V4713OUT	Knocknalosset SR Outlet	4971266	18/09/2024 09:33	Total Coliforms	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4971263	18/09/2024 09:48	Colony Counts 22	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4971263	18/09/2024 09:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4971263	18/09/2024 09:48	E. coli	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4971263	18/09/2024 09:48	Free - Residual disinfectant	mg Cl/l	0.47	
V4712OUT	Corranny SR Outlet	4971263	18/09/2024 09:48	Total - Residual disinfectant	mg Cl/l	0.53	
V4712OUT	Corranny SR Outlet	4971263	18/09/2024 09:48	Total Coliforms	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4971258	18/09/2024 10:00	Colony Counts 22	CFU/1 ml	47	
V1338OUT	Coagh SR Outlet	4971258	18/09/2024 10:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4971258	18/09/2024 10:00	E. coli	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4971258	18/09/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.35	
V1338OUT	Coagh SR Outlet	4971258	18/09/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.41	
V1338OUT	Coagh SR Outlet	4971258	18/09/2024 10:00	Total Coliforms	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4971215	18/09/2024 10:01	Colony Counts 22	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4971215	18/09/2024 10:01	Colony Counts 37 (48hrs)	CFU/1 ml	3	
V2510OUT	Calone SR Outlet	4971215	18/09/2024 10:01	E. coli	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4971215	18/09/2024 10:01	Free - Residual disinfectant	mg Cl/l	0.42	
V2510OUT	Calone SR Outlet	4971215	18/09/2024 10:01	Total - Residual disinfectant	mg Cl/l	0.68	
V2510OUT	Calone SR Outlet	4971215	18/09/2024 10:01	Total Coliforms	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4971254	18/09/2024 10:07	Colony Counts 22	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4971254	18/09/2024 10:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4971254	18/09/2024 10:07	E. coli	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4971254	18/09/2024 10:07	Free - Residual disinfectant	mg Cl/l	0.51	
V4533OUT	Inisclan SR Outlet	4971254	18/09/2024 10:07	Total - Residual disinfectant	mg Cl/l	0.65	
V4533OUT	Inisclan SR Outlet	4971254	18/09/2024 10:07	Total Coliforms	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4971010	18/09/2024 10:14	Colony Counts 22	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4971010	18/09/2024 10:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4971010	18/09/2024 10:14	E. coli	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4971010	18/09/2024 10:14	Free - Residual disinfectant	mg Cl/l	0.66	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4971010	18/09/2024 10:14	Total - Residual disinfectant	mg Cl/l	0.73	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4971010	18/09/2024 10:14	Total Coliforms	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4971221	18/09/2024 10:18	Colony Counts 22	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4971221	18/09/2024 10:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4971221	18/09/2024 10:18	E. coli	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4971221	18/09/2024 10:18	Free - Residual disinfectant	mg Cl/l	0.75	
V2514OUT	Edenaveys Command SR Outlet	4971221	18/09/2024 10:18	Total - Residual disinfectant	mg Cl/l	0.99	
V2514OUT	Edenaveys Command SR Outlet	4971221	18/09/2024 10:18	Total Coliforms	CFU/100 ml	0	0

V1335OUT	Brigh Quarry SR Outlet	4971257	18/09/2024 10:20	Colony Counts 22	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4971257	18/09/2024 10:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4971257	18/09/2024 10:20	E. coli	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4971257	18/09/2024 10:20	Free - Residual disinfectant	mg Cl/l	0.59	
V1335OUT	Brigh Quarry SR Outlet	4971257	18/09/2024 10:20	Total - Residual disinfectant	mg Cl/l	0.64	
V1335OUT	Brigh Quarry SR Outlet	4971257	18/09/2024 10:20	Total Coliforms	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4971261	18/09/2024 10:30	Colony Counts 22	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4971261	18/09/2024 10:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4971261	18/09/2024 10:30	E. coli	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4971261	18/09/2024 10:30	Free - Residual disinfectant	mg Cl/l	0.52	
V1342OUT	Dromore High SR Outlet	4971261	18/09/2024 10:30	Total - Residual disinfectant	mg Cl/l	0.58	
V1342OUT	Dromore High SR Outlet	4971261	18/09/2024 10:30	Total Coliforms	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4971212	18/09/2024 10:40	Colony Counts 22	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4971212	18/09/2024 10:40	Colony Counts 37 (48hrs)	CFU/1 ml	3	
V2523OUT	Rough Fort SR Outlet	4971212	18/09/2024 10:40	E. coli	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4971212	18/09/2024 10:40	Free - Residual disinfectant	mg Cl/l	0.78	
V2523OUT	Rough Fort SR Outlet	4971212	18/09/2024 10:40	Total - Residual disinfectant	mg Cl/l	1.02	
V2523OUT	Rough Fort SR Outlet	4971212	18/09/2024 10:40	Total Coliforms	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4971222	18/09/2024 10:50	Colony Counts 22	CFU/1 ml	7	
V2518OUT	Lisnastrane SR Outlet	4971222	18/09/2024 10:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4971222	18/09/2024 10:50	E. coli	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4971222	18/09/2024 10:50	Free - Residual disinfectant	mg Cl/l	0.95	
V2518OUT	Lisnastrane SR Outlet	4971222	18/09/2024 10:50	Total - Residual disinfectant	mg Cl/l	1.01	
V2518OUT	Lisnastrane SR Outlet	4971222	18/09/2024 10:50	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4971250	18/09/2024 11:41	Colony Counts 22	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4971250	18/09/2024 11:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1704OUT	Castlerock Downhill SR Outlet	4971250	18/09/2024 11:41	E. coli	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4971250	18/09/2024 11:41	Free - Residual disinfectant	mg Cl/l	0.31	
V1704OUT	Castlerock Downhill SR Outlet	4971250	18/09/2024 11:41	Total - Residual disinfectant	mg Cl/l	0.37	
V1704OUT	Castlerock Downhill SR Outlet	4971250	18/09/2024 11:41	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4971250	18/09/2024 11:41	Odour	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4971250	18/09/2024 11:41	Odour - Nature		No odour	
V1704OUT	Castlerock Downhill SR Outlet	4971250	18/09/2024 11:41	Taste	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4971250	18/09/2024 11:41	Taste - Nature		No taste	
V1711OUT	Sconce Hill SR Outlet	4971251	18/09/2024 12:04	Colony Counts 22	CFU/1 ml	18	
V1711OUT	Sconce Hill SR Outlet	4971251	18/09/2024 12:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1711OUT	Sconce Hill SR Outlet	4971251	18/09/2024 12:04	E. coli	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4971251	18/09/2024 12:04	Free - Residual disinfectant	mg Cl/l	0.07	
V1711OUT	Sconce Hill SR Outlet	4971251	18/09/2024 12:04	Total - Residual disinfectant	mg Cl/l	0.17	
V1711OUT	Sconce Hill SR Outlet	4971251	18/09/2024 12:04	Total Coliforms	CFU/100 ml	1	0

V1358OUT	Slaughtneil SR Outlet	4982202	18/09/2024 12:15	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4982202	18/09/2024 12:15	Free - Residual disinfectant	mg Cl/l	0.61	
V1358OUT	Slaughtneil SR Outlet	4982202	18/09/2024 12:15	Odour	Diln No	0	0
V1358OUT	Slaughtneil SR Outlet	4982202	18/09/2024 12:15	Odour - Nature		No odour	
V1358OUT	Slaughtneil SR Outlet	4982202	18/09/2024 12:15	Taste	Diln No	0	0
V1358OUT	Slaughtneil SR Outlet	4982202	18/09/2024 12:15	Taste - Nature		No taste	
V1358OUT	Slaughtneil SR Outlet	4982202	18/09/2024 12:15	Total - Residual disinfectant	mg Cl/l	0.77	
V1358OUT	Slaughtneil SR Outlet	4982202	18/09/2024 12:15	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4982201	18/09/2024 13:05	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4982201	18/09/2024 13:05	Free - Residual disinfectant	mg Cl/l	0.3	
V1354OUT	Knockoneill SR Outlet	4982201	18/09/2024 13:05	Odour	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4982201	18/09/2024 13:05	Odour - Nature		No odour	
V1354OUT	Knockoneill SR Outlet	4982201	18/09/2024 13:05	Taste	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4982201	18/09/2024 13:05	Taste - Nature		No taste	
V1354OUT	Knockoneill SR Outlet	4982201	18/09/2024 13:05	Total - Residual disinfectant	mg Cl/l	0.44	
V1354OUT	Knockoneill SR Outlet	4982201	18/09/2024 13:05	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4982037	19/09/2024 08:15	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4982037	19/09/2024 08:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4982037	19/09/2024 08:15	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4982037	19/09/2024 08:15	Free - Residual disinfectant	mg Cl/l	0.85	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4982037	19/09/2024 08:15	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4982037	19/09/2024 08:15	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4982037	19/09/2024 08:15	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4982037	19/09/2024 08:15	Taste - Nature		No taste	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4982037	19/09/2024 08:15	Total - Residual disinfectant	mg Cl/l	1.08	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4982037	19/09/2024 08:15	Total Coliforms	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4971006	19/09/2024 08:19	Colony Counts 22	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4971006	19/09/2024 08:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4971006	19/09/2024 08:19	E. coli	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4971006	19/09/2024 08:19	Free - Residual disinfectant	mg Cl/l	0.58	
V1702OUT	Cam SR Outlet	4971006	19/09/2024 08:19	Total - Residual disinfectant	mg Cl/l	0.89	
V1702OUT	Cam SR Outlet	4971006	19/09/2024 08:19	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4981627	19/09/2024 08:33	Colony Counts 22	CFU/1 ml	1	
V2508OUT	Carland SR Outlet	4981627	19/09/2024 08:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4981627	19/09/2024 08:33	E. coli	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4981627	19/09/2024 08:33	Free - Residual disinfectant	mg Cl/l	0.95	
V2508OUT	Carland SR Outlet	4981627	19/09/2024 08:33	Odour	Diln No	0	0
V2508OUT	Carland SR Outlet	4981627	19/09/2024 08:33	Odour - Nature		No odour	
V2508OUT	Carland SR Outlet	4981627	19/09/2024 08:33	Taste	Diln No	0	0
V2508OUT	Carland SR Outlet	4981627	19/09/2024 08:33	Taste - Nature		No taste	

V2508OUT	Carland SR Outlet	4981627	19/09/2024 08:33	Total - Residual disinfectant	mg Cl/l	1.09	
V2508OUT	Carland SR Outlet	4981627	19/09/2024 08:33	Total Coliforms	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4971012	19/09/2024 08:35	Colony Counts 22	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4971012	19/09/2024 08:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4971012	19/09/2024 08:35	E. coli	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4971012	19/09/2024 08:35	Free - Residual disinfectant	mg Cl/l	0.79	
V1351OUT	Cranny Moneymore SR Outlet	4971012	19/09/2024 08:35	Total - Residual disinfectant	mg Cl/l	0.86	
V1351OUT	Cranny Moneymore SR Outlet	4971012	19/09/2024 08:35	Total Coliforms	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4971000	19/09/2024 08:58	Colony Counts 22	CFU/1 ml	1	
V1352OUT	Cullion Desertmartin SR Outlet	4971000	19/09/2024 08:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4971000	19/09/2024 08:58	E. coli	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4971000	19/09/2024 08:58	Free - Residual disinfectant	mg Cl/l	0.48	
V1352OUT	Cullion Desertmartin SR Outlet	4971000	19/09/2024 08:58	Total - Residual disinfectant	mg Cl/l	0.57	
V1352OUT	Cullion Desertmartin SR Outlet	4971000	19/09/2024 08:58	Total Coliforms	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4971445	19/09/2024 09:08	Colony Counts 22	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4971445	19/09/2024 09:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4971445	19/09/2024 09:08	E. coli	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4971445	19/09/2024 09:08	Free - Residual disinfectant	mg Cl/l	0.58	
V1344OUT	Craigs Cookstown SR Outlet	4971445	19/09/2024 09:08	Total - Residual disinfectant	mg Cl/l	0.62	
V1344OUT	Craigs Cookstown SR Outlet	4971445	19/09/2024 09:08	Total Coliforms	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4971008	19/09/2024 09:09	Colony Counts 22	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4971008	19/09/2024 09:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4971008	19/09/2024 09:09	E. coli	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4971008	19/09/2024 09:09	Free - Residual disinfectant	mg Cl/l	0.37	
V1708OUT	North Garvagh SR Outlet	4971008	19/09/2024 09:09	Total - Residual disinfectant	mg Cl/l	0.51	
V1708OUT	North Garvagh SR Outlet	4971008	19/09/2024 09:09	Total Coliforms	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4971023	19/09/2024 09:19	Colony Counts 22	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4971023	19/09/2024 09:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4971023	19/09/2024 09:19	E. coli	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4971023	19/09/2024 09:19	Free - Residual disinfectant	mg Cl/l	0.85	
V1343OUT	Ballybriest SR Outlet	4971023	19/09/2024 09:19	Total - Residual disinfectant	mg Cl/l	0.91	
V1343OUT	Ballybriest SR Outlet	4971023	19/09/2024 09:19	Total Coliforms	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4982036	19/09/2024 09:23	Colony Counts 22	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4982036	19/09/2024 09:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4982036	19/09/2024 09:23	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4982036	19/09/2024 09:23	Free - Residual disinfectant	mg Cl/l	0.52	
V1362OUT	Unagh SR Outlet	4982036	19/09/2024 09:23	Odour	Diln No	0	0
V1362OUT	Unagh SR Outlet	4982036	19/09/2024 09:23	Odour - Nature		No odour	
V1362OUT	Unagh SR Outlet	4982036	19/09/2024 09:23	Taste	Diln No	0	0
V1362OUT	Unagh SR Outlet	4982036	19/09/2024 09:23	Taste - Nature		No taste	

V1362OUT	Unagh SR Outlet	4982036	19/09/2024 09:23	Total - Residual disinfectant	mg Cl/l	0.56	
V1362OUT	Unagh SR Outlet	4982036	19/09/2024 09:23	Total Coliforms	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4971442	19/09/2024 09:45	Colony Counts 22	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4971442	19/09/2024 09:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4971442	19/09/2024 09:45	E. coli	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4971442	19/09/2024 09:45	Free - Residual disinfectant	mg Cl/l	0.84	
V1339OUT	Corvanaghan High SR Outlet	4971442	19/09/2024 09:45	Total - Residual disinfectant	mg Cl/l	0.9	
V1339OUT	Corvanaghan High SR Outlet	4971442	19/09/2024 09:45	Total Coliforms	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4971443	19/09/2024 09:59	Colony Counts 22	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4971443	19/09/2024 09:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4971443	19/09/2024 09:59	E. coli	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4971443	19/09/2024 09:59	Free - Residual disinfectant	mg Cl/l	0.65	
V1340OUT	Craigballyharkey SR Outlet	4971443	19/09/2024 09:59	Total - Residual disinfectant	mg Cl/l	0.7	
V1340OUT	Craigballyharkey SR Outlet	4971443	19/09/2024 09:59	Total Coliforms	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4971410	19/09/2024 10:00	Colony Counts 22	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4971410	19/09/2024 10:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4971410	19/09/2024 10:00	E. coli	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4971410	19/09/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.26	
V4539OUT	Erganagh SR Outlet	4971410	19/09/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.35	
V4539OUT	Erganagh SR Outlet	4971410	19/09/2024 10:00	Total Coliforms	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4971011	19/09/2024 10:13	Colony Counts 22	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4971011	19/09/2024 10:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4971011	19/09/2024 10:13	E. coli	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4971011	19/09/2024 10:13	Free - Residual disinfectant	mg Cl/l	0.6	
V1713OUT	Trienaltenagh SR Outlet	4971011	19/09/2024 10:13	Total - Residual disinfectant	mg Cl/l	0.82	
V1713OUT	Trienaltenagh SR Outlet	4971011	19/09/2024 10:13	Total Coliforms	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4971446	19/09/2024 10:13	Colony Counts 22	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4971446	19/09/2024 10:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4971446	19/09/2024 10:13	E. coli	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4971446	19/09/2024 10:13	Free - Residual disinfectant	mg Cl/l	0.33	
V1346OUT	Gortaclady Evishanoran SR Outlet	4971446	19/09/2024 10:13	Total - Residual disinfectant	mg Cl/l	0.37	
V1346OUT	Gortaclady Evishanoran SR Outlet	4971446	19/09/2024 10:13	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4982038	19/09/2024 10:29	Colony Counts 22	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4982038	19/09/2024 10:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4982038	19/09/2024 10:29	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4982038	19/09/2024 10:29	Free - Residual disinfectant	mg Cl/l	0.55	
V1348OUT	Moydamlaght Draperstown SR Outlet	4982038	19/09/2024 10:29	Odour	Diln No	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4982038	19/09/2024 10:29	Odour - Nature		No odour	
V1348OUT	Moydamlaght Draperstown SR Outlet	4982038	19/09/2024 10:29	Taste	Diln No	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4982038	19/09/2024 10:29	Taste - Nature		No taste	

V1348OUT	Moydamlaght Draperstown SR Outlet	4982038	19/09/2024 10:29	Total - Residual disinfectant	mg Cl/l	0.67	
V1348OUT	Moydamlaght Draperstown SR Outlet	4982038	19/09/2024 10:29	Total Coliforms	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4971409	19/09/2024 10:55	Colony Counts 22	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4971409	19/09/2024 10:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4971409	19/09/2024 10:55	E. coli	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4971409	19/09/2024 10:55	Free - Residual disinfectant	mg Cl/l	0.39	
V4538OUT	Killyclogher SR Outlet	4971409	19/09/2024 10:55	Total - Residual disinfectant	mg Cl/l	0.45	
V4538OUT	Killyclogher SR Outlet	4971409	19/09/2024 10:55	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4982039	19/09/2024 11:00	Colony Counts 22	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4982039	19/09/2024 11:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4982039	19/09/2024 11:00	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4982039	19/09/2024 11:00	Free - Residual disinfectant	mg Cl/l	0.37	
V1349OUT	Ballyknock Magherafelt SR Outlet	4982039	19/09/2024 11:00	Odour	Diln No	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4982039	19/09/2024 11:00	Odour - Nature		No odour	
V1349OUT	Ballyknock Magherafelt SR Outlet	4982039	19/09/2024 11:00	Taste	Diln No	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4982039	19/09/2024 11:00	Taste - Nature		No taste	
V1349OUT	Ballyknock Magherafelt SR Outlet	4982039	19/09/2024 11:00	Total - Residual disinfectant	mg Cl/l	0.52	
V1349OUT	Ballyknock Magherafelt SR Outlet	4982039	19/09/2024 11:00	Total Coliforms	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4971418	19/09/2024 11:26	Colony Counts 22	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4971418	19/09/2024 11:26	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4971418	19/09/2024 11:26	E. coli	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4971418	19/09/2024 11:26	Free - Residual disinfectant	mg Cl/l	0.69	
V4536OUT	Lough Macrory North SR Outlet	4971418	19/09/2024 11:26	Total - Residual disinfectant	mg Cl/l	0.75	
V4536OUT	Lough Macrory North SR Outlet	4971418	19/09/2024 11:26	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4982040	19/09/2024 11:34	Colony Counts 22	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4982040	19/09/2024 11:34	Colony Counts 37 (48hrs)	CFU/1 ml	>300	
V1350OUT	Carnaman SR Outlet	4982040	19/09/2024 11:34	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4982040	19/09/2024 11:34	Free - Residual disinfectant	mg Cl/l	0.5	
V1350OUT	Carnaman SR Outlet	4982040	19/09/2024 11:34	Odour	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4982040	19/09/2024 11:34	Odour - Nature		No odour	
V1350OUT	Carnaman SR Outlet	4982040	19/09/2024 11:34	Taste	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4982040	19/09/2024 11:34	Taste - Nature		No taste	
V1350OUT	Carnaman SR Outlet	4982040	19/09/2024 11:34	Total - Residual disinfectant	mg Cl/l	0.83	
V1350OUT	Carnaman SR Outlet	4982040	19/09/2024 11:34	Total Coliforms	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4971408	19/09/2024 11:48	Colony Counts 22	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4971408	19/09/2024 11:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4971408	19/09/2024 11:48	E. coli	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4971408	19/09/2024 11:48	Free - Residual disinfectant	mg Cl/l	0.34	
V4526OUT	Black Lough Pomeroy SR Outlet	4971408	19/09/2024 11:48	Total - Residual disinfectant	mg Cl/l	0.45	
V4526OUT	Black Lough Pomeroy SR Outlet	4971408	19/09/2024 11:48	Total Coliforms	CFU/100 ml	0	0

V1711OUT	Sconce Hill SR Outlet	4983920	19/09/2024 11:55	E. coli	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4983920	19/09/2024 11:55	Free - Residual disinfectant	mg Cl/l	0.24	
V1711OUT	Sconce Hill SR Outlet	4983920	19/09/2024 11:55	Total - Residual disinfectant	mg Cl/l	0.32	
V1711OUT	Sconce Hill SR Outlet	4983920	19/09/2024 11:55	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4983977	19/09/2024 12:12	Aluminium	ug Al/l	17	200
V1725OUT	Glenlough SR Outlet	4983977	19/09/2024 12:12	Iron	ug/l Fe	<1.538	200
V1725OUT	Glenlough SR Outlet	4983977	19/09/2024 12:12	Manganese	ug Mn/l	<0.642	50
V1360OUT	Windmill Hill SR Outlet	4982044	20/09/2024 07:59	Colony Counts 22	CFU/1 ml	6	
V1360OUT	Windmill Hill SR Outlet	4982044	20/09/2024 07:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4982044	20/09/2024 07:59	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4982044	20/09/2024 07:59	Free - Residual disinfectant	mg Cl/l	0.5	
V1360OUT	Windmill Hill SR Outlet	4982044	20/09/2024 07:59	Odour	Diln No	0	0
V1360OUT	Windmill Hill SR Outlet	4982044	20/09/2024 07:59	Odour - Nature		No odour	
V1360OUT	Windmill Hill SR Outlet	4982044	20/09/2024 07:59	Taste	Diln No	0	0
V1360OUT	Windmill Hill SR Outlet	4982044	20/09/2024 07:59	Taste - Nature		No taste	
V1360OUT	Windmill Hill SR Outlet	4982044	20/09/2024 07:59	Total - Residual disinfectant	mg Cl/l	0.68	
V1360OUT	Windmill Hill SR Outlet	4982044	20/09/2024 07:59	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4971562	20/09/2024 09:00	Colony Counts 22	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4971562	20/09/2024 09:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4971562	20/09/2024 09:00	E. coli	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4971562	20/09/2024 09:00	Free - Residual disinfectant	mg Cl/l	0.58	
V1725OUT	Glenlough SR Outlet	4971562	20/09/2024 09:00	Total - Residual disinfectant	mg Cl/l	0.66	
V1725OUT	Glenlough SR Outlet	4971562	20/09/2024 09:00	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4971562	20/09/2024 09:00	Odour	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4971562	20/09/2024 09:00	Odour - Nature		No odour	
V1725OUT	Glenlough SR Outlet	4971562	20/09/2024 09:00	Taste	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4971562	20/09/2024 09:00	Taste - Nature		No taste	
V4527OUT	Carryglass SR Outlet	4971581	20/09/2024 09:15	Colony Counts 22	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4971581	20/09/2024 09:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4971581	20/09/2024 09:15	E. coli	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4971581	20/09/2024 09:15	Free - Residual disinfectant	mg Cl/l	0.22	
V4527OUT	Carryglass SR Outlet	4971581	20/09/2024 09:15	Total - Residual disinfectant	mg Cl/l	0.35	
V4527OUT	Carryglass SR Outlet	4971581	20/09/2024 09:15	Total Coliforms	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4971615	20/09/2024 09:20	Colony Counts 22	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4971615	20/09/2024 09:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4971615	20/09/2024 09:20	E. coli	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4971615	20/09/2024 09:20	Free - Residual disinfectant	mg Cl/l	0.61	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4971615	20/09/2024 09:20	Total - Residual disinfectant	mg Cl/l	0.69	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4971615	20/09/2024 09:20	Total Coliforms	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4971587	20/09/2024 09:42	Colony Counts 22	CFU/1 ml	0	

V2501OUT	Altmore River SR Outlet	4971587	20/09/2024 09:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4971587	20/09/2024 09:42	E. coli	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4971587	20/09/2024 09:42	Free - Residual disinfectant	mg Cl/l	0.87	
V2501OUT	Altmore River SR Outlet	4971587	20/09/2024 09:42	Total - Residual disinfectant	mg Cl/l	0.98	
V2501OUT	Altmore River SR Outlet	4971587	20/09/2024 09:42	Total Coliforms	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4971573	20/09/2024 09:43	Colony Counts 22	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4971573	20/09/2024 09:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4971573	20/09/2024 09:43	E. coli	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4971573	20/09/2024 09:43	Free - Residual disinfectant	mg Cl/l	0.82	
V4707OUT	Sidaire SR Outlet	4971573	20/09/2024 09:43	Total - Residual disinfectant	mg Cl/l	0.94	
V4707OUT	Sidaire SR Outlet	4971573	20/09/2024 09:43	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4982042	20/09/2024 09:51	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4982042	20/09/2024 09:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4982042	20/09/2024 09:51	E. coli	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4982042	20/09/2024 09:51	Free - Residual disinfectant	mg Cl/l	0.37	
V1356OUT	Mormeal SR Outlet	4982042	20/09/2024 09:51	Odour	Diln No	0	0
V1356OUT	Mormeal SR Outlet	4982042	20/09/2024 09:51	Odour - Nature		No odour	
V1356OUT	Mormeal SR Outlet	4982042	20/09/2024 09:51	Taste	Diln No	0	0
V1356OUT	Mormeal SR Outlet	4982042	20/09/2024 09:51	Taste - Nature		No taste	
V1356OUT	Mormeal SR Outlet	4982042	20/09/2024 09:51	Total - Residual disinfectant	mg Cl/l	0.55	
V1356OUT	Mormeal SR Outlet	4982042	20/09/2024 09:51	Total Coliforms	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4971561	20/09/2024 10:14	Colony Counts 22	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4971561	20/09/2024 10:14	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4971561	20/09/2024 10:14	E. coli	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4971561	20/09/2024 10:14	Free - Residual disinfectant	mg Cl/l	0.73	
V2507OUT	Cappagh SR Outlet	4971561	20/09/2024 10:14	Total - Residual disinfectant	mg Cl/l	0.82	
V2507OUT	Cappagh SR Outlet	4971561	20/09/2024 10:14	Total Coliforms	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4971619	20/09/2024 10:15	Colony Counts 22	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4971619	20/09/2024 10:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4971619	20/09/2024 10:15	E. coli	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4971619	20/09/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.33	
V4530OUT	Dungoran SR Outlet	4971619	20/09/2024 10:15	Total - Residual disinfectant	mg Cl/l	0.45	
V4530OUT	Dungoran SR Outlet	4971619	20/09/2024 10:15	Total Coliforms	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4971611	20/09/2024 10:25	Colony Counts 22	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4971611	20/09/2024 10:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4971611	20/09/2024 10:25	E. coli	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4971611	20/09/2024 10:25	Free - Residual disinfectant	mg Cl/l	0.37	
V4535OUT	Lisnagardy SR Outlet	4971611	20/09/2024 10:25	Total - Residual disinfectant	mg Cl/l	0.5	
V4535OUT	Lisnagardy SR Outlet	4971611	20/09/2024 10:25	Total Coliforms	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4971560	20/09/2024 10:34	Colony Counts 22	CFU/1 ml	0	

V2505OUT	Cabragh Fasglashagh SR Outlet	4971560	20/09/2024 10:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4971560	20/09/2024 10:34	E. coli	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4971560	20/09/2024 10:34	Free - Residual disinfectant	mg Cl/l	0.71	
V2505OUT	Cabragh Fasglashagh SR Outlet	4971560	20/09/2024 10:34	Total - Residual disinfectant	mg Cl/l	0.9	
V2505OUT	Cabragh Fasglashagh SR Outlet	4971560	20/09/2024 10:34	Total Coliforms	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4971004	20/09/2024 10:48	Colony Counts 22	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4971004	20/09/2024 10:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4971004	20/09/2024 10:48	E. coli	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4971004	20/09/2024 10:48	Free - Residual disinfectant	mg Cl/l	0.42	
V1706OUT	Killeague SR Outlet	4971004	20/09/2024 10:48	Total - Residual disinfectant	mg Cl/l	0.61	
V1706OUT	Killeague SR Outlet	4971004	20/09/2024 10:48	Total Coliforms	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4971609	20/09/2024 10:49	Colony Counts 22	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4971609	20/09/2024 10:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4971609	20/09/2024 10:49	E. coli	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4971609	20/09/2024 10:49	Free - Residual disinfectant	mg Cl/l	0.6	
V4719OUT	Glenchuil SR Outlet	4971609	20/09/2024 10:49	Total - Residual disinfectant	mg Cl/l	0.65	
V4719OUT	Glenchuil SR Outlet	4971609	20/09/2024 10:49	Total Coliforms	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4982043	20/09/2024 10:55	Colony Counts 22	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4982043	20/09/2024 10:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4982043	20/09/2024 10:55	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4982043	20/09/2024 10:55	Free - Residual disinfectant	mg Cl/l	0.61	
V1358OUT	Slaughtneil SR Outlet	4982043	20/09/2024 10:55	Odour	Diln No	0	0
V1358OUT	Slaughtneil SR Outlet	4982043	20/09/2024 10:55	Odour - Nature		No odour	
V1358OUT	Slaughtneil SR Outlet	4982043	20/09/2024 10:55	Taste	Diln No	0	0
V1358OUT	Slaughtneil SR Outlet	4982043	20/09/2024 10:55	Taste - Nature		No taste	
V1358OUT	Slaughtneil SR Outlet	4982043	20/09/2024 10:55	Total - Residual disinfectant	mg Cl/l	0.78	
V1358OUT	Slaughtneil SR Outlet	4982043	20/09/2024 10:55	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4982041	20/09/2024 11:45	Colony Counts 22	CFU/1 ml	6	
V1354OUT	Knockoneill SR Outlet	4982041	20/09/2024 11:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4982041	20/09/2024 11:45	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4982041	20/09/2024 11:45	Free - Residual disinfectant	mg Cl/l	0.26	
V1354OUT	Knockoneill SR Outlet	4982041	20/09/2024 11:45	Odour	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4982041	20/09/2024 11:45	Odour - Nature		No odour	
V1354OUT	Knockoneill SR Outlet	4982041	20/09/2024 11:45	Taste	Diln No	10	0
V1354OUT	Knockoneill SR Outlet	4982041	20/09/2024 11:45	Taste - Nature		Earthy/Musty	
V1354OUT	Knockoneill SR Outlet	4982041	20/09/2024 11:45	Total - Residual disinfectant	mg Cl/l	0.41	
V1354OUT	Knockoneill SR Outlet	4982041	20/09/2024 11:45	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4981630	20/09/2024 11:46	Colony Counts 22	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4981630	20/09/2024 11:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4981630	20/09/2024 11:46	E. coli	CFU/100 ml	0	0

V2301OUT	Ballydougan Command SR Outlet	4981630	20/09/2024 11:46	Free - Residual disinfectant	mg Cl/l	0.82	
V2301OUT	Ballydougan Command SR Outlet	4981630	20/09/2024 11:46	Odour	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4981630	20/09/2024 11:46	Odour - Nature		No odour	
V2301OUT	Ballydougan Command SR Outlet	4981630	20/09/2024 11:46	Taste	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4981630	20/09/2024 11:46	Taste - Nature		No taste	
V2301OUT	Ballydougan Command SR Outlet	4981630	20/09/2024 11:46	Total - Residual disinfectant	mg Cl/l	0.93	
V2301OUT	Ballydougan Command SR Outlet	4981630	20/09/2024 11:46	Total Coliforms	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4971607	20/09/2024 11:48	Colony Counts 22	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4971607	20/09/2024 11:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4971607	20/09/2024 11:48	E. coli	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4971607	20/09/2024 11:48	Free - Residual disinfectant	mg Cl/l	0.15	
V1715OUT	Ballystrone (Calvins) SR Outlet	4971607	20/09/2024 11:48	Total - Residual disinfectant	mg Cl/l	0.32	
V1715OUT	Ballystrone (Calvins) SR Outlet	4971607	20/09/2024 11:48	Total Coliforms	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4983905	21/09/2024 06:25	Colony Counts 22	CFU/1 ml	38	
V2302OUT	Ballyhannon SR Outlet	4983905	21/09/2024 06:25	Colony Counts 37 (48hrs)	CFU/1 ml	123	
V2302OUT	Ballyhannon SR Outlet	4983905	21/09/2024 06:25	E. coli	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4983905	21/09/2024 06:25	Free - Residual disinfectant	mg Cl/l	0.51	
V2302OUT	Ballyhannon SR Outlet	4983905	21/09/2024 06:25	Odour	Diln No	0	0
V2302OUT	Ballyhannon SR Outlet	4983905	21/09/2024 06:25	Odour - Nature		No odour	
V2302OUT	Ballyhannon SR Outlet	4983905	21/09/2024 06:25	Taste	Diln No	0	0
V2302OUT	Ballyhannon SR Outlet	4983905	21/09/2024 06:25	Taste - Nature		No taste	
V2302OUT	Ballyhannon SR Outlet	4983905	21/09/2024 06:25	Total - Residual disinfectant	mg Cl/l	0.56	
V2302OUT	Ballyhannon SR Outlet	4983905	21/09/2024 06:25	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983873	21/09/2024 08:49	Colony Counts 22	CFU/1 ml	1	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983873	21/09/2024 08:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983873	21/09/2024 08:49	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983873	21/09/2024 08:49	Free - Residual disinfectant	mg Cl/l	0.86	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983873	21/09/2024 08:49	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983873	21/09/2024 08:49	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983873	21/09/2024 08:49	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983873	21/09/2024 08:49	Taste - Nature		No taste	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983873	21/09/2024 08:49	Total - Residual disinfectant	mg Cl/l	1.07	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983873	21/09/2024 08:49	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4983874	21/09/2024 09:28	Colony Counts 22	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4983874	21/09/2024 09:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4983874	21/09/2024 09:28	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4983874	21/09/2024 09:28	Free - Residual disinfectant	mg Cl/l	0.6	
V1348OUT	Moydamlaght Draperstown SR Outlet	4983874	21/09/2024 09:28	Odour	Diln No	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4983874	21/09/2024 09:28	Odour - Nature		No odour	
V1348OUT	Moydamlaght Draperstown SR Outlet	4983874	21/09/2024 09:28	Taste	Diln No	0	0

V1348OUT	Moydamlaght Draperstown SR Outlet	4983874	21/09/2024 09:28	Taste - Nature		No taste	
V1348OUT	Moydamlaght Draperstown SR Outlet	4983874	21/09/2024 09:28	Total - Residual disinfectant	mg Cl/l	0.75	
V1348OUT	Moydamlaght Draperstown SR Outlet	4983874	21/09/2024 09:28	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4983875	21/09/2024 10:13	Colony Counts 22	CFU/1 ml	25	
V1349OUT	Ballyknock Magherafelt SR Outlet	4983875	21/09/2024 10:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4983875	21/09/2024 10:13	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4983875	21/09/2024 10:13	Free - Residual disinfectant	mg Cl/l	0.42	
V1349OUT	Ballyknock Magherafelt SR Outlet	4983875	21/09/2024 10:13	Odour	Diln No	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4983875	21/09/2024 10:13	Odour - Nature		No odour	
V1349OUT	Ballyknock Magherafelt SR Outlet	4983875	21/09/2024 10:13	Taste	Diln No	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4983875	21/09/2024 10:13	Taste - Nature		No taste	
V1349OUT	Ballyknock Magherafelt SR Outlet	4983875	21/09/2024 10:13	Total - Residual disinfectant	mg Cl/l	0.56	
V1349OUT	Ballyknock Magherafelt SR Outlet	4983875	21/09/2024 10:13	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4983876	21/09/2024 10:48	Colony Counts 22	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4983876	21/09/2024 10:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4983876	21/09/2024 10:48	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4983876	21/09/2024 10:48	Free - Residual disinfectant	mg Cl/l	0.47	
V1350OUT	Carnaman SR Outlet	4983876	21/09/2024 10:48	Odour	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4983876	21/09/2024 10:48	Odour - Nature		No odour	
V1350OUT	Carnaman SR Outlet	4983876	21/09/2024 10:48	Taste	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4983876	21/09/2024 10:48	Taste - Nature		No taste	
V1350OUT	Carnaman SR Outlet	4983876	21/09/2024 10:48	Total - Residual disinfectant	mg Cl/l	0.69	
V1350OUT	Carnaman SR Outlet	4983876	21/09/2024 10:48	Total Coliforms	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4983909	22/09/2024 06:50	Colony Counts 22	CFU/1 ml	0	
V2302OUT	Ballyhannon SR Outlet	4983909	22/09/2024 06:50	Colony Counts 37 (48hrs)	CFU/1 ml	209	
V2302OUT	Ballyhannon SR Outlet	4983909	22/09/2024 06:50	E. coli	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4983909	22/09/2024 06:50	Free - Residual disinfectant	mg Cl/l	0.48	
V2302OUT	Ballyhannon SR Outlet	4983909	22/09/2024 06:50	Odour	Diln No	0	0
V2302OUT	Ballyhannon SR Outlet	4983909	22/09/2024 06:50	Odour - Nature		No odour	
V2302OUT	Ballyhannon SR Outlet	4983909	22/09/2024 06:50	Taste	Diln No	0	0
V2302OUT	Ballyhannon SR Outlet	4983909	22/09/2024 06:50	Taste - Nature		No taste	
V2302OUT	Ballyhannon SR Outlet	4983909	22/09/2024 06:50	Total - Residual disinfectant	mg Cl/l	0.53	
V2302OUT	Ballyhannon SR Outlet	4983909	22/09/2024 06:50	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4983880	22/09/2024 08:51	Colony Counts 22	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4983880	22/09/2024 08:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4983880	22/09/2024 08:51	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4983880	22/09/2024 08:51	Free - Residual disinfectant	mg Cl/l	0.51	
V1360OUT	Windmill Hill SR Outlet	4983880	22/09/2024 08:51	Odour	Diln No	0	0
V1360OUT	Windmill Hill SR Outlet	4983880	22/09/2024 08:51	Odour - Nature		No odour	
V1360OUT	Windmill Hill SR Outlet	4983880	22/09/2024 08:51	Taste	Diln No	0	0

V1360OUT	Windmill Hill SR Outlet	4983880	22/09/2024 08:51	Taste - Nature		No taste	
V1360OUT	Windmill Hill SR Outlet	4983880	22/09/2024 08:51	Total - Residual disinfectant	mg Cl/l	0.65	
V1360OUT	Windmill Hill SR Outlet	4983880	22/09/2024 08:51	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4983877	22/09/2024 09:36	Colony Counts 22	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4983877	22/09/2024 09:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4983877	22/09/2024 09:36	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4983877	22/09/2024 09:36	Free - Residual disinfectant	mg Cl/l	0.32	
V1354OUT	Knockoneill SR Outlet	4983877	22/09/2024 09:36	Odour	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4983877	22/09/2024 09:36	Odour - Nature		No odour	
V1354OUT	Knockoneill SR Outlet	4983877	22/09/2024 09:36	Taste	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4983877	22/09/2024 09:36	Taste - Nature		No taste	
V1354OUT	Knockoneill SR Outlet	4983877	22/09/2024 09:36	Total - Residual disinfectant	mg Cl/l	0.51	
V1354OUT	Knockoneill SR Outlet	4983877	22/09/2024 09:36	Total Coliforms	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4983879	22/09/2024 09:58	Colony Counts 22	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4983879	22/09/2024 09:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4983879	22/09/2024 09:58	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4983879	22/09/2024 09:58	Free - Residual disinfectant	mg Cl/l	0.69	
V1358OUT	Slaughtneil SR Outlet	4983879	22/09/2024 09:58	Odour	Diln No	0	0
V1358OUT	Slaughtneil SR Outlet	4983879	22/09/2024 09:58	Odour - Nature		No odour	
V1358OUT	Slaughtneil SR Outlet	4983879	22/09/2024 09:58	Taste	Diln No	0	0
V1358OUT	Slaughtneil SR Outlet	4983879	22/09/2024 09:58	Taste - Nature		No taste	
V1358OUT	Slaughtneil SR Outlet	4983879	22/09/2024 09:58	Total - Residual disinfectant	mg Cl/l	0.81	
V1358OUT	Slaughtneil SR Outlet	4983879	22/09/2024 09:58	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4983878	22/09/2024 10:48	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4983878	22/09/2024 10:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4983878	22/09/2024 10:48	E. coli	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4983878	22/09/2024 10:48	Free - Residual disinfectant	mg Cl/l	0.21	
V1356OUT	Mormeal SR Outlet	4983878	22/09/2024 10:48	Odour	Diln No	0	0
V1356OUT	Mormeal SR Outlet	4983878	22/09/2024 10:48	Odour - Nature		No odour	
V1356OUT	Mormeal SR Outlet	4983878	22/09/2024 10:48	Taste	Diln No	0	0
V1356OUT	Mormeal SR Outlet	4983878	22/09/2024 10:48	Taste - Nature		No taste	
V1356OUT	Mormeal SR Outlet	4983878	22/09/2024 10:48	Total - Residual disinfectant	mg Cl/l	0.31	
V1356OUT	Mormeal SR Outlet	4983878	22/09/2024 10:48	Total Coliforms	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4973267	23/09/2024 00:00	Colony Counts 22	CFU/1 ml	1	
V4527OUT	Carryglass SR Outlet	4973267	23/09/2024 00:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4527OUT	Carryglass SR Outlet	4973267	23/09/2024 00:00	E. coli	CFU/100 ml	0	0
V4527OUT	Carryglass SR Outlet	4973267	23/09/2024 00:00	Free - Residual disinfectant	mg Cl/l	<0.05	
V4527OUT	Carryglass SR Outlet	4973267	23/09/2024 00:00	Total - Residual disinfectant	mg Cl/l	0.09	
V4527OUT	Carryglass SR Outlet	4973267	23/09/2024 00:00	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4973586	23/09/2024 07:24	Colony Counts 22	CFU/1 ml	0	

V2301OUT	Ballydougan Command SR Outlet	4973586	23/09/2024 07:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2301OUT	Ballydougan Command SR Outlet	4973586	23/09/2024 07:24	E. coli	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4973586	23/09/2024 07:24	Free - Residual disinfectant	mg Cl/l	0.89	
V2301OUT	Ballydougan Command SR Outlet	4973586	23/09/2024 07:24	Total - Residual disinfectant	mg Cl/l	0.95	
V2301OUT	Ballydougan Command SR Outlet	4973586	23/09/2024 07:24	Total Coliforms	CFU/100 ml	0	0
V2301OUT	Ballydougan Command SR Outlet	4973586	23/09/2024 07:24	Odour	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4973586	23/09/2024 07:24	Odour - Nature		No odour	
V2301OUT	Ballydougan Command SR Outlet	4973586	23/09/2024 07:24	Taste	Diln No	0	0
V2301OUT	Ballydougan Command SR Outlet	4973586	23/09/2024 07:24	Taste - Nature		No taste	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983882	23/09/2024 08:12	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983882	23/09/2024 08:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983882	23/09/2024 08:12	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983882	23/09/2024 08:12	Free - Residual disinfectant	mg Cl/l	0.8	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983882	23/09/2024 08:12	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983882	23/09/2024 08:12	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983882	23/09/2024 08:12	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983882	23/09/2024 08:12	Taste - Nature		No taste	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983882	23/09/2024 08:12	Total - Residual disinfectant	mg Cl/l	1.15	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983882	23/09/2024 08:12	Total Coliforms	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4973264	23/09/2024 08:57	Colony Counts 22	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4973264	23/09/2024 08:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4707OUT	Sidaire SR Outlet	4973264	23/09/2024 08:57	E. coli	CFU/100 ml	0	0
V4707OUT	Sidaire SR Outlet	4973264	23/09/2024 08:57	Free - Residual disinfectant	mg Cl/l	0.76	
V4707OUT	Sidaire SR Outlet	4973264	23/09/2024 08:57	Total - Residual disinfectant	mg Cl/l	0.85	
V4707OUT	Sidaire SR Outlet	4973264	23/09/2024 08:57	Total Coliforms	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4973298	23/09/2024 09:11	Colony Counts 22	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4973298	23/09/2024 09:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4973298	23/09/2024 09:11	E. coli	CFU/100 ml	0	0
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4973298	23/09/2024 09:11	Free - Residual disinfectant	mg Cl/l	0.42	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4973298	23/09/2024 09:11	Total - Residual disinfectant	mg Cl/l	0.46	
V1363OUT	Pomeroy Cavanakeeran SR Outlet	4973298	23/09/2024 09:11	Total Coliforms	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4973270	23/09/2024 09:32	Colony Counts 22	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4973270	23/09/2024 09:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2501OUT	Altmore River SR Outlet	4973270	23/09/2024 09:32	E. coli	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4973270	23/09/2024 09:32	Free - Residual disinfectant	mg Cl/l	0.89	
V2501OUT	Altmore River SR Outlet	4973270	23/09/2024 09:32	Total - Residual disinfectant	mg Cl/l	1	
V2501OUT	Altmore River SR Outlet	4973270	23/09/2024 09:32	Total Coliforms	CFU/100 ml	0	0
V2501OUT	Altmore River SR Outlet	4973270	23/09/2024 09:32	Odour	Diln No	0	0
V2501OUT	Altmore River SR Outlet	4973270	23/09/2024 09:32	Odour - Nature		No odour	
V2501OUT	Altmore River SR Outlet	4973270	23/09/2024 09:32	Taste	Diln No	10	0

V2501OUT	Altmore River SR Outlet	4973270	23/09/2024 09:32	Taste - Nature		Earthy	
V2507OUT	Cappagh SR Outlet	4973248	23/09/2024 09:43	Colony Counts 22	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4973248	23/09/2024 09:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2507OUT	Cappagh SR Outlet	4973248	23/09/2024 09:43	E. coli	CFU/100 ml	0	0
V2507OUT	Cappagh SR Outlet	4973248	23/09/2024 09:43	Free - Residual disinfectant	mg Cl/l	0.6	
V2507OUT	Cappagh SR Outlet	4973248	23/09/2024 09:43	Total - Residual disinfectant	mg Cl/l	0.65	
V2507OUT	Cappagh SR Outlet	4973248	23/09/2024 09:43	Total Coliforms	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4971616	23/09/2024 09:59	Colony Counts 22	CFU/1 ml	1	
V4708OUT	Cavanacross Enniskillen SR Outlet	4971616	23/09/2024 09:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4971616	23/09/2024 09:59	E. coli	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4971616	23/09/2024 09:59	Free - Residual disinfectant	mg Cl/l	1.17	
V4708OUT	Cavanacross Enniskillen SR Outlet	4971616	23/09/2024 09:59	Total - Residual disinfectant	mg Cl/l	1.32	
V4708OUT	Cavanacross Enniskillen SR Outlet	4971616	23/09/2024 09:59	Total Coliforms	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4973247	23/09/2024 10:00	Colony Counts 22	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4973247	23/09/2024 10:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2505OUT	Cabragh Fasglashagh SR Outlet	4973247	23/09/2024 10:00	E. coli	CFU/100 ml	0	0
V2505OUT	Cabragh Fasglashagh SR Outlet	4973247	23/09/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.8	
V2505OUT	Cabragh Fasglashagh SR Outlet	4973247	23/09/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.84	
V2505OUT	Cabragh Fasglashagh SR Outlet	4973247	23/09/2024 10:00	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4973623	23/09/2024 10:05	Colony Counts 22	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4973623	23/09/2024 10:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4973623	23/09/2024 10:05	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4973623	23/09/2024 10:05	Free - Residual disinfectant	mg Cl/l	0.11	
V1348OUT	Moydamlaght Draperstown SR Outlet	4973623	23/09/2024 10:05	Total - Residual disinfectant	mg Cl/l	0.28	
V1348OUT	Moydamlaght Draperstown SR Outlet	4973623	23/09/2024 10:05	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4973623	23/09/2024 10:05	Odour	Diln No	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4973623	23/09/2024 10:05	Odour - Nature		No odour	
V1348OUT	Moydamlaght Draperstown SR Outlet	4973623	23/09/2024 10:05	Taste	Diln No	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4973623	23/09/2024 10:05	Taste - Nature		No taste	
V1362OUT	Unagh SR Outlet	4983881	23/09/2024 10:36	Colony Counts 22	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4983881	23/09/2024 10:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4983881	23/09/2024 10:36	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4983881	23/09/2024 10:36	Free - Residual disinfectant	mg Cl/l	0.5	
V1362OUT	Unagh SR Outlet	4983881	23/09/2024 10:36	Odour	Diln No	0	0
V1362OUT	Unagh SR Outlet	4983881	23/09/2024 10:36	Odour - Nature		No odour	
V1362OUT	Unagh SR Outlet	4983881	23/09/2024 10:36	Taste	Diln No	0	0
V1362OUT	Unagh SR Outlet	4983881	23/09/2024 10:36	Taste - Nature		No taste	
V1362OUT	Unagh SR Outlet	4983881	23/09/2024 10:36	Total - Residual disinfectant	mg Cl/l	0.58	
V1362OUT	Unagh SR Outlet	4983881	23/09/2024 10:36	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4973250	23/09/2024 10:54	Colony Counts 22	CFU/1 ml	0	

V1725OUT	Glenlough SR Outlet	4973250	23/09/2024 10:54	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1725OUT	Glenlough SR Outlet	4973250	23/09/2024 10:54	E. coli	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4973250	23/09/2024 10:54	Free - Residual disinfectant	mg Cl/l	0.06	
V1725OUT	Glenlough SR Outlet	4973250	23/09/2024 10:54	Total - Residual disinfectant	mg Cl/l	0.16	
V1725OUT	Glenlough SR Outlet	4973250	23/09/2024 10:54	Total Coliforms	CFU/100 ml	0	0
V1725OUT	Glenlough SR Outlet	4973250	23/09/2024 10:54	Odour	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4973250	23/09/2024 10:54	Odour - Nature		No odour	
V1725OUT	Glenlough SR Outlet	4973250	23/09/2024 10:54	Taste	Diln No	0	0
V1725OUT	Glenlough SR Outlet	4973250	23/09/2024 10:54	Taste - Nature		No taste	
V4530OUT	Dungoran SR Outlet	4973302	23/09/2024 11:00	Colony Counts 22	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4973302	23/09/2024 11:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4530OUT	Dungoran SR Outlet	4973302	23/09/2024 11:00	E. coli	CFU/100 ml	0	0
V4530OUT	Dungoran SR Outlet	4973302	23/09/2024 11:00	Free - Residual disinfectant	mg Cl/l	0.4	
V4530OUT	Dungoran SR Outlet	4973302	23/09/2024 11:00	Total - Residual disinfectant	mg Cl/l	0.56	
V4530OUT	Dungoran SR Outlet	4973302	23/09/2024 11:00	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4973287	23/09/2024 11:09	Colony Counts 22	CFU/1 ml	259	
V1349OUT	Ballyknock Magherafelt SR Outlet	4973287	23/09/2024 11:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4973287	23/09/2024 11:09	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4973287	23/09/2024 11:09	Free - Residual disinfectant	mg Cl/l	0.39	
V1349OUT	Ballyknock Magherafelt SR Outlet	4973287	23/09/2024 11:09	Total - Residual disinfectant	mg Cl/l	0.52	
V1349OUT	Ballyknock Magherafelt SR Outlet	4973287	23/09/2024 11:09	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4973287	23/09/2024 11:09	Odour	Diln No	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4973287	23/09/2024 11:09	Odour - Nature		No odour	
V1349OUT	Ballyknock Magherafelt SR Outlet	4973287	23/09/2024 11:09	Taste	Diln No	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4973287	23/09/2024 11:09	Taste - Nature		No taste	
V4535OUT	Lisnagardy SR Outlet	4973294	23/09/2024 11:11	Colony Counts 22	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4973294	23/09/2024 11:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4535OUT	Lisnagardy SR Outlet	4973294	23/09/2024 11:11	E. coli	CFU/100 ml	0	0
V4535OUT	Lisnagardy SR Outlet	4973294	23/09/2024 11:11	Free - Residual disinfectant	mg Cl/l	0.48	
V4535OUT	Lisnagardy SR Outlet	4973294	23/09/2024 11:11	Total - Residual disinfectant	mg Cl/l	0.6	
V4535OUT	Lisnagardy SR Outlet	4973294	23/09/2024 11:11	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4983883	23/09/2024 11:36	Colony Counts 22	CFU/1 ml	4	
V1350OUT	Carnaman SR Outlet	4983883	23/09/2024 11:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4983883	23/09/2024 11:36	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4983883	23/09/2024 11:36	Free - Residual disinfectant	mg Cl/l	0.42	
V1350OUT	Carnaman SR Outlet	4983883	23/09/2024 11:36	Odour	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4983883	23/09/2024 11:36	Odour - Nature		No odour	
V1350OUT	Carnaman SR Outlet	4983883	23/09/2024 11:36	Taste	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4983883	23/09/2024 11:36	Taste - Nature		No taste	
V1350OUT	Carnaman SR Outlet	4983883	23/09/2024 11:36	Total - Residual disinfectant	mg Cl/l	0.58	

V1350OUT	Carnaman SR Outlet	4983883	23/09/2024 11:36	Total Coliforms	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4973290	23/09/2024 12:19	Colony Counts 22	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4973290	23/09/2024 12:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1715OUT	Ballystrone (Calvins) SR Outlet	4973290	23/09/2024 12:19	E. coli	CFU/100 ml	0	0
V1715OUT	Ballystrone (Calvins) SR Outlet	4973290	23/09/2024 12:19	Free - Residual disinfectant	mg Cl/l	0.65	
V1715OUT	Ballystrone (Calvins) SR Outlet	4973290	23/09/2024 12:19	Total - Residual disinfectant	mg Cl/l	0.74	
V1715OUT	Ballystrone (Calvins) SR Outlet	4973290	23/09/2024 12:19	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4983884	24/09/2024 07:51	Colony Counts 22	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4983884	24/09/2024 07:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4983884	24/09/2024 07:51	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4983884	24/09/2024 07:51	Free - Residual disinfectant	mg Cl/l	0.49	
V1360OUT	Windmill Hill SR Outlet	4983884	24/09/2024 07:51	Odour	Diln No	0	0
V1360OUT	Windmill Hill SR Outlet	4983884	24/09/2024 07:51	Odour - Nature		No odour	
V1360OUT	Windmill Hill SR Outlet	4983884	24/09/2024 07:51	Taste	Diln No	0	0
V1360OUT	Windmill Hill SR Outlet	4983884	24/09/2024 07:51	Taste - Nature		No taste	
V1360OUT	Windmill Hill SR Outlet	4983884	24/09/2024 07:51	Total - Residual disinfectant	mg Cl/l	0.7	
V1360OUT	Windmill Hill SR Outlet	4983884	24/09/2024 07:51	Total Coliforms	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4985663	24/09/2024 08:30	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4985663	24/09/2024 08:30	Free - Residual disinfectant	mg Cl/l	0.42	
V1362OUT	Unagh SR Outlet	4985663	24/09/2024 08:30	Odour	Diln No	0	0
V1362OUT	Unagh SR Outlet	4985663	24/09/2024 08:30	Odour - Nature		No odour	
V1362OUT	Unagh SR Outlet	4985663	24/09/2024 08:30	Taste	Diln No	0	0
V1362OUT	Unagh SR Outlet	4985663	24/09/2024 08:30	Taste - Nature		No taste	
V1362OUT	Unagh SR Outlet	4985663	24/09/2024 08:30	Total - Residual disinfectant	mg Cl/l	0.52	
V1362OUT	Unagh SR Outlet	4985663	24/09/2024 08:30	Total Coliforms	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4973610	24/09/2024 09:11	Colony Counts 22	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4973610	24/09/2024 09:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4973610	24/09/2024 09:11	E. coli	CFU/100 ml	0	0
V1365OUT	Lough Fea North (Blacks) SR Outlet	4973610	24/09/2024 09:11	Free - Residual disinfectant	mg Cl/l	0.96	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4973610	24/09/2024 09:11	Total - Residual disinfectant	mg Cl/l	1.05	
V1365OUT	Lough Fea North (Blacks) SR Outlet	4973610	24/09/2024 09:11	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4973628	24/09/2024 10:00	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4973628	24/09/2024 10:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4973628	24/09/2024 10:00	E. coli	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4973628	24/09/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.26	
V1356OUT	Mormeal SR Outlet	4973628	24/09/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.32	
V1356OUT	Mormeal SR Outlet	4973628	24/09/2024 10:00	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4973628	24/09/2024 10:00	Odour	Diln No	0	0
V1356OUT	Mormeal SR Outlet	4973628	24/09/2024 10:00	Odour - Nature		No odour	
V1356OUT	Mormeal SR Outlet	4973628	24/09/2024 10:00	Taste	Diln No	0	0

V1356OUT	Mormeal SR Outlet	4973628	24/09/2024 10:00	Taste - Nature		No taste	
V4528OUT	Crocknabohil SR Outlet	4973633	24/09/2024 10:04	Colony Counts 22	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4973633	24/09/2024 10:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4528OUT	Crocknabohil SR Outlet	4973633	24/09/2024 10:04	E. coli	CFU/100 ml	0	0
V4528OUT	Crocknabohil SR Outlet	4973633	24/09/2024 10:04	Free - Residual disinfectant	mg Cl/l	0.42	
V4528OUT	Crocknabohil SR Outlet	4973633	24/09/2024 10:04	Total - Residual disinfectant	mg Cl/l	0.55	
V4528OUT	Crocknabohil SR Outlet	4973633	24/09/2024 10:04	Total Coliforms	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4973629	24/09/2024 10:20	Colony Counts 22	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4973629	24/09/2024 10:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4537OUT	Sixmilecross SR Outlet	4973629	24/09/2024 10:20	E. coli	CFU/100 ml	0	0
V4537OUT	Sixmilecross SR Outlet	4973629	24/09/2024 10:20	Free - Residual disinfectant	mg Cl/l	0.36	
V4537OUT	Sixmilecross SR Outlet	4973629	24/09/2024 10:20	Total - Residual disinfectant	mg Cl/l	0.44	
V4537OUT	Sixmilecross SR Outlet	4973629	24/09/2024 10:20	Total Coliforms	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4973626	24/09/2024 10:34	Colony Counts 22	CFU/1 ml	0	
V4531OUT	Foremass SR Outlet	4973626	24/09/2024 10:34	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V4531OUT	Foremass SR Outlet	4973626	24/09/2024 10:34	E. coli	CFU/100 ml	0	0
V4531OUT	Foremass SR Outlet	4973626	24/09/2024 10:34	Free - Residual disinfectant	mg Cl/l	0.38	
V4531OUT	Foremass SR Outlet	4973626	24/09/2024 10:34	Total - Residual disinfectant	mg Cl/l	0.45	
V4531OUT	Foremass SR Outlet	4973626	24/09/2024 10:34	Total Coliforms	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4973295	24/09/2024 10:37	Colony Counts 22	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4973295	24/09/2024 10:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4973295	24/09/2024 10:37	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4973295	24/09/2024 10:37	Free - Residual disinfectant	mg Cl/l	0.7	
V1358OUT	Slaughtneil SR Outlet	4973295	24/09/2024 10:37	Total - Residual disinfectant	mg Cl/l	0.88	
V1358OUT	Slaughtneil SR Outlet	4973295	24/09/2024 10:37	Total Coliforms	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4973295	24/09/2024 10:37	Odour	Diln No	0	0
V1358OUT	Slaughtneil SR Outlet	4973295	24/09/2024 10:37	Odour - Nature		No odour	
V1358OUT	Slaughtneil SR Outlet	4973295	24/09/2024 10:37	Taste	Diln No	0	0
V1358OUT	Slaughtneil SR Outlet	4973295	24/09/2024 10:37	Taste - Nature		No taste	
V4540OUT	Radergan SR Outlet	4973601	24/09/2024 10:48	Colony Counts 22	CFU/1 ml	1	
V4540OUT	Radergan SR Outlet	4973601	24/09/2024 10:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4540OUT	Radergan SR Outlet	4973601	24/09/2024 10:48	E. coli	CFU/100 ml	0	0
V4540OUT	Radergan SR Outlet	4973601	24/09/2024 10:48	Free - Residual disinfectant	mg Cl/l	0.45	
V4540OUT	Radergan SR Outlet	4973601	24/09/2024 10:48	Total - Residual disinfectant	mg Cl/l	0.6	
V4540OUT	Radergan SR Outlet	4973601	24/09/2024 10:48	Total Coliforms	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4973292	24/09/2024 11:04	Colony Counts 22	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4973292	24/09/2024 11:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4719OUT	Glenchuil SR Outlet	4973292	24/09/2024 11:04	E. coli	CFU/100 ml	0	0
V4719OUT	Glenchuil SR Outlet	4973292	24/09/2024 11:04	Free - Residual disinfectant	mg Cl/l	0.7	
V4719OUT	Glenchuil SR Outlet	4973292	24/09/2024 11:04	Total - Residual disinfectant	mg Cl/l	0.8	

V4719OUT	Glenchuil SR Outlet	4973292	24/09/2024 11:04	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4973293	24/09/2024 11:25	Colony Counts 22	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4973293	24/09/2024 11:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4973293	24/09/2024 11:25	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4973293	24/09/2024 11:25	Free - Residual disinfectant	mg Cl/l	0.2	
V1354OUT	Knockoneill SR Outlet	4973293	24/09/2024 11:25	Total - Residual disinfectant	mg Cl/l	0.41	
V1354OUT	Knockoneill SR Outlet	4973293	24/09/2024 11:25	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4973293	24/09/2024 11:25	Odour	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4973293	24/09/2024 11:25	Odour - Nature		No odour	
V1354OUT	Knockoneill SR Outlet	4973293	24/09/2024 11:25	Taste	Diln No	7	0
V1354OUT	Knockoneill SR Outlet	4973293	24/09/2024 11:25	Taste - Nature		Earthy	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983886	25/09/2024 07:59	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983886	25/09/2024 07:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983886	25/09/2024 07:59	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983886	25/09/2024 07:59	Free - Residual disinfectant	mg Cl/l	1.07	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983886	25/09/2024 07:59	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983886	25/09/2024 07:59	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983886	25/09/2024 07:59	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983886	25/09/2024 07:59	Taste - Nature		No taste	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983886	25/09/2024 07:59	Total - Residual disinfectant	mg Cl/l	1.35	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4983886	25/09/2024 07:59	Total Coliforms	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4973832	25/09/2024 08:57	Colony Counts 22	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4973832	25/09/2024 08:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1351OUT	Cranny Moneymore SR Outlet	4973832	25/09/2024 08:57	E. coli	CFU/100 ml	0	0
V1351OUT	Cranny Moneymore SR Outlet	4973832	25/09/2024 08:57	Free - Residual disinfectant	mg Cl/l	0.53	
V1351OUT	Cranny Moneymore SR Outlet	4973832	25/09/2024 08:57	Total - Residual disinfectant	mg Cl/l	0.82	
V1351OUT	Cranny Moneymore SR Outlet	4973832	25/09/2024 08:57	Total Coliforms	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4973829	25/09/2024 09:17	Colony Counts 22	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4973829	25/09/2024 09:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4973829	25/09/2024 09:17	E. coli	CFU/100 ml	0	0
V4744OUT	Altaveedan Crockacleaven SR Outlet	4973829	25/09/2024 09:17	Free - Residual disinfectant	mg Cl/l	0.68	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4973829	25/09/2024 09:17	Total - Residual disinfectant	mg Cl/l	0.76	
V4744OUT	Altaveedan Crockacleaven SR Outlet	4973829	25/09/2024 09:17	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4983887	25/09/2024 09:29	Colony Counts 22	CFU/1 ml	1	
V1348OUT	Moydamlaght Draperstown SR Outlet	4983887	25/09/2024 09:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4983887	25/09/2024 09:29	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4983887	25/09/2024 09:29	Free - Residual disinfectant	mg Cl/l	0.81	
V1348OUT	Moydamlaght Draperstown SR Outlet	4983887	25/09/2024 09:29	Odour	Diln No	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4983887	25/09/2024 09:29	Odour - Nature		No odour	
V1348OUT	Moydamlaght Draperstown SR Outlet	4983887	25/09/2024 09:29	Taste	Diln No	0	0

V1348OUT	Moydamlaght Draperstown SR Outlet	4983887	25/09/2024 09:29	Taste - Nature		No taste	
V1348OUT	Moydamlaght Draperstown SR Outlet	4983887	25/09/2024 09:29	Total - Residual disinfectant	mg Cl/l	0.97	
V1348OUT	Moydamlaght Draperstown SR Outlet	4983887	25/09/2024 09:29	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4973786	25/09/2024 09:30	Colony Counts 22	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4973786	25/09/2024 09:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2508OUT	Carland SR Outlet	4973786	25/09/2024 09:30	E. coli	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4973786	25/09/2024 09:30	Free - Residual disinfectant	mg Cl/l	1.1	
V2508OUT	Carland SR Outlet	4973786	25/09/2024 09:30	Total - Residual disinfectant	mg Cl/l	1.2	
V2508OUT	Carland SR Outlet	4973786	25/09/2024 09:30	Total Coliforms	CFU/100 ml	0	0
V2508OUT	Carland SR Outlet	4973786	25/09/2024 09:30	Odour	Diln No	0	0
V2508OUT	Carland SR Outlet	4973786	25/09/2024 09:30	Odour - Nature		No odour	
V2508OUT	Carland SR Outlet	4973786	25/09/2024 09:30	Taste	Diln No	0	0
V2508OUT	Carland SR Outlet	4973786	25/09/2024 09:30	Taste - Nature		No taste	
V4715OUT	Brookeborough High SR Outlet	4973845	25/09/2024 09:46	Colony Counts 22	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4973845	25/09/2024 09:46	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4715OUT	Brookeborough High SR Outlet	4973845	25/09/2024 09:46	E. coli	CFU/100 ml	0	0
V4715OUT	Brookeborough High SR Outlet	4973845	25/09/2024 09:46	Free - Residual disinfectant	mg Cl/l	0.89	
V4715OUT	Brookeborough High SR Outlet	4973845	25/09/2024 09:46	Total - Residual disinfectant	mg Cl/l	1.03	
V4715OUT	Brookeborough High SR Outlet	4973845	25/09/2024 09:46	Total Coliforms	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4973820	25/09/2024 09:47	Colony Counts 22	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4973820	25/09/2024 09:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1352OUT	Cullion Desertmartin SR Outlet	4973820	25/09/2024 09:47	E. coli	CFU/100 ml	0	0
V1352OUT	Cullion Desertmartin SR Outlet	4973820	25/09/2024 09:47	Free - Residual disinfectant	mg Cl/l	0.46	
V1352OUT	Cullion Desertmartin SR Outlet	4973820	25/09/2024 09:47	Total - Residual disinfectant	mg Cl/l	0.56	
V1352OUT	Cullion Desertmartin SR Outlet	4973820	25/09/2024 09:47	Total Coliforms	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4983885	25/09/2024 10:00	Colony Counts 22	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4983885	25/09/2024 10:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4983885	25/09/2024 10:00	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4983885	25/09/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.52	
V1362OUT	Unagh SR Outlet	4983885	25/09/2024 10:00	Odour	Diln No	0	0
V1362OUT	Unagh SR Outlet	4983885	25/09/2024 10:00	Odour - Nature		No odour	
V1362OUT	Unagh SR Outlet	4983885	25/09/2024 10:00	Taste	Diln No	0	0
V1362OUT	Unagh SR Outlet	4983885	25/09/2024 10:00	Taste - Nature		No taste	
V1362OUT	Unagh SR Outlet	4983885	25/09/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.58	
V1362OUT	Unagh SR Outlet	4983885	25/09/2024 10:00	Total Coliforms	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4973843	25/09/2024 10:12	Colony Counts 22	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4973843	25/09/2024 10:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1343OUT	Ballybriest SR Outlet	4973843	25/09/2024 10:12	E. coli	CFU/100 ml	0	0
V1343OUT	Ballybriest SR Outlet	4973843	25/09/2024 10:12	Free - Residual disinfectant	mg Cl/l	0.95	
V1343OUT	Ballybriest SR Outlet	4973843	25/09/2024 10:12	Total - Residual disinfectant	mg Cl/l	1.3	

V1343OUT	Ballybriest SR Outlet	4973843	25/09/2024 10:12	Total Coliforms	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4973827	25/09/2024 10:17	Colony Counts 22	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4973827	25/09/2024 10:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4742OUT	Tattinbar SR Outlet	4973827	25/09/2024 10:17	E. coli	CFU/100 ml	0	0
V4742OUT	Tattinbar SR Outlet	4973827	25/09/2024 10:17	Free - Residual disinfectant	mg Cl/l	0.99	
V4742OUT	Tattinbar SR Outlet	4973827	25/09/2024 10:17	Total - Residual disinfectant	mg Cl/l	1.12	
V4742OUT	Tattinbar SR Outlet	4973827	25/09/2024 10:17	Total Coliforms	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4973831	25/09/2024 10:26	Colony Counts 22	CFU/1 ml	0	
V1713OUT	Trienaltenagh SR Outlet	4973831	25/09/2024 10:26	Colony Counts 37 (48hrs)	CFU/1 ml	4	
V1713OUT	Trienaltenagh SR Outlet	4973831	25/09/2024 10:26	E. coli	CFU/100 ml	0	0
V1713OUT	Trienaltenagh SR Outlet	4973831	25/09/2024 10:26	Free - Residual disinfectant	mg Cl/l	0.28	
V1713OUT	Trienaltenagh SR Outlet	4973831	25/09/2024 10:26	Total - Residual disinfectant	mg Cl/l	0.42	
V1713OUT	Trienaltenagh SR Outlet	4973831	25/09/2024 10:26	Total Coliforms	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4973787	25/09/2024 10:40	Colony Counts 22	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4973787	25/09/2024 10:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2509OUT	Castlehill Drumcoo SR Outlet	4973787	25/09/2024 10:40	E. coli	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4973787	25/09/2024 10:40	Free - Residual disinfectant	mg Cl/l	0.54	
V2509OUT	Castlehill Drumcoo SR Outlet	4973787	25/09/2024 10:40	Total - Residual disinfectant	mg Cl/l	0.63	
V2509OUT	Castlehill Drumcoo SR Outlet	4973787	25/09/2024 10:40	Total Coliforms	CFU/100 ml	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4973787	25/09/2024 10:40	Odour	Diln No	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4973787	25/09/2024 10:40	Odour - Nature		No odour	
V2509OUT	Castlehill Drumcoo SR Outlet	4973787	25/09/2024 10:40	Taste	Diln No	0	0
V2509OUT	Castlehill Drumcoo SR Outlet	4973787	25/09/2024 10:40	Taste - Nature		No taste	
V1349OUT	Ballyknock Magherafelt SR Outlet	4983888	25/09/2024 10:42	Colony Counts 22	CFU/1 ml	52	
V1349OUT	Ballyknock Magherafelt SR Outlet	4983888	25/09/2024 10:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4983888	25/09/2024 10:42	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4983888	25/09/2024 10:42	Free - Residual disinfectant	mg Cl/l	0.47	
V1349OUT	Ballyknock Magherafelt SR Outlet	4983888	25/09/2024 10:42	Odour	Diln No	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4983888	25/09/2024 10:42	Odour - Nature		No odour	
V1349OUT	Ballyknock Magherafelt SR Outlet	4983888	25/09/2024 10:42	Taste	Diln No	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4983888	25/09/2024 10:42	Taste - Nature		No taste	
V1349OUT	Ballyknock Magherafelt SR Outlet	4983888	25/09/2024 10:42	Total - Residual disinfectant	mg Cl/l	0.76	
V1349OUT	Ballyknock Magherafelt SR Outlet	4983888	25/09/2024 10:42	Total Coliforms	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4973830	25/09/2024 10:42	Colony Counts 22	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4973830	25/09/2024 10:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4973830	25/09/2024 10:42	E. coli	CFU/100 ml	0	0
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4973830	25/09/2024 10:42	Free - Residual disinfectant	mg Cl/l	0.63	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4973830	25/09/2024 10:42	Total - Residual disinfectant	mg Cl/l	0.7	
V4745OUT	Glasdrumman Lisnaskea SR Outlet	4973830	25/09/2024 10:42	Total Coliforms	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4973803	25/09/2024 10:55	Colony Counts 22	CFU/1 ml	1	

V2521OUT	Mullaghanagh SR Outlet	4973803	25/09/2024 10:55	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2521OUT	Mullaghanagh SR Outlet	4973803	25/09/2024 10:55	E. coli	CFU/100 ml	0	0
V2521OUT	Mullaghanagh SR Outlet	4973803	25/09/2024 10:55	Free - Residual disinfectant	mg Cl/l	0.84	
V2521OUT	Mullaghanagh SR Outlet	4973803	25/09/2024 10:55	Total - Residual disinfectant	mg Cl/l	0.99	
V2521OUT	Mullaghanagh SR Outlet	4973803	25/09/2024 10:55	Total Coliforms	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4973828	25/09/2024 10:58	Colony Counts 22	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4973828	25/09/2024 10:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1708OUT	North Garvagh SR Outlet	4973828	25/09/2024 10:58	E. coli	CFU/100 ml	0	0
V1708OUT	North Garvagh SR Outlet	4973828	25/09/2024 10:58	Free - Residual disinfectant	mg Cl/l	<0.05	
V1708OUT	North Garvagh SR Outlet	4973828	25/09/2024 10:58	Total - Residual disinfectant	mg Cl/l	0.21	
V1708OUT	North Garvagh SR Outlet	4973828	25/09/2024 10:58	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4983889	25/09/2024 11:12	Colony Counts 22	CFU/1 ml	7	
V1350OUT	Carnaman SR Outlet	4983889	25/09/2024 11:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4983889	25/09/2024 11:12	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4983889	25/09/2024 11:12	Free - Residual disinfectant	mg Cl/l	0.42	
V1350OUT	Carnaman SR Outlet	4983889	25/09/2024 11:12	Odour	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4983889	25/09/2024 11:12	Odour - Nature		No odour	
V1350OUT	Carnaman SR Outlet	4983889	25/09/2024 11:12	Taste	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4983889	25/09/2024 11:12	Taste - Nature		No taste	
V1350OUT	Carnaman SR Outlet	4983889	25/09/2024 11:12	Total - Residual disinfectant	mg Cl/l	0.55	
V1350OUT	Carnaman SR Outlet	4983889	25/09/2024 11:12	Total Coliforms	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4973819	25/09/2024 11:20	Colony Counts 22	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4973819	25/09/2024 11:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4973819	25/09/2024 11:20	E. coli	CFU/100 ml	0	0
V2522OUT	Rehaghy Aughnacloy SR Outlet	4973819	25/09/2024 11:20	Free - Residual disinfectant	mg Cl/l	0.69	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4973819	25/09/2024 11:20	Total - Residual disinfectant	mg Cl/l	0.79	
V2522OUT	Rehaghy Aughnacloy SR Outlet	4973819	25/09/2024 11:20	Total Coliforms	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4973824	25/09/2024 11:35	Colony Counts 22	CFU/1 ml	2	
V1706OUT	Killeague SR Outlet	4973824	25/09/2024 11:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1706OUT	Killeague SR Outlet	4973824	25/09/2024 11:35	E. coli	CFU/100 ml	0	0
V1706OUT	Killeague SR Outlet	4973824	25/09/2024 11:35	Free - Residual disinfectant	mg Cl/l	0.34	
V1706OUT	Killeague SR Outlet	4973824	25/09/2024 11:35	Total - Residual disinfectant	mg Cl/l	0.63	
V1706OUT	Killeague SR Outlet	4973824	25/09/2024 11:35	Total Coliforms	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4973826	25/09/2024 11:58	Colony Counts 22	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4973826	25/09/2024 11:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1702OUT	Cam SR Outlet	4973826	25/09/2024 11:58	E. coli	CFU/100 ml	0	0
V1702OUT	Cam SR Outlet	4973826	25/09/2024 11:58	Free - Residual disinfectant	mg Cl/l	0.12	
V1702OUT	Cam SR Outlet	4973826	25/09/2024 11:58	Total - Residual disinfectant	mg Cl/l	0.26	
V1702OUT	Cam SR Outlet	4973826	25/09/2024 11:58	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4983890	26/09/2024 08:17	Colony Counts 22	CFU/1 ml	0	

V1354OUT	Knockoneill SR Outlet	4983890	26/09/2024 08:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4983890	26/09/2024 08:17	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4983890	26/09/2024 08:17	Free - Residual disinfectant	mg Cl/l	0.35	
V1354OUT	Knockoneill SR Outlet	4983890	26/09/2024 08:17	Odour	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4983890	26/09/2024 08:17	Odour - Nature		No odour	
V1354OUT	Knockoneill SR Outlet	4983890	26/09/2024 08:17	Taste	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4983890	26/09/2024 08:17	Taste - Nature		No taste	
V1354OUT	Knockoneill SR Outlet	4983890	26/09/2024 08:17	Total - Residual disinfectant	mg Cl/l	0.46	
V1354OUT	Knockoneill SR Outlet	4983890	26/09/2024 08:17	Total Coliforms	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4983892	26/09/2024 08:39	Colony Counts 22	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4983892	26/09/2024 08:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4983892	26/09/2024 08:39	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4983892	26/09/2024 08:39	Free - Residual disinfectant	mg Cl/l	0.73	
V1358OUT	Slaughtneil SR Outlet	4983892	26/09/2024 08:39	Odour	Diln No	0	0
V1358OUT	Slaughtneil SR Outlet	4983892	26/09/2024 08:39	Odour - Nature		No odour	
V1358OUT	Slaughtneil SR Outlet	4983892	26/09/2024 08:39	Taste	Diln No	0	0
V1358OUT	Slaughtneil SR Outlet	4983892	26/09/2024 08:39	Taste - Nature		No taste	
V1358OUT	Slaughtneil SR Outlet	4983892	26/09/2024 08:39	Total - Residual disinfectant	mg Cl/l	0.83	
V1358OUT	Slaughtneil SR Outlet	4983892	26/09/2024 08:39	Total Coliforms	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4973299	26/09/2024 09:04	Colony Counts 22	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4973299	26/09/2024 09:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4708OUT	Cavanacross Enniskillen SR Outlet	4973299	26/09/2024 09:04	E. coli	CFU/100 ml	0	0
V4708OUT	Cavanacross Enniskillen SR Outlet	4973299	26/09/2024 09:04	Free - Residual disinfectant	mg Cl/l	1.1	
V4708OUT	Cavanacross Enniskillen SR Outlet	4973299	26/09/2024 09:04	Total - Residual disinfectant	mg Cl/l	1.23	
V4708OUT	Cavanacross Enniskillen SR Outlet	4973299	26/09/2024 09:04	Total Coliforms	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4974005	26/09/2024 09:30	Colony Counts 22	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4974005	26/09/2024 09:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1338OUT	Coagh SR Outlet	4974005	26/09/2024 09:30	E. coli	CFU/100 ml	0	0
V1338OUT	Coagh SR Outlet	4974005	26/09/2024 09:30	Free - Residual disinfectant	mg Cl/l	0.36	
V1338OUT	Coagh SR Outlet	4974005	26/09/2024 09:30	Total - Residual disinfectant	mg Cl/l	0.4	
V1338OUT	Coagh SR Outlet	4974005	26/09/2024 09:30	Total Coliforms	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4973969	26/09/2024 09:41	Colony Counts 22	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4973969	26/09/2024 09:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2511OUT	Corran Armagh SR Outlet	4973969	26/09/2024 09:41	E. coli	CFU/100 ml	0	0
V2511OUT	Corran Armagh SR Outlet	4973969	26/09/2024 09:41	Free - Residual disinfectant	mg Cl/l	0.45	
V2511OUT	Corran Armagh SR Outlet	4973969	26/09/2024 09:41	Total - Residual disinfectant	mg Cl/l	0.7	
V2511OUT	Corran Armagh SR Outlet	4973969	26/09/2024 09:41	Total Coliforms	CFU/100 ml	0	0
V4713OUT	Knocknalosset SR Outlet	4974013	26/09/2024 09:47	Colony Counts 22	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4974013	26/09/2024 09:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4713OUT	Knocknalosset SR Outlet	4974013	26/09/2024 09:47	E. coli	CFU/100 ml	0	0

V4713OUT	Knocknalosset SR Outlet	4974013	26/09/2024 09:47	Free - Residual disinfectant	mg Cl/l	0.62	
V4713OUT	Knocknalosset SR Outlet	4974013	26/09/2024 09:47	Total - Residual disinfectant	mg Cl/l	0.73	
V4713OUT	Knocknalosset SR Outlet	4974013	26/09/2024 09:47	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4983891	26/09/2024 09:51	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4983891	26/09/2024 09:51	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4983891	26/09/2024 09:51	E. coli	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4983891	26/09/2024 09:51	Free - Residual disinfectant	mg Cl/l	0.55	
V1356OUT	Mormeal SR Outlet	4983891	26/09/2024 09:51	Odour	Diln No	0	0
V1356OUT	Mormeal SR Outlet	4983891	26/09/2024 09:51	Odour - Nature		No odour	
V1356OUT	Mormeal SR Outlet	4983891	26/09/2024 09:51	Taste	Diln No	0	0
V1356OUT	Mormeal SR Outlet	4983891	26/09/2024 09:51	Taste - Nature		No taste	
V1356OUT	Mormeal SR Outlet	4983891	26/09/2024 09:51	Total - Residual disinfectant	mg Cl/l	0.69	
V1356OUT	Mormeal SR Outlet	4983891	26/09/2024 09:51	Total Coliforms	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4974004	26/09/2024 09:52	Colony Counts 22	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4974004	26/09/2024 09:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1335OUT	Brigh Quarry SR Outlet	4974004	26/09/2024 09:52	E. coli	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4974004	26/09/2024 09:52	Free - Residual disinfectant	mg Cl/l	0.7	
V1335OUT	Brigh Quarry SR Outlet	4974004	26/09/2024 09:52	Total - Residual disinfectant	mg Cl/l	0.74	
V1335OUT	Brigh Quarry SR Outlet	4974004	26/09/2024 09:52	Total Coliforms	CFU/100 ml	0	0
V1335OUT	Brigh Quarry SR Outlet	4974004	26/09/2024 09:52	Odour	Diln No	0	0
V1335OUT	Brigh Quarry SR Outlet	4974004	26/09/2024 09:52	Odour - Nature		No odour	
V1335OUT	Brigh Quarry SR Outlet	4974004	26/09/2024 09:52	Taste	Diln No	0	0
V1335OUT	Brigh Quarry SR Outlet	4974004	26/09/2024 09:52	Taste - Nature		No taste	
V1342OUT	Dromore High SR Outlet	4974008	26/09/2024 10:08	Colony Counts 22	CFU/1 ml	1	
V1342OUT	Dromore High SR Outlet	4974008	26/09/2024 10:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1342OUT	Dromore High SR Outlet	4974008	26/09/2024 10:08	E. coli	CFU/100 ml	0	0
V1342OUT	Dromore High SR Outlet	4974008	26/09/2024 10:08	Free - Residual disinfectant	mg Cl/l	0.7	
V1342OUT	Dromore High SR Outlet	4974008	26/09/2024 10:08	Total - Residual disinfectant	mg Cl/l	0.74	
V1342OUT	Dromore High SR Outlet	4974008	26/09/2024 10:08	Total Coliforms	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4974010	26/09/2024 10:08	Colony Counts 22	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4974010	26/09/2024 10:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4712OUT	Corranny SR Outlet	4974010	26/09/2024 10:08	E. coli	CFU/100 ml	0	0
V4712OUT	Corranny SR Outlet	4974010	26/09/2024 10:08	Free - Residual disinfectant	mg Cl/l	0.72	
V4712OUT	Corranny SR Outlet	4974010	26/09/2024 10:08	Total - Residual disinfectant	mg Cl/l	0.81	
V4712OUT	Corranny SR Outlet	4974010	26/09/2024 10:08	Total Coliforms	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4973968	26/09/2024 10:27	Colony Counts 22	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4973968	26/09/2024 10:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2510OUT	Calone SR Outlet	4973968	26/09/2024 10:27	E. coli	CFU/100 ml	0	0
V2510OUT	Calone SR Outlet	4973968	26/09/2024 10:27	Free - Residual disinfectant	mg Cl/l	0.28	
V2510OUT	Calone SR Outlet	4973968	26/09/2024 10:27	Total - Residual disinfectant	mg Cl/l	0.56	

V2510OUT	Calone SR Outlet	4973968	26/09/2024 10:27	Total Coliforms	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4973976	26/09/2024 10:31	Colony Counts 22	CFU/1 ml	28	
V2518OUT	Lisnastrane SR Outlet	4973976	26/09/2024 10:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2518OUT	Lisnastrane SR Outlet	4973976	26/09/2024 10:31	E. coli	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4973976	26/09/2024 10:31	Free - Residual disinfectant	mg Cl/l	0.75	
V2518OUT	Lisnastrane SR Outlet	4973976	26/09/2024 10:31	Total - Residual disinfectant	mg Cl/l	0.82	
V2518OUT	Lisnastrane SR Outlet	4973976	26/09/2024 10:31	Total Coliforms	CFU/100 ml	0	0
V2518OUT	Lisnastrane SR Outlet	4973976	26/09/2024 10:31	Odour	Diln No	0	0
V2518OUT	Lisnastrane SR Outlet	4973976	26/09/2024 10:31	Odour - Nature		No odour	
V2518OUT	Lisnastrane SR Outlet	4973976	26/09/2024 10:31	Taste	Diln No	0	0
V2518OUT	Lisnastrane SR Outlet	4973976	26/09/2024 10:31	Taste - Nature		No taste	
V4533OUT	Inisclan SR Outlet	4974001	26/09/2024 10:39	Colony Counts 22	CFU/1 ml	0	
V4533OUT	Inisclan SR Outlet	4974001	26/09/2024 10:39	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V4533OUT	Inisclan SR Outlet	4974001	26/09/2024 10:39	E. coli	CFU/100 ml	0	0
V4533OUT	Inisclan SR Outlet	4974001	26/09/2024 10:39	Free - Residual disinfectant	mg Cl/l	0.91	
V4533OUT	Inisclan SR Outlet	4974001	26/09/2024 10:39	Total - Residual disinfectant	mg Cl/l	1.05	
V4533OUT	Inisclan SR Outlet	4974001	26/09/2024 10:39	Total Coliforms	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4973974	26/09/2024 10:44	Colony Counts 22	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4973974	26/09/2024 10:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2514OUT	Edenaveys Command SR Outlet	4973974	26/09/2024 10:44	E. coli	CFU/100 ml	0	0
V2514OUT	Edenaveys Command SR Outlet	4973974	26/09/2024 10:44	Free - Residual disinfectant	mg Cl/l	0.72	
V2514OUT	Edenaveys Command SR Outlet	4973974	26/09/2024 10:44	Total - Residual disinfectant	mg Cl/l	0.88	
V2514OUT	Edenaveys Command SR Outlet	4973974	26/09/2024 10:44	Total Coliforms	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4973965	26/09/2024 11:05	Colony Counts 22	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4973965	26/09/2024 11:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V2523OUT	Rough Fort SR Outlet	4973965	26/09/2024 11:05	E. coli	CFU/100 ml	0	0
V2523OUT	Rough Fort SR Outlet	4973965	26/09/2024 11:05	Free - Residual disinfectant	mg Cl/l	0.71	
V2523OUT	Rough Fort SR Outlet	4973965	26/09/2024 11:05	Total - Residual disinfectant	mg Cl/l	0.96	
V2523OUT	Rough Fort SR Outlet	4973965	26/09/2024 11:05	Total Coliforms	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4986120	26/09/2024 11:10	Colony Counts 22	CFU/1 ml	12	
V2302OUT	Ballyhannon SR Outlet	4986120	26/09/2024 11:10	Colony Counts 37 (48hrs)	CFU/1 ml	213	
V2302OUT	Ballyhannon SR Outlet	4986120	26/09/2024 11:10	E. coli	CFU/100 ml	0	0
V2302OUT	Ballyhannon SR Outlet	4986120	26/09/2024 11:10	Free - Residual disinfectant	mg Cl/l	0.57	
V2302OUT	Ballyhannon SR Outlet	4986120	26/09/2024 11:10	Odour	Diln No	0	0
V2302OUT	Ballyhannon SR Outlet	4986120	26/09/2024 11:10	Odour - Nature		No odour	
V2302OUT	Ballyhannon SR Outlet	4986120	26/09/2024 11:10	Taste	Diln No	0	0
V2302OUT	Ballyhannon SR Outlet	4986120	26/09/2024 11:10	Taste - Nature		No taste	
V2302OUT	Ballyhannon SR Outlet	4986120	26/09/2024 11:10	Total - Residual disinfectant	mg Cl/l	0.66	
V2302OUT	Ballyhannon SR Outlet	4986120	26/09/2024 11:10	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4973998	26/09/2024 11:29	Colony Counts 22	CFU/1 ml	1	

V1704OUT	Castlerock Downhill SR Outlet	4973998	26/09/2024 11:29	Colony Counts 37 (48hrs)	CFU/1 ml	1	
V1704OUT	Castlerock Downhill SR Outlet	4973998	26/09/2024 11:29	E. coli	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4973998	26/09/2024 11:29	Free - Residual disinfectant	mg Cl/l	0.06	
V1704OUT	Castlerock Downhill SR Outlet	4973998	26/09/2024 11:29	Total - Residual disinfectant	mg Cl/l	0.25	
V1704OUT	Castlerock Downhill SR Outlet	4973998	26/09/2024 11:29	Total Coliforms	CFU/100 ml	0	0
V1704OUT	Castlerock Downhill SR Outlet	4973998	26/09/2024 11:29	Odour	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4973998	26/09/2024 11:29	Odour - Nature		No odour	
V1704OUT	Castlerock Downhill SR Outlet	4973998	26/09/2024 11:29	Taste	Diln No	0	0
V1704OUT	Castlerock Downhill SR Outlet	4973998	26/09/2024 11:29	Taste - Nature		No taste	
V1360OUT	Windmill Hill SR Outlet	4974172	26/09/2024 11:36	Colony Counts 22	CFU/1 ml	1	
V1360OUT	Windmill Hill SR Outlet	4974172	26/09/2024 11:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4974172	26/09/2024 11:36	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4974172	26/09/2024 11:36	Free - Residual disinfectant	mg Cl/l	0.62	
V1360OUT	Windmill Hill SR Outlet	4974172	26/09/2024 11:36	Total - Residual disinfectant	mg Cl/l	0.78	
V1360OUT	Windmill Hill SR Outlet	4974172	26/09/2024 11:36	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4974172	26/09/2024 11:36	Odour	Diln No	0	0
V1360OUT	Windmill Hill SR Outlet	4974172	26/09/2024 11:36	Odour - Nature		No odour	
V1360OUT	Windmill Hill SR Outlet	4974172	26/09/2024 11:36	Taste	Diln No	0	0
V1360OUT	Windmill Hill SR Outlet	4974172	26/09/2024 11:36	Taste - Nature		No taste	
V1711OUT	Sconce Hill SR Outlet	4973999	26/09/2024 12:00	Colony Counts 22	CFU/1 ml	94	
V1711OUT	Sconce Hill SR Outlet	4973999	26/09/2024 12:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1711OUT	Sconce Hill SR Outlet	4973999	26/09/2024 12:00	E. coli	CFU/100 ml	0	0
V1711OUT	Sconce Hill SR Outlet	4973999	26/09/2024 12:00	Free - Residual disinfectant	mg Cl/l	<0.05	
V1711OUT	Sconce Hill SR Outlet	4973999	26/09/2024 12:00	Total - Residual disinfectant	mg Cl/l	<0.05	
V1711OUT	Sconce Hill SR Outlet	4973999	26/09/2024 12:00	Total Coliforms	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4974187	27/09/2024 09:13	Colony Counts 22	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4974187	27/09/2024 09:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4974187	27/09/2024 09:13	E. coli	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4974187	27/09/2024 09:13	Free - Residual disinfectant	mg Cl/l	0.56	
V1344OUT	Craigs Cookstown SR Outlet	4974187	27/09/2024 09:13	Total - Residual disinfectant	mg Cl/l	0.6	
V1344OUT	Craigs Cookstown SR Outlet	4974187	27/09/2024 09:13	Total Coliforms	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4974174	27/09/2024 09:28	Colony Counts 22	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4974174	27/09/2024 09:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4974174	27/09/2024 09:28	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4974174	27/09/2024 09:28	Free - Residual disinfectant	mg Cl/l	0.58	
V1362OUT	Unagh SR Outlet	4974174	27/09/2024 09:28	Total - Residual disinfectant	mg Cl/l	0.62	
V1362OUT	Unagh SR Outlet	4974174	27/09/2024 09:28	Total Coliforms	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4974174	27/09/2024 09:28	Odour	Diln No	0	0
V1362OUT	Unagh SR Outlet	4974174	27/09/2024 09:28	Odour - Nature		No odour	
V1362OUT	Unagh SR Outlet	4974174	27/09/2024 09:28	Taste	Diln No	10	0

V1362OUT	Unagh SR Outlet	4974174	27/09/2024 09:28	Taste - Nature		Earthy	
V1348OUT	Moydamlaght Draperstown SR Outlet	4983893	27/09/2024 09:34	Colony Counts 22	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4983893	27/09/2024 09:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4983893	27/09/2024 09:34	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4983893	27/09/2024 09:34	Free - Residual disinfectant	mg Cl/l	0.91	
V1348OUT	Moydamlaght Draperstown SR Outlet	4983893	27/09/2024 09:34	Odour	Diln No	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4983893	27/09/2024 09:34	Odour - Nature		No odour	
V1348OUT	Moydamlaght Draperstown SR Outlet	4983893	27/09/2024 09:34	Taste	Diln No	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4983893	27/09/2024 09:34	Taste - Nature		No taste	
V1348OUT	Moydamlaght Draperstown SR Outlet	4983893	27/09/2024 09:34	Total - Residual disinfectant	mg Cl/l	0.98	
V1348OUT	Moydamlaght Draperstown SR Outlet	4983893	27/09/2024 09:34	Total Coliforms	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4974152	27/09/2024 09:40	Colony Counts 22	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4974152	27/09/2024 09:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4974152	27/09/2024 09:40	E. coli	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4974152	27/09/2024 09:40	Free - Residual disinfectant	mg Cl/l	0.26	
V4539OUT	Erganagh SR Outlet	4974152	27/09/2024 09:40	Total - Residual disinfectant	mg Cl/l	0.34	
V4539OUT	Erganagh SR Outlet	4974152	27/09/2024 09:40	Total Coliforms	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4974184	27/09/2024 09:50	Colony Counts 22	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4974184	27/09/2024 09:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4974184	27/09/2024 09:50	E. coli	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4974184	27/09/2024 09:50	Free - Residual disinfectant	mg Cl/l	0.85	
V1339OUT	Corvanaghan High SR Outlet	4974184	27/09/2024 09:50	Total - Residual disinfectant	mg Cl/l	0.9	
V1339OUT	Corvanaghan High SR Outlet	4974184	27/09/2024 09:50	Total Coliforms	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4974150	27/09/2024 10:03	Colony Counts 22	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4974150	27/09/2024 10:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4974150	27/09/2024 10:03	E. coli	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4974150	27/09/2024 10:03	Free - Residual disinfectant	mg Cl/l	0.49	
V4538OUT	Killyclogher SR Outlet	4974150	27/09/2024 10:03	Total - Residual disinfectant	mg Cl/l	0.56	
V4538OUT	Killyclogher SR Outlet	4974150	27/09/2024 10:03	Total Coliforms	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4974185	27/09/2024 10:03	Colony Counts 22	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4974185	27/09/2024 10:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4974185	27/09/2024 10:03	E. coli	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4974185	27/09/2024 10:03	Free - Residual disinfectant	mg Cl/l	0.64	
V1340OUT	Craigballyharkey SR Outlet	4974185	27/09/2024 10:03	Total - Residual disinfectant	mg Cl/l	0.71	
V1340OUT	Craigballyharkey SR Outlet	4974185	27/09/2024 10:03	Total Coliforms	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4974188	27/09/2024 10:16	Colony Counts 22	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4974188	27/09/2024 10:16	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4974188	27/09/2024 10:16	E. coli	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4974188	27/09/2024 10:16	Free - Residual disinfectant	mg Cl/l	0.4	
V1346OUT	Gortaclady Evishanoran SR Outlet	4974188	27/09/2024 10:16	Total - Residual disinfectant	mg Cl/l	0.46	

V1346OUT	Gortaclady Evishanoran SR Outlet	4974188	27/09/2024 10:16	Total Coliforms	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4974160	27/09/2024 10:25	Colony Counts 22	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4974160	27/09/2024 10:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4974160	27/09/2024 10:25	E. coli	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4974160	27/09/2024 10:25	Free - Residual disinfectant	mg Cl/l	0.71	
V4536OUT	Lough Macrory North SR Outlet	4974160	27/09/2024 10:25	Total - Residual disinfectant	mg Cl/l	0.79	
V4536OUT	Lough Macrory North SR Outlet	4974160	27/09/2024 10:25	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4983894	27/09/2024 10:31	Colony Counts 22	CFU/1 ml	43	
V1349OUT	Ballyknock Magherafelt SR Outlet	4983894	27/09/2024 10:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4983894	27/09/2024 10:31	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4983894	27/09/2024 10:31	Free - Residual disinfectant	mg Cl/l	0.27	
V1349OUT	Ballyknock Magherafelt SR Outlet	4983894	27/09/2024 10:31	Odour	Diln No	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4983894	27/09/2024 10:31	Odour - Nature		No odour	
V1349OUT	Ballyknock Magherafelt SR Outlet	4983894	27/09/2024 10:31	Taste	Diln No	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4983894	27/09/2024 10:31	Taste - Nature		No taste	
V1349OUT	Ballyknock Magherafelt SR Outlet	4983894	27/09/2024 10:31	Total - Residual disinfectant	mg Cl/l	0.46	
V1349OUT	Ballyknock Magherafelt SR Outlet	4983894	27/09/2024 10:31	Total Coliforms	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4974149	27/09/2024 10:44	Colony Counts 22	CFU/1 ml	7	
V4526OUT	Black Lough Pomeroy SR Outlet	4974149	27/09/2024 10:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4974149	27/09/2024 10:44	E. coli	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4974149	27/09/2024 10:44	Free - Residual disinfectant	mg Cl/l	0.65	
V4526OUT	Black Lough Pomeroy SR Outlet	4974149	27/09/2024 10:44	Total - Residual disinfectant	mg Cl/l	0.71	
V4526OUT	Black Lough Pomeroy SR Outlet	4974149	27/09/2024 10:44	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4974183	27/09/2024 10:58	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4974183	27/09/2024 10:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4974183	27/09/2024 10:58	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4974183	27/09/2024 10:58	Free - Residual disinfectant	mg Cl/l	0.9	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4974183	27/09/2024 10:58	Total - Residual disinfectant	mg Cl/l	1.04	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4974183	27/09/2024 10:58	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4974183	27/09/2024 10:58	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4974183	27/09/2024 10:58	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4974183	27/09/2024 10:58	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4974183	27/09/2024 10:58	Taste - Nature		No taste	
V1350OUT	Carnaman SR Outlet	4974179	27/09/2024 12:09	Colony Counts 22	CFU/1 ml	16	
V1350OUT	Carnaman SR Outlet	4974179	27/09/2024 12:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4974179	27/09/2024 12:09	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4974179	27/09/2024 12:09	Free - Residual disinfectant	mg Cl/l	0.42	
V1350OUT	Carnaman SR Outlet	4974179	27/09/2024 12:09	Total - Residual disinfectant	mg Cl/l	0.57	
V1350OUT	Carnaman SR Outlet	4974179	27/09/2024 12:09	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4974179	27/09/2024 12:09	Odour	Diln No	0	0

V1350OUT	Carnaman SR Outlet	4974179	27/09/2024 12:09	Odour - Nature		No odour	
V1350OUT	Carnaman SR Outlet	4974179	27/09/2024 12:09	Taste	Diln No	10	0
V1350OUT	Carnaman SR Outlet	4974179	27/09/2024 12:09	Taste - Nature		Earthy	
V1360OUT	Windmill Hill SR Outlet	4985299	28/09/2024 07:13	Colony Counts 22	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4985299	28/09/2024 07:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4985299	28/09/2024 07:13	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4985299	28/09/2024 07:13	Free - Residual disinfectant	mg Cl/l	0.61	
V1360OUT	Windmill Hill SR Outlet	4985299	28/09/2024 07:13	Odour	Diln No	0	0
V1360OUT	Windmill Hill SR Outlet	4985299	28/09/2024 07:13	Odour - Nature		No odour	
V1360OUT	Windmill Hill SR Outlet	4985299	28/09/2024 07:13	Taste	Diln No	0	0
V1360OUT	Windmill Hill SR Outlet	4985299	28/09/2024 07:13	Taste - Nature		No taste	
V1360OUT	Windmill Hill SR Outlet	4985299	28/09/2024 07:13	Total - Residual disinfectant	mg Cl/l	0.75	
V1360OUT	Windmill Hill SR Outlet	4985299	28/09/2024 07:13	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4985297	28/09/2024 08:33	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4985297	28/09/2024 08:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4985297	28/09/2024 08:33	E. coli	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4985297	28/09/2024 08:33	Free - Residual disinfectant	mg Cl/l	0.31	
V1356OUT	Mormeal SR Outlet	4985297	28/09/2024 08:33	Odour	Diln No	0	0
V1356OUT	Mormeal SR Outlet	4985297	28/09/2024 08:33	Odour - Nature		No odour	
V1356OUT	Mormeal SR Outlet	4985297	28/09/2024 08:33	Taste	Diln No	0	0
V1356OUT	Mormeal SR Outlet	4985297	28/09/2024 08:33	Taste - Nature		No taste	
V1356OUT	Mormeal SR Outlet	4985297	28/09/2024 08:33	Total - Residual disinfectant	mg Cl/l	0.54	
V1356OUT	Mormeal SR Outlet	4985297	28/09/2024 08:33	Total Coliforms	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4985298	28/09/2024 09:09	Colony Counts 22	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4985298	28/09/2024 09:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4985298	28/09/2024 09:09	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4985298	28/09/2024 09:09	Free - Residual disinfectant	mg Cl/l	0.76	
V1358OUT	Slaughtneil SR Outlet	4985298	28/09/2024 09:09	Odour	Diln No	0	0
V1358OUT	Slaughtneil SR Outlet	4985298	28/09/2024 09:09	Odour - Nature		No odour	
V1358OUT	Slaughtneil SR Outlet	4985298	28/09/2024 09:09	Taste	Diln No	0	0
V1358OUT	Slaughtneil SR Outlet	4985298	28/09/2024 09:09	Taste - Nature		No taste	
V1358OUT	Slaughtneil SR Outlet	4985298	28/09/2024 09:09	Total - Residual disinfectant	mg Cl/l	0.84	
V1358OUT	Slaughtneil SR Outlet	4985298	28/09/2024 09:09	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4985296	28/09/2024 09:31	Colony Counts 22	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4985296	28/09/2024 09:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4985296	28/09/2024 09:31	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4985296	28/09/2024 09:31	Free - Residual disinfectant	mg Cl/l	0.35	
V1354OUT	Knockoneill SR Outlet	4985296	28/09/2024 09:31	Odour	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4985296	28/09/2024 09:31	Odour - Nature		No odour	
V1354OUT	Knockoneill SR Outlet	4985296	28/09/2024 09:31	Taste	Diln No	0	0

V1354OUT	Knockoneill SR Outlet	4985296	28/09/2024 09:31	Taste - Nature		No taste	
V1354OUT	Knockoneill SR Outlet	4985296	28/09/2024 09:31	Total - Residual disinfectant	mg Cl/l	0.49	
V1354OUT	Knockoneill SR Outlet	4985296	28/09/2024 09:31	Total Coliforms	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4985304	29/09/2024 07:45	Colony Counts 22	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4985304	29/09/2024 07:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1350OUT	Carnaman SR Outlet	4985304	29/09/2024 07:45	E. coli	CFU/100 ml	0	0
V1350OUT	Carnaman SR Outlet	4985304	29/09/2024 07:45	Free - Residual disinfectant	mg Cl/l	0.5	
V1350OUT	Carnaman SR Outlet	4985304	29/09/2024 07:45	Odour	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4985304	29/09/2024 07:45	Odour - Nature		No odour	
V1350OUT	Carnaman SR Outlet	4985304	29/09/2024 07:45	Taste	Diln No	0	0
V1350OUT	Carnaman SR Outlet	4985304	29/09/2024 07:45	Taste - Nature		No taste	
V1350OUT	Carnaman SR Outlet	4985304	29/09/2024 07:45	Total - Residual disinfectant	mg Cl/l	0.61	
V1350OUT	Carnaman SR Outlet	4985304	29/09/2024 07:45	Total Coliforms	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4985303	29/09/2024 08:12	Colony Counts 22	CFU/1 ml	>300	
V1349OUT	Ballyknock Magherafelt SR Outlet	4985303	29/09/2024 08:12	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1349OUT	Ballyknock Magherafelt SR Outlet	4985303	29/09/2024 08:12	E. coli	CFU/100 ml	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4985303	29/09/2024 08:12	Free - Residual disinfectant	mg Cl/l	0.28	
V1349OUT	Ballyknock Magherafelt SR Outlet	4985303	29/09/2024 08:12	Odour	Diln No	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4985303	29/09/2024 08:12	Odour - Nature		No odour	
V1349OUT	Ballyknock Magherafelt SR Outlet	4985303	29/09/2024 08:12	Taste	Diln No	0	0
V1349OUT	Ballyknock Magherafelt SR Outlet	4985303	29/09/2024 08:12	Taste - Nature		No taste	
V1349OUT	Ballyknock Magherafelt SR Outlet	4985303	29/09/2024 08:12	Total - Residual disinfectant	mg Cl/l	0.52	
V1349OUT	Ballyknock Magherafelt SR Outlet	4985303	29/09/2024 08:12	Total Coliforms	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4985302	29/09/2024 08:44	Colony Counts 22	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4985302	29/09/2024 08:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1348OUT	Moydamlaght Draperstown SR Outlet	4985302	29/09/2024 08:44	E. coli	CFU/100 ml	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4985302	29/09/2024 08:44	Free - Residual disinfectant	mg Cl/l	0.43	
V1348OUT	Moydamlaght Draperstown SR Outlet	4985302	29/09/2024 08:44	Odour	Diln No	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4985302	29/09/2024 08:44	Odour - Nature		No odour	
V1348OUT	Moydamlaght Draperstown SR Outlet	4985302	29/09/2024 08:44	Taste	Diln No	0	0
V1348OUT	Moydamlaght Draperstown SR Outlet	4985302	29/09/2024 08:44	Taste - Nature		No taste	
V1348OUT	Moydamlaght Draperstown SR Outlet	4985302	29/09/2024 08:44	Total - Residual disinfectant	mg Cl/l	0.65	
V1348OUT	Moydamlaght Draperstown SR Outlet	4985302	29/09/2024 08:44	Total Coliforms	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4985300	29/09/2024 09:37	Colony Counts 22	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4985300	29/09/2024 09:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1362OUT	Unagh SR Outlet	4985300	29/09/2024 09:37	E. coli	CFU/100 ml	0	0
V1362OUT	Unagh SR Outlet	4985300	29/09/2024 09:37	Free - Residual disinfectant	mg Cl/l	0.47	
V1362OUT	Unagh SR Outlet	4985300	29/09/2024 09:37	Odour	Diln No	0	0
V1362OUT	Unagh SR Outlet	4985300	29/09/2024 09:37	Odour - Nature		No odour	
V1362OUT	Unagh SR Outlet	4985300	29/09/2024 09:37	Taste	Diln No	0	0

V1362OUT	Unagh SR Outlet	4985300	29/09/2024 09:37	Taste - Nature		No taste	
V1362OUT	Unagh SR Outlet	4985300	29/09/2024 09:37	Total - Residual disinfectant	mg Cl/l	0.57	
V1362OUT	Unagh SR Outlet	4985300	29/09/2024 09:37	Total Coliforms	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985301	29/09/2024 10:24	Colony Counts 22	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985301	29/09/2024 10:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985301	29/09/2024 10:24	E. coli	CFU/100 ml	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985301	29/09/2024 10:24	Free - Residual disinfectant	mg Cl/l	0.8	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985301	29/09/2024 10:24	Odour	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985301	29/09/2024 10:24	Odour - Nature		No odour	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985301	29/09/2024 10:24	Taste	Diln No	0	0
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985301	29/09/2024 10:24	Taste - Nature		No taste	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985301	29/09/2024 10:24	Total - Residual disinfectant	mg Cl/l	0.97	
V1357OUT	Mullaghboy Magherafelt SR Outlet	4985301	29/09/2024 10:24	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4976367	30/09/2024 07:39	Colony Counts 22	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4976367	30/09/2024 07:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1360OUT	Windmill Hill SR Outlet	4976367	30/09/2024 07:39	E. coli	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4976367	30/09/2024 07:39	Free - Residual disinfectant	mg Cl/l	0.64	
V1360OUT	Windmill Hill SR Outlet	4976367	30/09/2024 07:39	Total - Residual disinfectant	mg Cl/l	0.77	
V1360OUT	Windmill Hill SR Outlet	4976367	30/09/2024 07:39	Total Coliforms	CFU/100 ml	0	0
V1360OUT	Windmill Hill SR Outlet	4976367	30/09/2024 07:39	Odour	Diln No	10	0
V1360OUT	Windmill Hill SR Outlet	4976367	30/09/2024 07:39	Odour - Nature		Earthy/Musty	
V1360OUT	Windmill Hill SR Outlet	4976367	30/09/2024 07:39	Taste	Diln No	10	0
V1360OUT	Windmill Hill SR Outlet	4976367	30/09/2024 07:39	Taste - Nature		Earthy/Musty	
V1356OUT	Mormeal SR Outlet	4976786	30/09/2024 09:15	Colony Counts 22	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4976786	30/09/2024 09:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1356OUT	Mormeal SR Outlet	4976786	30/09/2024 09:15	E. coli	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4976786	30/09/2024 09:15	Free - Residual disinfectant	mg Cl/l	0.48	
V1356OUT	Mormeal SR Outlet	4976786	30/09/2024 09:15	Total - Residual disinfectant	mg Cl/l	0.78	
V1356OUT	Mormeal SR Outlet	4976786	30/09/2024 09:15	Total Coliforms	CFU/100 ml	0	0
V1356OUT	Mormeal SR Outlet	4976786	30/09/2024 09:15	Odour	Diln No	0	0
V1356OUT	Mormeal SR Outlet	4976786	30/09/2024 09:15	Odour - Nature		No odour	
V1356OUT	Mormeal SR Outlet	4976786	30/09/2024 09:15	Taste	Diln No	0	0
V1356OUT	Mormeal SR Outlet	4976786	30/09/2024 09:15	Taste - Nature		No taste	
V1344OUT	Craigs Cookstown SR Outlet	4976382	30/09/2024 09:27	Colony Counts 22	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4976382	30/09/2024 09:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1344OUT	Craigs Cookstown SR Outlet	4976382	30/09/2024 09:27	E. coli	CFU/100 ml	0	0
V1344OUT	Craigs Cookstown SR Outlet	4976382	30/09/2024 09:27	Free - Residual disinfectant	mg Cl/l	0.51	
V1344OUT	Craigs Cookstown SR Outlet	4976382	30/09/2024 09:27	Total - Residual disinfectant	mg Cl/l	0.55	
V1344OUT	Craigs Cookstown SR Outlet	4976382	30/09/2024 09:27	Total Coliforms	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4976379	30/09/2024 09:47	Colony Counts 22	CFU/1 ml	0	

V1339OUT	Corvanaghan High SR Outlet	4976379	30/09/2024 09:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1339OUT	Corvanaghan High SR Outlet	4976379	30/09/2024 09:47	E. coli	CFU/100 ml	0	0
V1339OUT	Corvanaghan High SR Outlet	4976379	30/09/2024 09:47	Free - Residual disinfectant	mg Cl/l	0.75	
V1339OUT	Corvanaghan High SR Outlet	4976379	30/09/2024 09:47	Total - Residual disinfectant	mg Cl/l	0.81	
V1339OUT	Corvanaghan High SR Outlet	4976379	30/09/2024 09:47	Total Coliforms	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4976569	30/09/2024 09:47	Colony Counts 22	CFU/1 ml	4	
V1358OUT	Slaughtneil SR Outlet	4976569	30/09/2024 09:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1358OUT	Slaughtneil SR Outlet	4976569	30/09/2024 09:47	E. coli	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4976569	30/09/2024 09:47	Free - Residual disinfectant	mg Cl/l	0.72	
V1358OUT	Slaughtneil SR Outlet	4976569	30/09/2024 09:47	Total - Residual disinfectant	mg Cl/l	0.82	
V1358OUT	Slaughtneil SR Outlet	4976569	30/09/2024 09:47	Total Coliforms	CFU/100 ml	0	0
V1358OUT	Slaughtneil SR Outlet	4976569	30/09/2024 09:47	Odour	Diln No	10	0
V1358OUT	Slaughtneil SR Outlet	4976569	30/09/2024 09:47	Odour - Nature		Musty	
V1358OUT	Slaughtneil SR Outlet	4976569	30/09/2024 09:47	Taste	Diln No	0	0
V1358OUT	Slaughtneil SR Outlet	4976569	30/09/2024 09:47	Taste - Nature		No taste	
V4539OUT	Erganagh SR Outlet	4976349	30/09/2024 10:01	Colony Counts 22	CFU/1 ml	2	
V4539OUT	Erganagh SR Outlet	4976349	30/09/2024 10:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4539OUT	Erganagh SR Outlet	4976349	30/09/2024 10:01	E. coli	CFU/100 ml	0	0
V4539OUT	Erganagh SR Outlet	4976349	30/09/2024 10:01	Free - Residual disinfectant	mg Cl/l	0.42	
V4539OUT	Erganagh SR Outlet	4976349	30/09/2024 10:01	Total - Residual disinfectant	mg Cl/l	0.51	
V4539OUT	Erganagh SR Outlet	4976349	30/09/2024 10:01	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4976567	30/09/2024 10:05	Colony Counts 22	CFU/1 ml	7	
V1354OUT	Knockoneill SR Outlet	4976567	30/09/2024 10:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1354OUT	Knockoneill SR Outlet	4976567	30/09/2024 10:05	E. coli	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4976567	30/09/2024 10:05	Free - Residual disinfectant	mg Cl/l	0.35	
V1354OUT	Knockoneill SR Outlet	4976567	30/09/2024 10:05	Total - Residual disinfectant	mg Cl/l	0.51	
V1354OUT	Knockoneill SR Outlet	4976567	30/09/2024 10:05	Total Coliforms	CFU/100 ml	0	0
V1354OUT	Knockoneill SR Outlet	4976567	30/09/2024 10:05	Odour	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4976567	30/09/2024 10:05	Odour - Nature		No odour	
V1354OUT	Knockoneill SR Outlet	4976567	30/09/2024 10:05	Taste	Diln No	0	0
V1354OUT	Knockoneill SR Outlet	4976567	30/09/2024 10:05	Taste - Nature		No taste	
V1340OUT	Craigballyharkey SR Outlet	4976380	30/09/2024 10:08	Colony Counts 22	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4976380	30/09/2024 10:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1340OUT	Craigballyharkey SR Outlet	4976380	30/09/2024 10:08	E. coli	CFU/100 ml	0	0
V1340OUT	Craigballyharkey SR Outlet	4976380	30/09/2024 10:08	Free - Residual disinfectant	mg Cl/l	0.61	
V1340OUT	Craigballyharkey SR Outlet	4976380	30/09/2024 10:08	Total - Residual disinfectant	mg Cl/l	0.71	
V1340OUT	Craigballyharkey SR Outlet	4976380	30/09/2024 10:08	Total Coliforms	CFU/100 ml	0	0
V4538OUT	Killyclogher SR Outlet	4976348	30/09/2024 10:17	Colony Counts 22	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4976348	30/09/2024 10:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4538OUT	Killyclogher SR Outlet	4976348	30/09/2024 10:17	E. coli	CFU/100 ml	0	0

V4538OUT	Killyclogher SR Outlet	4976348	30/09/2024 10:17	Free - Residual disinfectant	mg Cl/l	0.55	
V4538OUT	Killyclogher SR Outlet	4976348	30/09/2024 10:17	Total - Residual disinfectant	mg Cl/l	0.63	
V4538OUT	Killyclogher SR Outlet	4976348	30/09/2024 10:17	Total Coliforms	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4976383	30/09/2024 10:35	Colony Counts 22	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4976383	30/09/2024 10:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V1346OUT	Gortaclady Evishanoran SR Outlet	4976383	30/09/2024 10:35	E. coli	CFU/100 ml	0	0
V1346OUT	Gortaclady Evishanoran SR Outlet	4976383	30/09/2024 10:35	Free - Residual disinfectant	mg Cl/l	0.36	
V1346OUT	Gortaclady Evishanoran SR Outlet	4976383	30/09/2024 10:35	Total - Residual disinfectant	mg Cl/l	0.42	
V1346OUT	Gortaclady Evishanoran SR Outlet	4976383	30/09/2024 10:35	Total Coliforms	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4976355	30/09/2024 11:04	Colony Counts 22	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4976355	30/09/2024 11:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4536OUT	Lough Macrory North SR Outlet	4976355	30/09/2024 11:04	E. coli	CFU/100 ml	0	0
V4536OUT	Lough Macrory North SR Outlet	4976355	30/09/2024 11:04	Free - Residual disinfectant	mg Cl/l	0.7	
V4536OUT	Lough Macrory North SR Outlet	4976355	30/09/2024 11:04	Total - Residual disinfectant	mg Cl/l	0.81	
V4536OUT	Lough Macrory North SR Outlet	4976355	30/09/2024 11:04	Total Coliforms	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4976347	30/09/2024 11:24	Colony Counts 22	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4976347	30/09/2024 11:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
V4526OUT	Black Lough Pomeroy SR Outlet	4976347	30/09/2024 11:24	E. coli	CFU/100 ml	0	0
V4526OUT	Black Lough Pomeroy SR Outlet	4976347	30/09/2024 11:24	Free - Residual disinfectant	mg Cl/l	0.49	
V4526OUT	Black Lough Pomeroy SR Outlet	4976347	30/09/2024 11:24	Total - Residual disinfectant	mg Cl/l	0.54	
V4526OUT	Black Lough Pomeroy SR Outlet	4976347	30/09/2024 11:24	Total Coliforms	CFU/100 ml	0	0

CUSTOMER TAPS

Sample Point	Sample Id	Sample Date	Parameter	Units	Auth Result	PCV Limit
ZS0809AE	4924025	03/06/2024 09:34	Aluminium	ug Al/l	10	200
ZS0809AE	4924025	03/06/2024 09:34	Bromodichloromethane	ug/l	20	
ZS0809AE	4924025	03/06/2024 09:34	Bromoform	ug/l	<3.5	
ZS0809AE	4924025	03/06/2024 09:34	Chloroform	ug/l	52	
ZS0809AE	4924025	03/06/2024 09:34	Colony Counts 22	CFU/1 ml	0	
ZS0809AE	4924025	03/06/2024 09:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0809AE	4924025	03/06/2024 09:34	Colour	mg/l Pt/Co	<4.56	20
ZS0809AE	4924025	03/06/2024 09:34	Conductivity	uS/cm 20 C	380	2500
ZS0809AE	4924025	03/06/2024 09:34	Dibromochloromethane	ug/l	8.1	
ZS0809AE	4924025	03/06/2024 09:34	E. coli	CFU/100 ml	0	0
ZS0809AE	4924025	03/06/2024 09:34	Free - Residual disinfectant	mg Cl/l	0.4	
ZS0809AE	4924025	03/06/2024 09:34	Hydrogen Ion	pH value	7.4	9.5
ZS0809AE	4924025	03/06/2024 09:34	Iron	ug/l Fe	18	200
ZS0809AE	4924025	03/06/2024 09:34	Manganese	ug Mn/l	<2.0	50
ZS0809AE	4924025	03/06/2024 09:34	Odour	Diln No	0	0
ZS0809AE	4924025	03/06/2024 09:34	Odour - Nature		No odour	
ZS0809AE	4924025	03/06/2024 09:34	Taste	Diln No	0	0
ZS0809AE	4924025	03/06/2024 09:34	Taste - Nature		No taste	
ZS0809AE	4924025	03/06/2024 09:34	Total - Residual disinfectant	mg Cl/l	0.64	
ZS0809AE	4924025	03/06/2024 09:34	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4924025	03/06/2024 09:34	Total Trihalomethanes	ug/l	81	100
ZS0809AE	4924025	03/06/2024 09:34	Turbidity	NTU	0.16	4
ZS0809AE	4924025	03/06/2024 09:34	WHO Index		0.59	1
ZN0501AE	4924047	03/06/2024 11:04	E. coli	CFU/100 ml	0	0
ZN0501AE	4924047	03/06/2024 11:04	Free - Residual disinfectant	mg Cl/l	0.6	
ZN0501AE	4924047	03/06/2024 11:04	Total - Residual disinfectant	mg Cl/l	0.74	
ZN0501AE	4924047	03/06/2024 11:04	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4924065	03/06/2024 11:31	Bromodichloromethane	ug/l	16	
ZS0811AE	4924065	03/06/2024 11:31	Bromoform	ug/l	<3.5	
ZS0811AE	4924065	03/06/2024 11:31	Chloroform	ug/l	37	
ZS0811AE	4924065	03/06/2024 11:31	Dibromochloromethane	ug/l	6.2	
ZS0811AE	4924065	03/06/2024 11:31	E. coli	CFU/100 ml	0	0
ZS0811AE	4924065	03/06/2024 11:31	Free - Residual disinfectant	mg Cl/l	0.69	
ZS0811AE	4924065	03/06/2024 11:31	Total - Residual disinfectant	mg Cl/l	0.99	
ZS0811AE	4924065	03/06/2024 11:31	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4924065	03/06/2024 11:31	Total Trihalomethanes	ug/l	60	100
ZS0811AE	4924065	03/06/2024 11:31	Turbidity	NTU	0.15	4

ZS0811AE	4924065	03/06/2024 11:31	WHO Index		0.46	1
ZS0811AE	4924397	04/06/2024 09:45	Aluminium	ug Al/l	14	200
ZS0811AE	4924397	04/06/2024 09:45	Colony Counts 22	CFU/1 ml	0	
ZS0811AE	4924397	04/06/2024 09:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0811AE	4924397	04/06/2024 09:45	Colour	mg/l Pt/Co	<4.56	20
ZS0811AE	4924397	04/06/2024 09:45	Conductivity	uS/cm 20 C	390	2500
ZS0811AE	4924397	04/06/2024 09:45	E. coli	CFU/100 ml	0	0
ZS0811AE	4924397	04/06/2024 09:45	Free - Residual disinfectant	mg Cl/l	0.68	
ZS0811AE	4924397	04/06/2024 09:45	Hydrogen Ion	pH value	7.5	9.5
ZS0811AE	4924397	04/06/2024 09:45	Iron	ug/l Fe	<5.0	200
ZS0811AE	4924397	04/06/2024 09:45	Manganese	ug Mn/l	<2.0	50
ZS0811AE	4924397	04/06/2024 09:45	Odour	Diln No	0	0
ZS0811AE	4924397	04/06/2024 09:45	Odour - Nature		No odour	
ZS0811AE	4924397	04/06/2024 09:45	Taste	Diln No	0	0
ZS0811AE	4924397	04/06/2024 09:45	Taste - Nature		No taste	
ZS0811AE	4924397	04/06/2024 09:45	Total - Residual disinfectant	mg Cl/l	0.9	
ZS0811AE	4924397	04/06/2024 09:45	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4924397	04/06/2024 09:45	Turbidity	NTU	0.14	4
ZN1102AE	4924365	04/06/2024 10:17	Aluminium	ug Al/l	15	200
ZN1102AE	4924365	04/06/2024 10:17	Colony Counts 22	CFU/1 ml	0	
ZN1102AE	4924365	04/06/2024 10:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN1102AE	4924365	04/06/2024 10:17	Colour	mg/l Pt/Co	<4.56	20
ZN1102AE	4924365	04/06/2024 10:17	Conductivity	uS/cm 20 C	330	2500
ZN1102AE	4924365	04/06/2024 10:17	E. coli	CFU/100 ml	0	0
ZN1102AE	4924365	04/06/2024 10:17	Free - Residual disinfectant	mg Cl/l	0.49	
ZN1102AE	4924365	04/06/2024 10:17	Hydrogen Ion	pH value	7.5	9.5
ZN1102AE	4924365	04/06/2024 10:17	Iron	ug/l Fe	100	200
ZN1102AE	4924365	04/06/2024 10:17	Manganese	ug Mn/l	2.9	50
ZN1102AE	4924365	04/06/2024 10:17	Odour	Diln No	0	0
ZN1102AE	4924365	04/06/2024 10:17	Odour - Nature		No odour	
ZN1102AE	4924365	04/06/2024 10:17	Taste	Diln No	0	0
ZN1102AE	4924365	04/06/2024 10:17	Taste - Nature		No taste	
ZN1102AE	4924365	04/06/2024 10:17	Total - Residual disinfectant	mg Cl/l	0.64	
ZN1102AE	4924365	04/06/2024 10:17	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4924365	04/06/2024 10:17	Turbidity	NTU	0.25	4
ZN0706AE	4924067	04/06/2024 10:43	E. coli	CFU/100 ml	0	0
ZN0706AE	4924067	04/06/2024 10:43	Free - Residual disinfectant	mg Cl/l	0.61	
ZN0706AE	4924067	04/06/2024 10:43	Hydrogen Ion	pH value	7.2	9.5

ZN0706AE	4924067	04/06/2024 10:43	Total - Residual disinfectant	mg Cl/l	0.77	
ZN0706AE	4924067	04/06/2024 10:43	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4924398	04/06/2024 11:56	E. coli	CFU/100 ml	0	0
ZN0804AE	4924398	04/06/2024 11:56	Free - Residual disinfectant	mg Cl/l	0.73	
ZN0804AE	4924398	04/06/2024 11:56	Total - Residual disinfectant	mg Cl/l	0.85	
ZN0804AE	4924398	04/06/2024 11:56	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4924385	04/06/2024 12:29	E. coli	CFU/100 ml	0	0
ZN0102AE	4924385	04/06/2024 12:29	Free - Residual disinfectant	mg Cl/l	0.13	
ZN0102AE	4924385	04/06/2024 12:29	Hydrogen Ion	pH value	7.6	9.5
ZN0102AE	4924385	04/06/2024 12:29	Total - Residual disinfectant	mg Cl/l	0.25	
ZN0102AE	4924385	04/06/2024 12:29	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4925492	05/06/2024 12:13	Colony Counts 22	CFU/1 ml	0	
ZN0102AE	4925492	05/06/2024 12:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0102AE	4925492	05/06/2024 12:13	E. coli	CFU/100 ml	0	0
ZN0102AE	4925492	05/06/2024 12:13	Free - Residual disinfectant	mg Cl/l	0.11	
ZN0102AE	4925492	05/06/2024 12:13	Total - Residual disinfectant	mg Cl/l	0.22	
ZN0102AE	4925492	05/06/2024 12:13	Total Coliforms	CFU/100 ml	0	0
ZN1102CUST	4938197	06/06/2024 08:45	Aluminium	ug Al/l	13	200
ZN1102CUST	4938197	06/06/2024 08:45	Colour	mg/l Pt/Co	<4.56	20
ZN1102CUST	4938197	06/06/2024 08:45	E. coli	CFU/100 ml	0	0
ZN1102CUST	4938197	06/06/2024 08:45	Free - Residual disinfectant	mg Cl/l	0.5	
ZN1102CUST	4938197	06/06/2024 08:45	Hydrogen Ion	pH value	7.5	9.5
ZN1102CUST	4938197	06/06/2024 08:45	Iron	ug Fe/l	<14	200
ZN1102CUST	4938197	06/06/2024 08:45	Manganese	ug Mn/l	<0.8	50
ZN1102CUST	4938197	06/06/2024 08:45	Odour	Diln No	0	0
ZN1102CUST	4938197	06/06/2024 08:45	Odour - Nature		No odour	
ZN1102CUST	4938197	06/06/2024 08:45	Taste	Diln No	0	0
ZN1102CUST	4938197	06/06/2024 08:45	Taste - Nature		No taste	
ZN1102CUST	4938197	06/06/2024 08:45	Total - Residual disinfectant	mg Cl/l	0.62	
ZN1102CUST	4938197	06/06/2024 08:45	Total Coliforms	CFU/100 ml	0	0
ZN1102CUST	4938197	06/06/2024 08:45	Turbidity	NTU	<0.09	4
ZS0809AE	4924363	06/06/2024 10:00	E. coli	CFU/100 ml	0	0
ZS0809AE	4924363	06/06/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.52	
ZS0809AE	4924363	06/06/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.69	
ZS0809AE	4924363	06/06/2024 10:00	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4924363	06/06/2024 10:00	Turbidity	NTU	<0.09	4
ZS0809AE	4924596	07/06/2024 10:15	E. coli	CFU/100 ml	0	0
ZS0809AE	4924596	07/06/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.45	

ZS0809AE	4924596	07/06/2024 10:15	Total - Residual disinfectant	mg Cl/l	0.57	
ZS0809AE	4924596	07/06/2024 10:15	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4927206	10/06/2024 09:28	Aluminium	ug Al/l	13	200
ZS0809AE	4927206	10/06/2024 09:28	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZS0809AE	4927206	10/06/2024 09:28	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZS0809AE	4927206	10/06/2024 09:28	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZS0809AE	4927206	10/06/2024 09:28	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZS0809AE	4927206	10/06/2024 09:28	Bromate	ug BrO3/l	<0.50	10
ZS0809AE	4927206	10/06/2024 09:28	Colony Counts 22	CFU/1 ml	0	
ZS0809AE	4927206	10/06/2024 09:28	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0809AE	4927206	10/06/2024 09:28	Colour	mg/l Pt/Co	<4.56	20
ZS0809AE	4927206	10/06/2024 09:28	Conductivity	uS/cm 20 C	400	2500
ZS0809AE	4927206	10/06/2024 09:28	E. coli	CFU/100 ml	0	0
ZS0809AE	4927206	10/06/2024 09:28	Free - Residual disinfectant	mg Cl/l	0.66	
ZS0809AE	4927206	10/06/2024 09:28	Hydrogen Ion	pH value	7.6	9.5
ZS0809AE	4927206	10/06/2024 09:28	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZS0809AE	4927206	10/06/2024 09:28	Iron	ug/l Fe	<5.0	200
ZS0809AE	4927206	10/06/2024 09:28	Manganese	ug Mn/l	<2.0	50
ZS0809AE	4927206	10/06/2024 09:28	Odour	Diln No	0	0
ZS0809AE	4927206	10/06/2024 09:28	Odour - Nature		No odour	
ZS0809AE	4927206	10/06/2024 09:28	PAH - Sum of four substances	ug/l	0	0.1
ZS0809AE	4927206	10/06/2024 09:28	Taste	Diln No	0	0
ZS0809AE	4927206	10/06/2024 09:28	Taste - Nature		No taste	
ZS0809AE	4927206	10/06/2024 09:28	Total - Residual disinfectant	mg Cl/l	0.9	
ZS0809AE	4927206	10/06/2024 09:28	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4927206	10/06/2024 09:28	Turbidity	NTU	<0.09	4
ZS0811AE	4927255	10/06/2024 10:14	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZS0811AE	4927255	10/06/2024 10:14	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZS0811AE	4927255	10/06/2024 10:14	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZS0811AE	4927255	10/06/2024 10:14	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZS0811AE	4927255	10/06/2024 10:14	Bromate	ug BrO3/l	0.53	10
ZS0811AE	4927255	10/06/2024 10:14	E. coli	CFU/100 ml	0	0
ZS0811AE	4927255	10/06/2024 10:14	Free - Residual disinfectant	mg Cl/l	0.42	
ZS0811AE	4927255	10/06/2024 10:14	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZS0811AE	4927255	10/06/2024 10:14	PAH - Sum of four substances	ug/l	0	0.1
ZS0811AE	4927255	10/06/2024 10:14	Total - Residual disinfectant	mg Cl/l	0.67	
ZS0811AE	4927255	10/06/2024 10:14	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4927231	10/06/2024 10:21	Aluminium	ug Al/l	33	200

ZN0501AE	4927231	10/06/2024 10:21	Colony Counts 22	CFU/1 ml	0	
ZN0501AE	4927231	10/06/2024 10:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0501AE	4927231	10/06/2024 10:21	Colour	mg/l Pt/Co	<4.56	20
ZN0501AE	4927231	10/06/2024 10:21	Conductivity	uS/cm 20 C	360	2500
ZN0501AE	4927231	10/06/2024 10:21	E. coli	CFU/100 ml	0	0
ZN0501AE	4927231	10/06/2024 10:21	Free - Residual disinfectant	mg Cl/l	0.39	
ZN0501AE	4927231	10/06/2024 10:21	Hydrogen Ion	pH value	7.7	9.5
ZN0501AE	4927231	10/06/2024 10:21	Iron	ug/l Fe	<5.0	200
ZN0501AE	4927231	10/06/2024 10:21	Manganese	ug Mn/l	<2.0	50
ZN0501AE	4927231	10/06/2024 10:21	Odour	Diln No	0	0
ZN0501AE	4927231	10/06/2024 10:21	Odour - Nature		No odour	
ZN0501AE	4927231	10/06/2024 10:21	Taste	Diln No	0	0
ZN0501AE	4927231	10/06/2024 10:21	Taste - Nature		No taste	
ZN0501AE	4927231	10/06/2024 10:21	Total - Residual disinfectant	mg Cl/l	0.66	
ZN0501AE	4927231	10/06/2024 10:21	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4927231	10/06/2024 10:21	Turbidity	NTU	<0.09	4
ZN0705AE	4927258	10/06/2024 11:34	Aluminium	ug Al/l	18	200
ZN0705AE	4927258	10/06/2024 11:34	Colony Counts 22	CFU/1 ml	0	
ZN0705AE	4927258	10/06/2024 11:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0705AE	4927258	10/06/2024 11:34	Colour	mg/l Pt/Co	<4.56	20
ZN0705AE	4927258	10/06/2024 11:34	Conductivity	uS/cm 20 C	130	2500
ZN0705AE	4927258	10/06/2024 11:34	E. coli	CFU/100 ml	0	0
ZN0705AE	4927258	10/06/2024 11:34	Free - Residual disinfectant	mg Cl/l	0.34	
ZN0705AE	4927258	10/06/2024 11:34	Hydrogen Ion	pH value	7.1	9.5
ZN0705AE	4927258	10/06/2024 11:34	Iron	ug/l Fe	<5.0	200
ZN0705AE	4927258	10/06/2024 11:34	Manganese	ug Mn/l	<2.0	50
ZN0705AE	4927258	10/06/2024 11:34	Odour	Diln No	0	0
ZN0705AE	4927258	10/06/2024 11:34	Odour - Nature		No odour	
ZN0705AE	4927258	10/06/2024 11:34	Taste	Diln No	0	0
ZN0705AE	4927258	10/06/2024 11:34	Taste - Nature		No taste	
ZN0705AE	4927258	10/06/2024 11:34	Total - Residual disinfectant	mg Cl/l	0.47	
ZN0705AE	4927258	10/06/2024 11:34	Total Coliforms	CFU/100 ml	0	0
ZN0705AE	4927258	10/06/2024 11:34	Turbidity	NTU	<0.09	4
ZN0102AE	4927233	10/06/2024 11:43	Aluminium	ug Al/l	21	200
ZN0102AE	4927233	10/06/2024 11:43	Colony Counts 22	CFU/1 ml	0	
ZN0102AE	4927233	10/06/2024 11:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0102AE	4927233	10/06/2024 11:43	Colour	mg/l Pt/Co	<4.56	20
ZN0102AE	4927233	10/06/2024 11:43	Conductivity	uS/cm 20 C	310	2500

ZN0102AE	4927233	10/06/2024 11:43	E. coli	CFU/100 ml	0	0
ZN0102AE	4927233	10/06/2024 11:43	Free - Residual disinfectant	mg Cl/l	0.29	
ZN0102AE	4927233	10/06/2024 11:43	Hydrogen Ion	pH value	7.5	9.5
ZN0102AE	4927233	10/06/2024 11:43	Iron	ug/l Fe	32	200
ZN0102AE	4927233	10/06/2024 11:43	Manganese	ug Mn/l	<2.0	50
ZN0102AE	4927233	10/06/2024 11:43	Total - Residual disinfectant	mg Cl/l	0.47	
ZN0102AE	4927233	10/06/2024 11:43	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4927233	10/06/2024 11:43	Turbidity	NTU	0.12	4
ZN1102AE	4927570	11/06/2024 09:29	Aluminium	ug Al/l	16	200
ZN1102AE	4927570	11/06/2024 09:29	Colony Counts 22	CFU/1 ml	0	
ZN1102AE	4927570	11/06/2024 09:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN1102AE	4927570	11/06/2024 09:29	Colour	mg/l Pt/Co	<4.56	20
ZN1102AE	4927570	11/06/2024 09:29	Conductivity	uS/cm 20 C	340	2500
ZN1102AE	4927570	11/06/2024 09:29	E. coli	CFU/100 ml	0	0
ZN1102AE	4927570	11/06/2024 09:29	Free - Residual disinfectant	mg Cl/l	0.71	
ZN1102AE	4927570	11/06/2024 09:29	Hydrogen Ion	pH value	7.5	9.5
ZN1102AE	4927570	11/06/2024 09:29	Iron	ug/l Fe	<5.0	200
ZN1102AE	4927570	11/06/2024 09:29	Manganese	ug Mn/l	<2.0	50
ZN1102AE	4927570	11/06/2024 09:29	Odour	Diln No	0	0
ZN1102AE	4927570	11/06/2024 09:29	Odour - Nature		No odour	
ZN1102AE	4927570	11/06/2024 09:29	Taste	Diln No	0	0
ZN1102AE	4927570	11/06/2024 09:29	Taste - Nature		No taste	
ZN1102AE	4927570	11/06/2024 09:29	Total - Residual disinfectant	mg Cl/l	0.95	
ZN1102AE	4927570	11/06/2024 09:29	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4927570	11/06/2024 09:29	Turbidity	NTU	<0.09	4
ZN0804AE	4927257	11/06/2024 09:38	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN0804AE	4927257	11/06/2024 09:38	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0804AE	4927257	11/06/2024 09:38	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0804AE	4927257	11/06/2024 09:38	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0804AE	4927257	11/06/2024 09:38	Bromate	ug BrO3/l	1.5	10
ZN0804AE	4927257	11/06/2024 09:38	E. coli	CFU/100 ml	0	0
ZN0804AE	4927257	11/06/2024 09:38	Free - Residual disinfectant	mg Cl/l	0.69	
ZN0804AE	4927257	11/06/2024 09:38	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0804AE	4927257	11/06/2024 09:38	PAH - Sum of four substances	ug/l	0	0.1
ZN0804AE	4927257	11/06/2024 09:38	Total - Residual disinfectant	mg Cl/l	0.8	
ZN0804AE	4927257	11/06/2024 09:38	Total Coliforms	CFU/100 ml	0	0
ZN0706AE	4927259	11/06/2024 10:35	Aluminium	ug Al/l	12	200
ZN0706AE	4927259	11/06/2024 10:35	Colony Counts 22	CFU/1 ml	1	

ZN0706AE	4927259	11/06/2024 10:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0706AE	4927259	11/06/2024 10:35	Colour	mg/l Pt/Co	<4.56	20
ZN0706AE	4927259	11/06/2024 10:35	Conductivity	uS/cm 20 C	160	2500
ZN0706AE	4927259	11/06/2024 10:35	E. coli	CFU/100 ml	0	0
ZN0706AE	4927259	11/06/2024 10:35	Free - Residual disinfectant	mg Cl/l	0.6	
ZN0706AE	4927259	11/06/2024 10:35	Hydrogen Ion	pH value	7.4	9.5
ZN0706AE	4927259	11/06/2024 10:35	Iron	ug/l Fe	16	200
ZN0706AE	4927259	11/06/2024 10:35	Manganese	ug Mn/l	<2.0	50
ZN0706AE	4927259	11/06/2024 10:35	Odour	Diln No	0	0
ZN0706AE	4927259	11/06/2024 10:35	Odour - Nature		No odour	
ZN0706AE	4927259	11/06/2024 10:35	Taste	Diln No	0	0
ZN0706AE	4927259	11/06/2024 10:35	Taste - Nature		No taste	
ZN0706AE	4927259	11/06/2024 10:35	Total - Residual disinfectant	mg Cl/l	0.7	
ZN0706AE	4927259	11/06/2024 10:35	Total Coliforms	CFU/100 ml	0	0
ZN0706AE	4927259	11/06/2024 10:35	Turbidity	NTU	<0.09	4
ZN0502AE	4927592	11/06/2024 10:49	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN0502AE	4927592	11/06/2024 10:49	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0502AE	4927592	11/06/2024 10:49	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0502AE	4927592	11/06/2024 10:49	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0502AE	4927592	11/06/2024 10:49	E. coli	CFU/100 ml	0	0
ZN0502AE	4927592	11/06/2024 10:49	Free - Residual disinfectant	mg Cl/l	0.49	
ZN0502AE	4927592	11/06/2024 10:49	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0502AE	4927592	11/06/2024 10:49	PAH - Sum of four substances	ug/l	0	0.1
ZN0502AE	4927592	11/06/2024 10:49	Total - Residual disinfectant	mg Cl/l	0.55	
ZN0502AE	4927592	11/06/2024 10:49	Total Coliforms	CFU/100 ml	0	0
ZN0102CUST	4941051	12/06/2024 09:15	Aluminium	ug Al/l	25	200
ZN0102CUST	4941051	12/06/2024 09:15	Colour	mg/l Pt/Co	<4.56	20
ZN0102CUST	4941051	12/06/2024 09:15	E. coli	CFU/100 ml	0	0
ZN0102CUST	4941051	12/06/2024 09:15	Free - Residual disinfectant	mg Cl/l	0.06	
ZN0102CUST	4941051	12/06/2024 09:15	Hydrogen Ion	pH value	7.6	9.5
ZN0102CUST	4941051	12/06/2024 09:15	Iron	ug Fe/l	<14	200
ZN0102CUST	4941051	12/06/2024 09:15	Manganese	ug Mn/l	1.1	50
ZN0102CUST	4941051	12/06/2024 09:15	Odour	Diln No	0	0
ZN0102CUST	4941051	12/06/2024 09:15	Odour - Nature		No odour	
ZN0102CUST	4941051	12/06/2024 09:15	Taste	Diln No	0	0
ZN0102CUST	4941051	12/06/2024 09:15	Taste - Nature		No taste	
ZN0102CUST	4941051	12/06/2024 09:15	Total - Residual disinfectant	mg Cl/l	0.26	
ZN0102CUST	4941051	12/06/2024 09:15	Total Coliforms	CFU/100 ml	0	0

ZN0102CUST	4941051	12/06/2024 09:15	Turbidity	NTU	0.17	4
ZN1102AE	4927209	12/06/2024 09:17	E. coli	CFU/100 ml	0	0
ZN1102AE	4927209	12/06/2024 09:17	Free - Residual disinfectant	mg Cl/l	0.58	
ZN1102AE	4927209	12/06/2024 09:17	Total - Residual disinfectant	mg Cl/l	0.78	
ZN1102AE	4927209	12/06/2024 09:17	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4927209	12/06/2024 09:17	Turbidity	NTU	<0.09	4
ZN0504AE	4927203	12/06/2024 09:47	1,2 Dichloroethane	ug/l	<0.4	3
ZN0504AE	4927203	12/06/2024 09:47	Aluminium	ug Al/l	34	200
ZN0504AE	4927203	12/06/2024 09:47	Benzene	ug/l	<0.15	1
ZN0504AE	4927203	12/06/2024 09:47	Colony Counts 22	CFU/1 ml	0	
ZN0504AE	4927203	12/06/2024 09:47	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0504AE	4927203	12/06/2024 09:47	Colour	mg/l Pt/Co	<4.56	20
ZN0504AE	4927203	12/06/2024 09:47	Conductivity	uS/cm 20 C	240	2500
ZN0504AE	4927203	12/06/2024 09:47	E. coli	CFU/100 ml	0	0
ZN0504AE	4927203	12/06/2024 09:47	Free - Residual disinfectant	mg Cl/l	0.47	
ZN0504AE	4927203	12/06/2024 09:47	Hydrogen Ion	pH value	7.5	9.5
ZN0504AE	4927203	12/06/2024 09:47	Iron	ug/l Fe	7.7	200
ZN0504AE	4927203	12/06/2024 09:47	Manganese	ug Mn/l	<2.0	50
ZN0504AE	4927203	12/06/2024 09:47	Mercury	ug per l	<0.041	1
ZN0504AE	4927203	12/06/2024 09:47	Odour	Diln No	0	0
ZN0504AE	4927203	12/06/2024 09:47	Odour - Nature		No odour	
ZN0504AE	4927203	12/06/2024 09:47	Taste	Diln No	0	0
ZN0504AE	4927203	12/06/2024 09:47	Taste - Nature		No taste	
ZN0504AE	4927203	12/06/2024 09:47	Tetrachloroethene	ug/l	<0.8	
ZN0504AE	4927203	12/06/2024 09:47	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0504AE	4927203	12/06/2024 09:47	Tetrachloromethane	ug/l	<0.4	3
ZN0504AE	4927203	12/06/2024 09:47	Total - Residual disinfectant	mg Cl/l	0.56	
ZN0504AE	4927203	12/06/2024 09:47	Total Coliforms	CFU/100 ml	0	0
ZN0504AE	4927203	12/06/2024 09:47	Trichloroethene	ug/l	<0.7	
ZN0504AE	4927203	12/06/2024 09:47	Turbidity	NTU	<0.09	4
ZS0811AE	4927606	12/06/2024 09:59	Aluminium	ug Al/l	19	200
ZS0811AE	4927606	12/06/2024 09:59	Colony Counts 22	CFU/1 ml	0	
ZS0811AE	4927606	12/06/2024 09:59	Colony Counts 37 (48hrs)	CFU/1 ml	1	
ZS0811AE	4927606	12/06/2024 09:59	Colour	mg/l Pt/Co	<4.56	20
ZS0811AE	4927606	12/06/2024 09:59	Conductivity	uS/cm 20 C	390	2500
ZS0811AE	4927606	12/06/2024 09:59	E. coli	CFU/100 ml	0	0
ZS0811AE	4927606	12/06/2024 09:59	Free - Residual disinfectant	mg Cl/l	0.62	
ZS0811AE	4927606	12/06/2024 09:59	Hydrogen Ion	pH value	7.6	9.5

ZS0811AE	4927606	12/06/2024 09:59	Iron	ug/l Fe	5.4	200
ZS0811AE	4927606	12/06/2024 09:59	Manganese	ug Mn/l	<2.0	50
ZS0811AE	4927606	12/06/2024 09:59	Odour	Diln No	0	0
ZS0811AE	4927606	12/06/2024 09:59	Odour - Nature		No odour	
ZS0811AE	4927606	12/06/2024 09:59	Taste	Diln No	0	0
ZS0811AE	4927606	12/06/2024 09:59	Taste - Nature		No taste	
ZS0811AE	4927606	12/06/2024 09:59	Total - Residual disinfectant	mg Cl/l	0.82	
ZS0811AE	4927606	12/06/2024 09:59	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4927606	12/06/2024 09:59	Turbidity	NTU	<0.09	4
ZS0809CUST	4941026	12/06/2024 10:00	Aluminium	ug Al/l	9	200
ZS0809CUST	4941026	12/06/2024 10:00	Colour	mg/l Pt/Co	<4.56	20
ZS0809CUST	4941026	12/06/2024 10:00	E. coli	CFU/100 ml	0	0
ZS0809CUST	4941026	12/06/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.32	
ZS0809CUST	4941026	12/06/2024 10:00	Hydrogen Ion	pH value	7.3	9.5
ZS0809CUST	4941026	12/06/2024 10:00	Iron	ug Fe/l	<14	200
ZS0809CUST	4941026	12/06/2024 10:00	Manganese	ug Mn/l	<0.8	50
ZS0809CUST	4941026	12/06/2024 10:00	Odour	Diln No	0	0
ZS0809CUST	4941026	12/06/2024 10:00	Odour - Nature		No odour	
ZS0809CUST	4941026	12/06/2024 10:00	Taste	Diln No	0	0
ZS0809CUST	4941026	12/06/2024 10:00	Taste - Nature		No taste	
ZS0809CUST	4941026	12/06/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.45	
ZS0809CUST	4941026	12/06/2024 10:00	Total Coliforms	CFU/100 ml	0	0
ZS0809CUST	4941026	12/06/2024 10:00	Turbidity	NTU	<0.09	4
ZN0102AE	4927801	12/06/2024 10:43	E. coli	CFU/100 ml	0	0
ZN0102AE	4927801	12/06/2024 10:43	Free - Residual disinfectant	mg Cl/l	0.18	
ZN0102AE	4927801	12/06/2024 10:43	Total - Residual disinfectant	mg Cl/l	0.31	
ZN0102AE	4927801	12/06/2024 10:43	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4927568	13/06/2024 09:48	E. coli	CFU/100 ml	0	0
ZS0809AE	4927568	13/06/2024 09:48	Free - Residual disinfectant	mg Cl/l	0.23	
ZS0809AE	4927568	13/06/2024 09:48	Total - Residual disinfectant	mg Cl/l	0.34	
ZS0809AE	4927568	13/06/2024 09:48	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4927591	13/06/2024 09:49	Colour	mg/l Pt/Co	<4.56	20
ZN0102AE	4927591	13/06/2024 09:49	E. coli	CFU/100 ml	0	0
ZN0102AE	4927591	13/06/2024 09:49	Free - Residual disinfectant	mg Cl/l	0.4	
ZN0102AE	4927591	13/06/2024 09:49	Total - Residual disinfectant	mg Cl/l	0.58	
ZN0102AE	4927591	13/06/2024 09:49	Total Coliforms	CFU/100 ml	0	0
ZN0502AE	4927234	13/06/2024 10:10	Aluminium	ug Al/l	22	200
ZN0502AE	4927234	13/06/2024 10:10	Colony Counts 22	CFU/1 ml	0	

ZN0502AE	4927234	13/06/2024 10:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0502AE	4927234	13/06/2024 10:10	Colour	mg/l Pt/Co	<4.56	20
ZN0502AE	4927234	13/06/2024 10:10	Conductivity	uS/cm 20 C	120	2500
ZN0502AE	4927234	13/06/2024 10:10	E. coli	CFU/100 ml	0	0
ZN0502AE	4927234	13/06/2024 10:10	Free - Residual disinfectant	mg Cl/l	0.48	
ZN0502AE	4927234	13/06/2024 10:10	Hydrogen Ion	pH value	7.3	9.5
ZN0502AE	4927234	13/06/2024 10:10	Iron	ug/l Fe	<5.0	200
ZN0502AE	4927234	13/06/2024 10:10	Manganese	ug Mn/l	<2.0	50
ZN0502AE	4927234	13/06/2024 10:10	Mercury	ug per l	<0.041	1
ZN0502AE	4927234	13/06/2024 10:10	Odour	Diln No	0	0
ZN0502AE	4927234	13/06/2024 10:10	Odour - Nature		No odour	
ZN0502AE	4927234	13/06/2024 10:10	Taste	Diln No	0	0
ZN0502AE	4927234	13/06/2024 10:10	Taste - Nature		No taste	
ZN0502AE	4927234	13/06/2024 10:10	Total - Residual disinfectant	mg Cl/l	0.57	
ZN0502AE	4927234	13/06/2024 10:10	Total Coliforms	CFU/100 ml	0	0
ZN0502AE	4927234	13/06/2024 10:10	Turbidity	NTU	<0.09	4
ZS0811AE	4927803	13/06/2024 10:18	E. coli	CFU/100 ml	0	0
ZS0811AE	4927803	13/06/2024 10:18	Free - Residual disinfectant	mg Cl/l	0.7	
ZS0811AE	4927803	13/06/2024 10:18	Total - Residual disinfectant	mg Cl/l	0.88	
ZS0811AE	4927803	13/06/2024 10:18	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4927590	13/06/2024 10:21	E. coli	CFU/100 ml	0	0
ZN0501AE	4927590	13/06/2024 10:21	Free - Residual disinfectant	mg Cl/l	0.14	
ZN0501AE	4927590	13/06/2024 10:21	Total - Residual disinfectant	mg Cl/l	0.48	
ZN0501AE	4927590	13/06/2024 10:21	Total Coliforms	CFU/100 ml	0	0
ZS0809CUST	4941551	13/06/2024 11:00	Aluminium	ug Al/l	18	200
ZS0809CUST	4941551	13/06/2024 11:00	Colour	mg/l Pt/Co	<4.56	20
ZS0809CUST	4941551	13/06/2024 11:00	E. coli	CFU/100 ml	0	0
ZS0809CUST	4941551	13/06/2024 11:00	Free - Residual disinfectant	mg Cl/l	0.24	
ZS0809CUST	4941551	13/06/2024 11:00	Hydrogen Ion	pH value	7.5	9.5
ZS0809CUST	4941551	13/06/2024 11:00	Iron	ug Fe/l	<14	200
ZS0809CUST	4941551	13/06/2024 11:00	Manganese	ug Mn/l	<0.8	50
ZS0809CUST	4941551	13/06/2024 11:00	Odour	Diln No	0	0
ZS0809CUST	4941551	13/06/2024 11:00	Odour - Nature		No odour	
ZS0809CUST	4941551	13/06/2024 11:00	Taste	Diln No	0	0
ZS0809CUST	4941551	13/06/2024 11:00	Taste - Nature		No taste	
ZS0809CUST	4941551	13/06/2024 11:00	Total - Residual disinfectant	mg Cl/l	0.37	
ZS0809CUST	4941551	13/06/2024 11:00	Total Coliforms	CFU/100 ml	0	0
ZS0809CUST	4941551	13/06/2024 11:00	Turbidity	NTU	<0.09	4

ZN0706AE	4927609	13/06/2024 11:47	E. coli	CFU/100 ml	0	0
ZN0706AE	4927609	13/06/2024 11:47	Free - Residual disinfectant	mg Cl/l	1.01	
ZN0706AE	4927609	13/06/2024 11:47	Total - Residual disinfectant	mg Cl/l	1.12	
ZN0706AE	4927609	13/06/2024 11:47	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4930548	17/06/2024 09:44	Aluminium	ug Al/l	21	200
ZS0809AE	4930548	17/06/2024 09:44	Colony Counts 22	CFU/1 ml	0	
ZS0809AE	4930548	17/06/2024 09:44	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0809AE	4930548	17/06/2024 09:44	Colour	mg/l Pt/Co	<4.56	20
ZS0809AE	4930548	17/06/2024 09:44	Conductivity	uS/cm 20 C	390	2500
ZS0809AE	4930548	17/06/2024 09:44	E. coli	CFU/100 ml	0	0
ZS0809AE	4930548	17/06/2024 09:44	Free - Residual disinfectant	mg Cl/l	0.53	
ZS0809AE	4930548	17/06/2024 09:44	Hydrogen Ion	pH value	7.6	9.5
ZS0809AE	4930548	17/06/2024 09:44	Iron	ug/l Fe	4.4	200
ZS0809AE	4930548	17/06/2024 09:44	Manganese	ug Mn/l	<0.80	50
ZS0809AE	4930548	17/06/2024 09:44	Odour	Diln No	0	0
ZS0809AE	4930548	17/06/2024 09:44	Odour - Nature		No odour	
ZS0809AE	4930548	17/06/2024 09:44	Taste	Diln No	0	0
ZS0809AE	4930548	17/06/2024 09:44	Taste - Nature		No taste	
ZS0809AE	4930548	17/06/2024 09:44	Total - Residual disinfectant	mg Cl/l	0.69	
ZS0809AE	4930548	17/06/2024 09:44	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4930548	17/06/2024 09:44	Turbidity	NTU	<0.09	4
ZN0706AE	4930597	17/06/2024 10:19	E. coli	CFU/100 ml	0	0
ZN0706AE	4930597	17/06/2024 10:19	Free - Residual disinfectant	mg Cl/l	0.51	
ZN0706AE	4930597	17/06/2024 10:19	Total - Residual disinfectant	mg Cl/l	0.6	
ZN0706AE	4930597	17/06/2024 10:19	Total Coliforms	CFU/100 ml	0	0
ZN0504AE	4930546	17/06/2024 10:21	Aluminium	ug Al/l	30	200
ZN0504AE	4930546	17/06/2024 10:21	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN0504AE	4930546	17/06/2024 10:21	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0504AE	4930546	17/06/2024 10:21	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0504AE	4930546	17/06/2024 10:21	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0504AE	4930546	17/06/2024 10:21	E. coli	CFU/100 ml	0	0
ZN0504AE	4930546	17/06/2024 10:21	Free - Residual disinfectant	mg Cl/l	0.38	
ZN0504AE	4930546	17/06/2024 10:21	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0504AE	4930546	17/06/2024 10:21	Iron	ug/l Fe	3.6	200
ZN0504AE	4930546	17/06/2024 10:21	Manganese	ug Mn/l	<0.80	50
ZN0504AE	4930546	17/06/2024 10:21	Mercury	ug per l	<0.041	1
ZN0504AE	4930546	17/06/2024 10:21	PAH - Sum of four substances	ug/l	0	0.1
ZN0504AE	4930546	17/06/2024 10:21	Total - Residual disinfectant	mg Cl/l	0.46	

ZN0504AE	4930546	17/06/2024 10:21	Total Coliforms	CFU/100 ml	0	0
ZN0504AE	4930546	17/06/2024 10:21	Turbidity	NTU	<0.09	4
ZS0811AE	4930593	17/06/2024 10:32	E. coli	CFU/100 ml	0	0
ZS0811AE	4930593	17/06/2024 10:32	Free - Residual disinfectant	mg Cl/l	0.19	
ZS0811AE	4930593	17/06/2024 10:32	Total - Residual disinfectant	mg Cl/l	0.37	
ZS0811AE	4930593	17/06/2024 10:32	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4930571	17/06/2024 11:06	Aluminium	ug Al/l	32	200
ZN0501AE	4930571	17/06/2024 11:06	Colony Counts 22	CFU/1 ml	0	
ZN0501AE	4930571	17/06/2024 11:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0501AE	4930571	17/06/2024 11:06	Colour	mg/l Pt/Co	<4.56	20
ZN0501AE	4930571	17/06/2024 11:06	Conductivity	uS/cm 20 C	360	2500
ZN0501AE	4930571	17/06/2024 11:06	E. coli	CFU/100 ml	0	0
ZN0501AE	4930571	17/06/2024 11:06	Free - Residual disinfectant	mg Cl/l	0.56	
ZN0501AE	4930571	17/06/2024 11:06	Hydrogen Ion	pH value	7.7	9.5
ZN0501AE	4930571	17/06/2024 11:06	Iron	ug/l Fe	<1.538	200
ZN0501AE	4930571	17/06/2024 11:06	Manganese	ug Mn/l	<0.80	50
ZN0501AE	4930571	17/06/2024 11:06	Odour	Diln No	0	0
ZN0501AE	4930571	17/06/2024 11:06	Odour - Nature		No odour	
ZN0501AE	4930571	17/06/2024 11:06	Taste	Diln No	0	0
ZN0501AE	4930571	17/06/2024 11:06	Taste - Nature		No taste	
ZN0501AE	4930571	17/06/2024 11:06	Total - Residual disinfectant	mg Cl/l	0.65	
ZN0501AE	4930571	17/06/2024 11:06	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4930571	17/06/2024 11:06	Turbidity	NTU	<0.09	4
ZN0102AE	4930573	18/06/2024 09:23	Aluminium	ug Al/l	18	200
ZN0102AE	4930573	18/06/2024 09:23	Colony Counts 22	CFU/1 ml	0	
ZN0102AE	4930573	18/06/2024 09:23	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0102AE	4930573	18/06/2024 09:23	Colour	mg/l Pt/Co	<4.56	20
ZN0102AE	4930573	18/06/2024 09:23	Conductivity	uS/cm 20 C	320	2500
ZN0102AE	4930573	18/06/2024 09:23	E. coli	CFU/100 ml	0	0
ZN0102AE	4930573	18/06/2024 09:23	Free - Residual disinfectant	mg Cl/l	0.2	
ZN0102AE	4930573	18/06/2024 09:23	Hydrogen Ion	pH value	7.2	9.5
ZN0102AE	4930573	18/06/2024 09:23	Iron	ug Fe/l	64	200
ZN0102AE	4930573	18/06/2024 09:23	Manganese	ug Mn/l	4.2	50
ZN0102AE	4930573	18/06/2024 09:23	Odour	Diln No	0	0
ZN0102AE	4930573	18/06/2024 09:23	Odour - Nature		No odour	
ZN0102AE	4930573	18/06/2024 09:23	Taste	Diln No	0	0
ZN0102AE	4930573	18/06/2024 09:23	Taste - Nature		No taste	
ZN0102AE	4930573	18/06/2024 09:23	Total - Residual disinfectant	mg Cl/l	0.34	

ZN0102AE	4930573	18/06/2024 09:23	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4930573	18/06/2024 09:23	Turbidity	NTU	0.14	4
ZS0809AE	4930841	18/06/2024 09:53	E. coli	CFU/100 ml	0	0
ZS0809AE	4930841	18/06/2024 09:53	Free - Residual disinfectant	mg Cl/l	0.41	
ZS0809AE	4930841	18/06/2024 09:53	Total - Residual disinfectant	mg Cl/l	0.7	
ZS0809AE	4930841	18/06/2024 09:53	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4930843	18/06/2024 10:30	Aluminium	ug Al/l	6.4	200
ZN1102AE	4930843	18/06/2024 10:30	Colony Counts 22	CFU/1 ml	0	
ZN1102AE	4930843	18/06/2024 10:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN1102AE	4930843	18/06/2024 10:30	Colour	mg/l Pt/Co	<4.56	20
ZN1102AE	4930843	18/06/2024 10:30	Conductivity	uS/cm 20 C	340	2500
ZN1102AE	4930843	18/06/2024 10:30	E. coli	CFU/100 ml	0	0
ZN1102AE	4930843	18/06/2024 10:30	Free - Residual disinfectant	mg Cl/l	0.71	
ZN1102AE	4930843	18/06/2024 10:30	Hydrogen Ion	pH value	7.5	9.5
ZN1102AE	4930843	18/06/2024 10:30	Iron	ug/l Fe	8.5	200
ZN1102AE	4930843	18/06/2024 10:30	Manganese	ug Mn/l	<0.80	50
ZN1102AE	4930843	18/06/2024 10:30	Odour	Diln No	0	0
ZN1102AE	4930843	18/06/2024 10:30	Odour - Nature		No odour	
ZN1102AE	4930843	18/06/2024 10:30	Taste	Diln No	0	0
ZN1102AE	4930843	18/06/2024 10:30	Taste - Nature		No taste	
ZN1102AE	4930843	18/06/2024 10:30	Total - Residual disinfectant	mg Cl/l	0.94	
ZN1102AE	4930843	18/06/2024 10:30	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4930843	18/06/2024 10:30	Turbidity	NTU	<0.09	4
ZS0811AE	4930874	18/06/2024 11:16	Aluminium	ug Al/l	20	200
ZS0811AE	4930874	18/06/2024 11:16	Colony Counts 22	CFU/1 ml	0	
ZS0811AE	4930874	18/06/2024 11:16	Colony Counts 37 (48hrs)	CFU/1 ml	1	
ZS0811AE	4930874	18/06/2024 11:16	Colour	mg/l Pt/Co	<4.56	20
ZS0811AE	4930874	18/06/2024 11:16	Conductivity	uS/cm 20 C	390	2500
ZS0811AE	4930874	18/06/2024 11:16	E. coli	CFU/100 ml	0	0
ZS0811AE	4930874	18/06/2024 11:16	Free - Residual disinfectant	mg Cl/l	0.41	
ZS0811AE	4930874	18/06/2024 11:16	Hydrogen Ion	pH value	7.6	9.5
ZS0811AE	4930874	18/06/2024 11:16	Iron	ug/l Fe	13	200
ZS0811AE	4930874	18/06/2024 11:16	Manganese	ug Mn/l	<0.80	50
ZS0811AE	4930874	18/06/2024 11:16	Odour	Diln No	0	0
ZS0811AE	4930874	18/06/2024 11:16	Odour - Nature		No odour	
ZS0811AE	4930874	18/06/2024 11:16	Taste	Diln No	0	0
ZS0811AE	4930874	18/06/2024 11:16	Taste - Nature		No taste	
ZS0811AE	4930874	18/06/2024 11:16	Total - Residual disinfectant	mg Cl/l	0.59	

ZS0811AE	4930874	18/06/2024 11:16	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4930874	18/06/2024 11:16	Turbidity	NTU	<0.09	4
ZN0804AE	4927608	18/06/2024 11:37	Aluminium	ug Al/l	23	200
ZN0804AE	4927608	18/06/2024 11:37	Colony Counts 22	CFU/1 ml	0	
ZN0804AE	4927608	18/06/2024 11:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0804AE	4927608	18/06/2024 11:37	Colour	mg/l Pt/Co	<4.56	20
ZN0804AE	4927608	18/06/2024 11:37	Conductivity	uS/cm 20 C	420	2500
ZN0804AE	4927608	18/06/2024 11:37	E. coli	CFU/100 ml	0	0
ZN0804AE	4927608	18/06/2024 11:37	Free - Residual disinfectant	mg Cl/l	0.8	
ZN0804AE	4927608	18/06/2024 11:37	Hydrogen Ion	pH value	7.7	9.5
ZN0804AE	4927608	18/06/2024 11:37	Iron	ug/l Fe	9.8	200
ZN0804AE	4927608	18/06/2024 11:37	Manganese	ug Mn/l	7.8	50
ZN0804AE	4927608	18/06/2024 11:37	Odour	Diln No	0	0
ZN0804AE	4927608	18/06/2024 11:37	Odour - Nature		No odour	
ZN0804AE	4927608	18/06/2024 11:37	Taste	Diln No	0	0
ZN0804AE	4927608	18/06/2024 11:37	Taste - Nature		No taste	
ZN0804AE	4927608	18/06/2024 11:37	Total - Residual disinfectant	mg Cl/l	1.19	
ZN0804AE	4927608	18/06/2024 11:37	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4927608	18/06/2024 11:37	Turbidity	NTU	<0.09	4
ZN0501AE	4930861	19/06/2024 11:21	E. coli	CFU/100 ml	0	0
ZN0501AE	4930861	19/06/2024 11:21	Free - Residual disinfectant	mg Cl/l	0.24	
ZN0501AE	4930861	19/06/2024 11:21	Total - Residual disinfectant	mg Cl/l	0.41	
ZN0501AE	4930861	19/06/2024 11:21	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4930550	20/06/2024 10:04	E. coli	CFU/100 ml	0	0
ZN1102AE	4930550	20/06/2024 10:04	Free - Residual disinfectant	mg Cl/l	0.49	
ZN1102AE	4930550	20/06/2024 10:04	Total - Residual disinfectant	mg Cl/l	0.68	
ZN1102AE	4930550	20/06/2024 10:04	Total Coliforms	CFU/100 ml	0	0
ZN0502AE	4930574	21/06/2024 09:22	E. coli	CFU/100 ml	0	0
ZN0502AE	4930574	21/06/2024 09:22	Free - Residual disinfectant	mg Cl/l	0.62	
ZN0502AE	4930574	21/06/2024 09:22	Total - Residual disinfectant	mg Cl/l	0.71	
ZN0502AE	4930574	21/06/2024 09:22	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4930863	21/06/2024 09:44	E. coli	CFU/100 ml	0	0
ZN0102AE	4930863	21/06/2024 09:44	Free - Residual disinfectant	mg Cl/l	0.37	
ZN0102AE	4930863	21/06/2024 09:44	Total - Residual disinfectant	mg Cl/l	0.61	
ZN0102AE	4930863	21/06/2024 09:44	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4931055	21/06/2024 10:50	E. coli	CFU/100 ml	0	0
ZS0809AE	4931055	21/06/2024 10:50	Free - Residual disinfectant	mg Cl/l	0.33	
ZS0809AE	4931055	21/06/2024 10:50	Total - Residual disinfectant	mg Cl/l	0.48	

ZS0809AE	4931055	21/06/2024 10:50	Total Coliforms	CFU/100 ml	0	0
ZN0502AE	4933337	24/06/2024 09:04	E. coli	CFU/100 ml	0	0
ZN0502AE	4933337	24/06/2024 09:04	Free - Residual disinfectant	mg Cl/l	0.39	
ZN0502AE	4933337	24/06/2024 09:04	Total - Residual disinfectant	mg Cl/l	0.44	
ZN0502AE	4933337	24/06/2024 09:04	Total Coliforms	CFU/100 ml	0	0
ZN0505AE	4933338	24/06/2024 09:48	1,2 Dichloroethane	ug/l	<0.4	3
ZN0505AE	4933338	24/06/2024 09:48	Aluminium	ug Al/l	26	200
ZN0505AE	4933338	24/06/2024 09:48	Ammonium	mg NH4/l	<0.01	0.5
ZN0505AE	4933338	24/06/2024 09:48	Benzene	ug/l	<0.15	1
ZN0505AE	4933338	24/06/2024 09:48	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN0505AE	4933338	24/06/2024 09:48	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0505AE	4933338	24/06/2024 09:48	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0505AE	4933338	24/06/2024 09:48	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0505AE	4933338	24/06/2024 09:48	Bromate	ug BrO3/l	<0.50	10
ZN0505AE	4933338	24/06/2024 09:48	Bromodichloromethane	ug/l	11	
ZN0505AE	4933338	24/06/2024 09:48	Bromoform	ug/l	<3.5	
ZN0505AE	4933338	24/06/2024 09:48	Calcium	mg/l	46	
ZN0505AE	4933338	24/06/2024 09:48	Chloride	mg Cl/l	19	250
ZN0505AE	4933338	24/06/2024 09:48	Chloroform	ug/l	22	
ZN0505AE	4933338	24/06/2024 09:48	Colony Counts 22	CFU/1 ml	0	
ZN0505AE	4933338	24/06/2024 09:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0505AE	4933338	24/06/2024 09:48	Colour	mg/l Pt/Co	<4.56	20
ZN0505AE	4933338	24/06/2024 09:48	Conductivity	uS/cm 20 C	360	2500
ZN0505AE	4933338	24/06/2024 09:48	Copper	mg Cu/l	<0.043	2
ZN0505AE	4933338	24/06/2024 09:48	Dibromochloromethane	ug/l	7.4	
ZN0505AE	4933338	24/06/2024 09:48	E. coli	CFU/100 ml	0	0
ZN0505AE	4933338	24/06/2024 09:48	Enterococci	CFU/100ml	0	0
ZN0505AE	4933338	24/06/2024 09:48	Fluoride	mg F/l	<0.150	1.5
ZN0505AE	4933338	24/06/2024 09:48	Free - Residual disinfectant	mg Cl/l	0.43	
ZN0505AE	4933338	24/06/2024 09:48	Hydrogen Ion	pH value	7.7	9.5
ZN0505AE	4933338	24/06/2024 09:48	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0505AE	4933338	24/06/2024 09:48	Iron	ug Fe/l	17	200
ZN0505AE	4933338	24/06/2024 09:48	Lead	ug Pb/l	<0.09	10
ZN0505AE	4933338	24/06/2024 09:48	Magnesium	mg/l	13	
ZN0505AE	4933338	24/06/2024 09:48	Manganese	ug Mn/l	0.86	50
ZN0505AE	4933338	24/06/2024 09:48	Mercury	ug per l	<0.041	1
ZN0505AE	4933338	24/06/2024 09:48	Nickel	ug Ni/l	0.83	20
ZN0505AE	4933338	24/06/2024 09:48	Nitrate	mg/l	6.4	50

ZN0505AE	4933338	24/06/2024 09:48	Nitrate/Nitrite Formula	mg/l	<0.13	1
ZN0505AE	4933338	24/06/2024 09:48	Nitrite	mg/l	<0.03	0.5
ZN0505AE	4933338	24/06/2024 09:48	Odour	Diln No	0	0
ZN0505AE	4933338	24/06/2024 09:48	Odour - Nature		No odour	
ZN0505AE	4933338	24/06/2024 09:48	PAH - Sum of four substances	ug/l	0	0.1
ZN0505AE	4933338	24/06/2024 09:48	Potassium	mg/l	2.9	
ZN0505AE	4933338	24/06/2024 09:48	Sodium	mg Na/l	13	200
ZN0505AE	4933338	24/06/2024 09:48	Sulphate	mg SO4/l	54	250
ZN0505AE	4933338	24/06/2024 09:48	Taste	Diln No	0	0
ZN0505AE	4933338	24/06/2024 09:48	Taste - Nature		No taste	
ZN0505AE	4933338	24/06/2024 09:48	Tetrachloroethene	ug/l	<0.8	
ZN0505AE	4933338	24/06/2024 09:48	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0505AE	4933338	24/06/2024 09:48	Tetrachloromethane	ug/l	<0.4	3
ZN0505AE	4933338	24/06/2024 09:48	Total - Residual disinfectant	mg Cl/l	0.58	
ZN0505AE	4933338	24/06/2024 09:48	Total Coliforms	CFU/100 ml	0	0
ZN0505AE	4933338	24/06/2024 09:48	Total hardness	mg/l	67	
ZN0505AE	4933338	24/06/2024 09:48	Total Organic Carbon	mg C/l	1.6	
ZN0505AE	4933338	24/06/2024 09:48	Total Trihalomethanes	ug/l	42	100
ZN0505AE	4933338	24/06/2024 09:48	Trichloroethene	ug/l	<0.7	
ZN0505AE	4933338	24/06/2024 09:48	Turbidity	NTU	<0.09	4
ZN0505AE	4933338	24/06/2024 09:48	WHO Index		0.34	1
ZN0706AE	4933332	24/06/2024 11:21	1,2 Dichloroethane	ug/l	<0.4	3
ZN0706AE	4933332	24/06/2024 11:21	Aluminium	ug Al/l	11	200
ZN0706AE	4933332	24/06/2024 11:21	Ammonium	mg NH4/l	<0.01	0.5
ZN0706AE	4933332	24/06/2024 11:21	Benzene	ug/l	<0.15	1
ZN0706AE	4933332	24/06/2024 11:21	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN0706AE	4933332	24/06/2024 11:21	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0706AE	4933332	24/06/2024 11:21	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0706AE	4933332	24/06/2024 11:21	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0706AE	4933332	24/06/2024 11:21	Bromate	ug BrO3/l	1	10
ZN0706AE	4933332	24/06/2024 11:21	Bromodichloromethane	ug/l	11	
ZN0706AE	4933332	24/06/2024 11:21	Bromoform	ug/l	<3.5	
ZN0706AE	4933332	24/06/2024 11:21	Calcium	mg/l	20	
ZN0706AE	4933332	24/06/2024 11:21	Chloride	mg Cl/l	9.9	250
ZN0706AE	4933332	24/06/2024 11:21	Chloroform	ug/l	42	
ZN0706AE	4933332	24/06/2024 11:21	Colony Counts 22	CFU/1 ml	0	
ZN0706AE	4933332	24/06/2024 11:21	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0706AE	4933332	24/06/2024 11:21	Colour	mg/l Pt/Co	<4.56	20

ZN0706AE	4933332	24/06/2024 11:21	Conductivity	uS/cm 20 C	160	2500
ZN0706AE	4933332	24/06/2024 11:21	Copper	mg Cu/l	<0.043	2
ZN0706AE	4933332	24/06/2024 11:21	Dibromochloromethane	ug/l	2.5	
ZN0706AE	4933332	24/06/2024 11:21	E. coli	CFU/100 ml	0	0
ZN0706AE	4933332	24/06/2024 11:21	Enterococci	CFU/100ml	0	0
ZN0706AE	4933332	24/06/2024 11:21	Fluoride	mg F/l	<0.150	1.5
ZN0706AE	4933332	24/06/2024 11:21	Free - Residual disinfectant	mg Cl/l	0.69	
ZN0706AE	4933332	24/06/2024 11:21	Hydrogen Ion	pH value	7.4	9.5
ZN0706AE	4933332	24/06/2024 11:21	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0706AE	4933332	24/06/2024 11:21	Iron	ug Fe/l	<14	200
ZN0706AE	4933332	24/06/2024 11:21	Lead	ug Pb/l	<0.09	10
ZN0706AE	4933332	24/06/2024 11:21	Magnesium	mg/l	2.1	
ZN0706AE	4933332	24/06/2024 11:21	Manganese	ug Mn/l	<0.8	50
ZN0706AE	4933332	24/06/2024 11:21	Mercury	ug per l	<0.041	1
ZN0706AE	4933332	24/06/2024 11:21	Nickel	ug Ni/l	<0.26	20
ZN0706AE	4933332	24/06/2024 11:21	Nitrate	mg/l	1.1	50
ZN0706AE	4933332	24/06/2024 11:21	Nitrate/Nitrite Formula	mg/l	<0.022	1
ZN0706AE	4933332	24/06/2024 11:21	Nitrite	mg/l	<0.03	0.5
ZN0706AE	4933332	24/06/2024 11:21	Odour	Diln No	0	0
ZN0706AE	4933332	24/06/2024 11:21	Odour - Nature		No odour	
ZN0706AE	4933332	24/06/2024 11:21	PAH - Sum of four substances	ug/l	0	0.1
ZN0706AE	4933332	24/06/2024 11:21	Potassium	mg/l	0.64	
ZN0706AE	4933332	24/06/2024 11:21	Sodium	mg Na/l	8.6	200
ZN0706AE	4933332	24/06/2024 11:21	Sulphate	mg SO4/l	39	250
ZN0706AE	4933332	24/06/2024 11:21	Taste	Diln No	0	0
ZN0706AE	4933332	24/06/2024 11:21	Taste - Nature		No taste	
ZN0706AE	4933332	24/06/2024 11:21	Tetrachloroethene	ug/l	<0.8	
ZN0706AE	4933332	24/06/2024 11:21	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0706AE	4933332	24/06/2024 11:21	Tetrachloromethane	ug/l	<0.4	3
ZN0706AE	4933332	24/06/2024 11:21	Total - Residual disinfectant	mg Cl/l	0.81	
ZN0706AE	4933332	24/06/2024 11:21	Total Coliforms	CFU/100 ml	0	0
ZN0706AE	4933332	24/06/2024 11:21	Total hardness	mg/l	23	
ZN0706AE	4933332	24/06/2024 11:21	Total Organic Carbon	mg C/l	1.5	
ZN0706AE	4933332	24/06/2024 11:21	Total Trihalomethanes	ug/l	56	100
ZN0706AE	4933332	24/06/2024 11:21	Trichloroethene	ug/l	<0.7	
ZN0706AE	4933332	24/06/2024 11:21	Turbidity	NTU	<0.09	4
ZN0706AE	4933332	24/06/2024 11:21	WHO Index		0.35	1
ZN0804AE	4933357	25/06/2024 09:22	Benzo(a)pyrene	ug/l	<0.0021	0.01

ZN0804AE	4933357	25/06/2024 09:22	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0804AE	4933357	25/06/2024 09:22	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0804AE	4933357	25/06/2024 09:22	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0804AE	4933357	25/06/2024 09:22	Bromate	ug BrO3/l	1.6	10
ZN0804AE	4933357	25/06/2024 09:22	E. coli	CFU/100 ml	0	0
ZN0804AE	4933357	25/06/2024 09:22	Free - Residual disinfectant	mg Cl/l	0.66	
ZN0804AE	4933357	25/06/2024 09:22	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0804AE	4933357	25/06/2024 09:22	Nitrite	mg/l	<0.03	0.5
ZN0804AE	4933357	25/06/2024 09:22	PAH - Sum of four substances	ug/l	0	0.1
ZN0804AE	4933357	25/06/2024 09:22	Total - Residual disinfectant	mg Cl/l	0.66	
ZN0804AE	4933357	25/06/2024 09:22	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4933308	25/06/2024 10:05	Aluminium	ug Al/l	21	200
ZS0809AE	4933308	25/06/2024 10:05	Colony Counts 22	CFU/1 ml	1	
ZS0809AE	4933308	25/06/2024 10:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0809AE	4933308	25/06/2024 10:05	Colour	mg/l Pt/Co	<4.56	20
ZS0809AE	4933308	25/06/2024 10:05	Conductivity	uS/cm 20 C	390	2500
ZS0809AE	4933308	25/06/2024 10:05	E. coli	CFU/100 ml	0	0
ZS0809AE	4933308	25/06/2024 10:05	Free - Residual disinfectant	mg Cl/l	0.73	
ZS0809AE	4933308	25/06/2024 10:05	Hydrogen Ion	pH value	7.6	9.5
ZS0809AE	4933308	25/06/2024 10:05	Iron	ug/l Fe	8.3	200
ZS0809AE	4933308	25/06/2024 10:05	Manganese	ug Mn/l	1.1	50
ZS0809AE	4933308	25/06/2024 10:05	Odour	Diln No	0	0
ZS0809AE	4933308	25/06/2024 10:05	Odour - Nature		No odour	
ZS0809AE	4933308	25/06/2024 10:05	Taste	Diln No	0	0
ZS0809AE	4933308	25/06/2024 10:05	Taste - Nature		No taste	
ZS0809AE	4933308	25/06/2024 10:05	Total - Residual disinfectant	mg Cl/l	1.02	
ZS0809AE	4933308	25/06/2024 10:05	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4933308	25/06/2024 10:05	Turbidity	NTU	<0.09	4
ZN0501AE	4933334	25/06/2024 10:20	1,2 Dichloroethane	ug/l	<0.4	3
ZN0501AE	4933334	25/06/2024 10:20	Aluminium	ug Al/l	37	200
ZN0501AE	4933334	25/06/2024 10:20	Ammonium	mg NH4/l	<0.01	0.5
ZN0501AE	4933334	25/06/2024 10:20	Benzene	ug/l	<0.15	1
ZN0501AE	4933334	25/06/2024 10:20	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN0501AE	4933334	25/06/2024 10:20	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0501AE	4933334	25/06/2024 10:20	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0501AE	4933334	25/06/2024 10:20	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0501AE	4933334	25/06/2024 10:20	Bromate	ug BrO3/l	<0.50	10
ZN0501AE	4933334	25/06/2024 10:20	Bromodichloromethane	ug/l	13	

ZN0501AE	4933334	25/06/2024 10:20	Bromoform	ug/l	<3.5	
ZN0501AE	4933334	25/06/2024 10:20	Calcium	mg/l	52	
ZN0501AE	4933334	25/06/2024 10:20	Chloride	mg Cl/l	21	250
ZN0501AE	4933334	25/06/2024 10:20	Chloroform	ug/l	29	
ZN0501AE	4933334	25/06/2024 10:20	Colony Counts 22	CFU/1 ml	0	
ZN0501AE	4933334	25/06/2024 10:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0501AE	4933334	25/06/2024 10:20	Colour	mg/l Pt/Co	<4.56	20
ZN0501AE	4933334	25/06/2024 10:20	Conductivity	uS/cm 20 C	360	2500
ZN0501AE	4933334	25/06/2024 10:20	Copper	mg Cu/l	<0.043	2
ZN0501AE	4933334	25/06/2024 10:20	Dibromochloromethane	ug/l	8.2	
ZN0501AE	4933334	25/06/2024 10:20	E. coli	CFU/100 ml	0	0
ZN0501AE	4933334	25/06/2024 10:20	Enterococci	CFU/100ml	1	0
ZN0501AE	4933334	25/06/2024 10:20	Fluoride	mg F/l	<0.150	1.5
ZN0501AE	4933334	25/06/2024 10:20	Free - Residual disinfectant	mg Cl/l	0.61	
ZN0501AE	4933334	25/06/2024 10:20	Hydrogen Ion	pH value	7.6	9.5
ZN0501AE	4933334	25/06/2024 10:20	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0501AE	4933334	25/06/2024 10:20	Iron	ug Fe/l	<14	200
ZN0501AE	4933334	25/06/2024 10:20	Lead	ug Pb/l	0.24	10
ZN0501AE	4933334	25/06/2024 10:20	Magnesium	mg/l	8.3	
ZN0501AE	4933334	25/06/2024 10:20	Manganese	ug Mn/l	<0.8	50
ZN0501AE	4933334	25/06/2024 10:20	Mercury	ug per l	<0.041	1
ZN0501AE	4933334	25/06/2024 10:20	Nickel	ug Ni/l	3	20
ZN0501AE	4933334	25/06/2024 10:20	Nitrate	mg/l	4.9	50
ZN0501AE	4933334	25/06/2024 10:20	Nitrate/Nitrite Formula	mg/l	<0.098	1
ZN0501AE	4933334	25/06/2024 10:20	Nitrite	mg/l	<0.03	0.5
ZN0501AE	4933334	25/06/2024 10:20	Odour	Diln No	0	0
ZN0501AE	4933334	25/06/2024 10:20	Odour - Nature		No odour	
ZN0501AE	4933334	25/06/2024 10:20	PAH - Sum of four substances	ug/l	0	0.1
ZN0501AE	4933334	25/06/2024 10:20	Potassium	mg/l	3.7	
ZN0501AE	4933334	25/06/2024 10:20	Sodium	mg Na/l	14	200
ZN0501AE	4933334	25/06/2024 10:20	Sulphate	mg SO4/l	78	250
ZN0501AE	4933334	25/06/2024 10:20	Taste	Diln No	0	0
ZN0501AE	4933334	25/06/2024 10:20	Taste - Nature		No taste	
ZN0501AE	4933334	25/06/2024 10:20	Tetrachloroethene	ug/l	<0.8	
ZN0501AE	4933334	25/06/2024 10:20	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0501AE	4933334	25/06/2024 10:20	Tetrachloromethane	ug/l	<0.4	3
ZN0501AE	4933334	25/06/2024 10:20	Total - Residual disinfectant	mg Cl/l	0.8	
ZN0501AE	4933334	25/06/2024 10:20	Total Coliforms	CFU/100 ml	0	0

ZN0501AE	4933334	25/06/2024 10:20	Total hardness	mg/l	66	
ZN0501AE	4933334	25/06/2024 10:20	Total Organic Carbon	mg C/l	2.3	
ZN0501AE	4933334	25/06/2024 10:20	Total Trihalomethanes	ug/l	51	100
ZN0501AE	4933334	25/06/2024 10:20	Trichloroethene	ug/l	<0.7	
ZN0501AE	4933334	25/06/2024 10:20	Turbidity	NTU	<0.09	4
ZN0501AE	4933334	25/06/2024 10:20	WHO Index		0.41	1
ZN0102AE	4933574	25/06/2024 10:52	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN0102AE	4933574	25/06/2024 10:52	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0102AE	4933574	25/06/2024 10:52	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0102AE	4933574	25/06/2024 10:52	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0102AE	4933574	25/06/2024 10:52	E. coli	CFU/100 ml	0	0
ZN0102AE	4933574	25/06/2024 10:52	Free - Residual disinfectant	mg Cl/l	0.68	
ZN0102AE	4933574	25/06/2024 10:52	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0102AE	4933574	25/06/2024 10:52	Odour	Diln No	0	0
ZN0102AE	4933574	25/06/2024 10:52	Odour - Nature		No odour	
ZN0102AE	4933574	25/06/2024 10:52	PAH - Sum of four substances	ug/l	0	0.1
ZN0102AE	4933574	25/06/2024 10:52	Taste	Diln No	0	0
ZN0102AE	4933574	25/06/2024 10:52	Taste - Nature		No taste	
ZN0102AE	4933574	25/06/2024 10:52	Total - Residual disinfectant	mg Cl/l	0.81	
ZN0102AE	4933574	25/06/2024 10:52	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4933586	25/06/2024 10:57	Aluminium	ug Al/l	24	200
ZS0811AE	4933586	25/06/2024 10:57	Colony Counts 22	CFU/1 ml	1	
ZS0811AE	4933586	25/06/2024 10:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0811AE	4933586	25/06/2024 10:57	Colour	mg/l Pt/Co	<4.56	20
ZS0811AE	4933586	25/06/2024 10:57	Conductivity	uS/cm 20 C	390	2500
ZS0811AE	4933586	25/06/2024 10:57	E. coli	CFU/100 ml	0	0
ZS0811AE	4933586	25/06/2024 10:57	Free - Residual disinfectant	mg Cl/l	0.85	
ZS0811AE	4933586	25/06/2024 10:57	Hydrogen Ion	pH value	7.5	9.5
ZS0811AE	4933586	25/06/2024 10:57	Iron	ug/l Fe	1.8	200
ZS0811AE	4933586	25/06/2024 10:57	Manganese	ug Mn/l	<0.80	50
ZS0811AE	4933586	25/06/2024 10:57	Odour	Diln No	0	0
ZS0811AE	4933586	25/06/2024 10:57	Odour - Nature		No odour	
ZS0811AE	4933586	25/06/2024 10:57	Taste	Diln No	0	0
ZS0811AE	4933586	25/06/2024 10:57	Taste - Nature		No taste	
ZS0811AE	4933586	25/06/2024 10:57	Total - Residual disinfectant	mg Cl/l	1.09	
ZS0811AE	4933586	25/06/2024 10:57	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4933586	25/06/2024 10:57	Turbidity	NTU	<0.09	4
ZS0811CUST	4947742	26/06/2024 10:10	Aluminium	ug Al/l	380	200

ZS0811CUST	4947742	26/06/2024 10:10	Colour	mg/l Pt/Co	<4.56	20
ZS0811CUST	4947742	26/06/2024 10:10	Conductivity	uS/cm 20 C	390	2500
ZS0811CUST	4947742	26/06/2024 10:10	E. coli	CFU/100 ml	0	0
ZS0811CUST	4947742	26/06/2024 10:10	Free - Residual disinfectant	mg Cl/l	0.32	
ZS0811CUST	4947742	26/06/2024 10:10	Hydrogen Ion	pH value	7.5	9.5
ZS0811CUST	4947742	26/06/2024 10:10	Iron	ug Fe/l	350	200
ZS0811CUST	4947742	26/06/2024 10:10	Manganese	ug Mn/l	37	50
ZS0811CUST	4947742	26/06/2024 10:10	Odour	Diln No	0	0
ZS0811CUST	4947742	26/06/2024 10:10	Odour - Nature		No odour	
ZS0811CUST	4947742	26/06/2024 10:10	Taste	Diln No	0	0
ZS0811CUST	4947742	26/06/2024 10:10	Taste - Nature		No taste	
ZS0811CUST	4947742	26/06/2024 10:10	Total - Residual disinfectant	mg Cl/l	0.49	
ZS0811CUST	4947742	26/06/2024 10:10	Total Coliforms	CFU/100 ml	0	0
ZS0811CUST	4947742	26/06/2024 10:10	Turbidity	NTU	1.7	4
ZS0811CUST	4947743	26/06/2024 10:35	Aluminium	ug Al/l	30	200
ZS0811CUST	4947743	26/06/2024 10:35	Colour	mg/l Pt/Co	<4.56	20
ZS0811CUST	4947743	26/06/2024 10:35	Conductivity	uS/cm 20 C	390	2500
ZS0811CUST	4947743	26/06/2024 10:35	E. coli	CFU/100 ml	0	0
ZS0811CUST	4947743	26/06/2024 10:35	Free - Residual disinfectant	mg Cl/l	0.36	
ZS0811CUST	4947743	26/06/2024 10:35	Hydrogen Ion	pH value	7.5	9.5
ZS0811CUST	4947743	26/06/2024 10:35	Iron	ug Fe/l	28	200
ZS0811CUST	4947743	26/06/2024 10:35	Manganese	ug Mn/l	1.2	50
ZS0811CUST	4947743	26/06/2024 10:35	Odour	Diln No	0	0
ZS0811CUST	4947743	26/06/2024 10:35	Odour - Nature		No odour	
ZS0811CUST	4947743	26/06/2024 10:35	Taste	Diln No	0	0
ZS0811CUST	4947743	26/06/2024 10:35	Taste - Nature		No taste	
ZS0811CUST	4947743	26/06/2024 10:35	Total - Residual disinfectant	mg Cl/l	0.48	
ZS0811CUST	4947743	26/06/2024 10:35	Total Coliforms	CFU/100 ml	0	0
ZS0811CUST	4947743	26/06/2024 10:35	Turbidity	NTU	<0.09	4
ZS0811CUST	4947749	26/06/2024 10:45	Aluminium	ug Al/l	26	200
ZS0811CUST	4947749	26/06/2024 10:45	Colour	mg/l Pt/Co	<4.56	20
ZS0811CUST	4947749	26/06/2024 10:45	Conductivity	uS/cm 20 C	390	2500
ZS0811CUST	4947749	26/06/2024 10:45	E. coli	CFU/100 ml	0	0
ZS0811CUST	4947749	26/06/2024 10:45	Free - Residual disinfectant	mg Cl/l	0.39	
ZS0811CUST	4947749	26/06/2024 10:45	Hydrogen Ion	pH value	7.2	9.5
ZS0811CUST	4947749	26/06/2024 10:45	Iron	ug Fe/l	<14	200
ZS0811CUST	4947749	26/06/2024 10:45	Manganese	ug Mn/l	<0.8	50
ZS0811CUST	4947749	26/06/2024 10:45	Odour	Diln No	0	0

ZS0811CUST	4947749	26/06/2024 10:45	Odour - Nature		No odour	
ZS0811CUST	4947749	26/06/2024 10:45	Taste	Diln No	0	0
ZS0811CUST	4947749	26/06/2024 10:45	Taste - Nature		No taste	
ZS0811CUST	4947749	26/06/2024 10:45	Total - Residual disinfectant	mg Cl/l	0.48	
ZS0811CUST	4947749	26/06/2024 10:45	Total Coliforms	CFU/100 ml	0	0
ZS0811CUST	4947749	26/06/2024 10:45	Turbidity	NTU	<0.09	4
ZN0705AE	4930596	26/06/2024 10:47	1,2 Dichloroethane	ug/l	<0.4	3
ZN0705AE	4930596	26/06/2024 10:47	Benzene	ug/l	<0.15	1
ZN0705AE	4930596	26/06/2024 10:47	E. coli	CFU/100 ml	0	0
ZN0705AE	4930596	26/06/2024 10:47	Free - Residual disinfectant	mg Cl/l	0.64	
ZN0705AE	4930596	26/06/2024 10:47	Tetrachloroethene	ug/l	<0.8	
ZN0705AE	4930596	26/06/2024 10:47	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0705AE	4930596	26/06/2024 10:47	Tetrachloromethane	ug/l	<0.4	3
ZN0705AE	4930596	26/06/2024 10:47	Total - Residual disinfectant	mg Cl/l	0.7	
ZN0705AE	4930596	26/06/2024 10:47	Total Coliforms	CFU/100 ml	0	0
ZN0705AE	4930596	26/06/2024 10:47	Trichloroethene	ug/l	<0.7	
ZN0705AE	4930596	26/06/2024 10:47	Turbidity	NTU	<0.09	4
ZN0804AE	4930875	26/06/2024 10:59	Aluminium	ug Al/l	22	200
ZN0804AE	4930875	26/06/2024 10:59	Colony Counts 22	CFU/1 ml	1	
ZN0804AE	4930875	26/06/2024 10:59	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0804AE	4930875	26/06/2024 10:59	Colour	mg/l Pt/Co	<4.56	20
ZN0804AE	4930875	26/06/2024 10:59	Conductivity	uS/cm 20 C	440	2500
ZN0804AE	4930875	26/06/2024 10:59	E. coli	CFU/100 ml	0	0
ZN0804AE	4930875	26/06/2024 10:59	Free - Residual disinfectant	mg Cl/l	0.83	
ZN0804AE	4930875	26/06/2024 10:59	Hydrogen Ion	pH value	7.9	9.5
ZN0804AE	4930875	26/06/2024 10:59	Iron	ug Fe/l	<14	200
ZN0804AE	4930875	26/06/2024 10:59	Manganese	ug Mn/l	2.9	50
ZN0804AE	4930875	26/06/2024 10:59	Odour	Diln No	0	0
ZN0804AE	4930875	26/06/2024 10:59	Odour - Nature		No odour	
ZN0804AE	4930875	26/06/2024 10:59	Taste	Diln No	0	0
ZN0804AE	4930875	26/06/2024 10:59	Taste - Nature		No taste	
ZN0804AE	4930875	26/06/2024 10:59	Total - Residual disinfectant	mg Cl/l	1.04	
ZN0804AE	4930875	26/06/2024 10:59	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4930875	26/06/2024 10:59	Turbidity	NTU	<0.09	4
ZN0102AE	4933336	26/06/2024 11:36	Aluminium	ug Al/l	22	200
ZN0102AE	4933336	26/06/2024 11:36	Colony Counts 22	CFU/1 ml	2	
ZN0102AE	4933336	26/06/2024 11:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0102AE	4933336	26/06/2024 11:36	Colour	mg/l Pt/Co	<4.56	20

ZN0102AE	4933336	26/06/2024 11:36	Conductivity	uS/cm 20 C	320	2500
ZN0102AE	4933336	26/06/2024 11:36	E. coli	CFU/100 ml	0	0
ZN0102AE	4933336	26/06/2024 11:36	Free - Residual disinfectant	mg Cl/l	0.52	
ZN0102AE	4933336	26/06/2024 11:36	Hydrogen Ion	pH value	7.6	9.5
ZN0102AE	4933336	26/06/2024 11:36	Iron	ug Fe/l	20	200
ZN0102AE	4933336	26/06/2024 11:36	Manganese	ug Mn/l	2.9	50
ZN0102AE	4933336	26/06/2024 11:36	Odour	Diln No	0	0
ZN0102AE	4933336	26/06/2024 11:36	Odour - Nature		No odour	
ZN0102AE	4933336	26/06/2024 11:36	Taste	Diln No	0	0
ZN0102AE	4933336	26/06/2024 11:36	Taste - Nature		No taste	
ZN0102AE	4933336	26/06/2024 11:36	Total - Residual disinfectant	mg Cl/l	0.65	
ZN0102AE	4933336	26/06/2024 11:36	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4933336	26/06/2024 11:36	Turbidity	NTU	<0.09	4
ZN1102AE	4933312	26/06/2024 11:50	E. coli	CFU/100 ml	0	0
ZN1102AE	4933312	26/06/2024 11:50	Free - Residual disinfectant	mg Cl/l	0.74	
ZN1102AE	4933312	26/06/2024 11:50	Total - Residual disinfectant	mg Cl/l	0.98	
ZN1102AE	4933312	26/06/2024 11:50	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4933551	27/06/2024 09:26	E. coli	CFU/100 ml	0	0
ZS0809AE	4933551	27/06/2024 09:26	Free - Residual disinfectant	mg Cl/l	0.19	
ZS0809AE	4933551	27/06/2024 09:26	Total - Residual disinfectant	mg Cl/l	0.43	
ZS0809AE	4933551	27/06/2024 09:26	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4933553	27/06/2024 10:12	E. coli	CFU/100 ml	0	0
ZN1102AE	4933553	27/06/2024 10:12	Free - Residual disinfectant	mg Cl/l	0.69	
ZN1102AE	4933553	27/06/2024 10:12	Total - Residual disinfectant	mg Cl/l	0.85	
ZN1102AE	4933553	27/06/2024 10:12	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4933355	27/06/2024 10:44	E. coli	CFU/100 ml	0	0
ZS0811AE	4933355	27/06/2024 10:44	Free - Residual disinfectant	mg Cl/l	0.84	
ZS0811AE	4933355	27/06/2024 10:44	Total - Residual disinfectant	mg Cl/l	1.09	
ZS0811AE	4933355	27/06/2024 10:44	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4933786	27/06/2024 11:16	E. coli	CFU/100 ml	0	0
ZN0102AE	4933786	27/06/2024 11:16	Free - Residual disinfectant	mg Cl/l	0.31	
ZN0102AE	4933786	27/06/2024 11:16	Total - Residual disinfectant	mg Cl/l	0.42	
ZN0102AE	4933786	27/06/2024 11:16	Total Coliforms	CFU/100 ml	0	0
ZN0501OP	4948181	27/06/2024 11:40	E. coli	CFU/100 ml	0	0
ZN0501OP	4948181	27/06/2024 11:40	Free - Residual disinfectant	mg Cl/l	0.47	
ZN0501OP	4948181	27/06/2024 11:40	Total - Residual disinfectant	mg Cl/l	0.79	
ZN0501OP	4948181	27/06/2024 11:40	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4948180	27/06/2024 12:00	E. coli	CFU/100 ml	0	0

ZN0501AE	4948180	27/06/2024 12:00	Free - Residual disinfectant	mg Cl/l	0.67	
ZN0501AE	4948180	27/06/2024 12:00	Total - Residual disinfectant	mg Cl/l	0.8	
ZN0501AE	4948180	27/06/2024 12:00	Total Coliforms	CFU/100 ml	0	0
ZN0501OP	4948182	27/06/2024 12:15	E. coli	CFU/100 ml	0	0
ZN0501OP	4948182	27/06/2024 12:15	Free - Residual disinfectant	mg Cl/l	0.62	
ZN0501OP	4948182	27/06/2024 12:15	Total - Residual disinfectant	mg Cl/l	0.81	
ZN0501OP	4948182	27/06/2024 12:15	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4933778	28/06/2024 10:08	E. coli	CFU/100 ml	0	0
ZS0809AE	4933778	28/06/2024 10:08	Free - Residual disinfectant	mg Cl/l	0.76	
ZS0809AE	4933778	28/06/2024 10:08	Total - Residual disinfectant	mg Cl/l	0.95	
ZS0809AE	4933778	28/06/2024 10:08	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4933573	28/06/2024 10:32	E. coli	CFU/100 ml	0	0
ZN0501AE	4933573	28/06/2024 10:32	Free - Residual disinfectant	mg Cl/l	0.93	
ZN0501AE	4933573	28/06/2024 10:32	Total - Residual disinfectant	mg Cl/l	0.95	
ZN0501AE	4933573	28/06/2024 10:32	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4933790	28/06/2024 10:53	E. coli	CFU/100 ml	0	0
ZS0811AE	4933790	28/06/2024 10:53	Free - Residual disinfectant	mg Cl/l	0.21	
ZS0811AE	4933790	28/06/2024 10:53	Total - Residual disinfectant	mg Cl/l	0.48	
ZS0811AE	4933790	28/06/2024 10:53	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4936187	01/07/2024 10:01	1,2 Dichloroethane	ug/l	<0.4	3
ZS0809AE	4936187	01/07/2024 10:01	Aluminium	ug Al/l	14	200
ZS0809AE	4936187	01/07/2024 10:01	Ammonium	mg NH4/l	<0.01	0.5
ZS0809AE	4936187	01/07/2024 10:01	Antimony	ug/l Sb	<0.18	5
ZS0809AE	4936187	01/07/2024 10:01	Arsenic	ug/l As	<0.3	10
ZS0809AE	4936187	01/07/2024 10:01	Benzene	ug/l	<0.15	1
ZS0809AE	4936187	01/07/2024 10:01	Boron	mg/l B	<0.038	1
ZS0809AE	4936187	01/07/2024 10:01	Bromodichloromethane	ug/l	17	
ZS0809AE	4936187	01/07/2024 10:01	Bromoform	ug/l	<3.5	
ZS0809AE	4936187	01/07/2024 10:01	Cadmium	ug/l Cd	<0.30	5
ZS0809AE	4936187	01/07/2024 10:01	Calcium	mg/l	55	
ZS0809AE	4936187	01/07/2024 10:01	Chloride	mg Cl/l	21	250
ZS0809AE	4936187	01/07/2024 10:01	Chloroform	ug/l	45	
ZS0809AE	4936187	01/07/2024 10:01	Chromium	ug/l Cr	<0.4	50
ZS0809AE	4936187	01/07/2024 10:01	Colony Counts 22	CFU/1 ml	0	
ZS0809AE	4936187	01/07/2024 10:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0809AE	4936187	01/07/2024 10:01	Colour	mg/l Pt/Co	<4.56	20
ZS0809AE	4936187	01/07/2024 10:01	Conductivity	uS/cm 20 C	390	2500
ZS0809AE	4936187	01/07/2024 10:01	Copper	mg Cu/l	<0.043	2

ZS0809AE	4936187	01/07/2024 10:01	Dibromochloromethane	ug/l	8.5	
ZS0809AE	4936187	01/07/2024 10:01	E. coli	CFU/100 ml	0	0
ZS0809AE	4936187	01/07/2024 10:01	Enterococci	CFU/100ml	0	0
ZS0809AE	4936187	01/07/2024 10:01	Fluoride	mg F/l	<0.150	1.5
ZS0809AE	4936187	01/07/2024 10:01	Free - Residual disinfectant	mg Cl/l	0.28	
ZS0809AE	4936187	01/07/2024 10:01	Hydrogen Ion	pH value	7.6	9.5
ZS0809AE	4936187	01/07/2024 10:01	Iron	ug Fe/l	18	200
ZS0809AE	4936187	01/07/2024 10:01	Lead	ug Pb/l	<0.09	10
ZS0809AE	4936187	01/07/2024 10:01	Magnesium	mg/l	8.3	
ZS0809AE	4936187	01/07/2024 10:01	Manganese	ug Mn/l	1.4	50
ZS0809AE	4936187	01/07/2024 10:01	Mercury	ug per l	<0.041	1
ZS0809AE	4936187	01/07/2024 10:01	Nickel	ug Ni/l	1.5	20
ZS0809AE	4936187	01/07/2024 10:01	Nitrate	mg/l	3.5	50
ZS0809AE	4936187	01/07/2024 10:01	Nitrate/Nitrite Formula	mg/l	<0.070	1
ZS0809AE	4936187	01/07/2024 10:01	Nitrite	mg/l	<0.03	0.5
ZS0809AE	4936187	01/07/2024 10:01	Odour	Diln No	0	0
ZS0809AE	4936187	01/07/2024 10:01	Odour - Nature		No odour	
ZS0809AE	4936187	01/07/2024 10:01	Potassium	mg/l	3.7	
ZS0809AE	4936187	01/07/2024 10:01	Selenium	ug/l Se	<0.4	10
ZS0809AE	4936187	01/07/2024 10:01	Sodium	mg Na/l	16	200
ZS0809AE	4936187	01/07/2024 10:01	Sulphate	mg SO4/l	87	250
ZS0809AE	4936187	01/07/2024 10:01	Taste	Diln No	0	0
ZS0809AE	4936187	01/07/2024 10:01	Taste - Nature		No taste	
ZS0809AE	4936187	01/07/2024 10:01	Tetrachloroethene	ug/l	<0.8	
ZS0809AE	4936187	01/07/2024 10:01	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZS0809AE	4936187	01/07/2024 10:01	Tetrachloromethane	ug/l	<0.4	3
ZS0809AE	4936187	01/07/2024 10:01	Total - Residual disinfectant	mg Cl/l	0.52	
ZS0809AE	4936187	01/07/2024 10:01	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4936187	01/07/2024 10:01	Total hardness	mg/l	69	
ZS0809AE	4936187	01/07/2024 10:01	Total Organic Carbon	mg C/l	2.3	
ZS0809AE	4936187	01/07/2024 10:01	Total Trihalomethanes	ug/l	72	100
ZS0809AE	4936187	01/07/2024 10:01	Trichloroethene	ug/l	<0.7	
ZS0809AE	4936187	01/07/2024 10:01	Turbidity	NTU	<0.09	4
ZS0809AE	4936187	01/07/2024 10:01	WHO Index		0.53	1
ZN0501AE	4936212	01/07/2024 10:28	E. coli	CFU/100 ml	0	0
ZN0501AE	4936212	01/07/2024 10:28	Free - Residual disinfectant	mg Cl/l	0.52	
ZN0501AE	4936212	01/07/2024 10:28	Total - Residual disinfectant	mg Cl/l	0.71	
ZN0501AE	4936212	01/07/2024 10:28	Total Coliforms	CFU/100 ml	0	0

ZN0501AE	4949072	01/07/2024 10:55	Enterococci	CFU/100ml	0	0
ZN0501AE	4949072	01/07/2024 10:55	Free - Residual disinfectant	mg Cl/l	0.57	
ZN0501AE	4949072	01/07/2024 10:55	Total - Residual disinfectant	mg Cl/l	0.6	
ZN1102AE	4936190	01/07/2024 11:00	E. coli	CFU/100 ml	0	0
ZN1102AE	4936190	01/07/2024 11:00	Free - Residual disinfectant	mg Cl/l	0.75	
ZN1102AE	4936190	01/07/2024 11:00	Total - Residual disinfectant	mg Cl/l	0.89	
ZN1102AE	4936190	01/07/2024 11:00	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4949069	01/07/2024 11:05	Enterococci	CFU/100ml	0	0
ZN0501AE	4949069	01/07/2024 11:05	Free - Residual disinfectant	mg Cl/l	0.61	
ZN0501AE	4949069	01/07/2024 11:05	Total - Residual disinfectant	mg Cl/l	0.77	
ZN0102AE	4936214	01/07/2024 11:18	1,2 Dichloroethane	ug/l	<0.4	3
ZN0102AE	4936214	01/07/2024 11:18	Aluminium	ug Al/l	22	200
ZN0102AE	4936214	01/07/2024 11:18	Antimony	ug/l Sb	<0.18	5
ZN0102AE	4936214	01/07/2024 11:18	Arsenic	ug/l As	<0.3	10
ZN0102AE	4936214	01/07/2024 11:18	Benzene	ug/l	<0.15	1
ZN0102AE	4936214	01/07/2024 11:18	Boron	mg/l B	<0.038	1
ZN0102AE	4936214	01/07/2024 11:18	Bromodichloromethane	ug/l	21	
ZN0102AE	4936214	01/07/2024 11:18	Bromoform	ug/l	<3.5	
ZN0102AE	4936214	01/07/2024 11:18	Cadmium	ug/l Cd	<0.30	5
ZN0102AE	4936214	01/07/2024 11:18	Calcium	mg/l	38	
ZN0102AE	4936214	01/07/2024 11:18	Chloride	mg Cl/l	20	250
ZN0102AE	4936214	01/07/2024 11:18	Chloroform	ug/l	57	
ZN0102AE	4936214	01/07/2024 11:18	Chromium	ug/l Cr	<0.4	50
ZN0102AE	4936214	01/07/2024 11:18	Colony Counts 22	CFU/1 ml	0	
ZN0102AE	4936214	01/07/2024 11:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0102AE	4936214	01/07/2024 11:18	Colour	mg/l Pt/Co	<4.56	20
ZN0102AE	4936214	01/07/2024 11:18	Conductivity	uS/cm 20 C	320	2500
ZN0102AE	4936214	01/07/2024 11:18	Copper	mg Cu/l	<0.043	2
ZN0102AE	4936214	01/07/2024 11:18	Dibromochloromethane	ug/l	6.3	
ZN0102AE	4936214	01/07/2024 11:18	E. coli	CFU/100 ml	0	0
ZN0102AE	4936214	01/07/2024 11:18	Enterococci	CFU/100ml	0	0
ZN0102AE	4936214	01/07/2024 11:18	Fluoride	mg F/l	<0.150	1.5
ZN0102AE	4936214	01/07/2024 11:18	Free - Residual disinfectant	mg Cl/l	0.29	
ZN0102AE	4936214	01/07/2024 11:18	Hydrogen Ion	pH value	7.6	9.5
ZN0102AE	4936214	01/07/2024 11:18	Iron	ug Fe/l	33	200
ZN0102AE	4936214	01/07/2024 11:18	Lead	ug Pb/l	<0.09	10
ZN0102AE	4936214	01/07/2024 11:18	Magnesium	mg/l	9.9	
ZN0102AE	4936214	01/07/2024 11:18	Manganese	ug Mn/l	2.8	50

ZN0102AE	4936214	01/07/2024 11:18	Nickel	ug Ni/l	1.1	20
ZN0102AE	4936214	01/07/2024 11:18	Nitrate	mg/l	2.4	50
ZN0102AE	4936214	01/07/2024 11:18	Nitrate/Nitrite Formula	mg/l	<0.048	1
ZN0102AE	4936214	01/07/2024 11:18	Nitrite	mg/l	<0.03	0.5
ZN0102AE	4936214	01/07/2024 11:18	Odour	Diln No	5	0
ZN0102AE	4936214	01/07/2024 11:18	Odour - Nature		Earthy	
ZN0102AE	4936214	01/07/2024 11:18	Potassium	mg/l	2.7	
ZN0102AE	4936214	01/07/2024 11:18	Selenium	ug/l Se	<0.4	10
ZN0102AE	4936214	01/07/2024 11:18	Sodium	mg Na/l	16	200
ZN0102AE	4936214	01/07/2024 11:18	Sulphate	mg SO4/l	52	250
ZN0102AE	4936214	01/07/2024 11:18	Taste	Diln No	99	0
ZN0102AE	4936214	01/07/2024 11:18	Taste - Nature		is performed due to odour contravention	
ZN0102AE	4936214	01/07/2024 11:18	Tetrachloroethene	ug/l	<0.8	
ZN0102AE	4936214	01/07/2024 11:18	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0102AE	4936214	01/07/2024 11:18	Tetrachloromethane	ug/l	<0.4	3
ZN0102AE	4936214	01/07/2024 11:18	Total - Residual disinfectant	mg Cl/l	0.44	
ZN0102AE	4936214	01/07/2024 11:18	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4936214	01/07/2024 11:18	Total hardness	mg/l	54	
ZN0102AE	4936214	01/07/2024 11:18	Total Organic Carbon	mg C/l	2.6	
ZN0102AE	4936214	01/07/2024 11:18	Total Trihalomethanes	ug/l	85	100
ZN0102AE	4936214	01/07/2024 11:18	Trichloroethene	ug/l	<0.7	
ZN0102AE	4936214	01/07/2024 11:18	Turbidity	NTU	0.11	4
ZN0102AE	4936214	01/07/2024 11:18	WHO Index		0.61	1
ZN0501AE	4949071	01/07/2024 11:20	Enterococci	CFU/100ml	0	0
ZN0501AE	4949071	01/07/2024 11:20	Free - Residual disinfectant	mg Cl/l	0.52	
ZN0501AE	4949071	01/07/2024 11:20	Total - Residual disinfectant	mg Cl/l	0.77	
ZS0809CUST	4950289	02/07/2024 09:00	Aluminium	ug Al/l	21	200
ZS0809CUST	4950289	02/07/2024 09:00	Colour	mg/l Pt/Co	<4.56	20
ZS0809CUST	4950289	02/07/2024 09:00	E. coli	CFU/100 ml	0	0
ZS0809CUST	4950289	02/07/2024 09:00	Free - Residual disinfectant	mg Cl/l	0.2	
ZS0809CUST	4950289	02/07/2024 09:00	Hydrogen Ion	pH value	7.5	9.5
ZS0809CUST	4950289	02/07/2024 09:00	Iron	ug Fe/l	65	200
ZS0809CUST	4950289	02/07/2024 09:00	Manganese	ug Mn/l	1.7	50
ZS0809CUST	4950289	02/07/2024 09:00	Odour	Diln No	0	0
ZS0809CUST	4950289	02/07/2024 09:00	Odour - Nature		No odour	
ZS0809CUST	4950289	02/07/2024 09:00	Taste	Diln No	0	0
ZS0809CUST	4950289	02/07/2024 09:00	Taste - Nature		No taste	
ZS0809CUST	4950289	02/07/2024 09:00	Total - Residual disinfectant	mg Cl/l	0.4	

ZS0809CUST	4950289	02/07/2024 09:00	Total Coliforms	CFU/100 ml	0	0
ZS0809CUST	4950289	02/07/2024 09:00	Turbidity	NTU	0.13	4
ZN1102CUST	4950291	02/07/2024 10:00	Aluminium	ug Al/l	19	200
ZN1102CUST	4950291	02/07/2024 10:00	Colour	mg/l Pt/Co	<4.56	20
ZN1102CUST	4950291	02/07/2024 10:00	E. coli	CFU/100 ml	0	0
ZN1102CUST	4950291	02/07/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.54	
ZN1102CUST	4950291	02/07/2024 10:00	Hydrogen Ion	pH value	7.5	9.5
ZN1102CUST	4950291	02/07/2024 10:00	Iron	ug Fe/l	90	200
ZN1102CUST	4950291	02/07/2024 10:00	Manganese	ug Mn/l	5.1	50
ZN1102CUST	4950291	02/07/2024 10:00	Odour	Diln No	0	0
ZN1102CUST	4950291	02/07/2024 10:00	Odour - Nature		No odour	
ZN1102CUST	4950291	02/07/2024 10:00	Taste	Diln No	0	0
ZN1102CUST	4950291	02/07/2024 10:00	Taste - Nature		No taste	
ZN1102CUST	4950291	02/07/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.66	
ZN1102CUST	4950291	02/07/2024 10:00	Total Coliforms	CFU/100 ml	0	0
ZN1102CUST	4950291	02/07/2024 10:00	Turbidity	NTU	0.69	4
ZN0705AE	4936237	02/07/2024 10:17	1,2 Dichloroethane	ug/l	<0.4	3
ZN0705AE	4936237	02/07/2024 10:17	Aluminium	ug Al/l	<3.089	200
ZN0705AE	4936237	02/07/2024 10:17	Ammonium	mg NH4/l	<0.01	0.5
ZN0705AE	4936237	02/07/2024 10:17	Antimony	ug/l Sb	<0.18	5
ZN0705AE	4936237	02/07/2024 10:17	Arsenic	ug/l As	<0.3	10
ZN0705AE	4936237	02/07/2024 10:17	Benzene	ug/l	<0.15	1
ZN0705AE	4936237	02/07/2024 10:17	Boron	mg/l B	<0.038	1
ZN0705AE	4936237	02/07/2024 10:17	Bromodichloromethane	ug/l	9.8	
ZN0705AE	4936237	02/07/2024 10:17	Bromoform	ug/l	<3.5	
ZN0705AE	4936237	02/07/2024 10:17	Cadmium	ug/l Cd	<0.30	5
ZN0705AE	4936237	02/07/2024 10:17	Calcium	mg/l	14	
ZN0705AE	4936237	02/07/2024 10:17	Chloride	mg Cl/l	8.9	250
ZN0705AE	4936237	02/07/2024 10:17	Chloroform	ug/l	34	
ZN0705AE	4936237	02/07/2024 10:17	Chromium	ug/l Cr	<0.4	50
ZN0705AE	4936237	02/07/2024 10:17	Colony Counts 22	CFU/1 ml	0	
ZN0705AE	4936237	02/07/2024 10:17	Colony Counts 37 (48hrs)	CFU/1 ml	4	
ZN0705AE	4936237	02/07/2024 10:17	Colour	mg/l Pt/Co	<4.56	20
ZN0705AE	4936237	02/07/2024 10:17	Conductivity	uS/cm 20 C	120	2500
ZN0705AE	4936237	02/07/2024 10:17	Copper	mg Cu/l	<0.043	2
ZN0705AE	4936237	02/07/2024 10:17	Dibromochloromethane	ug/l	2.1	
ZN0705AE	4936237	02/07/2024 10:17	E. coli	CFU/100 ml	0	0
ZN0705AE	4936237	02/07/2024 10:17	Enterococci	CFU/100ml	0	0

ZN0705AE	4936237	02/07/2024 10:17	Fluoride	mg F/l	<0.150	1.5
ZN0705AE	4936237	02/07/2024 10:17	Free - Residual disinfectant	mg Cl/l	0.6	
ZN0705AE	4936237	02/07/2024 10:17	Hydrogen Ion	pH value	7.2	9.5
ZN0705AE	4936237	02/07/2024 10:17	Iron	ug/l Fe	3.7	200
ZN0705AE	4936237	02/07/2024 10:17	Lead	ug Pb/l	<0.09	10
ZN0705AE	4936237	02/07/2024 10:17	Magnesium	mg/l	1.9	
ZN0705AE	4936237	02/07/2024 10:17	Manganese	ug Mn/l	<0.642	50
ZN0705AE	4936237	02/07/2024 10:17	Nickel	ug Ni/l	<0.26	20
ZN0705AE	4936237	02/07/2024 10:17	Nitrate	mg/l	0.47	50
ZN0705AE	4936237	02/07/2024 10:17	Nitrate/Nitrite Formula	mg/l	<0.0094	1
ZN0705AE	4936237	02/07/2024 10:17	Nitrite	mg/l	<0.03	0.5
ZN0705AE	4936237	02/07/2024 10:17	Odour	Diln No	0	0
ZN0705AE	4936237	02/07/2024 10:17	Odour - Nature		No odour	
ZN0705AE	4936237	02/07/2024 10:17	Potassium	mg/l	<0.5	
ZN0705AE	4936237	02/07/2024 10:17	Selenium	ug/l Se	<0.4	10
ZN0705AE	4936237	02/07/2024 10:17	Sodium	mg Na/l	6.6	200
ZN0705AE	4936237	02/07/2024 10:17	Sulphate	mg SO4/l	23	250
ZN0705AE	4936237	02/07/2024 10:17	Taste	Diln No	0	0
ZN0705AE	4936237	02/07/2024 10:17	Taste - Nature		No taste	
ZN0705AE	4936237	02/07/2024 10:17	Tetrachloroethene	ug/l	<0.8	
ZN0705AE	4936237	02/07/2024 10:17	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0705AE	4936237	02/07/2024 10:17	Tetrachloromethane	ug/l	<0.4	3
ZN0705AE	4936237	02/07/2024 10:17	Total - Residual disinfectant	mg Cl/l	0.73	
ZN0705AE	4936237	02/07/2024 10:17	Total Coliforms	CFU/100 ml	0	0
ZN0705AE	4936237	02/07/2024 10:17	Total hardness	mg/l	17	
ZN0705AE	4936237	02/07/2024 10:17	Total Organic Carbon	mg C/l	1.5	
ZN0705AE	4936237	02/07/2024 10:17	Total Trihalomethanes	ug/l	46	100
ZN0705AE	4936237	02/07/2024 10:17	Trichloroethene	ug/l	<0.7	
ZN0705AE	4936237	02/07/2024 10:17	Turbidity	NTU	<0.09	4
ZN0705AE	4936237	02/07/2024 10:17	WHO Index		0.3	1
ZN0502AE	4936215	02/07/2024 10:52	1,2 Dichloroethane	ug/l	<0.4	3
ZN0502AE	4936215	02/07/2024 10:52	Aluminium	ug Al/l	15	200
ZN0502AE	4936215	02/07/2024 10:52	Ammonium	mg NH4/l	<0.01	0.5
ZN0502AE	4936215	02/07/2024 10:52	Antimony	ug/l Sb	<0.18	5
ZN0502AE	4936215	02/07/2024 10:52	Arsenic	ug/l As	<0.3	10
ZN0502AE	4936215	02/07/2024 10:52	Benzene	ug/l	<0.15	1
ZN0502AE	4936215	02/07/2024 10:52	Boron	mg/l B	<0.038	1
ZN0502AE	4936215	02/07/2024 10:52	Bromodichloromethane	ug/l	11	

ZN0502AE	4936215	02/07/2024 10:52	Bromoform	ug/l	<3.5	
ZN0502AE	4936215	02/07/2024 10:52	Cadmium	ug/l Cd	<0.30	5
ZN0502AE	4936215	02/07/2024 10:52	Calcium	mg/l	16	
ZN0502AE	4936215	02/07/2024 10:52	Chloride	mg Cl/l	9.4	250
ZN0502AE	4936215	02/07/2024 10:52	Chloroform	ug/l	48	
ZN0502AE	4936215	02/07/2024 10:52	Chromium	ug/l Cr	<0.4	50
ZN0502AE	4936215	02/07/2024 10:52	Colony Counts 22	CFU/1 ml	0	
ZN0502AE	4936215	02/07/2024 10:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0502AE	4936215	02/07/2024 10:52	Colour	mg/l Pt/Co	<4.56	20
ZN0502AE	4936215	02/07/2024 10:52	Conductivity	uS/cm 20 C	120	2500
ZN0502AE	4936215	02/07/2024 10:52	Copper	mg Cu/l	<0.546	2
ZN0502AE	4936215	02/07/2024 10:52	Dibromochloromethane	ug/l	1.9	
ZN0502AE	4936215	02/07/2024 10:52	E. coli	CFU/100 ml	0	0
ZN0502AE	4936215	02/07/2024 10:52	Enterococci	CFU/100ml	0	0
ZN0502AE	4936215	02/07/2024 10:52	Fluoride	mg F/l	<0.150	1.5
ZN0502AE	4936215	02/07/2024 10:52	Free - Residual disinfectant	mg Cl/l	0.7	
ZN0502AE	4936215	02/07/2024 10:52	Hydrogen Ion	pH value	7.4	9.5
ZN0502AE	4936215	02/07/2024 10:52	Iron	ug/l Fe	<1.538	200
ZN0502AE	4936215	02/07/2024 10:52	Lead	ug Pb/l	<0.095	10
ZN0502AE	4936215	02/07/2024 10:52	Magnesium	mg/l	2.3	
ZN0502AE	4936215	02/07/2024 10:52	Manganese	ug Mn/l	<0.642	50
ZN0502AE	4936215	02/07/2024 10:52	Mercury	ug per l	<0.041	1
ZN0502AE	4936215	02/07/2024 10:52	Nickel	ug Ni/l	<0.625	20
ZN0502AE	4936215	02/07/2024 10:52	Nitrate	mg/l	<0.3	50
ZN0502AE	4936215	02/07/2024 10:52	Nitrate/Nitrite Formula	mg/l	<0.0042	1
ZN0502AE	4936215	02/07/2024 10:52	Nitrite	mg/l	<0.03	0.5
ZN0502AE	4936215	02/07/2024 10:52	Odour	Diln No	0	0
ZN0502AE	4936215	02/07/2024 10:52	Odour - Nature		No odour	
ZN0502AE	4936215	02/07/2024 10:52	Potassium	mg/l	<0.5	
ZN0502AE	4936215	02/07/2024 10:52	Selenium	ug/l Se	<0.4	10
ZN0502AE	4936215	02/07/2024 10:52	Sodium	mg Na/l	5.5	200
ZN0502AE	4936215	02/07/2024 10:52	Sulphate	mg SO4/l	27	250
ZN0502AE	4936215	02/07/2024 10:52	Taste	Diln No	0	0
ZN0502AE	4936215	02/07/2024 10:52	Taste - Nature		No taste	
ZN0502AE	4936215	02/07/2024 10:52	Tetrachloroethene	ug/l	<0.8	
ZN0502AE	4936215	02/07/2024 10:52	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0502AE	4936215	02/07/2024 10:52	Tetrachloromethane	ug/l	<0.4	3
ZN0502AE	4936215	02/07/2024 10:52	Total - Residual disinfectant	mg Cl/l	0.76	

ZN0502AE	4936215	02/07/2024 10:52	Total Coliforms	CFU/100 ml	0	0
ZN0502AE	4936215	02/07/2024 10:52	Total hardness	mg/l	20	
ZN0502AE	4936215	02/07/2024 10:52	Total Organic Carbon	mg C/l	1.8	
ZN0502AE	4936215	02/07/2024 10:52	Total Trihalomethanes	ug/l	62	100
ZN0502AE	4936215	02/07/2024 10:52	Trichloroethene	ug/l	<0.7	
ZN0502AE	4936215	02/07/2024 10:52	Turbidity	NTU	<0.09	4
ZN0502AE	4936215	02/07/2024 10:52	WHO Index		0.37	1
ZN0804AE	4933587	02/07/2024 12:00	1,2 Dichloroethane	ug/l	<0.4	3
ZN0804AE	4933587	02/07/2024 12:00	Aluminium	ug Al/l	22	200
ZN0804AE	4933587	02/07/2024 12:00	Ammonium	mg NH4/l	<0.01	0.5
ZN0804AE	4933587	02/07/2024 12:00	Antimony	ug/l Sb	<0.18	5
ZN0804AE	4933587	02/07/2024 12:00	Arsenic	ug/l As	0.32	10
ZN0804AE	4933587	02/07/2024 12:00	Benzene	ug/l	<0.15	1
ZN0804AE	4933587	02/07/2024 12:00	Boron	mg/l B	<0.038	1
ZN0804AE	4933587	02/07/2024 12:00	Bromodichloromethane	ug/l	18	
ZN0804AE	4933587	02/07/2024 12:00	Bromoform	ug/l	<3.5	
ZN0804AE	4933587	02/07/2024 12:00	Cadmium	ug/l Cd	<0.30	5
ZN0804AE	4933587	02/07/2024 12:00	Calcium	mg/l	56	
ZN0804AE	4933587	02/07/2024 12:00	Chloride	mg Cl/l	16	250
ZN0804AE	4933587	02/07/2024 12:00	Chloroform	ug/l	58	
ZN0804AE	4933587	02/07/2024 12:00	Chromium	ug/l Cr	<0.4	50
ZN0804AE	4933587	02/07/2024 12:00	Colony Counts 22	CFU/1 ml	0	
ZN0804AE	4933587	02/07/2024 12:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0804AE	4933587	02/07/2024 12:00	Colour	mg/l Pt/Co	<4.56	20
ZN0804AE	4933587	02/07/2024 12:00	Conductivity	uS/cm 20 C	440	2500
ZN0804AE	4933587	02/07/2024 12:00	Copper	mg Cu/l	<0.546	2
ZN0804AE	4933587	02/07/2024 12:00	Dibromochloromethane	ug/l	5.7	
ZN0804AE	4933587	02/07/2024 12:00	E. coli	CFU/100 ml	0	0
ZN0804AE	4933587	02/07/2024 12:00	Enterococci	CFU/100ml	0	0
ZN0804AE	4933587	02/07/2024 12:00	Fluoride	mg F/l	<0.150	1.5
ZN0804AE	4933587	02/07/2024 12:00	Free - Residual disinfectant	mg Cl/l	0.33	
ZN0804AE	4933587	02/07/2024 12:00	Hydrogen Ion	pH value	7.7	9.5
ZN0804AE	4933587	02/07/2024 12:00	Iron	ug/l Fe	19	200
ZN0804AE	4933587	02/07/2024 12:00	Lead	ug Pb/l	<0.095	10
ZN0804AE	4933587	02/07/2024 12:00	Magnesium	mg/l	4.2	
ZN0804AE	4933587	02/07/2024 12:00	Manganese	ug Mn/l	1.2	50
ZN0804AE	4933587	02/07/2024 12:00	Mercury	ug per l	<0.041	1
ZN0804AE	4933587	02/07/2024 12:00	Nickel	ug Ni/l	0.73	20

ZN0804AE	4933587	02/07/2024 12:00	Nitrate	mg/l	0.68	50
ZN0804AE	4933587	02/07/2024 12:00	Nitrate/Nitrite Formula	mg/l	<0.014	1
ZN0804AE	4933587	02/07/2024 12:00	Nitrite	mg/l	<0.03	0.5
ZN0804AE	4933587	02/07/2024 12:00	Odour	Diln No	0	0
ZN0804AE	4933587	02/07/2024 12:00	Odour - Nature		No odour	
ZN0804AE	4933587	02/07/2024 12:00	Potassium	mg/l	2.3	
ZN0804AE	4933587	02/07/2024 12:00	Selenium	ug/l Se	<0.4	10
ZN0804AE	4933587	02/07/2024 12:00	Sodium	mg Na/l	35	200
ZN0804AE	4933587	02/07/2024 12:00	Sulphate	mg SO4/l	120	250
ZN0804AE	4933587	02/07/2024 12:00	Taste	Diln No	0	0
ZN0804AE	4933587	02/07/2024 12:00	Taste - Nature		No taste	
ZN0804AE	4933587	02/07/2024 12:00	Tetrachloroethene	ug/l	<0.8	
ZN0804AE	4933587	02/07/2024 12:00	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0804AE	4933587	02/07/2024 12:00	Tetrachloromethane	ug/l	<0.4	3
ZN0804AE	4933587	02/07/2024 12:00	Total - Residual disinfectant	mg Cl/l	0.42	
ZN0804AE	4933587	02/07/2024 12:00	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4933587	02/07/2024 12:00	Total hardness	mg/l	63	
ZN0804AE	4933587	02/07/2024 12:00	Total Organic Carbon	mg C/l	2.2	
ZN0804AE	4933587	02/07/2024 12:00	Total Trihalomethanes	ug/l	82	100
ZN0804AE	4933587	02/07/2024 12:00	Trichloroethene	ug/l	<0.7	
ZN0804AE	4933587	02/07/2024 12:00	Turbidity	NTU	<0.09	4
ZN0804AE	4933587	02/07/2024 12:00	WHO Index		0.56	1
ZS0811AE	4936636	02/07/2024 12:08	1,2 Dichloroethane	ug/l	<0.4	3
ZS0811AE	4936636	02/07/2024 12:08	Aluminium	ug Al/l	20	200
ZS0811AE	4936636	02/07/2024 12:08	Ammonium	mg NH4/l	<0.01	0.5
ZS0811AE	4936636	02/07/2024 12:08	Antimony	ug/l Sb	<0.18	5
ZS0811AE	4936636	02/07/2024 12:08	Arsenic	ug/l As	<0.3	10
ZS0811AE	4936636	02/07/2024 12:08	Benzene	ug/l	<0.15	1
ZS0811AE	4936636	02/07/2024 12:08	Boron	mg/l B	<0.038	1
ZS0811AE	4936636	02/07/2024 12:08	Bromodichloromethane	ug/l	13	
ZS0811AE	4936636	02/07/2024 12:08	Bromoform	ug/l	<3.5	
ZS0811AE	4936636	02/07/2024 12:08	Cadmium	ug/l Cd	<0.30	5
ZS0811AE	4936636	02/07/2024 12:08	Calcium	mg/l	53	
ZS0811AE	4936636	02/07/2024 12:08	Chloride	mg Cl/l	21	250
ZS0811AE	4936636	02/07/2024 12:08	Chloroform	ug/l	29	
ZS0811AE	4936636	02/07/2024 12:08	Chromium	ug/l Cr	<0.4	50
ZS0811AE	4936636	02/07/2024 12:08	Colony Counts 22	CFU/1 ml	0	
ZS0811AE	4936636	02/07/2024 12:08	Colony Counts 37 (48hrs)	CFU/1 ml	0	

ZS0811AE	4936636	02/07/2024 12:08	Colour	mg/l Pt/Co	<4.56	20
ZS0811AE	4936636	02/07/2024 12:08	Conductivity	uS/cm 20 C	380	2500
ZS0811AE	4936636	02/07/2024 12:08	Copper	mg Cu/l	<0.546	2
ZS0811AE	4936636	02/07/2024 12:08	Dibromochloromethane	ug/l	6.1	
ZS0811AE	4936636	02/07/2024 12:08	E. coli	CFU/100 ml	0	0
ZS0811AE	4936636	02/07/2024 12:08	Enterococci	CFU/100ml	0	0
ZS0811AE	4936636	02/07/2024 12:08	Fluoride	mg F/l	<0.150	1.5
ZS0811AE	4936636	02/07/2024 12:08	Free - Residual disinfectant	mg Cl/l	0.7	
ZS0811AE	4936636	02/07/2024 12:08	Hydrogen Ion	pH value	7.6	9.5
ZS0811AE	4936636	02/07/2024 12:08	Iron	ug/l Fe	2.8	200
ZS0811AE	4936636	02/07/2024 12:08	Lead	ug Pb/l	<0.095	10
ZS0811AE	4936636	02/07/2024 12:08	Magnesium	mg/l	8.1	
ZS0811AE	4936636	02/07/2024 12:08	Manganese	ug Mn/l	<0.642	50
ZS0811AE	4936636	02/07/2024 12:08	Mercury	ug per l	<0.041	1
ZS0811AE	4936636	02/07/2024 12:08	Nickel	ug Ni/l	2.2	20
ZS0811AE	4936636	02/07/2024 12:08	Nitrate	mg/l	3.3	50
ZS0811AE	4936636	02/07/2024 12:08	Nitrate/Nitrite Formula	mg/l	<0.066	1
ZS0811AE	4936636	02/07/2024 12:08	Nitrite	mg/l	<0.03	0.5
ZS0811AE	4936636	02/07/2024 12:08	Odour	Diln No	0	0
ZS0811AE	4936636	02/07/2024 12:08	Odour - Nature		No odour	
ZS0811AE	4936636	02/07/2024 12:08	Potassium	mg/l	3.7	
ZS0811AE	4936636	02/07/2024 12:08	Selenium	ug/l Se	<0.4	10
ZS0811AE	4936636	02/07/2024 12:08	Sodium	mg Na/l	17	200
ZS0811AE	4936636	02/07/2024 12:08	Sulphate	mg SO4/l	85	250
ZS0811AE	4936636	02/07/2024 12:08	Taste	Diln No	0	0
ZS0811AE	4936636	02/07/2024 12:08	Taste - Nature		No taste	
ZS0811AE	4936636	02/07/2024 12:08	Tetrachloroethene	ug/l	<0.8	
ZS0811AE	4936636	02/07/2024 12:08	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZS0811AE	4936636	02/07/2024 12:08	Tetrachloromethane	ug/l	<0.4	3
ZS0811AE	4936636	02/07/2024 12:08	Total - Residual disinfectant	mg Cl/l	0.9	
ZS0811AE	4936636	02/07/2024 12:08	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4936636	02/07/2024 12:08	Total hardness	mg/l	66	
ZS0811AE	4936636	02/07/2024 12:08	Total Organic Carbon	mg C/l	2.8	
ZS0811AE	4936636	02/07/2024 12:08	Total Trihalomethanes	ug/l	49	100
ZS0811AE	4936636	02/07/2024 12:08	Trichloroethene	ug/l	<0.7	
ZS0811AE	4936636	02/07/2024 12:08	Turbidity	NTU	<0.09	4
ZS0811AE	4936636	02/07/2024 12:08	WHO Index		0.38	1
ZS0809CUST	4950780	03/07/2024 09:00	Aluminium	ug Al/l	16	200

ZS0809CUST	4950780	03/07/2024 09:00	Colour	mg/l Pt/Co	<4.56	20
ZS0809CUST	4950780	03/07/2024 09:00	Conductivity	uS/cm 20 C	380	2500
ZS0809CUST	4950780	03/07/2024 09:00	E. coli	CFU/100 ml	0	0
ZS0809CUST	4950780	03/07/2024 09:00	Free - Residual disinfectant	mg Cl/l	0.5	
ZS0809CUST	4950780	03/07/2024 09:00	Hydrogen Ion	pH value	7.6	9.5
ZS0809CUST	4950780	03/07/2024 09:00	Iron	ug/l Fe	<1.538	200
ZS0809CUST	4950780	03/07/2024 09:00	Lead	ug Pb/l	<0.095	10
ZS0809CUST	4950780	03/07/2024 09:00	Manganese	ug Mn/l	<0.642	50
ZS0809CUST	4950780	03/07/2024 09:00	Odour	Diln No	0	0
ZS0809CUST	4950780	03/07/2024 09:00	Odour - Nature		No odour	
ZS0809CUST	4950780	03/07/2024 09:00	Taste	Diln No	0	0
ZS0809CUST	4950780	03/07/2024 09:00	Taste - Nature		No taste	
ZS0809CUST	4950780	03/07/2024 09:00	Total - Residual disinfectant	mg Cl/l	0.7	
ZS0809CUST	4950780	03/07/2024 09:00	Total Coliforms	CFU/100 ml	0	0
ZS0809CUST	4950780	03/07/2024 09:00	Turbidity	NTU	<0.09	4
ZS0809AE	4936811	03/07/2024 09:14	E. coli	CFU/100 ml	0	0
ZS0809AE	4936811	03/07/2024 09:14	Free - Residual disinfectant	mg Cl/l	0.37	
ZS0809AE	4936811	03/07/2024 09:14	Total - Residual disinfectant	mg Cl/l	0.53	
ZS0809AE	4936811	03/07/2024 09:14	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4936623	03/07/2024 09:21	E. coli	CFU/100 ml	0	0
ZN0501AE	4936623	03/07/2024 09:21	Free - Residual disinfectant	mg Cl/l	0.64	
ZN0501AE	4936623	03/07/2024 09:21	Total - Residual disinfectant	mg Cl/l	0.83	
ZN0501AE	4936623	03/07/2024 09:21	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4936604	03/07/2024 09:57	1,2 Dichloroethane	ug/l	<0.4	3
ZN1102AE	4936604	03/07/2024 09:57	Aluminium	ug Al/l	4.7	200
ZN1102AE	4936604	03/07/2024 09:57	Ammonium	mg NH4/l	<0.01	0.5
ZN1102AE	4936604	03/07/2024 09:57	Antimony	ug/l Sb	0.11	5
ZN1102AE	4936604	03/07/2024 09:57	Arsenic	ug/l As	0.33	10
ZN1102AE	4936604	03/07/2024 09:57	Benzene	ug/l	<0.15	1
ZN1102AE	4936604	03/07/2024 09:57	Boron	mg/l B	<0.0586	1
ZN1102AE	4936604	03/07/2024 09:57	Bromodichloromethane	ug/l	15	
ZN1102AE	4936604	03/07/2024 09:57	Bromoform	ug/l	<3.5	
ZN1102AE	4936604	03/07/2024 09:57	Cadmium	ug/l Cd	<0.042	5
ZN1102AE	4936604	03/07/2024 09:57	Calcium	mg/l	26	
ZN1102AE	4936604	03/07/2024 09:57	Chloride	mg Cl/l	15	250
ZN1102AE	4936604	03/07/2024 09:57	Chloroform	ug/l	43	
ZN1102AE	4936604	03/07/2024 09:57	Chromium	ug/l Cr	<0.260	50
ZN1102AE	4936604	03/07/2024 09:57	Colony Counts 22	CFU/1 ml	0	

ZN1102AE	4936604	03/07/2024 09:57	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN1102AE	4936604	03/07/2024 09:57	Colour	mg/l Pt/Co	<4.56	20
ZN1102AE	4936604	03/07/2024 09:57	Conductivity	uS/cm 20 C	380	2500
ZN1102AE	4936604	03/07/2024 09:57	Copper	mg Cu/l	<0.546	2
ZN1102AE	4936604	03/07/2024 09:57	Dibromochloromethane	ug/l	4.3	
ZN1102AE	4936604	03/07/2024 09:57	E. coli	CFU/100 ml	0	0
ZN1102AE	4936604	03/07/2024 09:57	Enterococci	CFU/100ml	0	0
ZN1102AE	4936604	03/07/2024 09:57	Fluoride	mg F/l	<0.150	1.5
ZN1102AE	4936604	03/07/2024 09:57	Free - Residual disinfectant	mg Cl/l	0.39	
ZN1102AE	4936604	03/07/2024 09:57	Hydrogen Ion	pH value	7.5	9.5
ZN1102AE	4936604	03/07/2024 09:57	Iron	ug/l Fe	19	200
ZN1102AE	4936604	03/07/2024 09:57	Lead	ug Pb/l	<0.095	10
ZN1102AE	4936604	03/07/2024 09:57	Magnesium	mg/l	7.1	
ZN1102AE	4936604	03/07/2024 09:57	Manganese	ug Mn/l	0.7	50
ZN1102AE	4936604	03/07/2024 09:57	Mercury	ug per l	<0.041	1
ZN1102AE	4936604	03/07/2024 09:57	Nickel	ug Ni/l	1.7	20
ZN1102AE	4936604	03/07/2024 09:57	Nitrate	mg/l	2.6	50
ZN1102AE	4936604	03/07/2024 09:57	Nitrate/Nitrite Formula	mg/l	<0.052	1
ZN1102AE	4936604	03/07/2024 09:57	Nitrite	mg/l	<0.03	0.5
ZN1102AE	4936604	03/07/2024 09:57	Odour	Diln No	0	0
ZN1102AE	4936604	03/07/2024 09:57	Odour - Nature		No odour	
ZN1102AE	4936604	03/07/2024 09:57	Potassium	mg/l	4.1	
ZN1102AE	4936604	03/07/2024 09:57	Selenium	ug/l Se	0.14	10
ZN1102AE	4936604	03/07/2024 09:57	Sodium	mg Na/l	51	200
ZN1102AE	4936604	03/07/2024 09:57	Sulphate	mg SO4/l	71	250
ZN1102AE	4936604	03/07/2024 09:57	Taste	Diln No	0	0
ZN1102AE	4936604	03/07/2024 09:57	Taste - Nature		No taste	
ZN1102AE	4936604	03/07/2024 09:57	Tetrachloroethene	ug/l	<0.8	
ZN1102AE	4936604	03/07/2024 09:57	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN1102AE	4936604	03/07/2024 09:57	Tetrachloromethane	ug/l	<0.4	3
ZN1102AE	4936604	03/07/2024 09:57	Total - Residual disinfectant	mg Cl/l	0.6	
ZN1102AE	4936604	03/07/2024 09:57	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4936604	03/07/2024 09:57	Total hardness	mg/l	38	
ZN1102AE	4936604	03/07/2024 09:57	Total Organic Carbon	mg C/l	2.2	
ZN1102AE	4936604	03/07/2024 09:57	Total Trihalomethanes	ug/l	63	100
ZN1102AE	4936604	03/07/2024 09:57	Trichloroethene	ug/l	<0.7	
ZN1102AE	4936604	03/07/2024 09:57	Turbidity	NTU	<0.09	4
ZN1102AE	4936604	03/07/2024 09:57	WHO Index		0.44	1

ZN0706AE	4936209	03/07/2024 10:32	E. coli	CFU/100 ml	0	0
ZN0706AE	4936209	03/07/2024 10:32	Free - Residual disinfectant	mg Cl/l	0.49	
ZN0706AE	4936209	03/07/2024 10:32	Total - Residual disinfectant	mg Cl/l	0.58	
ZN0706AE	4936209	03/07/2024 10:32	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4936825	03/07/2024 10:59	E. coli	CFU/100 ml	0	0
ZS0811AE	4936825	03/07/2024 10:59	Free - Residual disinfectant	mg Cl/l	0.42	
ZS0811AE	4936825	03/07/2024 10:59	Total - Residual disinfectant	mg Cl/l	0.55	
ZS0811AE	4936825	03/07/2024 10:59	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4936234	04/07/2024 09:43	E. coli	CFU/100 ml	0	0
ZS0811AE	4936234	04/07/2024 09:43	Free - Residual disinfectant	mg Cl/l	0.53	
ZS0811AE	4936234	04/07/2024 09:43	Total - Residual disinfectant	mg Cl/l	0.83	
ZS0811AE	4936234	04/07/2024 09:43	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4936624	04/07/2024 11:57	E. coli	CFU/100 ml	0	0
ZN0102AE	4936624	04/07/2024 11:57	Free - Residual disinfectant	mg Cl/l	0.2	
ZN0102AE	4936624	04/07/2024 11:57	Total - Residual disinfectant	mg Cl/l	0.29	
ZN0102AE	4936624	04/07/2024 11:57	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4936600	05/07/2024 09:52	E. coli	CFU/100 ml	0	0
ZS0809AE	4936600	05/07/2024 09:52	Free - Residual disinfectant	mg Cl/l	0.37	
ZS0809AE	4936600	05/07/2024 09:52	Total - Residual disinfectant	mg Cl/l	0.71	
ZS0809AE	4936600	05/07/2024 09:52	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4936821	05/07/2024 10:36	E. coli	CFU/100 ml	0	0
ZN0102AE	4936821	05/07/2024 10:36	Free - Residual disinfectant	mg Cl/l	0.42	
ZN0102AE	4936821	05/07/2024 10:36	Total - Residual disinfectant	mg Cl/l	0.56	
ZN0102AE	4936821	05/07/2024 10:36	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4936236	05/07/2024 11:11	E. coli	CFU/100 ml	0	0
ZN0804AE	4936236	05/07/2024 11:11	Free - Residual disinfectant	mg Cl/l	1.17	
ZN0804AE	4936236	05/07/2024 11:11	Total - Residual disinfectant	mg Cl/l	1.35	
ZN0804AE	4936236	05/07/2024 11:11	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4936637	08/07/2024 09:21	E. coli	CFU/100 ml	0	0
ZN0804AE	4936637	08/07/2024 09:21	Free - Residual disinfectant	mg Cl/l	0.54	
ZN0804AE	4936637	08/07/2024 09:21	Total - Residual disinfectant	mg Cl/l	0.63	
ZN0804AE	4936637	08/07/2024 09:21	Total Coliforms	CFU/100 ml	0	0
ZN0705AE	4939484	08/07/2024 09:56	Turbidity	NTU	<0.09	4
ZN1102AE	4939396	08/07/2024 11:13	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN1102AE	4939396	08/07/2024 11:13	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN1102AE	4939396	08/07/2024 11:13	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN1102AE	4939396	08/07/2024 11:13	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN1102AE	4939396	08/07/2024 11:13	Bromate	ug BrO3/l	<0.50	10

ZN1102AE	4939396	08/07/2024 11:13	Calcium	mg/l	41	
ZN1102AE	4939396	08/07/2024 11:13	E. coli	CFU/100 ml	0	0
ZN1102AE	4939396	08/07/2024 11:13	Free - Residual disinfectant	mg Cl/l	0.42	
ZN1102AE	4939396	08/07/2024 11:13	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN1102AE	4939396	08/07/2024 11:13	Magnesium	mg/l	7.7	
ZN1102AE	4939396	08/07/2024 11:13	PAH - Sum of four substances	ug/l	0	0.1
ZN1102AE	4939396	08/07/2024 11:13	Total - Residual disinfectant	mg Cl/l	0.53	
ZN1102AE	4939396	08/07/2024 11:13	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4939396	08/07/2024 11:13	Total hardness	mg/l	54	
ZN0102AE	4939419	08/07/2024 11:15	Aluminium	ug Al/l	21	200
ZN0102AE	4939419	08/07/2024 11:15	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN0102AE	4939419	08/07/2024 11:15	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0102AE	4939419	08/07/2024 11:15	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0102AE	4939419	08/07/2024 11:15	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0102AE	4939419	08/07/2024 11:15	Bromate	ug BrO3/l	<0.50	10
ZN0102AE	4939419	08/07/2024 11:15	Colony Counts 22	CFU/1 ml	0	
ZN0102AE	4939419	08/07/2024 11:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0102AE	4939419	08/07/2024 11:15	Colour	mg/l Pt/Co	<4.56	20
ZN0102AE	4939419	08/07/2024 11:15	Conductivity	uS/cm 20 C	340	2500
ZN0102AE	4939419	08/07/2024 11:15	E. coli	CFU/100 ml	0	0
ZN0102AE	4939419	08/07/2024 11:15	Free - Residual disinfectant	mg Cl/l	0.43	
ZN0102AE	4939419	08/07/2024 11:15	Hydrogen Ion	pH value	7.7	9.5
ZN0102AE	4939419	08/07/2024 11:15	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0102AE	4939419	08/07/2024 11:15	Iron	ug/l Fe	12	200
ZN0102AE	4939419	08/07/2024 11:15	Manganese	ug Mn/l	1.1	50
ZN0102AE	4939419	08/07/2024 11:15	Odour	Diln No	0	0
ZN0102AE	4939419	08/07/2024 11:15	Odour - Nature		No odour	
ZN0102AE	4939419	08/07/2024 11:15	PAH - Sum of four substances	ug/l	0	0.1
ZN0102AE	4939419	08/07/2024 11:15	Taste	Diln No	0	0
ZN0102AE	4939419	08/07/2024 11:15	Taste - Nature		No taste	
ZN0102AE	4939419	08/07/2024 11:15	Total - Residual disinfectant	mg Cl/l	0.56	
ZN0102AE	4939419	08/07/2024 11:15	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4939419	08/07/2024 11:15	Turbidity	NTU	<0.09	4
ZN0706AE	4939414	08/07/2024 11:24	Ammonium	mg NH4/l	<0.01	0.5
ZN0706AE	4939414	08/07/2024 11:24	E. coli	CFU/100 ml	0	0
ZN0706AE	4939414	08/07/2024 11:24	Free - Residual disinfectant	mg Cl/l	0.27	
ZN0706AE	4939414	08/07/2024 11:24	Total - Residual disinfectant	mg Cl/l	0.35	
ZN0706AE	4939414	08/07/2024 11:24	Total Coliforms	CFU/100 ml	0	0

ZS0809AE	4939393	08/07/2024 12:05	Aluminium	ug Al/l	15	200
ZS0809AE	4939393	08/07/2024 12:05	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZS0809AE	4939393	08/07/2024 12:05	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZS0809AE	4939393	08/07/2024 12:05	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZS0809AE	4939393	08/07/2024 12:05	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZS0809AE	4939393	08/07/2024 12:05	Bromate	ug BrO3/l	<0.50	10
ZS0809AE	4939393	08/07/2024 12:05	Colony Counts 22	CFU/1 ml	0	
ZS0809AE	4939393	08/07/2024 12:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0809AE	4939393	08/07/2024 12:05	Colour	mg/l Pt/Co	<4.56	20
ZS0809AE	4939393	08/07/2024 12:05	Conductivity	uS/cm 20 C	380	2500
ZS0809AE	4939393	08/07/2024 12:05	E. coli	CFU/100 ml	0	0
ZS0809AE	4939393	08/07/2024 12:05	Free - Residual disinfectant	mg Cl/l	0.43	
ZS0809AE	4939393	08/07/2024 12:05	Hydrogen Ion	pH value	7.6	9.5
ZS0809AE	4939393	08/07/2024 12:05	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZS0809AE	4939393	08/07/2024 12:05	Iron	ug/l Fe	5.7	200
ZS0809AE	4939393	08/07/2024 12:05	Manganese	ug Mn/l	<0.642	50
ZS0809AE	4939393	08/07/2024 12:05	Odour	Diln No	0	0
ZS0809AE	4939393	08/07/2024 12:05	Odour - Nature		No odour	
ZS0809AE	4939393	08/07/2024 12:05	PAH - Sum of four substances	ug/l	0	0.1
ZS0809AE	4939393	08/07/2024 12:05	Taste	Diln No	0	0
ZS0809AE	4939393	08/07/2024 12:05	Taste - Nature		No taste	
ZS0809AE	4939393	08/07/2024 12:05	Total - Residual disinfectant	mg Cl/l	0.63	
ZS0809AE	4939393	08/07/2024 12:05	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4939393	08/07/2024 12:05	Turbidity	NTU	<0.09	4
ZS0811AE	4939439	08/07/2024 12:52	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZS0811AE	4939439	08/07/2024 12:52	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZS0811AE	4939439	08/07/2024 12:52	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZS0811AE	4939439	08/07/2024 12:52	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZS0811AE	4939439	08/07/2024 12:52	Bromate	ug BrO3/l	<0.50	10
ZS0811AE	4939439	08/07/2024 12:52	E. coli	CFU/100 ml	0	0
ZS0811AE	4939439	08/07/2024 12:52	Free - Residual disinfectant	mg Cl/l	0.38	
ZS0811AE	4939439	08/07/2024 12:52	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZS0811AE	4939439	08/07/2024 12:52	PAH - Sum of four substances	ug/l	0	0.1
ZS0811AE	4939439	08/07/2024 12:52	Total - Residual disinfectant	mg Cl/l	0.52	
ZS0811AE	4939439	08/07/2024 12:52	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4939801	09/07/2024 09:22	E. coli	CFU/100 ml	0	0
ZS0809AE	4939801	09/07/2024 09:22	Free - Residual disinfectant	mg Cl/l	0.22	
ZS0809AE	4939801	09/07/2024 09:22	Total - Residual disinfectant	mg Cl/l	0.39	

ZS0809AE	4939801	09/07/2024 09:22	Total Coliforms	CFU/100 ml	0	0
ZN0502AE	4939420	09/07/2024 09:43	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN0502AE	4939420	09/07/2024 09:43	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0502AE	4939420	09/07/2024 09:43	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0502AE	4939420	09/07/2024 09:43	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0502AE	4939420	09/07/2024 09:43	Bromate	ug BrO3/l	<0.50	10
ZN0502AE	4939420	09/07/2024 09:43	E. coli	CFU/100 ml	0	0
ZN0502AE	4939420	09/07/2024 09:43	Free - Residual disinfectant	mg Cl/l	0.58	
ZN0502AE	4939420	09/07/2024 09:43	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0502AE	4939420	09/07/2024 09:43	PAH - Sum of four substances	ug/l	0	0.1
ZN0502AE	4939420	09/07/2024 09:43	Total - Residual disinfectant	mg Cl/l	0.64	
ZN0502AE	4939420	09/07/2024 09:43	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4939835	09/07/2024 10:05	Aluminium	ug Al/l	16	200
ZS0811AE	4939835	09/07/2024 10:05	Colony Counts 22	CFU/1 ml	0	
ZS0811AE	4939835	09/07/2024 10:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0811AE	4939835	09/07/2024 10:05	Colour	mg/l Pt/Co	<4.56	20
ZS0811AE	4939835	09/07/2024 10:05	Conductivity	uS/cm 20 C	380	2500
ZS0811AE	4939835	09/07/2024 10:05	E. coli	CFU/100 ml	0	0
ZS0811AE	4939835	09/07/2024 10:05	Free - Residual disinfectant	mg Cl/l	0.74	
ZS0811AE	4939835	09/07/2024 10:05	Hydrogen Ion	pH value	7.6	9.5
ZS0811AE	4939835	09/07/2024 10:05	Iron	ug/l Fe	2.3	200
ZS0811AE	4939835	09/07/2024 10:05	Manganese	ug Mn/l	<0.642	50
ZS0811AE	4939835	09/07/2024 10:05	Odour	Diln No	0	0
ZS0811AE	4939835	09/07/2024 10:05	Odour - Nature		No odour	
ZS0811AE	4939835	09/07/2024 10:05	Taste	Diln No	0	0
ZS0811AE	4939835	09/07/2024 10:05	Taste - Nature		No taste	
ZS0811AE	4939835	09/07/2024 10:05	Total - Residual disinfectant	mg Cl/l	0.89	
ZS0811AE	4939835	09/07/2024 10:05	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4939835	09/07/2024 10:05	Turbidity	NTU	<0.09	4
ZN0102CUST	4953476	09/07/2024 10:40	Aluminium	ug Al/l	18	200
ZN0102CUST	4953476	09/07/2024 10:40	Colour	mg/l Pt/Co	<4.56	20
ZN0102CUST	4953476	09/07/2024 10:40	E. coli	CFU/100 ml	0	0
ZN0102CUST	4953476	09/07/2024 10:40	Free - Residual disinfectant	mg Cl/l	0.09	
ZN0102CUST	4953476	09/07/2024 10:40	Hydrogen Ion	pH value	7.7	9.5
ZN0102CUST	4953476	09/07/2024 10:40	Iron	ug/l Fe	40	200
ZN0102CUST	4953476	09/07/2024 10:40	Manganese	ug Mn/l	3.6	50
ZN0102CUST	4953476	09/07/2024 10:40	Odour	Diln No	0	0
ZN0102CUST	4953476	09/07/2024 10:40	Odour - Nature		No odour	

ZN0102CUST	4953476	09/07/2024 10:40	Taste	Diln No	0	0
ZN0102CUST	4953476	09/07/2024 10:40	Taste - Nature		No taste	
ZN0102CUST	4953476	09/07/2024 10:40	Total - Residual disinfectant	mg Cl/l	0.16	
ZN0102CUST	4953476	09/07/2024 10:40	Total Coliforms	CFU/100 ml	0	0
ZN0102CUST	4953476	09/07/2024 10:40	Turbidity	NTU	0.23	4
ZN1102AE	4939804	09/07/2024 10:42	Aluminium	ug Al/l	7.8	200
ZN1102AE	4939804	09/07/2024 10:42	Colony Counts 22	CFU/1 ml	0	
ZN1102AE	4939804	09/07/2024 10:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN1102AE	4939804	09/07/2024 10:42	Colour	mg/l Pt/Co	<4.56	20
ZN1102AE	4939804	09/07/2024 10:42	Conductivity	uS/cm 20 C	370	2500
ZN1102AE	4939804	09/07/2024 10:42	E. coli	CFU/100 ml	0	0
ZN1102AE	4939804	09/07/2024 10:42	Free - Residual disinfectant	mg Cl/l	0.71	
ZN1102AE	4939804	09/07/2024 10:42	Hydrogen Ion	pH value	7.5	9.5
ZN1102AE	4939804	09/07/2024 10:42	Iron	ug/l Fe	2.9	200
ZN1102AE	4939804	09/07/2024 10:42	Manganese	ug Mn/l	<0.642	50
ZN1102AE	4939804	09/07/2024 10:42	Odour	Diln No	0	0
ZN1102AE	4939804	09/07/2024 10:42	Odour - Nature		No odour	
ZN1102AE	4939804	09/07/2024 10:42	Taste	Diln No	0	0
ZN1102AE	4939804	09/07/2024 10:42	Taste - Nature		No taste	
ZN1102AE	4939804	09/07/2024 10:42	Total - Residual disinfectant	mg Cl/l	0.88	
ZN1102AE	4939804	09/07/2024 10:42	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4939804	09/07/2024 10:42	Turbidity	NTU	<0.09	4
ZN0501AE	4939417	09/07/2024 10:58	Aluminium	ug Al/l	23	200
ZN0501AE	4939417	09/07/2024 10:58	Colony Counts 22	CFU/1 ml	0	
ZN0501AE	4939417	09/07/2024 10:58	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0501AE	4939417	09/07/2024 10:58	Colour	mg/l Pt/Co	<4.56	20
ZN0501AE	4939417	09/07/2024 10:58	Conductivity	uS/cm 20 C	120	2500
ZN0501AE	4939417	09/07/2024 10:58	E. coli	CFU/100 ml	0	0
ZN0501AE	4939417	09/07/2024 10:58	Free - Residual disinfectant	mg Cl/l	0.52	
ZN0501AE	4939417	09/07/2024 10:58	Hydrogen Ion	pH value	7.3	9.5
ZN0501AE	4939417	09/07/2024 10:58	Iron	ug/l Fe	14	200
ZN0501AE	4939417	09/07/2024 10:58	Manganese	ug Mn/l	<0.642	50
ZN0501AE	4939417	09/07/2024 10:58	Odour	Diln No	0	0
ZN0501AE	4939417	09/07/2024 10:58	Odour - Nature		No odour	
ZN0501AE	4939417	09/07/2024 10:58	Taste	Diln No	0	0
ZN0501AE	4939417	09/07/2024 10:58	Taste - Nature		No taste	
ZN0501AE	4939417	09/07/2024 10:58	Total - Residual disinfectant	mg Cl/l	0.56	
ZN0501AE	4939417	09/07/2024 10:58	Total Coliforms	CFU/100 ml	0	0

ZN0501AE	4939417	09/07/2024 10:58	Turbidity	NTU	0.11	4
ZN0102AE	4953807	10/07/2024 10:50	E. coli	CFU/100 ml	0	0
ZN0102AE	4953807	10/07/2024 10:50	Free - Residual disinfectant	mg Cl/l	0.18	
ZN0102AE	4953807	10/07/2024 10:50	Odour	Diln No	0	0
ZN0102AE	4953807	10/07/2024 10:50	Odour - Nature		No odour	
ZN0102AE	4953807	10/07/2024 10:50	Taste	Diln No	0	0
ZN0102AE	4953807	10/07/2024 10:50	Taste - Nature		No taste	
ZN0102AE	4953807	10/07/2024 10:50	Total - Residual disinfectant	mg Cl/l	0.29	
ZN0102AE	4953807	10/07/2024 10:50	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4953806	10/07/2024 11:05	E. coli	CFU/100 ml	0	0
ZN0102AE	4953806	10/07/2024 11:05	Free - Residual disinfectant	mg Cl/l	0.17	
ZN0102AE	4953806	10/07/2024 11:05	Odour	Diln No	0	0
ZN0102AE	4953806	10/07/2024 11:05	Odour - Nature		No odour	
ZN0102AE	4953806	10/07/2024 11:05	Taste	Diln No	0	0
ZN0102AE	4953806	10/07/2024 11:05	Taste - Nature		No taste	
ZN0102AE	4953806	10/07/2024 11:05	Total - Residual disinfectant	mg Cl/l	0.25	
ZN0102AE	4953806	10/07/2024 11:05	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4953805	10/07/2024 11:15	E. coli	CFU/100 ml	0	0
ZN0102AE	4953805	10/07/2024 11:15	Free - Residual disinfectant	mg Cl/l	0.19	
ZN0102AE	4953805	10/07/2024 11:15	Odour	Diln No	0	0
ZN0102AE	4953805	10/07/2024 11:15	Odour - Nature		No odour	
ZN0102AE	4953805	10/07/2024 11:15	Taste	Diln No	0	0
ZN0102AE	4953805	10/07/2024 11:15	Taste - Nature		No taste	
ZN0102AE	4953805	10/07/2024 11:15	Total - Residual disinfectant	mg Cl/l	0.3	
ZN0102AE	4953805	10/07/2024 11:15	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4939441	10/07/2024 11:16	E. coli	CFU/100 ml	0	0
ZN0804AE	4939441	10/07/2024 11:16	Free - Residual disinfectant	mg Cl/l	0.92	
ZN0804AE	4939441	10/07/2024 11:16	Total - Residual disinfectant	mg Cl/l	1.06	
ZN0804AE	4939441	10/07/2024 11:16	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4940031	10/07/2024 12:27	E. coli	CFU/100 ml	0	0
ZS0809AE	4940031	10/07/2024 12:27	Free - Residual disinfectant	mg Cl/l	0.63	
ZS0809AE	4940031	10/07/2024 12:27	Total - Residual disinfectant	mg Cl/l	0.79	
ZS0809AE	4940031	10/07/2024 12:27	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4939822	11/07/2024 08:16	E. coli	CFU/100 ml	0	0
ZN0501AE	4939822	11/07/2024 08:16	Free - Residual disinfectant	mg Cl/l	0.47	
ZN0501AE	4939822	11/07/2024 08:16	Total - Residual disinfectant	mg Cl/l	0.5	
ZN0501AE	4939822	11/07/2024 08:16	Total Coliforms	CFU/100 ml	0	0
ZN0501OP	4954259	11/07/2024 09:35	Turbidity	NTU	0.12	4

ZN0501OP	4954260	11/07/2024 09:45	Turbidity	NTU	0.096	4
ZN0804AE	4949180	11/07/2024 09:46	E. coli	CFU/100 ml	0	0
ZN0804AE	4949180	11/07/2024 09:46	Free - Residual disinfectant	mg Cl/l	0.63	
ZN0804AE	4949180	11/07/2024 09:46	Total - Residual disinfectant	mg Cl/l	0.82	
ZN0804AE	4949180	11/07/2024 09:46	Total Coliforms	CFU/100 ml	0	0
ZN0504AE	4942857	16/07/2024 09:22	Aluminium	ug Al/l	29	200
ZN0504AE	4942857	16/07/2024 09:22	Colony Counts 22	CFU/1 ml	0	
ZN0504AE	4942857	16/07/2024 09:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0504AE	4942857	16/07/2024 09:22	Colour	mg/l Pt/Co	<4.56	20
ZN0504AE	4942857	16/07/2024 09:22	Conductivity	uS/cm 20 C	330	2500
ZN0504AE	4942857	16/07/2024 09:22	E. coli	CFU/100 ml	0	0
ZN0504AE	4942857	16/07/2024 09:22	Free - Residual disinfectant	mg Cl/l	<0.05	
ZN0504AE	4942857	16/07/2024 09:22	Hydrogen Ion	pH value	7.7	9.5
ZN0504AE	4942857	16/07/2024 09:22	Iron	ug/l Fe	71	200
ZN0504AE	4942857	16/07/2024 09:22	Manganese	ug Mn/l	4.4	50
ZN0504AE	4942857	16/07/2024 09:22	Odour	Diln No	0	0
ZN0504AE	4942857	16/07/2024 09:22	Odour - Nature		No odour	
ZN0504AE	4942857	16/07/2024 09:22	Taste	Diln No	0	0
ZN0504AE	4942857	16/07/2024 09:22	Taste - Nature		No taste	
ZN0504AE	4942857	16/07/2024 09:22	Total - Residual disinfectant	mg Cl/l	0.14	
ZN0504AE	4942857	16/07/2024 09:22	Total Coliforms	CFU/100 ml	0	0
ZN0504AE	4942857	16/07/2024 09:22	Turbidity	NTU	0.25	4
ZN0804AE	4939836	16/07/2024 10:10	Aluminium	ug Al/l	26	200
ZN0804AE	4939836	16/07/2024 10:10	Colony Counts 22	CFU/1 ml	0	
ZN0804AE	4939836	16/07/2024 10:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0804AE	4939836	16/07/2024 10:10	Colour	mg/l Pt/Co	<4.56	20
ZN0804AE	4939836	16/07/2024 10:10	Conductivity	uS/cm 20 C	420	2500
ZN0804AE	4939836	16/07/2024 10:10	E. coli	CFU/100 ml	0	0
ZN0804AE	4939836	16/07/2024 10:10	Free - Residual disinfectant	mg Cl/l	0.84	
ZN0804AE	4939836	16/07/2024 10:10	Hydrogen Ion	pH value	7.9	9.5
ZN0804AE	4939836	16/07/2024 10:10	Iron	ug/l Fe	3.2	200
ZN0804AE	4939836	16/07/2024 10:10	Manganese	ug Mn/l	2.3	50
ZN0804AE	4939836	16/07/2024 10:10	Odour	Diln No	0	0
ZN0804AE	4939836	16/07/2024 10:10	Odour - Nature		No odour	
ZN0804AE	4939836	16/07/2024 10:10	Taste	Diln No	0	0
ZN0804AE	4939836	16/07/2024 10:10	Taste - Nature		No taste	
ZN0804AE	4939836	16/07/2024 10:10	Total - Residual disinfectant	mg Cl/l	0.91	
ZN0804AE	4939836	16/07/2024 10:10	Total Coliforms	CFU/100 ml	0	0

ZN0804AE	4939836	16/07/2024 10:10	Turbidity	NTU	0.14	4
ZN0501AE	4942886	16/07/2024 11:03	Aluminium	ug Al/l	32	200
ZN0501AE	4942886	16/07/2024 11:03	Colony Counts 22	CFU/1 ml	0	
ZN0501AE	4942886	16/07/2024 11:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0501AE	4942886	16/07/2024 11:03	Colour	mg/l Pt/Co	<4.56	20
ZN0501AE	4942886	16/07/2024 11:03	Conductivity	uS/cm 20 C	360	2500
ZN0501AE	4942886	16/07/2024 11:03	E. coli	CFU/100 ml	0	0
ZN0501AE	4942886	16/07/2024 11:03	Free - Residual disinfectant	mg Cl/l	0.55	
ZN0501AE	4942886	16/07/2024 11:03	Hydrogen Ion	pH value	7.7	9.5
ZN0501AE	4942886	16/07/2024 11:03	Iron	ug/l Fe	4.3	200
ZN0501AE	4942886	16/07/2024 11:03	Manganese	ug Mn/l	<0.80	50
ZN0501AE	4942886	16/07/2024 11:03	Odour	Diln No	0	0
ZN0501AE	4942886	16/07/2024 11:03	Odour - Nature		No odour	
ZN0501AE	4942886	16/07/2024 11:03	Taste	Diln No	0	0
ZN0501AE	4942886	16/07/2024 11:03	Taste - Nature		No taste	
ZN0501AE	4942886	16/07/2024 11:03	Total - Residual disinfectant	mg Cl/l	0.72	
ZN0501AE	4942886	16/07/2024 11:03	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4942886	16/07/2024 11:03	Turbidity	NTU	0.11	4
ZN0705AE	4942912	16/07/2024 11:22	Aluminium	ug Al/l	4.9	200
ZN0705AE	4942912	16/07/2024 11:22	Colony Counts 22	CFU/1 ml	0	
ZN0705AE	4942912	16/07/2024 11:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0705AE	4942912	16/07/2024 11:22	Colour	mg/l Pt/Co	<4.56	20
ZN0705AE	4942912	16/07/2024 11:22	Conductivity	uS/cm 20 C	120	2500
ZN0705AE	4942912	16/07/2024 11:22	E. coli	CFU/100 ml	0	0
ZN0705AE	4942912	16/07/2024 11:22	Free - Residual disinfectant	mg Cl/l	0.49	
ZN0705AE	4942912	16/07/2024 11:22	Hydrogen Ion	pH value	7.5	9.5
ZN0705AE	4942912	16/07/2024 11:22	Iron	ug/l Fe	2.9	200
ZN0705AE	4942912	16/07/2024 11:22	Manganese	ug Mn/l	<0.642	50
ZN0705AE	4942912	16/07/2024 11:22	Odour	Diln No	0	0
ZN0705AE	4942912	16/07/2024 11:22	Odour - Nature		No odour	
ZN0705AE	4942912	16/07/2024 11:22	Taste	Diln No	0	0
ZN0705AE	4942912	16/07/2024 11:22	Taste - Nature		No taste	
ZN0705AE	4942912	16/07/2024 11:22	Total - Residual disinfectant	mg Cl/l	0.61	
ZN0705AE	4942912	16/07/2024 11:22	Total Coliforms	CFU/100 ml	0	0
ZN0705AE	4942912	16/07/2024 11:22	Turbidity	NTU	0.095	4
ZN0706AE	4943144	17/07/2024 00:00	E. coli	CFU/100 ml	0	0
ZN0706AE	4943144	17/07/2024 00:00	Free - Residual disinfectant	mg Cl/l	0.79	
ZN0706AE	4943144	17/07/2024 00:00	Total - Residual disinfectant	mg Cl/l	0.84	

ZN0706AE	4943144	17/07/2024 00:00	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4942859	17/07/2024 09:24	Aluminium	ug Al/l	30	200
ZS0809AE	4942859	17/07/2024 09:24	Colony Counts 22	CFU/1 ml	0	
ZS0809AE	4942859	17/07/2024 09:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0809AE	4942859	17/07/2024 09:24	Colour	mg/l Pt/Co	<4.56	20
ZS0809AE	4942859	17/07/2024 09:24	Conductivity	uS/cm 20 C	380	2500
ZS0809AE	4942859	17/07/2024 09:24	E. coli	CFU/100 ml	0	0
ZS0809AE	4942859	17/07/2024 09:24	Free - Residual disinfectant	mg Cl/l	0.99	
ZS0809AE	4942859	17/07/2024 09:24	Hydrogen Ion	pH value	7.6	9.5
ZS0809AE	4942859	17/07/2024 09:24	Iron	ug/l Fe	3.3	200
ZS0809AE	4942859	17/07/2024 09:24	Manganese	ug Mn/l	<0.80	50
ZS0809AE	4942859	17/07/2024 09:24	Odour	Diln No	0	0
ZS0809AE	4942859	17/07/2024 09:24	Odour - Nature		No odour	
ZS0809AE	4942859	17/07/2024 09:24	Taste	Diln No	0	0
ZS0809AE	4942859	17/07/2024 09:24	Taste - Nature		No taste	
ZS0809AE	4942859	17/07/2024 09:24	Total - Residual disinfectant	mg Cl/l	1.13	
ZS0809AE	4942859	17/07/2024 09:24	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4942859	17/07/2024 09:24	Turbidity	NTU	0.1	4
ZN1102AE	4942863	17/07/2024 10:22	Aluminium	ug Al/l	54	200
ZN1102AE	4942863	17/07/2024 10:22	Colony Counts 22	CFU/1 ml	0	
ZN1102AE	4942863	17/07/2024 10:22	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN1102AE	4942863	17/07/2024 10:22	Colour	mg/l Pt/Co	<4.56	20
ZN1102AE	4942863	17/07/2024 10:22	Conductivity	uS/cm 20 C	380	2500
ZN1102AE	4942863	17/07/2024 10:22	E. coli	CFU/100 ml	0	0
ZN1102AE	4942863	17/07/2024 10:22	Free - Residual disinfectant	mg Cl/l	0.7	
ZN1102AE	4942863	17/07/2024 10:22	Hydrogen Ion	pH value	7.9	9.5
ZN1102AE	4942863	17/07/2024 10:22	Iron	ug/l Fe	2.6	200
ZN1102AE	4942863	17/07/2024 10:22	Manganese	ug Mn/l	<0.80	50
ZN1102AE	4942863	17/07/2024 10:22	Odour	Diln No	0	0
ZN1102AE	4942863	17/07/2024 10:22	Odour - Nature		No odour	
ZN1102AE	4942863	17/07/2024 10:22	Taste	Diln No	0	0
ZN1102AE	4942863	17/07/2024 10:22	Taste - Nature		No taste	
ZN1102AE	4942863	17/07/2024 10:22	Total - Residual disinfectant	mg Cl/l	0.85	
ZN1102AE	4942863	17/07/2024 10:22	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4942863	17/07/2024 10:22	Turbidity	NTU	0.13	4
ZN0501AE	4943146	17/07/2024 10:53	E. coli	CFU/100 ml	0	0
ZN0501AE	4943146	17/07/2024 10:53	Free - Residual disinfectant	mg Cl/l	0.65	
ZN0501AE	4943146	17/07/2024 10:53	Total - Residual disinfectant	mg Cl/l	0.82	

ZN0501AE	4943146	17/07/2024 10:53	Total Coliforms	CFU/100 ml	0	0
ZN0502AE	4943148	17/07/2024 11:23	E. coli	CFU/100 ml	0	0
ZN0502AE	4943148	17/07/2024 11:23	Free - Residual disinfectant	mg Cl/l	0.4	
ZN0502AE	4943148	17/07/2024 11:23	Total - Residual disinfectant	mg Cl/l	0.44	
ZN0502AE	4943148	17/07/2024 11:23	Total Coliforms	CFU/100 ml	0	0
ZN0706AE	4942883	17/07/2024 11:45	Aluminium	ug Al/l	12	200
ZN0706AE	4942883	17/07/2024 11:45	Colony Counts 22	CFU/1 ml	0	
ZN0706AE	4942883	17/07/2024 11:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0706AE	4942883	17/07/2024 11:45	Colour	mg/l Pt/Co	<4.56	20
ZN0706AE	4942883	17/07/2024 11:45	Conductivity	uS/cm 20 C	140	2500
ZN0706AE	4942883	17/07/2024 11:45	E. coli	CFU/100 ml	0	0
ZN0706AE	4942883	17/07/2024 11:45	Free - Residual disinfectant	mg Cl/l	0.73	
ZN0706AE	4942883	17/07/2024 11:45	Hydrogen Ion	pH value	7.7	9.5
ZN0706AE	4942883	17/07/2024 11:45	Iron	ug/l Fe	2.1	200
ZN0706AE	4942883	17/07/2024 11:45	Manganese	ug Mn/l	<0.642	50
ZN0706AE	4942883	17/07/2024 11:45	Odour	Diln No	0	0
ZN0706AE	4942883	17/07/2024 11:45	Odour - Nature		No odour	
ZN0706AE	4942883	17/07/2024 11:45	Taste	Diln No	0	0
ZN0706AE	4942883	17/07/2024 11:45	Taste - Nature		No taste	
ZN0706AE	4942883	17/07/2024 11:45	Total - Residual disinfectant	mg Cl/l	0.82	
ZN0706AE	4942883	17/07/2024 11:45	Total Coliforms	CFU/100 ml	0	0
ZN0706AE	4942883	17/07/2024 11:45	Turbidity	NTU	0.13	4
ZS0811AE	4942909	17/07/2024 12:00	Aluminium	ug Al/l	13	200
ZS0811AE	4942909	17/07/2024 12:00	Colony Counts 22	CFU/1 ml	54	
ZS0811AE	4942909	17/07/2024 12:00	Colony Counts 37 (48hrs)	CFU/1 ml	1	
ZS0811AE	4942909	17/07/2024 12:00	Colour	mg/l Pt/Co	<4.56	20
ZS0811AE	4942909	17/07/2024 12:00	Conductivity	uS/cm 20 C	380	2500
ZS0811AE	4942909	17/07/2024 12:00	E. coli	CFU/100 ml	0	0
ZS0811AE	4942909	17/07/2024 12:00	Free - Residual disinfectant	mg Cl/l	0.18	
ZS0811AE	4942909	17/07/2024 12:00	Hydrogen Ion	pH value	7.7	9.5
ZS0811AE	4942909	17/07/2024 12:00	Iron	ug/l Fe	49	200
ZS0811AE	4942909	17/07/2024 12:00	Manganese	ug Mn/l	4.5	50
ZS0811AE	4942909	17/07/2024 12:00	Odour	Diln No	0	0
ZS0811AE	4942909	17/07/2024 12:00	Odour - Nature		No odour	
ZS0811AE	4942909	17/07/2024 12:00	Taste	Diln No	0	0
ZS0811AE	4942909	17/07/2024 12:00	Taste - Nature		No taste	
ZS0811AE	4942909	17/07/2024 12:00	Total - Residual disinfectant	mg Cl/l	0.35	
ZS0811AE	4942909	17/07/2024 12:00	Total Coliforms	CFU/100 ml	0	0

ZS0811AE	4942909	17/07/2024 12:00	Turbidity	NTU	0.29	4
ZN0102AE	4942888	17/07/2024 12:17	Aluminium	ug Al/l	23	200
ZN0102AE	4942888	17/07/2024 12:17	Colony Counts 22	CFU/1 ml	0	
ZN0102AE	4942888	17/07/2024 12:17	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0102AE	4942888	17/07/2024 12:17	Colour	mg/l Pt/Co	<4.56	20
ZN0102AE	4942888	17/07/2024 12:17	Conductivity	uS/cm 20 C	340	2500
ZN0102AE	4942888	17/07/2024 12:17	E. coli	CFU/100 ml	0	0
ZN0102AE	4942888	17/07/2024 12:17	Free - Residual disinfectant	mg Cl/l	0.35	
ZN0102AE	4942888	17/07/2024 12:17	Hydrogen Ion	pH value	7.5	9.5
ZN0102AE	4942888	17/07/2024 12:17	Iron	ug/l Fe	78	200
ZN0102AE	4942888	17/07/2024 12:17	Manganese	ug Mn/l	1.9	50
ZN0102AE	4942888	17/07/2024 12:17	Odour	Diln No	0	0
ZN0102AE	4942888	17/07/2024 12:17	Odour - Nature		No odour	
ZN0102AE	4942888	17/07/2024 12:17	Taste	Diln No	0	0
ZN0102AE	4942888	17/07/2024 12:17	Taste - Nature		No taste	
ZN0102AE	4942888	17/07/2024 12:17	Total - Residual disinfectant	mg Cl/l	0.48	
ZN0102AE	4942888	17/07/2024 12:17	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4942888	17/07/2024 12:17	Turbidity	NTU	0.29	4
ZN0504AE	4939392	18/07/2024 09:21	E. coli	CFU/100 ml	0	0
ZN0504AE	4939392	18/07/2024 09:21	Free - Residual disinfectant	mg Cl/l	0.19	
ZN0504AE	4939392	18/07/2024 09:21	Total - Residual disinfectant	mg Cl/l	0.37	
ZN0504AE	4939392	18/07/2024 09:21	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4943122	18/07/2024 09:23	E. coli	CFU/100 ml	0	0
ZS0809AE	4943122	18/07/2024 09:23	Free - Residual disinfectant	mg Cl/l	0.28	
ZS0809AE	4943122	18/07/2024 09:23	Total - Residual disinfectant	mg Cl/l	0.45	
ZS0809AE	4943122	18/07/2024 09:23	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4943147	18/07/2024 09:45	E. coli	CFU/100 ml	0	0
ZN0102AE	4943147	18/07/2024 09:45	Free - Residual disinfectant	mg Cl/l	0.42	
ZN0102AE	4943147	18/07/2024 09:45	Total - Residual disinfectant	mg Cl/l	0.62	
ZN0102AE	4943147	18/07/2024 09:45	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4943164	18/07/2024 09:57	E. coli	CFU/100 ml	0	0
ZN0804AE	4943164	18/07/2024 09:57	Free - Residual disinfectant	mg Cl/l	0.64	
ZN0804AE	4943164	18/07/2024 09:57	Total - Residual disinfectant	mg Cl/l	0.76	
ZN0804AE	4943164	18/07/2024 09:57	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4943125	18/07/2024 10:13	E. coli	CFU/100 ml	0	0
ZN1102AE	4943125	18/07/2024 10:13	Free - Residual disinfectant	mg Cl/l	0.7	
ZN1102AE	4943125	18/07/2024 10:13	Total - Residual disinfectant	mg Cl/l	0.9	
ZN1102AE	4943125	18/07/2024 10:13	Total Coliforms	CFU/100 ml	0	0

ZS0811AE	4943162	18/07/2024 11:44	E. coli	CFU/100 ml	0	0
ZS0811AE	4943162	18/07/2024 11:44	Free - Residual disinfectant	mg Cl/l	0.41	
ZS0811AE	4943162	18/07/2024 11:44	Total - Residual disinfectant	mg Cl/l	0.56	
ZS0811AE	4943162	18/07/2024 11:44	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4943360	19/07/2024 11:57	E. coli	CFU/100 ml	0	0
ZS0811AE	4943360	19/07/2024 11:57	Free - Residual disinfectant	mg Cl/l	0.33	
ZS0811AE	4943360	19/07/2024 11:57	Total - Residual disinfectant	mg Cl/l	0.55	
ZS0811AE	4943360	19/07/2024 11:57	Total Coliforms	CFU/100 ml	0	0
ZN0504AE	4946193	22/07/2024 09:35	Aluminium	ug Al/l	30	200
ZN0504AE	4946193	22/07/2024 09:35	Ammonium	mg NH4/l	<0.01	0.5
ZN0504AE	4946193	22/07/2024 09:35	Antimony	ug/l Sb	0.23	5
ZN0504AE	4946193	22/07/2024 09:35	Arsenic	ug/l As	0.47	10
ZN0504AE	4946193	22/07/2024 09:35	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN0504AE	4946193	22/07/2024 09:35	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0504AE	4946193	22/07/2024 09:35	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0504AE	4946193	22/07/2024 09:35	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0504AE	4946193	22/07/2024 09:35	Boron	mg/l B	<0.0586	1
ZN0504AE	4946193	22/07/2024 09:35	Bromate	ug BrO3/l	<0.50	10
ZN0504AE	4946193	22/07/2024 09:35	Bromodichloromethane	ug/l	22	
ZN0504AE	4946193	22/07/2024 09:35	Bromoform	ug/l	<3.5	
ZN0504AE	4946193	22/07/2024 09:35	Cadmium	ug/l Cd	0.11	5
ZN0504AE	4946193	22/07/2024 09:35	Calcium	mg/l	39	
ZN0504AE	4946193	22/07/2024 09:35	Chloride	mg Cl/l	17	250
ZN0504AE	4946193	22/07/2024 09:35	Chromium	ug/l Cr	0.46	50
ZN0504AE	4946193	22/07/2024 09:35	Colony Counts 22	CFU/1 ml	0	
ZN0504AE	4946193	22/07/2024 09:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0504AE	4946193	22/07/2024 09:35	Colour	mg/l Pt/Co	<4.56	20
ZN0504AE	4946193	22/07/2024 09:35	Conductivity	uS/cm 20 C	290	2500
ZN0504AE	4946193	22/07/2024 09:35	Copper	mg Cu/l	<0.546	2
ZN0504AE	4946193	22/07/2024 09:35	Dibromochloromethane	ug/l	6	
ZN0504AE	4946193	22/07/2024 09:35	E. coli	CFU/100 ml	0	0
ZN0504AE	4946193	22/07/2024 09:35	Enterococci	CFU/100ml	0	0
ZN0504AE	4946193	22/07/2024 09:35	Fluoride	mg F/l	<0.150	1.5
ZN0504AE	4946193	22/07/2024 09:35	Free - Residual disinfectant	mg Cl/l	0.08	
ZN0504AE	4946193	22/07/2024 09:35	Hydrogen Ion	pH value	7.6	9.5
ZN0504AE	4946193	22/07/2024 09:35	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0504AE	4946193	22/07/2024 09:35	Iron	ug/l Fe	4.3	200
ZN0504AE	4946193	22/07/2024 09:35	Lead	ug Pb/l	<0.095	10

ZN0504AE	4946193	22/07/2024 09:35	Magnesium	mg/l	6.2	
ZN0504AE	4946193	22/07/2024 09:35	Manganese	ug Mn/l	0.68	50
ZN0504AE	4946193	22/07/2024 09:35	Mercury	ug per l	<0.041	1
ZN0504AE	4946193	22/07/2024 09:35	Nickel	ug Ni/l	0.86	20
ZN0504AE	4946193	22/07/2024 09:35	Nitrate	mg/l	2.8	50
ZN0504AE	4946193	22/07/2024 09:35	Nitrate/Nitrite Formula	mg/l	<0.056	1
ZN0504AE	4946193	22/07/2024 09:35	Nitrite	mg/l	<0.03	0.5
ZN0504AE	4946193	22/07/2024 09:35	Odour	Diln No	0	0
ZN0504AE	4946193	22/07/2024 09:35	Odour - Nature		No odour	
ZN0504AE	4946193	22/07/2024 09:35	PAH - Sum of four substances	ug/l	0	0.1
ZN0504AE	4946193	22/07/2024 09:35	Potassium	mg/l	2.5	
ZN0504AE	4946193	22/07/2024 09:35	Selenium	ug/l Se	0.22	10
ZN0504AE	4946193	22/07/2024 09:35	Sodium	mg Na/l	11	200
ZN0504AE	4946193	22/07/2024 09:35	Sulphate	mg SO4/l	60	250
ZN0504AE	4946193	22/07/2024 09:35	Taste	Diln No	0	0
ZN0504AE	4946193	22/07/2024 09:35	Taste - Nature		No taste	
ZN0504AE	4946193	22/07/2024 09:35	Total - Residual disinfectant	mg Cl/l	0.22	
ZN0504AE	4946193	22/07/2024 09:35	Total Coliforms	CFU/100 ml	0	0
ZN0504AE	4946193	22/07/2024 09:35	Total hardness	mg/l	49	
ZN0504AE	4946193	22/07/2024 09:35	Turbidity	NTU	<0.09	4
ZN0804AE	4942911	22/07/2024 09:46	Aluminium	ug Al/l	25	200
ZN0804AE	4942911	22/07/2024 09:46	Ammonium	mg NH4/l	<0.01	0.5
ZN0804AE	4942911	22/07/2024 09:46	Colony Counts 22	CFU/1 ml	0	
ZN0804AE	4942911	22/07/2024 09:46	Colour	mg/l Pt/Co	<4.56	20
ZN0804AE	4942911	22/07/2024 09:46	Conductivity	uS/cm 20 C	430	2500
ZN0804AE	4942911	22/07/2024 09:46	E. coli	CFU/100 ml	0	0
ZN0804AE	4942911	22/07/2024 09:46	Free - Residual disinfectant	mg Cl/l	0.7	
ZN0804AE	4942911	22/07/2024 09:46	Hydrogen Ion	pH value	7.7	9.5
ZN0804AE	4942911	22/07/2024 09:46	Iron	ug/l Fe	5.4	200
ZN0804AE	4942911	22/07/2024 09:46	Manganese	ug Mn/l	1.5	50
ZN0804AE	4942911	22/07/2024 09:46	Odour	Diln No	0	0
ZN0804AE	4942911	22/07/2024 09:46	Odour - Nature		No odour	
ZN0804AE	4942911	22/07/2024 09:46	Taste	Diln No	0	0
ZN0804AE	4942911	22/07/2024 09:46	Taste - Nature		No taste	
ZN0804AE	4942911	22/07/2024 09:46	Total - Residual disinfectant	mg Cl/l	0.81	
ZN0804AE	4942911	22/07/2024 09:46	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4942911	22/07/2024 09:46	Turbidity	NTU	0.091	4
ZN0705AE	4946195	22/07/2024 10:45	Benzo(a)pyrene	ug/l	<0.0021	0.01

ZN0705AE	4946195	22/07/2024 10:45	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0705AE	4946195	22/07/2024 10:45	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0705AE	4946195	22/07/2024 10:45	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0705AE	4946195	22/07/2024 10:45	E. coli	CFU/100 ml	0	0
ZN0705AE	4946195	22/07/2024 10:45	Free - Residual disinfectant	mg Cl/l	0.98	
ZN0705AE	4946195	22/07/2024 10:45	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0705AE	4946195	22/07/2024 10:45	PAH - Sum of four substances	ug/l	0	0.1
ZN0705AE	4946195	22/07/2024 10:45	Total - Residual disinfectant	mg Cl/l	1.1	
ZN0705AE	4946195	22/07/2024 10:45	Total Coliforms	CFU/100 ml	0	0
ZN0706AE	4946126	22/07/2024 11:29	E. coli	CFU/100 ml	0	0
ZN0706AE	4946126	22/07/2024 11:29	Free - Residual disinfectant	mg Cl/l	0.38	
ZN0706AE	4946126	22/07/2024 11:29	Total - Residual disinfectant	mg Cl/l	0.63	
ZN0706AE	4946126	22/07/2024 11:29	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4946105	23/07/2024 10:01	Aluminium	ug Al/l	28	200
ZS0809AE	4946105	23/07/2024 10:01	Colony Counts 22	CFU/1 ml	0	
ZS0809AE	4946105	23/07/2024 10:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0809AE	4946105	23/07/2024 10:01	Colour	mg/l Pt/Co	<4.56	20
ZS0809AE	4946105	23/07/2024 10:01	Conductivity	uS/cm 20 C	430	2500
ZS0809AE	4946105	23/07/2024 10:01	E. coli	CFU/100 ml	0	0
ZS0809AE	4946105	23/07/2024 10:01	Free - Residual disinfectant	mg Cl/l	0.15	
ZS0809AE	4946105	23/07/2024 10:01	Hydrogen Ion	pH value	7.8	9.5
ZS0809AE	4946105	23/07/2024 10:01	Iron	ug/l Fe	12	200
ZS0809AE	4946105	23/07/2024 10:01	Manganese	ug Mn/l	<0.80	50
ZS0809AE	4946105	23/07/2024 10:01	Mercury	ug per l	<0.041	1
ZS0809AE	4946105	23/07/2024 10:01	Odour	Diln No	0	0
ZS0809AE	4946105	23/07/2024 10:01	Odour - Nature		No odour	
ZS0809AE	4946105	23/07/2024 10:01	Taste	Diln No	0	0
ZS0809AE	4946105	23/07/2024 10:01	Taste - Nature		No taste	
ZS0809AE	4946105	23/07/2024 10:01	Total - Residual disinfectant	mg Cl/l	0.35	
ZS0809AE	4946105	23/07/2024 10:01	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4946105	23/07/2024 10:01	Turbidity	NTU	<0.09	4
ZN0501AE	4946129	23/07/2024 10:23	E. coli	CFU/100 ml	0	0
ZN0501AE	4946129	23/07/2024 10:23	Free - Residual disinfectant	mg Cl/l	0.49	
ZN0501AE	4946129	23/07/2024 10:23	Total - Residual disinfectant	mg Cl/l	0.81	
ZN0501AE	4946129	23/07/2024 10:23	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4946354	23/07/2024 10:48	E. coli	CFU/100 ml	0	0
ZN1102AE	4946354	23/07/2024 10:48	Free - Residual disinfectant	mg Cl/l	0.34	
ZN1102AE	4946354	23/07/2024 10:48	Mercury	ug per l	<0.041	1

ZN1102AE	4946354	23/07/2024 10:48	Total - Residual disinfectant	mg Cl/l	0.5	
ZN1102AE	4946354	23/07/2024 10:48	Total Coliforms	CFU/100 ml	0	0
ZN0502AE	4946133	23/07/2024 10:55	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN0502AE	4946133	23/07/2024 10:55	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0502AE	4946133	23/07/2024 10:55	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0502AE	4946133	23/07/2024 10:55	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0502AE	4946133	23/07/2024 10:55	Bromate	ug BrO3/l	<0.50	10
ZN0502AE	4946133	23/07/2024 10:55	E. coli	CFU/100 ml	0	0
ZN0502AE	4946133	23/07/2024 10:55	Free - Residual disinfectant	mg Cl/l	0.41	
ZN0502AE	4946133	23/07/2024 10:55	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0502AE	4946133	23/07/2024 10:55	Mercury	ug per l	<0.041	1
ZN0502AE	4946133	23/07/2024 10:55	PAH - Sum of four substances	ug/l	0	0.1
ZN0502AE	4946133	23/07/2024 10:55	Total - Residual disinfectant	mg Cl/l	0.48	
ZN0502AE	4946133	23/07/2024 10:55	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4946131	23/07/2024 11:07	Aluminium	ug Al/l	28	200
ZN0102AE	4946131	23/07/2024 11:07	Ammonium	mg NH4/l	<0.01	0.5
ZN0102AE	4946131	23/07/2024 11:07	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN0102AE	4946131	23/07/2024 11:07	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0102AE	4946131	23/07/2024 11:07	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0102AE	4946131	23/07/2024 11:07	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0102AE	4946131	23/07/2024 11:07	Bromate	ug BrO3/l	<0.50	10
ZN0102AE	4946131	23/07/2024 11:07	Colour	mg/l Pt/Co	<4.56	20
ZN0102AE	4946131	23/07/2024 11:07	Conductivity	uS/cm 20 C	340	2500
ZN0102AE	4946131	23/07/2024 11:07	E. coli	CFU/100 ml	0	0
ZN0102AE	4946131	23/07/2024 11:07	Free - Residual disinfectant	mg Cl/l	0.56	
ZN0102AE	4946131	23/07/2024 11:07	Hydrogen Ion	pH value	7.5	9.5
ZN0102AE	4946131	23/07/2024 11:07	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0102AE	4946131	23/07/2024 11:07	Iron	ug/l Fe	3.3	200
ZN0102AE	4946131	23/07/2024 11:07	Manganese	ug Mn/l	<0.80	50
ZN0102AE	4946131	23/07/2024 11:07	Odour	Diln No	0	0
ZN0102AE	4946131	23/07/2024 11:07	Odour - Nature		No odour	
ZN0102AE	4946131	23/07/2024 11:07	PAH - Sum of four substances	ug/l	0	0.1
ZN0102AE	4946131	23/07/2024 11:07	Taste	Diln No	0	0
ZN0102AE	4946131	23/07/2024 11:07	Taste - Nature		No taste	
ZN0102AE	4946131	23/07/2024 11:07	Total - Residual disinfectant	mg Cl/l	0.72	
ZN0102AE	4946131	23/07/2024 11:07	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4946131	23/07/2024 11:07	Turbidity	NTU	<0.09	4
ZS0811AE	4946147	23/07/2024 11:34	E. coli	CFU/100 ml	0	0

ZS0811AE	4946147	23/07/2024 11:34	Free - Residual disinfectant	mg Cl/l	0.27	
ZS0811AE	4946147	23/07/2024 11:34	Mercury	ug per l	<0.041	1
ZS0811AE	4946147	23/07/2024 11:34	Total - Residual disinfectant	mg Cl/l	0.49	
ZS0811AE	4946147	23/07/2024 11:34	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4946387	24/07/2024 12:05	Aluminium	ug Al/l	24	200
ZS0811AE	4946387	24/07/2024 12:05	Colony Counts 22	CFU/1 ml	0	
ZS0811AE	4946387	24/07/2024 12:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0811AE	4946387	24/07/2024 12:05	Colour	mg/l Pt/Co	<4.56	20
ZS0811AE	4946387	24/07/2024 12:05	Conductivity	uS/cm 20 C	380	2500
ZS0811AE	4946387	24/07/2024 12:05	E. coli	CFU/100 ml	0	0
ZS0811AE	4946387	24/07/2024 12:05	Free - Residual disinfectant	mg Cl/l	0.26	
ZS0811AE	4946387	24/07/2024 12:05	Hydrogen Ion	pH value	7.6	9.5
ZS0811AE	4946387	24/07/2024 12:05	Iron	ug/l Fe	3.2	200
ZS0811AE	4946387	24/07/2024 12:05	Manganese	ug Mn/l	<0.80	50
ZS0811AE	4946387	24/07/2024 12:05	Odour	Diln No	0	0
ZS0811AE	4946387	24/07/2024 12:05	Odour - Nature		No odour	
ZS0811AE	4946387	24/07/2024 12:05	Taste	Diln No	0	0
ZS0811AE	4946387	24/07/2024 12:05	Taste - Nature		No taste	
ZS0811AE	4946387	24/07/2024 12:05	Total - Residual disinfectant	mg Cl/l	0.45	
ZS0811AE	4946387	24/07/2024 12:05	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4946387	24/07/2024 12:05	Turbidity	NTU	0.096	4
ZS0809AE	4946351	25/07/2024 09:00	E. coli	CFU/100 ml	0	0
ZS0809AE	4946351	25/07/2024 09:00	Free - Residual disinfectant	mg Cl/l	0.69	
ZS0809AE	4946351	25/07/2024 09:00	Total - Residual disinfectant	mg Cl/l	0.84	
ZS0809AE	4946351	25/07/2024 09:00	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4946388	25/07/2024 10:05	E. coli	CFU/100 ml	0	0
ZN0804AE	4946388	25/07/2024 10:05	Free - Residual disinfectant	mg Cl/l	0.71	
ZN0804AE	4946388	25/07/2024 10:05	Total - Residual disinfectant	mg Cl/l	0.8	
ZN0804AE	4946388	25/07/2024 10:05	Total Coliforms	CFU/100 ml	0	0
ZS0811CUST	4960155	25/07/2024 11:00	Aluminium	ug Al/l	46	200
ZS0811CUST	4960155	25/07/2024 11:00	Colour	mg/l Pt/Co	<4.56	20
ZS0811CUST	4960155	25/07/2024 11:00	Conductivity	uS/cm 20 C	380	2500
ZS0811CUST	4960155	25/07/2024 11:00	Free - Residual disinfectant	mg Cl/l	0.05	
ZS0811CUST	4960155	25/07/2024 11:00	Hydrogen Ion	pH value	7.8	9.5
ZS0811CUST	4960155	25/07/2024 11:00	Iron	ug/l Fe	28	200
ZS0811CUST	4960155	25/07/2024 11:00	Manganese	ug Mn/l	3.3	50
ZS0811CUST	4960155	25/07/2024 11:00	Total - Residual disinfectant	mg Cl/l	0.16	
ZS0811CUST	4960155	25/07/2024 11:00	Turbidity	NTU	0.22	4

ZS0809AE	4946569	26/07/2024 09:25	E. coli	CFU/100 ml	0	0
ZS0809AE	4946569	26/07/2024 09:25	Free - Residual disinfectant	mg Cl/l	0.26	
ZS0809AE	4946569	26/07/2024 09:25	Total - Residual disinfectant	mg Cl/l	0.42	
ZS0809AE	4946569	26/07/2024 09:25	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4943358	26/07/2024 10:10	E. coli	CFU/100 ml	0	0
ZN0102AE	4943358	26/07/2024 10:10	Free - Residual disinfectant	mg Cl/l	0.28	
ZN0102AE	4943358	26/07/2024 10:10	Total - Residual disinfectant	mg Cl/l	0.36	
ZN0102AE	4943358	26/07/2024 10:10	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4949248	29/07/2024 09:20	Aluminium	ug Al/l	25	200
ZS0809AE	4949248	29/07/2024 09:20	Colony Counts 22	CFU/1 ml	1	
ZS0809AE	4949248	29/07/2024 09:20	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0809AE	4949248	29/07/2024 09:20	Colour	mg/l Pt/Co	<4.56	20
ZS0809AE	4949248	29/07/2024 09:20	Conductivity	uS/cm 20 C	380	2500
ZS0809AE	4949248	29/07/2024 09:20	E. coli	CFU/100 ml	0	0
ZS0809AE	4949248	29/07/2024 09:20	Free - Residual disinfectant	mg Cl/l	0.58	
ZS0809AE	4949248	29/07/2024 09:20	Hydrogen Ion	pH value	7.6	9.5
ZS0809AE	4949248	29/07/2024 09:20	Iron	ug/l Fe	5.9	200
ZS0809AE	4949248	29/07/2024 09:20	Manganese	ug Mn/l	<0.80	50
ZS0809AE	4949248	29/07/2024 09:20	Odour	Diln No	0	0
ZS0809AE	4949248	29/07/2024 09:20	Odour - Nature		No odour	
ZS0809AE	4949248	29/07/2024 09:20	Taste	Diln No	0	0
ZS0809AE	4949248	29/07/2024 09:20	Taste - Nature		No taste	
ZS0809AE	4949248	29/07/2024 09:20	Total - Residual disinfectant	mg Cl/l	0.89	
ZS0809AE	4949248	29/07/2024 09:20	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4949248	29/07/2024 09:20	Turbidity	NTU	<0.09	4
ZS0811AE	4949294	29/07/2024 09:55	E. coli	CFU/100 ml	0	0
ZS0811AE	4949294	29/07/2024 09:55	Free - Residual disinfectant	mg Cl/l	0.68	
ZS0811AE	4949294	29/07/2024 09:55	Total - Residual disinfectant	mg Cl/l	0.84	
ZS0811AE	4949294	29/07/2024 09:55	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4949275	29/07/2024 10:06	Aluminium	ug Al/l	25	200
ZN0102AE	4949275	29/07/2024 10:06	Colony Counts 22	CFU/1 ml	0	
ZN0102AE	4949275	29/07/2024 10:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0102AE	4949275	29/07/2024 10:06	Colour	mg/l Pt/Co	<4.56	20
ZN0102AE	4949275	29/07/2024 10:06	Conductivity	uS/cm 20 C	350	2500
ZN0102AE	4949275	29/07/2024 10:06	E. coli	CFU/100 ml	0	0
ZN0102AE	4949275	29/07/2024 10:06	Free - Residual disinfectant	mg Cl/l	0.69	
ZN0102AE	4949275	29/07/2024 10:06	Hydrogen Ion	pH value	7.7	9.5
ZN0102AE	4949275	29/07/2024 10:06	Iron	ug/l Fe	3	200

ZN0102AE	4949275	29/07/2024 10:06	Manganese	ug Mn/l	<0.80	50
ZN0102AE	4949275	29/07/2024 10:06	Mercury	ug per l	<0.041	1
ZN0102AE	4949275	29/07/2024 10:06	Odour	Diln No	0	0
ZN0102AE	4949275	29/07/2024 10:06	Odour - Nature		No odour	
ZN0102AE	4949275	29/07/2024 10:06	Taste	Diln No	0	0
ZN0102AE	4949275	29/07/2024 10:06	Taste - Nature		No taste	
ZN0102AE	4949275	29/07/2024 10:06	Total - Residual disinfectant	mg Cl/l	0.83	
ZN0102AE	4949275	29/07/2024 10:06	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4949275	29/07/2024 10:06	Turbidity	NTU	<0.09	4
ZN0804AE	4949295	29/07/2024 10:10	E. coli	CFU/100 ml	0	0
ZN0804AE	4949295	29/07/2024 10:10	Free - Residual disinfectant	mg Cl/l	0.41	
ZN0804AE	4949295	29/07/2024 10:10	Total - Residual disinfectant	mg Cl/l	0.63	
ZN0804AE	4949295	29/07/2024 10:10	Total Coliforms	CFU/100 ml	0	0
ZN0502AE	4949278	29/07/2024 10:11	E. coli	CFU/100 ml	0	0
ZN0502AE	4949278	29/07/2024 10:11	Free - Residual disinfectant	mg Cl/l	0.54	
ZN0502AE	4949278	29/07/2024 10:11	Total - Residual disinfectant	mg Cl/l	0.59	
ZN0502AE	4949278	29/07/2024 10:11	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4949253	29/07/2024 11:15	E. coli	CFU/100 ml	0	0
ZN1102AE	4949253	29/07/2024 11:15	Free - Residual disinfectant	mg Cl/l	0.47	
ZN1102AE	4949253	29/07/2024 11:15	Total - Residual disinfectant	mg Cl/l	0.63	
ZN1102AE	4949253	29/07/2024 11:15	Total Coliforms	CFU/100 ml	0	0
ZS0809CUST	4962141	30/07/2024 09:00	Aluminium	ug Al/l	19	200
ZS0809CUST	4962141	30/07/2024 09:00	Iron	ug/l Fe	3.9	200
ZS0809CUST	4962141	30/07/2024 09:00	Manganese	ug Mn/l	<0.642	50
ZS0809AE	4949566	30/07/2024 09:15	E. coli	CFU/100 ml	0	0
ZS0809AE	4949566	30/07/2024 09:15	Free - Residual disinfectant	mg Cl/l	0.62	
ZS0809AE	4949566	30/07/2024 09:15	Total - Residual disinfectant	mg Cl/l	0.79	
ZS0809AE	4949566	30/07/2024 09:15	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4949568	30/07/2024 10:18	E. coli	CFU/100 ml	0	0
ZN1102AE	4949568	30/07/2024 10:18	Free - Residual disinfectant	mg Cl/l	0.54	
ZN1102AE	4949568	30/07/2024 10:18	Total - Residual disinfectant	mg Cl/l	0.68	
ZN1102AE	4949568	30/07/2024 10:18	Total Coliforms	CFU/100 ml	0	0
ZN0505AE	4949276	30/07/2024 10:28	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN0505AE	4949276	30/07/2024 10:28	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0505AE	4949276	30/07/2024 10:28	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0505AE	4949276	30/07/2024 10:28	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0505AE	4949276	30/07/2024 10:28	E. coli	CFU/100 ml	0	0
ZN0505AE	4949276	30/07/2024 10:28	Free - Residual disinfectant	mg Cl/l	0.56	

ZN0505AE	4949276	30/07/2024 10:28	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0505AE	4949276	30/07/2024 10:28	PAH - Sum of four substances	ug/l	0	0.1
ZN0505AE	4949276	30/07/2024 10:28	Total - Residual disinfectant	mg Cl/l	0.65	
ZN0505AE	4949276	30/07/2024 10:28	Total Coliforms	CFU/100 ml	0	0
ZN0501OP	4962361	30/07/2024 11:25	E. coli	CFU/100 ml	0	0
ZN0501OP	4962361	30/07/2024 11:25	Free - Residual disinfectant	mg Cl/l	0.52	
ZN0501OP	4962361	30/07/2024 11:25	Total - Residual disinfectant	mg Cl/l	0.6	
ZN0501OP	4962361	30/07/2024 11:25	Total Coliforms	CFU/100 ml	0	0
ZN0501OP	4962362	30/07/2024 11:35	E. coli	CFU/100 ml	0	0
ZN0501OP	4962362	30/07/2024 11:35	Free - Residual disinfectant	mg Cl/l	0.55	
ZN0501OP	4962362	30/07/2024 11:35	Total - Residual disinfectant	mg Cl/l	0.59	
ZN0501OP	4962362	30/07/2024 11:35	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4949273	31/07/2024 09:13	Aluminium	ug Al/l	40	200
ZN0501AE	4949273	31/07/2024 09:13	Colony Counts 22	CFU/1 ml	0	
ZN0501AE	4949273	31/07/2024 09:13	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0501AE	4949273	31/07/2024 09:13	Colour	mg/l Pt/Co	<4.56	20
ZN0501AE	4949273	31/07/2024 09:13	Conductivity	uS/cm 20 C	370	2500
ZN0501AE	4949273	31/07/2024 09:13	E. coli	CFU/100 ml	0	0
ZN0501AE	4949273	31/07/2024 09:13	Free - Residual disinfectant	mg Cl/l	0.45	
ZN0501AE	4949273	31/07/2024 09:13	Hydrogen Ion	pH value	7.9	9.5
ZN0501AE	4949273	31/07/2024 09:13	Iron	ug/l Fe	3.5	200
ZN0501AE	4949273	31/07/2024 09:13	Manganese	ug Mn/l	<0.80	50
ZN0501AE	4949273	31/07/2024 09:13	Odour	Diln No	0	0
ZN0501AE	4949273	31/07/2024 09:13	Odour - Nature		No odour	
ZN0501AE	4949273	31/07/2024 09:13	Taste	Diln No	0	0
ZN0501AE	4949273	31/07/2024 09:13	Taste - Nature		No taste	
ZN0501AE	4949273	31/07/2024 09:13	Total - Residual disinfectant	mg Cl/l	0.54	
ZN0501AE	4949273	31/07/2024 09:13	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4949273	31/07/2024 09:13	Turbidity	NTU	<0.09	4
ZS0809CUST	4962774	31/07/2024 09:30	Aluminium	ug Al/l	10	200
ZS0809CUST	4962774	31/07/2024 09:30	Colour	mg/l Pt/Co	<4.56	20
ZS0809CUST	4962774	31/07/2024 09:30	E. coli	CFU/100 ml	0	0
ZS0809CUST	4962774	31/07/2024 09:30	Free - Residual disinfectant	mg Cl/l	0.1	
ZS0809CUST	4962774	31/07/2024 09:30	Hydrogen Ion	pH value	7.4	9.5
ZS0809CUST	4962774	31/07/2024 09:30	Iron	ug/l Fe	<1.538	200
ZS0809CUST	4962774	31/07/2024 09:30	Manganese	ug Mn/l	<0.642	50
ZS0809CUST	4962774	31/07/2024 09:30	Odour	Diln No	0	0
ZS0809CUST	4962774	31/07/2024 09:30	Odour - Nature		No odour	

ZS0809CUST	4962774	31/07/2024 09:30	Taste	Diln No	0	0
ZS0809CUST	4962774	31/07/2024 09:30	Taste - Nature		No taste	
ZS0809CUST	4962774	31/07/2024 09:30	Total - Residual disinfectant	mg Cl/l	0.3	
ZS0809CUST	4962774	31/07/2024 09:30	Total Coliforms	CFU/100 ml	0	0
ZS0809CUST	4962774	31/07/2024 09:30	Turbidity	NTU	0.18	4
ZS0811AE	4949598	31/07/2024 10:40	Aluminium	ug Al/l	17	200
ZS0811AE	4949598	31/07/2024 10:40	Colony Counts 22	CFU/1 ml	0	
ZS0811AE	4949598	31/07/2024 10:40	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0811AE	4949598	31/07/2024 10:40	Colour	mg/l Pt/Co	<4.56	20
ZS0811AE	4949598	31/07/2024 10:40	Conductivity	uS/cm 20 C	380	2500
ZS0811AE	4949598	31/07/2024 10:40	E. coli	CFU/100 ml	0	0
ZS0811AE	4949598	31/07/2024 10:40	Free - Residual disinfectant	mg Cl/l	0.26	
ZS0811AE	4949598	31/07/2024 10:40	Hydrogen Ion	pH value	7.6	9.5
ZS0811AE	4949598	31/07/2024 10:40	Iron	ug/l Fe	1.6	200
ZS0811AE	4949598	31/07/2024 10:40	Manganese	ug Mn/l	<0.80	50
ZS0811AE	4949598	31/07/2024 10:40	Odour	Diln No	0	0
ZS0811AE	4949598	31/07/2024 10:40	Odour - Nature		No odour	
ZS0811AE	4949598	31/07/2024 10:40	Taste	Diln No	0	0
ZS0811AE	4949598	31/07/2024 10:40	Taste - Nature		No taste	
ZS0811AE	4949598	31/07/2024 10:40	Total - Residual disinfectant	mg Cl/l	0.48	
ZS0811AE	4949598	31/07/2024 10:40	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4949598	31/07/2024 10:40	Turbidity	NTU	<0.09	4
ZN0706AE	4949271	31/07/2024 11:19	Aluminium	ug Al/l	13	200
ZN0706AE	4949271	31/07/2024 11:19	Colony Counts 22	CFU/1 ml	0	
ZN0706AE	4949271	31/07/2024 11:19	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0706AE	4949271	31/07/2024 11:19	Colour	mg/l Pt/Co	<4.56	20
ZN0706AE	4949271	31/07/2024 11:19	Conductivity	uS/cm 20 C	170	2500
ZN0706AE	4949271	31/07/2024 11:19	E. coli	CFU/100 ml	0	0
ZN0706AE	4949271	31/07/2024 11:19	Free - Residual disinfectant	mg Cl/l	0.54	
ZN0706AE	4949271	31/07/2024 11:19	Hydrogen Ion	pH value	7.6	9.5
ZN0706AE	4949271	31/07/2024 11:19	Iron	ug/l Fe	5.2	200
ZN0706AE	4949271	31/07/2024 11:19	Manganese	ug Mn/l	0.81	50
ZN0706AE	4949271	31/07/2024 11:19	Odour	Diln No	0	0
ZN0706AE	4949271	31/07/2024 11:19	Odour - Nature		No odour	
ZN0706AE	4949271	31/07/2024 11:19	Taste	Diln No	0	0
ZN0706AE	4949271	31/07/2024 11:19	Taste - Nature		No taste	
ZN0706AE	4949271	31/07/2024 11:19	Total - Residual disinfectant	mg Cl/l	0.66	
ZN0706AE	4949271	31/07/2024 11:19	Total Coliforms	CFU/100 ml	0	0

ZN0706AE	4949271	31/07/2024 11:19	Turbidity	NTU	<0.09	4
ZN0102AE	4946375	31/07/2024 11:54	E. coli	CFU/100 ml	0	0
ZN0102AE	4946375	31/07/2024 11:54	Free - Residual disinfectant	mg Cl/l	0.63	
ZN0102AE	4946375	31/07/2024 11:54	Total - Residual disinfectant	mg Cl/l	0.78	
ZN0102AE	4946375	31/07/2024 11:54	Total Coliforms	CFU/100 ml	0	0
ZN0504AE	4960280	01/08/2024 08:52	E. coli	CFU/100 ml	0	0
ZN0504AE	4960280	01/08/2024 08:52	Free - Residual disinfectant	mg Cl/l	0.49	
ZN0504AE	4960280	01/08/2024 08:52	Total - Residual disinfectant	mg Cl/l	0.51	
ZN0504AE	4960280	01/08/2024 08:52	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4949777	01/08/2024 09:27	E. coli	CFU/100 ml	0	0
ZS0811AE	4949777	01/08/2024 09:27	Free - Residual disinfectant	mg Cl/l	0.45	
ZS0811AE	4949777	01/08/2024 09:27	Total - Residual disinfectant	mg Cl/l	0.68	
ZS0811AE	4949777	01/08/2024 09:27	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4949760	02/08/2024 09:46	E. coli	CFU/100 ml	0	0
ZS0809AE	4949760	02/08/2024 09:46	Free - Residual disinfectant	mg Cl/l	0.28	
ZS0809AE	4949760	02/08/2024 09:46	Total - Residual disinfectant	mg Cl/l	0.42	
ZS0809AE	4949760	02/08/2024 09:46	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4949586	02/08/2024 09:51	E. coli	CFU/100 ml	0	0
ZN0501AE	4949586	02/08/2024 09:51	Free - Residual disinfectant	mg Cl/l	0.49	
ZN0501AE	4949586	02/08/2024 09:51	Total - Residual disinfectant	mg Cl/l	0.59	
ZN0501AE	4949586	02/08/2024 09:51	Total Coliforms	CFU/100 ml	0	0
ZN0102CUST	4963559	02/08/2024 16:15	Colour	mg/l Pt/Co	<4.56	20
ZN0102CUST	4963559	02/08/2024 16:15	Free - Residual disinfectant	mg Cl/l	0.14	
ZN0102CUST	4963559	02/08/2024 16:15	Hydrogen Ion	pH value	7.6	9.5
ZN0102CUST	4963559	02/08/2024 16:15	Total - Residual disinfectant	mg Cl/l	0.24	
ZN0102CUST	4963559	02/08/2024 16:15	Turbidity	NTU	0.36	4
ZN0102CUST	4963560	02/08/2024 16:40	Colour	mg/l Pt/Co	<4.56	20
ZN0102CUST	4963560	02/08/2024 16:40	Free - Residual disinfectant	mg Cl/l	0.21	
ZN0102CUST	4963560	02/08/2024 16:40	Hydrogen Ion	pH value	7.6	9.5
ZN0102CUST	4963560	02/08/2024 16:40	Total - Residual disinfectant	mg Cl/l	0.41	
ZN0102CUST	4963560	02/08/2024 16:40	Turbidity	NTU	0.15	4
ZN0102CUST	4963561	02/08/2024 17:00	Colour	mg/l Pt/Co	<4.56	20
ZN0102CUST	4963561	02/08/2024 17:00	Free - Residual disinfectant	mg Cl/l	0.2	
ZN0102CUST	4963561	02/08/2024 17:00	Hydrogen Ion	pH value	7.5	9.5
ZN0102CUST	4963561	02/08/2024 17:00	Total - Residual disinfectant	mg Cl/l	0.31	
ZN0102CUST	4963561	02/08/2024 17:00	Turbidity	NTU	0.35	4
ZS0811CUST	4963768	05/08/2024 08:40	Aluminium	ug Al/l	8.7	200
ZS0811CUST	4963768	05/08/2024 08:40	Colour	mg/l Pt/Co	<4.56	20

ZS0811CUST	4963768	05/08/2024 08:40	E. coli	CFU/100 ml	0	0
ZS0811CUST	4963768	05/08/2024 08:40	Free - Residual disinfectant	mg Cl/l	0.61	
ZS0811CUST	4963768	05/08/2024 08:40	Hydrogen Ion	pH value	7.6	9.5
ZS0811CUST	4963768	05/08/2024 08:40	Iron	ug/l Fe	1.9	200
ZS0811CUST	4963768	05/08/2024 08:40	Manganese	ug Mn/l	<0.642	50
ZS0811CUST	4963768	05/08/2024 08:40	Odour	Diln No	10	0
ZS0811CUST	4963768	05/08/2024 08:40	Odour - Nature		Petrochemical	
ZS0811CUST	4963768	05/08/2024 08:40	Taste	Diln No	99	0
ZS0811CUST	4963768	05/08/2024 08:40	Taste - Nature		is performed due to odour contravention	
ZS0811CUST	4963768	05/08/2024 08:40	Total - Residual disinfectant	mg Cl/l	0.75	
ZS0811CUST	4963768	05/08/2024 08:40	Total Coliforms	CFU/100 ml	0	0
ZS0811CUST	4963768	05/08/2024 08:40	Turbidity	NTU	<0.09	4
ZN0504AE	4952272	05/08/2024 09:50	Aluminium	ug Al/l	32	200
ZN0504AE	4952272	05/08/2024 09:50	Colony Counts 22	CFU/1 ml	0	
ZN0504AE	4952272	05/08/2024 09:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0504AE	4952272	05/08/2024 09:50	Colour	mg/l Pt/Co	<4.56	20
ZN0504AE	4952272	05/08/2024 09:50	Conductivity	uS/cm 20 C	350	2500
ZN0504AE	4952272	05/08/2024 09:50	E. coli	CFU/100 ml	0	0
ZN0504AE	4952272	05/08/2024 09:50	Free - Residual disinfectant	mg Cl/l	0.07	
ZN0504AE	4952272	05/08/2024 09:50	Hydrogen Ion	pH value	7.6	9.5
ZN0504AE	4952272	05/08/2024 09:50	Iron	ug/l Fe	96	200
ZN0504AE	4952272	05/08/2024 09:50	Manganese	ug Mn/l	1.4	50
ZN0504AE	4952272	05/08/2024 09:50	Odour	Diln No	0	0
ZN0504AE	4952272	05/08/2024 09:50	Odour - Nature		No odour	
ZN0504AE	4952272	05/08/2024 09:50	Taste	Diln No	0	0
ZN0504AE	4952272	05/08/2024 09:50	Taste - Nature		No taste	
ZN0504AE	4952272	05/08/2024 09:50	Total - Residual disinfectant	mg Cl/l	0.39	
ZN0504AE	4952272	05/08/2024 09:50	Total Coliforms	CFU/100 ml	0	0
ZN0504AE	4952272	05/08/2024 09:50	Turbidity	NTU	0.16	4
ZN1102AE	4952277	05/08/2024 10:30	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN1102AE	4952277	05/08/2024 10:30	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN1102AE	4952277	05/08/2024 10:30	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN1102AE	4952277	05/08/2024 10:30	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN1102AE	4952277	05/08/2024 10:30	Bromate	ug BrO3/l	<0.50	10
ZN1102AE	4952277	05/08/2024 10:30	E. coli	CFU/100 ml	0	0
ZN1102AE	4952277	05/08/2024 10:30	Free - Residual disinfectant	mg Cl/l	0.36	
ZN1102AE	4952277	05/08/2024 10:30	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN1102AE	4952277	05/08/2024 10:30	PAH - Sum of four substances	ug/l	0	0.1

ZN1102AE	4952277	05/08/2024 10:30	Total - Residual disinfectant	mg Cl/l	0.52	
ZN1102AE	4952277	05/08/2024 10:30	Total Coliforms	CFU/100 ml	0	0
ZN0705AE	4952328	05/08/2024 10:32	Aluminium	ug Al/l	8.6	200
ZN0705AE	4952328	05/08/2024 10:32	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN0705AE	4952328	05/08/2024 10:32	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0705AE	4952328	05/08/2024 10:32	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0705AE	4952328	05/08/2024 10:32	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0705AE	4952328	05/08/2024 10:32	Bromate	ug BrO3/l	1	10
ZN0705AE	4952328	05/08/2024 10:32	Colony Counts 22	CFU/1 ml	0	
ZN0705AE	4952328	05/08/2024 10:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0705AE	4952328	05/08/2024 10:32	Colour	mg/l Pt/Co	<4.56	20
ZN0705AE	4952328	05/08/2024 10:32	Conductivity	uS/cm 20 C	120	2500
ZN0705AE	4952328	05/08/2024 10:32	E. coli	CFU/100 ml	0	0
ZN0705AE	4952328	05/08/2024 10:32	Free - Residual disinfectant	mg Cl/l	0.98	
ZN0705AE	4952328	05/08/2024 10:32	Hydrogen Ion	pH value	7.5	9.5
ZN0705AE	4952328	05/08/2024 10:32	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0705AE	4952328	05/08/2024 10:32	Iron	ug/l Fe	4.9	200
ZN0705AE	4952328	05/08/2024 10:32	Manganese	ug Mn/l	<0.80	50
ZN0705AE	4952328	05/08/2024 10:32	Mercury	ug per l	<0.041	1
ZN0705AE	4952328	05/08/2024 10:32	Odour	Diln No	0	0
ZN0705AE	4952328	05/08/2024 10:32	Odour - Nature		No odour	
ZN0705AE	4952328	05/08/2024 10:32	PAH - Sum of four substances	ug/l	0	0.1
ZN0705AE	4952328	05/08/2024 10:32	Taste	Diln No	0	0
ZN0705AE	4952328	05/08/2024 10:32	Taste - Nature		No taste	
ZN0705AE	4952328	05/08/2024 10:32	Total - Residual disinfectant	mg Cl/l	1.21	
ZN0705AE	4952328	05/08/2024 10:32	Total Coliforms	CFU/100 ml	0	0
ZN0705AE	4952328	05/08/2024 10:32	Turbidity	NTU	<0.09	4
ZN0804AE	4949599	05/08/2024 10:56	Aluminium	ug Al/l	33	200
ZN0804AE	4949599	05/08/2024 10:56	Colony Counts 22	CFU/1 ml	0	
ZN0804AE	4949599	05/08/2024 10:56	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0804AE	4949599	05/08/2024 10:56	Colour	mg/l Pt/Co	<4.56	20
ZN0804AE	4949599	05/08/2024 10:56	Conductivity	uS/cm 20 C	420	2500
ZN0804AE	4949599	05/08/2024 10:56	E. coli	CFU/100 ml	0	0
ZN0804AE	4949599	05/08/2024 10:56	Free - Residual disinfectant	mg Cl/l	0.9	
ZN0804AE	4949599	05/08/2024 10:56	Hydrogen Ion	pH value	7.9	9.5
ZN0804AE	4949599	05/08/2024 10:56	Iron	ug/l Fe	4.2	200
ZN0804AE	4949599	05/08/2024 10:56	Manganese	ug Mn/l	2.7	50
ZN0804AE	4949599	05/08/2024 10:56	Odour	Diln No	0	0

ZN0804AE	4949599	05/08/2024 10:56	Odour - Nature		No odour	
ZN0804AE	4949599	05/08/2024 10:56	Taste	Diln No	0	0
ZN0804AE	4949599	05/08/2024 10:56	Taste - Nature		No taste	
ZN0804AE	4949599	05/08/2024 10:56	Total - Residual disinfectant	mg Cl/l	1.1	
ZN0804AE	4949599	05/08/2024 10:56	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4949599	05/08/2024 10:56	Turbidity	NTU	0.092	4
ZN0706AE	4952298	05/08/2024 11:12	E. coli	CFU/100 ml	0	0
ZN0706AE	4952298	05/08/2024 11:12	Free - Residual disinfectant	mg Cl/l	0.51	
ZN0706AE	4952298	05/08/2024 11:12	Total - Residual disinfectant	mg Cl/l	0.57	
ZN0706AE	4952298	05/08/2024 11:12	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4952304	05/08/2024 12:00	Aluminium	ug Al/l	140	200
ZN0102AE	4952304	05/08/2024 12:00	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN0102AE	4952304	05/08/2024 12:00	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0102AE	4952304	05/08/2024 12:00	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0102AE	4952304	05/08/2024 12:00	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0102AE	4952304	05/08/2024 12:00	Bromate	ug BrO3/l	<0.50	10
ZN0102AE	4952304	05/08/2024 12:00	Colony Counts 22	CFU/1 ml	3	
ZN0102AE	4952304	05/08/2024 12:00	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0102AE	4952304	05/08/2024 12:00	Colour	mg/l Pt/Co	<4.56	20
ZN0102AE	4952304	05/08/2024 12:00	Conductivity	uS/cm 20 C	350	2500
ZN0102AE	4952304	05/08/2024 12:00	E. coli	CFU/100 ml	0	0
ZN0102AE	4952304	05/08/2024 12:00	Free - Residual disinfectant	mg Cl/l	0.22	
ZN0102AE	4952304	05/08/2024 12:00	Hydrogen Ion	pH value	7.7	9.5
ZN0102AE	4952304	05/08/2024 12:00	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0102AE	4952304	05/08/2024 12:00	Iron	ug/l Fe	520	200
ZN0102AE	4952304	05/08/2024 12:00	Manganese	ug Mn/l	25	50
ZN0102AE	4952304	05/08/2024 12:00	Odour	Diln No	10	0
ZN0102AE	4952304	05/08/2024 12:00	Odour - Nature		Charred Wood/Bituminous	
ZN0102AE	4952304	05/08/2024 12:00	PAH - Sum of four substances	ug/l	0	0.1
ZN0102AE	4952304	05/08/2024 12:00	Taste	Diln No	99	0
ZN0102AE	4952304	05/08/2024 12:00	Taste - Nature		is performed due to odour contravention	
ZN0102AE	4952304	05/08/2024 12:00	Total - Residual disinfectant	mg Cl/l	0.28	
ZN0102AE	4952304	05/08/2024 12:00	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4952304	05/08/2024 12:00	Turbidity	NTU	2.8	4
ZS0811AE	4952325	05/08/2024 12:08	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZS0811AE	4952325	05/08/2024 12:08	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZS0811AE	4952325	05/08/2024 12:08	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZS0811AE	4952325	05/08/2024 12:08	Benzo(k)fluoranthene	ug/l	<0.0040	0.1

ZS0811AE	4952325	05/08/2024 12:08	Bromate	ug BrO3/l	<0.50	10
ZS0811AE	4952325	05/08/2024 12:08	E. coli	CFU/100 ml	0	0
ZS0811AE	4952325	05/08/2024 12:08	Free - Residual disinfectant	mg Cl/l	0.25	
ZS0811AE	4952325	05/08/2024 12:08	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZS0811AE	4952325	05/08/2024 12:08	PAH - Sum of four substances	ug/l	0	0.1
ZS0811AE	4952325	05/08/2024 12:08	Total - Residual disinfectant	mg Cl/l	0.48	
ZS0811AE	4952325	05/08/2024 12:08	Total Coliforms	CFU/100 ml	0	0
ZN0502CUST	4965433	06/08/2024 09:00	Aluminium	ug Al/l	9.9	200
ZN0502CUST	4965433	06/08/2024 09:00	Colour	mg/l Pt/Co	<4.56	20
ZN0502CUST	4965433	06/08/2024 09:00	E. coli	CFU/100 ml	0	0
ZN0502CUST	4965433	06/08/2024 09:00	Free - Residual disinfectant	mg Cl/l	0.24	
ZN0502CUST	4965433	06/08/2024 09:00	Hydrogen Ion	pH value	7	9.5
ZN0502CUST	4965433	06/08/2024 09:00	Iron	ug/l Fe	11	200
ZN0502CUST	4965433	06/08/2024 09:00	Manganese	ug Mn/l	<0.642	50
ZN0502CUST	4965433	06/08/2024 09:00	Odour	Diln No	0	0
ZN0502CUST	4965433	06/08/2024 09:00	Odour - Nature		No odour	
ZN0502CUST	4965433	06/08/2024 09:00	Taste	Diln No	0	0
ZN0502CUST	4965433	06/08/2024 09:00	Taste - Nature		No taste	
ZN0502CUST	4965433	06/08/2024 09:00	Total - Residual disinfectant	mg Cl/l	0.29	
ZN0502CUST	4965433	06/08/2024 09:00	Total Coliforms	CFU/100 ml	0	0
ZN0502CUST	4965433	06/08/2024 09:00	Turbidity	NTU	<0.09	4
ZN0502AE	4952306	06/08/2024 10:31	Aluminium	ug Al/l	8.7	200
ZN0502AE	4952306	06/08/2024 10:31	Colony Counts 22	CFU/1 ml	0	
ZN0502AE	4952306	06/08/2024 10:31	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0502AE	4952306	06/08/2024 10:31	Colour	mg/l Pt/Co	<4.56	20
ZN0502AE	4952306	06/08/2024 10:31	Conductivity	uS/cm 20 C	120	2500
ZN0502AE	4952306	06/08/2024 10:31	E. coli	CFU/100 ml	0	0
ZN0502AE	4952306	06/08/2024 10:31	Free - Residual disinfectant	mg Cl/l	0.5	
ZN0502AE	4952306	06/08/2024 10:31	Hydrogen Ion	pH value	7.2	9.5
ZN0502AE	4952306	06/08/2024 10:31	Iron	ug/l Fe	4.7	200
ZN0502AE	4952306	06/08/2024 10:31	Manganese	ug Mn/l	<0.80	50
ZN0502AE	4952306	06/08/2024 10:31	Odour	Diln No	0	0
ZN0502AE	4952306	06/08/2024 10:31	Odour - Nature		No odour	
ZN0502AE	4952306	06/08/2024 10:31	Taste	Diln No	0	0
ZN0502AE	4952306	06/08/2024 10:31	Taste - Nature		No taste	
ZN0502AE	4952306	06/08/2024 10:31	Total - Residual disinfectant	mg Cl/l	0.54	
ZN0502AE	4952306	06/08/2024 10:31	Total Coliforms	CFU/100 ml	0	0
ZN0502AE	4952306	06/08/2024 10:31	Turbidity	NTU	<0.09	4

ZN0501AE	4952302	06/08/2024 11:01	Aluminium	ug Al/l	33	200
ZN0501AE	4952302	06/08/2024 11:01	Colony Counts 22	CFU/1 ml	0	
ZN0501AE	4952302	06/08/2024 11:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0501AE	4952302	06/08/2024 11:01	Colour	mg/l Pt/Co	<4.56	20
ZN0501AE	4952302	06/08/2024 11:01	Conductivity	uS/cm 20 C	370	2500
ZN0501AE	4952302	06/08/2024 11:01	E. coli	CFU/100 ml	0	0
ZN0501AE	4952302	06/08/2024 11:01	Free - Residual disinfectant	mg Cl/l	0.08	
ZN0501AE	4952302	06/08/2024 11:01	Hydrogen Ion	pH value	7.8	9.5
ZN0501AE	4952302	06/08/2024 11:01	Iron	ug/l Fe	<1.538	200
ZN0501AE	4952302	06/08/2024 11:01	Manganese	ug Mn/l	<0.642	50
ZN0501AE	4952302	06/08/2024 11:01	Odour	Diln No	0	0
ZN0501AE	4952302	06/08/2024 11:01	Odour - Nature		No odour	
ZN0501AE	4952302	06/08/2024 11:01	Taste	Diln No	0	0
ZN0501AE	4952302	06/08/2024 11:01	Taste - Nature		No taste	
ZN0501AE	4952302	06/08/2024 11:01	Total - Residual disinfectant	mg Cl/l	0.33	
ZN0501AE	4952302	06/08/2024 11:01	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4952302	06/08/2024 11:01	Turbidity	NTU	<0.09	4
ZS0811AE	4952669	06/08/2024 11:43	Aluminium	ug Al/l	15	200
ZS0811AE	4952669	06/08/2024 11:43	Colony Counts 22	CFU/1 ml	0	
ZS0811AE	4952669	06/08/2024 11:43	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0811AE	4952669	06/08/2024 11:43	Colour	mg/l Pt/Co	<4.56	20
ZS0811AE	4952669	06/08/2024 11:43	Conductivity	uS/cm 20 C	370	2500
ZS0811AE	4952669	06/08/2024 11:43	E. coli	CFU/100 ml	0	0
ZS0811AE	4952669	06/08/2024 11:43	Free - Residual disinfectant	mg Cl/l	0.71	
ZS0811AE	4952669	06/08/2024 11:43	Hydrogen Ion	pH value	7.7	9.5
ZS0811AE	4952669	06/08/2024 11:43	Iron	ug/l Fe	21	200
ZS0811AE	4952669	06/08/2024 11:43	Manganese	ug Mn/l	<0.80	50
ZS0811AE	4952669	06/08/2024 11:43	Odour	Diln No	0	0
ZS0811AE	4952669	06/08/2024 11:43	Odour - Nature		No odour	
ZS0811AE	4952669	06/08/2024 11:43	Taste	Diln No	0	0
ZS0811AE	4952669	06/08/2024 11:43	Taste - Nature		No taste	
ZS0811AE	4952669	06/08/2024 11:43	Total - Residual disinfectant	mg Cl/l	0.86	
ZS0811AE	4952669	06/08/2024 11:43	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4952669	06/08/2024 11:43	Turbidity	NTU	<0.09	4
ZS0809AE	4952275	06/08/2024 12:38	Aluminium	ug Al/l	15	200
ZS0809AE	4952275	06/08/2024 12:38	Colony Counts 22	CFU/1 ml	0	
ZS0809AE	4952275	06/08/2024 12:38	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0809AE	4952275	06/08/2024 12:38	Colour	mg/l Pt/Co	<4.56	20

ZS0809AE	4952275	06/08/2024 12:38	Conductivity	uS/cm 20 C	370	2500
ZS0809AE	4952275	06/08/2024 12:38	E. coli	CFU/100 ml	0	0
ZS0809AE	4952275	06/08/2024 12:38	Free - Residual disinfectant	mg Cl/l	0.83	
ZS0809AE	4952275	06/08/2024 12:38	Hydrogen Ion	pH value	7.6	9.5
ZS0809AE	4952275	06/08/2024 12:38	Iron	ug/l Fe	<1.538	200
ZS0809AE	4952275	06/08/2024 12:38	Manganese	ug Mn/l	<0.80	50
ZS0809AE	4952275	06/08/2024 12:38	Odour	Diln No	0	0
ZS0809AE	4952275	06/08/2024 12:38	Odour - Nature		No odour	
ZS0809AE	4952275	06/08/2024 12:38	Taste	Diln No	0	0
ZS0809AE	4952275	06/08/2024 12:38	Taste - Nature		No taste	
ZS0809AE	4952275	06/08/2024 12:38	Total - Residual disinfectant	mg Cl/l	0.97	
ZS0809AE	4952275	06/08/2024 12:38	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4952275	06/08/2024 12:38	Turbidity	NTU	<0.09	4
ZN0705CUST	4965773	07/08/2024 10:30	E. coli	CFU/100 ml	0	0
ZN0705CUST	4965773	07/08/2024 10:30	Free - Residual disinfectant	mg Cl/l	0.49	
ZN0705CUST	4965773	07/08/2024 10:30	Odour	Diln No	0	0
ZN0705CUST	4965773	07/08/2024 10:30	Odour - Nature		No odour	
ZN0705CUST	4965773	07/08/2024 10:30	Taste	Diln No	0	0
ZN0705CUST	4965773	07/08/2024 10:30	Taste - Nature		No taste	
ZN0705CUST	4965773	07/08/2024 10:30	Total - Residual disinfectant	mg Cl/l	0.71	
ZN0705CUST	4965773	07/08/2024 10:30	Total Coliforms	CFU/100 ml	0	0
ZN0705CUST	4965771	07/08/2024 10:30	E. coli	CFU/100 ml	0	0
ZN0705CUST	4965771	07/08/2024 10:30	Free - Residual disinfectant	mg Cl/l	0.48	
ZN0705CUST	4965771	07/08/2024 10:30	Odour	Diln No	0	0
ZN0705CUST	4965771	07/08/2024 10:30	Odour - Nature		No odour	
ZN0705CUST	4965771	07/08/2024 10:30	Taste	Diln No	0	0
ZN0705CUST	4965771	07/08/2024 10:30	Taste - Nature		No taste	
ZN0705CUST	4965771	07/08/2024 10:30	Total - Residual disinfectant	mg Cl/l	0.71	
ZN0705CUST	4965771	07/08/2024 10:30	Total Coliforms	CFU/100 ml	2	0
ZN0705CUST	4965772	07/08/2024 10:30	E. coli	CFU/100 ml	0	0
ZN0705CUST	4965772	07/08/2024 10:30	Free - Residual disinfectant	mg Cl/l	0.48	
ZN0705CUST	4965772	07/08/2024 10:30	Odour	Diln No	0	0
ZN0705CUST	4965772	07/08/2024 10:30	Odour - Nature		No odour	
ZN0705CUST	4965772	07/08/2024 10:30	Taste	Diln No	0	0
ZN0705CUST	4965772	07/08/2024 10:30	Taste - Nature		No taste	
ZN0705CUST	4965772	07/08/2024 10:30	Total - Residual disinfectant	mg Cl/l	0.71	
ZN0705CUST	4965772	07/08/2024 10:30	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4952656	07/08/2024 10:31	E. coli	CFU/100 ml	0	0

ZN0501AE	4952656	07/08/2024 10:31	Free - Residual disinfectant	mg Cl/l	0.52	
ZN0501AE	4952656	07/08/2024 10:31	Total - Residual disinfectant	mg Cl/l	0.7	
ZN0501AE	4952656	07/08/2024 10:31	Total Coliforms	CFU/100 ml	0	0
ZS0811CUST	4965902	07/08/2024 11:00	E. coli	CFU/100 ml	0	0
ZS0811CUST	4965902	07/08/2024 11:00	Free - Residual disinfectant	mg Cl/l	0.66	
ZS0811CUST	4965902	07/08/2024 11:00	Odour	Diln No	7	0
ZS0811CUST	4965902	07/08/2024 11:00	Odour - Nature		petrol	
ZS0811CUST	4965902	07/08/2024 11:00	Taste	Diln No	99	0
ZS0811CUST	4965902	07/08/2024 11:00	Taste - Nature		is performed due to odour contravention	
ZS0811CUST	4965902	07/08/2024 11:00	Total - Residual disinfectant	mg Cl/l	0.74	
ZS0811CUST	4965902	07/08/2024 11:00	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4952637	07/08/2024 11:03	Aluminium	ug Al/l	10	200
ZN1102AE	4952637	07/08/2024 11:03	Colony Counts 22	CFU/1 ml	0	
ZN1102AE	4952637	07/08/2024 11:03	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN1102AE	4952637	07/08/2024 11:03	Colour	mg/l Pt/Co	<4.56	20
ZN1102AE	4952637	07/08/2024 11:03	Conductivity	uS/cm 20 C	400	2500
ZN1102AE	4952637	07/08/2024 11:03	E. coli	CFU/100 ml	0	0
ZN1102AE	4952637	07/08/2024 11:03	Free - Residual disinfectant	mg Cl/l	0.71	
ZN1102AE	4952637	07/08/2024 11:03	Hydrogen Ion	pH value	7.6	9.5
ZN1102AE	4952637	07/08/2024 11:03	Iron	ug/l Fe	<1.538	200
ZN1102AE	4952637	07/08/2024 11:03	Manganese	ug Mn/l	0.84	50
ZN1102AE	4952637	07/08/2024 11:03	Odour	Diln No	0	0
ZN1102AE	4952637	07/08/2024 11:03	Odour - Nature		No odour	
ZN1102AE	4952637	07/08/2024 11:03	Taste	Diln No	0	0
ZN1102AE	4952637	07/08/2024 11:03	Taste - Nature		No taste	
ZN1102AE	4952637	07/08/2024 11:03	Total - Residual disinfectant	mg Cl/l	0.92	
ZN1102AE	4952637	07/08/2024 11:03	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4952637	07/08/2024 11:03	Turbidity	NTU	<0.09	4
ZS0811CUST	4965903	07/08/2024 11:15	E. coli	CFU/100 ml	0	0
ZS0811CUST	4965903	07/08/2024 11:15	Free - Residual disinfectant	mg Cl/l	0.8	
ZS0811CUST	4965903	07/08/2024 11:15	Total - Residual disinfectant	mg Cl/l	0.84	
ZS0811CUST	4965903	07/08/2024 11:15	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4952657	07/08/2024 11:18	1,2 Dichloroethane	ug/l	<0.4	3
ZN0102AE	4952657	07/08/2024 11:18	Aluminium	ug Al/l	21	200
ZN0102AE	4952657	07/08/2024 11:18	Antimony	ug/l Sb	0.099	5
ZN0102AE	4952657	07/08/2024 11:18	Arsenic	ug/l As	0.22	10
ZN0102AE	4952657	07/08/2024 11:18	Benzene	ug/l	<0.15	1
ZN0102AE	4952657	07/08/2024 11:18	Boron	mg/l B	<0.0586	1

ZN0102AE	4952657	07/08/2024 11:18	Bromodichloromethane	ug/l	21	
ZN0102AE	4952657	07/08/2024 11:18	Bromoform	ug/l	<3.5	
ZN0102AE	4952657	07/08/2024 11:18	Cadmium	ug/l Cd	<0.042	5
ZN0102AE	4952657	07/08/2024 11:18	Chloroform	ug/l	53	
ZN0102AE	4952657	07/08/2024 11:18	Chromium	ug/l Cr	<0.260	50
ZN0102AE	4952657	07/08/2024 11:18	Colony Counts 22	CFU/1 ml	1	
ZN0102AE	4952657	07/08/2024 11:18	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0102AE	4952657	07/08/2024 11:18	Dibromochloromethane	ug/l	6.7	
ZN0102AE	4952657	07/08/2024 11:18	E. coli	CFU/100 ml	0	0
ZN0102AE	4952657	07/08/2024 11:18	Free - Residual disinfectant	mg Cl/l	0.37	
ZN0102AE	4952657	07/08/2024 11:18	Iron	ug/l Fe	17	200
ZN0102AE	4952657	07/08/2024 11:18	Manganese	ug Mn/l	0.97	50
ZN0102AE	4952657	07/08/2024 11:18	Selenium	ug/l Se	<0.057	10
ZN0102AE	4952657	07/08/2024 11:18	Tetrachloroethene	ug/l	<0.8	
ZN0102AE	4952657	07/08/2024 11:18	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0102AE	4952657	07/08/2024 11:18	Tetrachloromethane	ug/l	<0.4	3
ZN0102AE	4952657	07/08/2024 11:18	Total - Residual disinfectant	mg Cl/l	0.44	
ZN0102AE	4952657	07/08/2024 11:18	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4952657	07/08/2024 11:18	Total Organic Carbon	mg C/l	2.6	
ZN0102AE	4952657	07/08/2024 11:18	Total Trihalomethanes	ug/l	81	100
ZN0102AE	4952657	07/08/2024 11:18	Trichloroethene	ug/l	<0.7	
ZN0102AE	4952657	07/08/2024 11:18	WHO Index		0.6	1
ZS0811CUST	4965904	07/08/2024 11:30	E. coli	CFU/100 ml	0	0
ZS0811CUST	4965904	07/08/2024 11:30	Free - Residual disinfectant	mg Cl/l	0.64	
ZS0811CUST	4965904	07/08/2024 11:30	Total - Residual disinfectant	mg Cl/l	0.72	
ZS0811CUST	4965904	07/08/2024 11:30	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4952635	07/08/2024 12:15	E. coli	CFU/100 ml	0	0
ZS0809AE	4952635	07/08/2024 12:15	Free - Residual disinfectant	mg Cl/l	0.77	
ZS0809AE	4952635	07/08/2024 12:15	Total - Residual disinfectant	mg Cl/l	0.91	
ZS0809AE	4952635	07/08/2024 12:15	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4949587	08/08/2024 10:35	Aluminium	ug Al/l	17	200
ZN0102AE	4949587	08/08/2024 10:35	E. coli	CFU/100 ml	0	0
ZN0102AE	4949587	08/08/2024 10:35	Free - Residual disinfectant	mg Cl/l	0.13	
ZN0102AE	4949587	08/08/2024 10:35	Iron	ug/l Fe	250	200
ZN0102AE	4949587	08/08/2024 10:35	Manganese	ug Mn/l	8.2	50
ZN0102AE	4949587	08/08/2024 10:35	Total - Residual disinfectant	mg Cl/l	0.31	
ZN0102AE	4949587	08/08/2024 10:35	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4966130	08/08/2024 10:50	E. coli	CFU/100 ml	0	0

ZN0102AE	4966130	08/08/2024 10:50	Free - Residual disinfectant	mg Cl/l	0.21	
ZN0102AE	4966130	08/08/2024 10:50	Odour	Diln No	0	0
ZN0102AE	4966130	08/08/2024 10:50	Odour - Nature		No odour	
ZN0102AE	4966130	08/08/2024 10:50	Taste	Diln No	0	0
ZN0102AE	4966130	08/08/2024 10:50	Taste - Nature		No taste	
ZN0102AE	4966130	08/08/2024 10:50	Total - Residual disinfectant	mg Cl/l	0.46	
ZN0102AE	4966130	08/08/2024 10:50	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4966131	08/08/2024 11:05	E. coli	CFU/100 ml	0	0
ZN0102AE	4966131	08/08/2024 11:05	Free - Residual disinfectant	mg Cl/l	0.09	
ZN0102AE	4966131	08/08/2024 11:05	Odour	Diln No	0	0
ZN0102AE	4966131	08/08/2024 11:05	Odour - Nature		No odour	
ZN0102AE	4966131	08/08/2024 11:05	Taste	Diln No	0	0
ZN0102AE	4966131	08/08/2024 11:05	Taste - Nature		No taste	
ZN0102AE	4966131	08/08/2024 11:05	Total - Residual disinfectant	mg Cl/l	0.35	
ZN0102AE	4966131	08/08/2024 11:05	Total Coliforms	CFU/100 ml	0	0
ZS0811CUST	4966524	09/08/2024 08:50	Aluminium	ug Al/l	13	200
ZS0811CUST	4966524	09/08/2024 08:50	Colour	mg/l Pt/Co	<4.56	20
ZS0811CUST	4966524	09/08/2024 08:50	E. coli	CFU/100 ml	0	0
ZS0811CUST	4966524	09/08/2024 08:50	Free - Residual disinfectant	mg Cl/l	0.37	
ZS0811CUST	4966524	09/08/2024 08:50	Hydrogen Ion	pH value	7.6	9.5
ZS0811CUST	4966524	09/08/2024 08:50	Iron	ug/l Fe	5.1	200
ZS0811CUST	4966524	09/08/2024 08:50	Manganese	ug Mn/l	<0.642	50
ZS0811CUST	4966524	09/08/2024 08:50	Total - Residual disinfectant	mg Cl/l	0.54	
ZS0811CUST	4966524	09/08/2024 08:50	Total Coliforms	CFU/100 ml	2	0
ZS0811CUST	4966524	09/08/2024 08:50	Turbidity	NTU	<0.09	4
ZN0705CUST	4966494	09/08/2024 09:15	Aluminium	ug Al/l	<3.089	200
ZN0705CUST	4966494	09/08/2024 09:15	Colour	mg/l Pt/Co	<4.56	20
ZN0705CUST	4966494	09/08/2024 09:15	E. coli	CFU/100 ml	0	0
ZN0705CUST	4966494	09/08/2024 09:15	Free - Residual disinfectant	mg Cl/l	0.49	
ZN0705CUST	4966494	09/08/2024 09:15	Hydrogen Ion	pH value	7.5	9.5
ZN0705CUST	4966494	09/08/2024 09:15	Iron	ug/l Fe	5.1	200
ZN0705CUST	4966494	09/08/2024 09:15	Manganese	ug Mn/l	<0.642	50
ZN0705CUST	4966494	09/08/2024 09:15	Total - Residual disinfectant	mg Cl/l	0.7	
ZN0705CUST	4966494	09/08/2024 09:15	Total Coliforms	CFU/100 ml	0	0
ZN0705CUST	4966494	09/08/2024 09:15	Turbidity	NTU	<0.09	4
ZS0811CUST	4966525	09/08/2024 11:00	Aluminium	ug Al/l	16	200
ZS0811CUST	4966525	09/08/2024 11:00	Colour	mg/l Pt/Co	<4.56	20
ZS0811CUST	4966525	09/08/2024 11:00	E. coli	CFU/100 ml	0	0

ZS0811CUST	4966525	09/08/2024 11:00	Free - Residual disinfectant	mg Cl/l	0.1	
ZS0811CUST	4966525	09/08/2024 11:00	Hydrogen Ion	pH value	7.7	9.5
ZS0811CUST	4966525	09/08/2024 11:00	Iron	ug/l Fe	23	200
ZS0811CUST	4966525	09/08/2024 11:00	Manganese	ug Mn/l	1	50
ZS0811CUST	4966525	09/08/2024 11:00	Total - Residual disinfectant	mg Cl/l	0.29	
ZS0811CUST	4966525	09/08/2024 11:00	Total Coliforms	CFU/100 ml	0	0
ZS0811CUST	4966525	09/08/2024 11:00	Turbidity	NTU	0.12	4
ZN0102OP	4966603	09/08/2024 11:35	E. coli	CFU/100 ml	0	0
ZN0102OP	4966603	09/08/2024 11:35	Free - Residual disinfectant	mg Cl/l	0.26	
ZN0102OP	4966603	09/08/2024 11:35	Odour	Diln No	0	0
ZN0102OP	4966603	09/08/2024 11:35	Odour - Nature		No odour	
ZN0102OP	4966603	09/08/2024 11:35	Taste	Diln No	0	0
ZN0102OP	4966603	09/08/2024 11:35	Taste - Nature		No taste	
ZN0102OP	4966603	09/08/2024 11:35	Total - Residual disinfectant	mg Cl/l	0.34	
ZN0102OP	4966603	09/08/2024 11:35	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4949772	09/08/2024 11:40	E. coli	CFU/100 ml	0	0
ZN0102AE	4949772	09/08/2024 11:40	Free - Residual disinfectant	mg Cl/l	0.26	
ZN0102AE	4949772	09/08/2024 11:40	Total - Residual disinfectant	mg Cl/l	0.34	
ZN0102AE	4949772	09/08/2024 11:40	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4952854	09/08/2024 11:57	E. coli	CFU/100 ml	0	0
ZS0809AE	4952854	09/08/2024 11:57	Free - Residual disinfectant	mg Cl/l	0.25	
ZS0809AE	4952854	09/08/2024 11:57	Total - Residual disinfectant	mg Cl/l	0.43	
ZS0809AE	4952854	09/08/2024 11:57	Total Coliforms	CFU/100 ml	0	0
ZN0102OP	4966604	09/08/2024 12:00	E. coli	CFU/100 ml	0	0
ZN0102OP	4966604	09/08/2024 12:00	Free - Residual disinfectant	mg Cl/l	0.34	
ZN0102OP	4966604	09/08/2024 12:00	Odour	Diln No	0	0
ZN0102OP	4966604	09/08/2024 12:00	Odour - Nature		No odour	
ZN0102OP	4966604	09/08/2024 12:00	Taste	Diln No	0	0
ZN0102OP	4966604	09/08/2024 12:00	Taste - Nature		No taste	
ZN0102OP	4966604	09/08/2024 12:00	Total - Residual disinfectant	mg Cl/l	0.42	
ZN0102OP	4966604	09/08/2024 12:00	Total Coliforms	CFU/100 ml	0	0
ZS0811CUST	4966833	10/08/2024 12:00	Aluminium	ug Al/l	16	200
ZS0811CUST	4966833	10/08/2024 12:00	Colour	mg/l Pt/Co	<4.56	20
ZS0811CUST	4966833	10/08/2024 12:00	E. coli	CFU/100 ml	0	0
ZS0811CUST	4966833	10/08/2024 12:00	Free - Residual disinfectant	mg Cl/l	0.42	
ZS0811CUST	4966833	10/08/2024 12:00	Hydrogen Ion	pH value	7.6	9.5
ZS0811CUST	4966833	10/08/2024 12:00	Iron	ug/l Fe	9	200
ZS0811CUST	4966833	10/08/2024 12:00	Manganese	ug Mn/l	<0.642	50

ZS0811CUST	4966833	10/08/2024 12:00	Odour	Diln No	0	0
ZS0811CUST	4966833	10/08/2024 12:00	Odour - Nature		No odour	
ZS0811CUST	4966833	10/08/2024 12:00	Taste	Diln No	0	0
ZS0811CUST	4966833	10/08/2024 12:00	Taste - Nature		No taste	
ZS0811CUST	4966833	10/08/2024 12:00	Total - Residual disinfectant	mg Cl/l	0.59	
ZS0811CUST	4966833	10/08/2024 12:00	Total Coliforms	CFU/100 ml	0	0
ZS0811CUST	4966833	10/08/2024 12:00	Turbidity	NTU	<0.09	4
ZS0809AE	4954996	12/08/2024 09:39	1,2 Dichloroethane	ug/l	<0.4	3
ZS0809AE	4954996	12/08/2024 09:39	Aluminium	ug Al/l	20	200
ZS0809AE	4954996	12/08/2024 09:39	Ammonium	mg NH4/l	<0.01	0.5
ZS0809AE	4954996	12/08/2024 09:39	Antimony	ug/l Sb	0.12	5
ZS0809AE	4954996	12/08/2024 09:39	Arsenic	ug/l As	0.23	10
ZS0809AE	4954996	12/08/2024 09:39	Benzene	ug/l	<0.15	1
ZS0809AE	4954996	12/08/2024 09:39	Boron	mg/l B	<0.0586	1
ZS0809AE	4954996	12/08/2024 09:39	Bromodichloromethane	ug/l	15	
ZS0809AE	4954996	12/08/2024 09:39	Bromoform	ug/l	<3.5	
ZS0809AE	4954996	12/08/2024 09:39	Cadmium	ug/l Cd	<0.042	5
ZS0809AE	4954996	12/08/2024 09:39	Calcium	mg/l	40	
ZS0809AE	4954996	12/08/2024 09:39	Chloride	mg Cl/l	17	250
ZS0809AE	4954996	12/08/2024 09:39	Chloroform	ug/l	45	
ZS0809AE	4954996	12/08/2024 09:39	Chromium	ug/l Cr	<0.260	50
ZS0809AE	4954996	12/08/2024 09:39	Colony Counts 22	CFU/1 ml	0	
ZS0809AE	4954996	12/08/2024 09:39	Colony Counts 37 (48hrs)	CFU/1 ml	1	
ZS0809AE	4954996	12/08/2024 09:39	Colour	mg/l Pt/Co	<4.56	20
ZS0809AE	4954996	12/08/2024 09:39	Conductivity	uS/cm 20 C	290	2500
ZS0809AE	4954996	12/08/2024 09:39	Copper	mg Cu/l	<0.546	2
ZS0809AE	4954996	12/08/2024 09:39	Dibromochloromethane	ug/l	5	
ZS0809AE	4954996	12/08/2024 09:39	E. coli	CFU/100 ml	0	0
ZS0809AE	4954996	12/08/2024 09:39	Enterococci	CFU/100ml	0	0
ZS0809AE	4954996	12/08/2024 09:39	Fluoride	mg F/l	<0.150	1.5
ZS0809AE	4954996	12/08/2024 09:39	Free - Residual disinfectant	mg Cl/l	0.24	
ZS0809AE	4954996	12/08/2024 09:39	Hydrogen Ion	pH value	7.6	9.5
ZS0809AE	4954996	12/08/2024 09:39	Iron	ug/l Fe	5.3	200
ZS0809AE	4954996	12/08/2024 09:39	Lead	ug Pb/l	<0.095	10
ZS0809AE	4954996	12/08/2024 09:39	Magnesium	mg/l	6.3	
ZS0809AE	4954996	12/08/2024 09:39	Manganese	ug Mn/l	<0.642	50
ZS0809AE	4954996	12/08/2024 09:39	Nickel	ug Ni/l	1.1	20
ZS0809AE	4954996	12/08/2024 09:39	Nitrate	mg/l	2.4	50

ZS0809AE	4954996	12/08/2024 09:39	Nitrate/Nitrite Formula	mg/l	<0.048	1
ZS0809AE	4954996	12/08/2024 09:39	Nitrite	mg/l	<0.03	0.5
ZS0809AE	4954996	12/08/2024 09:39	Odour	Diln No	0	0
ZS0809AE	4954996	12/08/2024 09:39	Odour - Nature		No odour	
ZS0809AE	4954996	12/08/2024 09:39	Potassium	mg/l	2.6	
ZS0809AE	4954996	12/08/2024 09:39	Selenium	ug/l Se	0.06	10
ZS0809AE	4954996	12/08/2024 09:39	Sodium	mg Na/l	11	200
ZS0809AE	4954996	12/08/2024 09:39	Sulphate	mg SO4/l	62	250
ZS0809AE	4954996	12/08/2024 09:39	Taste	Diln No	0	0
ZS0809AE	4954996	12/08/2024 09:39	Taste - Nature		No taste	
ZS0809AE	4954996	12/08/2024 09:39	Tetrachloroethene	ug/l	<0.8	
ZS0809AE	4954996	12/08/2024 09:39	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZS0809AE	4954996	12/08/2024 09:39	Tetrachloromethane	ug/l	<0.4	3
ZS0809AE	4954996	12/08/2024 09:39	Total - Residual disinfectant	mg Cl/l	0.41	
ZS0809AE	4954996	12/08/2024 09:39	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4954996	12/08/2024 09:39	Total hardness	mg/l	50	
ZS0809AE	4954996	12/08/2024 09:39	Total Organic Carbon	mg C/l	2.4	
ZS0809AE	4954996	12/08/2024 09:39	Total Trihalomethanes	ug/l	66	100
ZS0809AE	4954996	12/08/2024 09:39	Trichloroethene	ug/l	<0.7	
ZS0809AE	4954996	12/08/2024 09:39	Turbidity	NTU	0.23	4
ZS0809AE	4954996	12/08/2024 09:39	WHO Index		0.46	1
ZN0705AE	4955045	12/08/2024 09:54	1,2 Dichloroethane	ug/l	<0.4	3
ZN0705AE	4955045	12/08/2024 09:54	Ammonium	mg NH4/l	<0.01	0.5
ZN0705AE	4955045	12/08/2024 09:54	Antimony	ug/l Sb	0.035	5
ZN0705AE	4955045	12/08/2024 09:54	Arsenic	ug/l As	0.13	10
ZN0705AE	4955045	12/08/2024 09:54	Benzene	ug/l	<0.15	1
ZN0705AE	4955045	12/08/2024 09:54	Boron	mg/l B	<0.0586	1
ZN0705AE	4955045	12/08/2024 09:54	Bromodichloromethane	ug/l	10	
ZN0705AE	4955045	12/08/2024 09:54	Bromoform	ug/l	<3.5	
ZN0705AE	4955045	12/08/2024 09:54	Cadmium	ug/l Cd	<0.042	5
ZN0705AE	4955045	12/08/2024 09:54	Calcium	mg/l	14	
ZN0705AE	4955045	12/08/2024 09:54	Chloride	mg Cl/l	9.8	250
ZN0705AE	4955045	12/08/2024 09:54	Chloroform	ug/l	40	
ZN0705AE	4955045	12/08/2024 09:54	Chromium	ug/l Cr	<0.260	50
ZN0705AE	4955045	12/08/2024 09:54	Copper	mg Cu/l	<0.546	2
ZN0705AE	4955045	12/08/2024 09:54	Dibromochloromethane	ug/l	1.6	
ZN0705AE	4955045	12/08/2024 09:54	E. coli	CFU/100 ml	0	0
ZN0705AE	4955045	12/08/2024 09:54	Enterococci	CFU/100ml	0	0

ZN0705AE	4955045	12/08/2024 09:54	Fluoride	mg F/l	<0.150	1.5
ZN0705AE	4955045	12/08/2024 09:54	Free - Residual disinfectant	mg Cl/l	0.53	
ZN0705AE	4955045	12/08/2024 09:54	Hydrogen Ion	pH value	7.5	9.5
ZN0705AE	4955045	12/08/2024 09:54	Lead	ug Pb/l	<0.095	10
ZN0705AE	4955045	12/08/2024 09:54	Magnesium	mg/l	1.9	
ZN0705AE	4955045	12/08/2024 09:54	Mercury	ug per l	<0.041	1
ZN0705AE	4955045	12/08/2024 09:54	Nickel	ug Ni/l	<0.625	20
ZN0705AE	4955045	12/08/2024 09:54	Nitrate	mg/l	0.51	50
ZN0705AE	4955045	12/08/2024 09:54	Nitrate/Nitrite Formula	mg/l	<0.010	1
ZN0705AE	4955045	12/08/2024 09:54	Nitrite	mg/l	<0.03	0.5
ZN0705AE	4955045	12/08/2024 09:54	Potassium	mg/l	<0.5	
ZN0705AE	4955045	12/08/2024 09:54	Selenium	ug/l Se	<0.057	10
ZN0705AE	4955045	12/08/2024 09:54	Sodium	mg Na/l	6.7	200
ZN0705AE	4955045	12/08/2024 09:54	Sulphate	mg SO4/l	24	250
ZN0705AE	4955045	12/08/2024 09:54	Tetrachloroethene	ug/l	<0.8	
ZN0705AE	4955045	12/08/2024 09:54	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0705AE	4955045	12/08/2024 09:54	Tetrachloromethane	ug/l	<0.4	3
ZN0705AE	4955045	12/08/2024 09:54	Total - Residual disinfectant	mg Cl/l	0.64	
ZN0705AE	4955045	12/08/2024 09:54	Total Coliforms	CFU/100 ml	0	0
ZN0705AE	4955045	12/08/2024 09:54	Total hardness	mg/l	17	
ZN0705AE	4955045	12/08/2024 09:54	Total Organic Carbon	mg C/l	2	
ZN0705AE	4955045	12/08/2024 09:54	Total Trihalomethanes	ug/l	52	100
ZN0705AE	4955045	12/08/2024 09:54	Trichloroethene	ug/l	<0.7	
ZN0705AE	4955045	12/08/2024 09:54	WHO Index		0.32	1
ZN0501AE	4955020	12/08/2024 10:21	1,2 Dichloroethane	ug/l	<0.4	3
ZN0501AE	4955020	12/08/2024 10:21	Ammonium	mg NH4/l	<0.01	0.5
ZN0501AE	4955020	12/08/2024 10:21	Antimony	ug/l Sb	0.13	5
ZN0501AE	4955020	12/08/2024 10:21	Arsenic	ug/l As	0.26	10
ZN0501AE	4955020	12/08/2024 10:21	Benzene	ug/l	<0.15	1
ZN0501AE	4955020	12/08/2024 10:21	Boron	mg/l B	<0.0586	1
ZN0501AE	4955020	12/08/2024 10:21	Bromodichloromethane	ug/l	16	
ZN0501AE	4955020	12/08/2024 10:21	Bromoform	ug/l	<3.5	
ZN0501AE	4955020	12/08/2024 10:21	Cadmium	ug/l Cd	<0.042	5
ZN0501AE	4955020	12/08/2024 10:21	Calcium	mg/l	52	
ZN0501AE	4955020	12/08/2024 10:21	Chloride	mg Cl/l	21	250
ZN0501AE	4955020	12/08/2024 10:21	Chloroform	ug/l	39	
ZN0501AE	4955020	12/08/2024 10:21	Chromium	ug/l Cr	<0.260	50
ZN0501AE	4955020	12/08/2024 10:21	Copper	mg Cu/l	<0.546	2

ZN0501AE	4955020	12/08/2024 10:21	Dibromochloromethane	ug/l	4.5	
ZN0501AE	4955020	12/08/2024 10:21	E. coli	CFU/100 ml	0	0
ZN0501AE	4955020	12/08/2024 10:21	Enterococci	CFU/100ml	0	0
ZN0501AE	4955020	12/08/2024 10:21	Fluoride	mg F/l	<0.150	1.5
ZN0501AE	4955020	12/08/2024 10:21	Free - Residual disinfectant	mg Cl/l	0.62	
ZN0501AE	4955020	12/08/2024 10:21	Lead	ug Pb/l	<0.095	10
ZN0501AE	4955020	12/08/2024 10:21	Magnesium	mg/l	8.4	
ZN0501AE	4955020	12/08/2024 10:21	Mercury	ug per l	<0.041	1
ZN0501AE	4955020	12/08/2024 10:21	Nickel	ug Ni/l	1.4	20
ZN0501AE	4955020	12/08/2024 10:21	Nitrate	mg/l	3.2	50
ZN0501AE	4955020	12/08/2024 10:21	Nitrate/Nitrite Formula	mg/l	<0.064	1
ZN0501AE	4955020	12/08/2024 10:21	Nitrite	mg/l	<0.03	0.5
ZN0501AE	4955020	12/08/2024 10:21	Potassium	mg/l	3.7	
ZN0501AE	4955020	12/08/2024 10:21	Selenium	ug/l Se	0.089	10
ZN0501AE	4955020	12/08/2024 10:21	Sodium	mg Na/l	14	200
ZN0501AE	4955020	12/08/2024 10:21	Sulphate	mg SO4/l	81	250
ZN0501AE	4955020	12/08/2024 10:21	Tetrachloroethene	ug/l	<0.8	
ZN0501AE	4955020	12/08/2024 10:21	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0501AE	4955020	12/08/2024 10:21	Tetrachloromethane	ug/l	<0.4	3
ZN0501AE	4955020	12/08/2024 10:21	Total - Residual disinfectant	mg Cl/l	0.89	
ZN0501AE	4955020	12/08/2024 10:21	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4955020	12/08/2024 10:21	Total hardness	mg/l	66	
ZN0501AE	4955020	12/08/2024 10:21	Total Organic Carbon	mg C/l	2.8	
ZN0501AE	4955020	12/08/2024 10:21	Total Trihalomethanes	ug/l	60	100
ZN0501AE	4955020	12/08/2024 10:21	Trichloroethene	ug/l	<0.7	
ZN0501AE	4955020	12/08/2024 10:21	WHO Index		0.45	1
ZN1102AE	4954997	12/08/2024 10:42	E. coli	CFU/100 ml	0	0
ZN1102AE	4954997	12/08/2024 10:42	Free - Residual disinfectant	mg Cl/l	0.4	
ZN1102AE	4954997	12/08/2024 10:42	Total - Residual disinfectant	mg Cl/l	0.57	
ZN1102AE	4954997	12/08/2024 10:42	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4955042	12/08/2024 11:26	E. coli	CFU/100 ml	0	0
ZS0811AE	4955042	12/08/2024 11:26	Free - Residual disinfectant	mg Cl/l	0.26	
ZS0811AE	4955042	12/08/2024 11:26	Total - Residual disinfectant	mg Cl/l	0.41	
ZS0811AE	4955042	12/08/2024 11:26	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4955022	12/08/2024 11:35	1,2 Dichloroethane	ug/l	<0.4	3
ZN0102AE	4955022	12/08/2024 11:35	Aluminium	ug Al/l	17	200
ZN0102AE	4955022	12/08/2024 11:35	Ammonium	mg NH4/l	<0.01	0.5
ZN0102AE	4955022	12/08/2024 11:35	Antimony	ug/l Sb	0.11	5

ZN0102AE	4955022	12/08/2024 11:35	Arsenic	ug/l As	0.24	10
ZN0102AE	4955022	12/08/2024 11:35	Benzene	ug/l	<0.15	1
ZN0102AE	4955022	12/08/2024 11:35	Boron	mg/l B	<0.0586	1
ZN0102AE	4955022	12/08/2024 11:35	Bromodichloromethane	ug/l	20	
ZN0102AE	4955022	12/08/2024 11:35	Bromoform	ug/l	<3.5	
ZN0102AE	4955022	12/08/2024 11:35	Cadmium	ug/l Cd	<0.042	5
ZN0102AE	4955022	12/08/2024 11:35	Calcium	mg/l	45	
ZN0102AE	4955022	12/08/2024 11:35	Chloride	mg Cl/l	22	250
ZN0102AE	4955022	12/08/2024 11:35	Chloroform	ug/l	64	
ZN0102AE	4955022	12/08/2024 11:35	Chromium	ug/l Cr	<0.260	50
ZN0102AE	4955022	12/08/2024 11:35	Colony Counts 22	CFU/1 ml	0	
ZN0102AE	4955022	12/08/2024 11:35	Colony Counts 37 (48hrs)	CFU/1 ml	1	
ZN0102AE	4955022	12/08/2024 11:35	Colour	mg/l Pt/Co	<4.56	20
ZN0102AE	4955022	12/08/2024 11:35	Conductivity	uS/cm 20 C	350	2500
ZN0102AE	4955022	12/08/2024 11:35	Copper	mg Cu/l	<0.546	2
ZN0102AE	4955022	12/08/2024 11:35	Dibromochloromethane	ug/l	5.3	
ZN0102AE	4955022	12/08/2024 11:35	E. coli	CFU/100 ml	0	0
ZN0102AE	4955022	12/08/2024 11:35	Enterococci	CFU/100ml	0	0
ZN0102AE	4955022	12/08/2024 11:35	Fluoride	mg F/l	<0.150	1.5
ZN0102AE	4955022	12/08/2024 11:35	Free - Residual disinfectant	mg Cl/l	0.12	
ZN0102AE	4955022	12/08/2024 11:35	Hydrogen Ion	pH value	7.7	9.5
ZN0102AE	4955022	12/08/2024 11:35	Iron	ug/l Fe	8.7	200
ZN0102AE	4955022	12/08/2024 11:35	Lead	ug Pb/l	0.2	10
ZN0102AE	4955022	12/08/2024 11:35	Magnesium	mg/l	9.9	
ZN0102AE	4955022	12/08/2024 11:35	Manganese	ug Mn/l	<0.642	50
ZN0102AE	4955022	12/08/2024 11:35	Nickel	ug Ni/l	1.3	20
ZN0102AE	4955022	12/08/2024 11:35	Nitrate	mg/l	2.1	50
ZN0102AE	4955022	12/08/2024 11:35	Nitrate/Nitrite Formula	mg/l	<0.042	1
ZN0102AE	4955022	12/08/2024 11:35	Nitrite	mg/l	<0.03	0.5
ZN0102AE	4955022	12/08/2024 11:35	Odour	Diln No	0	0
ZN0102AE	4955022	12/08/2024 11:35	Odour - Nature		No odour	
ZN0102AE	4955022	12/08/2024 11:35	Potassium	mg/l	2.8	
ZN0102AE	4955022	12/08/2024 11:35	Selenium	ug/l Se	<0.057	10
ZN0102AE	4955022	12/08/2024 11:35	Sodium	mg Na/l	14	200
ZN0102AE	4955022	12/08/2024 11:35	Sulphate	mg SO4/l	69	250
ZN0102AE	4955022	12/08/2024 11:35	Taste	Diln No	0	0
ZN0102AE	4955022	12/08/2024 11:35	Taste - Nature		No taste	
ZN0102AE	4955022	12/08/2024 11:35	Tetrachloroethene	ug/l	<0.8	

ZN0102AE	4955022	12/08/2024 11:35	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0102AE	4955022	12/08/2024 11:35	Tetrachloromethane	ug/l	<0.4	3
ZN0102AE	4955022	12/08/2024 11:35	Total - Residual disinfectant	mg Cl/l	0.46	
ZN0102AE	4955022	12/08/2024 11:35	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4955022	12/08/2024 11:35	Total hardness	mg/l	61	
ZN0102AE	4955022	12/08/2024 11:35	Total Organic Carbon	mg C/l	2.8	
ZN0102AE	4955022	12/08/2024 11:35	Total Trihalomethanes	ug/l	90	100
ZN0102AE	4955022	12/08/2024 11:35	Trichloroethene	ug/l	<0.7	
ZN0102AE	4955022	12/08/2024 11:35	Turbidity	NTU	<0.09	4
ZN0102AE	4955022	12/08/2024 11:35	WHO Index		0.61	1
ZN0804AE	4952670	12/08/2024 11:48	Colony Counts 22	CFU/1 ml	0	
ZN0804AE	4952670	12/08/2024 11:48	Colony Counts 37 (48hrs)	CFU/1 ml	17	
ZN0804AE	4952670	12/08/2024 11:48	Colour	mg/l Pt/Co	<4.56	20
ZN0804AE	4952670	12/08/2024 11:48	Conductivity	uS/cm 20 C	420	2500
ZN0804AE	4952670	12/08/2024 11:48	E. coli	CFU/100 ml	0	0
ZN0804AE	4952670	12/08/2024 11:48	Free - Residual disinfectant	mg Cl/l	0.26	
ZN0804AE	4952670	12/08/2024 11:48	Hydrogen Ion	pH value	8.1	9.5
ZN0804AE	4952670	12/08/2024 11:48	Odour	Diln No	0	0
ZN0804AE	4952670	12/08/2024 11:48	Odour - Nature		No odour	
ZN0804AE	4952670	12/08/2024 11:48	Taste	Diln No	0	0
ZN0804AE	4952670	12/08/2024 11:48	Taste - Nature		No taste	
ZN0804AE	4952670	12/08/2024 11:48	Total - Residual disinfectant	mg Cl/l	0.42	
ZN0804AE	4952670	12/08/2024 11:48	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4952670	12/08/2024 11:48	Turbidity	NTU	<0.09	4
ZN0102CUST	4968665	13/08/2024 08:45	Aluminium	ug Al/l	22	200
ZN0102CUST	4968665	13/08/2024 08:45	Iron	ug/l Fe	200	200
ZN0102CUST	4968665	13/08/2024 08:45	Manganese	ug Mn/l	22	50
ZN0502AE	4942889	13/08/2024 09:35	Aluminium	ug Al/l	160	200
ZN0502AE	4942889	13/08/2024 09:35	Colony Counts 22	CFU/1 ml	0	
ZN0502AE	4942889	13/08/2024 09:35	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0502AE	4942889	13/08/2024 09:35	Colour	mg/l Pt/Co	<4.56	20
ZN0502AE	4942889	13/08/2024 09:35	Conductivity	uS/cm 20 C	120	2500
ZN0502AE	4942889	13/08/2024 09:35	E. coli	CFU/100 ml	0	0
ZN0502AE	4942889	13/08/2024 09:35	Free - Residual disinfectant	mg Cl/l	0.27	
ZN0502AE	4942889	13/08/2024 09:35	Hydrogen Ion	pH value	7.3	9.5
ZN0502AE	4942889	13/08/2024 09:35	Iron	ug/l Fe	140	200
ZN0502AE	4942889	13/08/2024 09:35	Manganese	ug Mn/l	9.8	50
ZN0502AE	4942889	13/08/2024 09:35	Odour	Diln No	0	0

ZN0502AE	4942889	13/08/2024 09:35	Odour - Nature		No odour	
ZN0502AE	4942889	13/08/2024 09:35	Taste	Diln No	0	0
ZN0502AE	4942889	13/08/2024 09:35	Taste - Nature		No taste	
ZN0502AE	4942889	13/08/2024 09:35	Total - Residual disinfectant	mg Cl/l	0.35	
ZN0502AE	4942889	13/08/2024 09:35	Total Coliforms	CFU/100 ml	0	0
ZN0502AE	4942889	13/08/2024 09:35	Turbidity	NTU	0.47	4
ZN0804AE	4952326	13/08/2024 09:45	Aluminium	ug Al/l	47	200
ZN0804AE	4952326	13/08/2024 09:45	E. coli	CFU/100 ml	0	0
ZN0804AE	4952326	13/08/2024 09:45	Free - Residual disinfectant	mg Cl/l	0.48	
ZN0804AE	4952326	13/08/2024 09:45	Iron	ug/l Fe	5.8	200
ZN0804AE	4952326	13/08/2024 09:45	Manganese	ug Mn/l	2	50
ZN0804AE	4952326	13/08/2024 09:45	Total - Residual disinfectant	mg Cl/l	0.63	
ZN0804AE	4952326	13/08/2024 09:45	Total Coliforms	CFU/100 ml	0	0
ZN0504AE	4954994	13/08/2024 09:55	1,2 Dichloroethane	ug/l	<0.4	3
ZN0504AE	4954994	13/08/2024 09:55	Ammonium	mg NH4/l	<0.01	0.5
ZN0504AE	4954994	13/08/2024 09:55	Antimony	ug/l Sb	0.12	5
ZN0504AE	4954994	13/08/2024 09:55	Arsenic	ug/l As	0.24	10
ZN0504AE	4954994	13/08/2024 09:55	Benzene	ug/l	<0.15	1
ZN0504AE	4954994	13/08/2024 09:55	Boron	mg/l B	<0.0586	1
ZN0504AE	4954994	13/08/2024 09:55	Bromodichloromethane	ug/l	15	
ZN0504AE	4954994	13/08/2024 09:55	Bromoform	ug/l	<3.5	
ZN0504AE	4954994	13/08/2024 09:55	Cadmium	ug/l Cd	<0.042	5
ZN0504AE	4954994	13/08/2024 09:55	Calcium	mg/l	39	
ZN0504AE	4954994	13/08/2024 09:55	Chloroform	ug/l	49	
ZN0504AE	4954994	13/08/2024 09:55	Chromium	ug/l Cr	<0.260	50
ZN0504AE	4954994	13/08/2024 09:55	Copper	mg Cu/l	<0.546	2
ZN0504AE	4954994	13/08/2024 09:55	Dibromochloromethane	ug/l	5	
ZN0504AE	4954994	13/08/2024 09:55	E. coli	CFU/100 ml	0	0
ZN0504AE	4954994	13/08/2024 09:55	Enterococci	CFU/100ml	0	0
ZN0504AE	4954994	13/08/2024 09:55	Free - Residual disinfectant	mg Cl/l	0.07	
ZN0504AE	4954994	13/08/2024 09:55	Lead	ug Pb/l	<0.095	10
ZN0504AE	4954994	13/08/2024 09:55	Magnesium	mg/l	6.2	
ZN0504AE	4954994	13/08/2024 09:55	Mercury	ug per l	<0.041	1
ZN0504AE	4954994	13/08/2024 09:55	Nickel	ug Ni/l	0.87	20
ZN0504AE	4954994	13/08/2024 09:55	Potassium	mg/l	2.6	
ZN0504AE	4954994	13/08/2024 09:55	Selenium	ug/l Se	0.066	10
ZN0504AE	4954994	13/08/2024 09:55	Sodium	mg Na/l	11	200
ZN0504AE	4954994	13/08/2024 09:55	Tetrachloroethene	ug/l	<0.8	

ZN0504AE	4954994	13/08/2024 09:55	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0504AE	4954994	13/08/2024 09:55	Tetrachloromethane	ug/l	<0.4	3
ZN0504AE	4954994	13/08/2024 09:55	Total - Residual disinfectant	mg Cl/l	0.15	
ZN0504AE	4954994	13/08/2024 09:55	Total Coliforms	CFU/100 ml	0	0
ZN0504AE	4954994	13/08/2024 09:55	Total hardness	mg/l	49	
ZN0504AE	4954994	13/08/2024 09:55	Total Organic Carbon	mg C/l	2.2	
ZN0504AE	4954994	13/08/2024 09:55	Total Trihalomethanes	ug/l	70	100
ZN0504AE	4954994	13/08/2024 09:55	Trichloroethene	ug/l	<0.7	
ZN0504AE	4954994	13/08/2024 09:55	WHO Index		0.47	1
ZN0505AE	4962850	13/08/2024 10:26	Antimony	ug/l Sb	0.14	5
ZN0505AE	4962850	13/08/2024 10:26	Arsenic	ug/l As	0.31	10
ZN0505AE	4962850	13/08/2024 10:26	Boron	mg/l B	<0.0586	1
ZN0505AE	4962850	13/08/2024 10:26	Cadmium	ug/l Cd	<0.042	5
ZN0505AE	4962850	13/08/2024 10:26	Chromium	ug/l Cr	<0.260	50
ZN0505AE	4962850	13/08/2024 10:26	Selenium	ug/l Se	0.079	10
ZN0706AE	4955016	13/08/2024 10:45	1,2 Dichloroethane	ug/l	<0.4	3
ZN0706AE	4955016	13/08/2024 10:45	Aluminium	ug Al/l	9.3	200
ZN0706AE	4955016	13/08/2024 10:45	Ammonium	mg NH4/l	<0.01	0.5
ZN0706AE	4955016	13/08/2024 10:45	Antimony	ug/l Sb	0.041	5
ZN0706AE	4955016	13/08/2024 10:45	Arsenic	ug/l As	0.3	10
ZN0706AE	4955016	13/08/2024 10:45	Benzene	ug/l	<0.15	1
ZN0706AE	4955016	13/08/2024 10:45	Boron	mg/l B	<0.0586	1
ZN0706AE	4955016	13/08/2024 10:45	Bromodichloromethane	ug/l	13	
ZN0706AE	4955016	13/08/2024 10:45	Bromoform	ug/l	<3.5	
ZN0706AE	4955016	13/08/2024 10:45	Cadmium	ug/l Cd	<0.042	5
ZN0706AE	4955016	13/08/2024 10:45	Calcium	mg/l	25	
ZN0706AE	4955016	13/08/2024 10:45	Chloroform	ug/l	59	
ZN0706AE	4955016	13/08/2024 10:45	Chromium	ug/l Cr	<0.260	50
ZN0706AE	4955016	13/08/2024 10:45	Colony Counts 22	CFU/1 ml	0	
ZN0706AE	4955016	13/08/2024 10:45	Colony Counts 37 (48hrs)	CFU/1 ml	1	
ZN0706AE	4955016	13/08/2024 10:45	Colour	mg/l Pt/Co	<4.56	20
ZN0706AE	4955016	13/08/2024 10:45	Conductivity	uS/cm 20 C	180	2500
ZN0706AE	4955016	13/08/2024 10:45	Copper	mg Cu/l	<0.546	2
ZN0706AE	4955016	13/08/2024 10:45	Dibromochloromethane	ug/l	2	
ZN0706AE	4955016	13/08/2024 10:45	E. coli	CFU/100 ml	0	0
ZN0706AE	4955016	13/08/2024 10:45	Enterococci	CFU/100ml	0	0
ZN0706AE	4955016	13/08/2024 10:45	Free - Residual disinfectant	mg Cl/l	0.48	
ZN0706AE	4955016	13/08/2024 10:45	Hydrogen Ion	pH value	7.6	9.5

ZN0706AE	4955016	13/08/2024 10:45	Iron	ug/l Fe	3.6	200
ZN0706AE	4955016	13/08/2024 10:45	Lead	ug Pb/l	<0.095	10
ZN0706AE	4955016	13/08/2024 10:45	Magnesium	mg/l	2	
ZN0706AE	4955016	13/08/2024 10:45	Manganese	ug Mn/l	<0.642	50
ZN0706AE	4955016	13/08/2024 10:45	Mercury	ug per l	<0.041	1
ZN0706AE	4955016	13/08/2024 10:45	Nickel	ug Ni/l	<0.625	20
ZN0706AE	4955016	13/08/2024 10:45	Odour	Diln No	0	0
ZN0706AE	4955016	13/08/2024 10:45	Odour - Nature		No odour	
ZN0706AE	4955016	13/08/2024 10:45	Potassium	mg/l	0.75	
ZN0706AE	4955016	13/08/2024 10:45	Selenium	ug/l Se	<0.057	10
ZN0706AE	4955016	13/08/2024 10:45	Sodium	mg Na/l	9.3	200
ZN0706AE	4955016	13/08/2024 10:45	Taste	Diln No	0	0
ZN0706AE	4955016	13/08/2024 10:45	Taste - Nature		No taste	
ZN0706AE	4955016	13/08/2024 10:45	Tetrachloroethene	ug/l	<0.8	
ZN0706AE	4955016	13/08/2024 10:45	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0706AE	4955016	13/08/2024 10:45	Tetrachloromethane	ug/l	<0.4	3
ZN0706AE	4955016	13/08/2024 10:45	Total - Residual disinfectant	mg Cl/l	0.6	
ZN0706AE	4955016	13/08/2024 10:45	Total Coliforms	CFU/100 ml	0	0
ZN0706AE	4955016	13/08/2024 10:45	Total hardness	mg/l	28	
ZN0706AE	4955016	13/08/2024 10:45	Total Organic Carbon	mg C/l	2.3	
ZN0706AE	4955016	13/08/2024 10:45	Total Trihalomethanes	ug/l	75	100
ZN0706AE	4955016	13/08/2024 10:45	Trichloroethene	ug/l	<0.7	
ZN0706AE	4955016	13/08/2024 10:45	Turbidity	NTU	<0.09	4
ZN0706AE	4955016	13/08/2024 10:45	WHO Index		0.44	1
ZN0501AE	4955329	13/08/2024 11:36	1,2 Dichloroethane	ug/l	<0.4	3
ZN0501AE	4955329	13/08/2024 11:36	Antimony	ug/l Sb	0.13	5
ZN0501AE	4955329	13/08/2024 11:36	Arsenic	ug/l As	0.26	10
ZN0501AE	4955329	13/08/2024 11:36	Benzene	ug/l	<0.15	1
ZN0501AE	4955329	13/08/2024 11:36	Boron	mg/l B	<0.0586	1
ZN0501AE	4955329	13/08/2024 11:36	Bromodichloromethane	ug/l	15	
ZN0501AE	4955329	13/08/2024 11:36	Bromoform	ug/l	<3.5	
ZN0501AE	4955329	13/08/2024 11:36	Cadmium	ug/l Cd	<0.042	5
ZN0501AE	4955329	13/08/2024 11:36	Chloroform	ug/l	38	
ZN0501AE	4955329	13/08/2024 11:36	Chromium	ug/l Cr	<0.260	50
ZN0501AE	4955329	13/08/2024 11:36	Dibromochloromethane	ug/l	4.5	
ZN0501AE	4955329	13/08/2024 11:36	E. coli	CFU/100 ml	0	0
ZN0501AE	4955329	13/08/2024 11:36	Free - Residual disinfectant	mg Cl/l	0.56	
ZN0501AE	4955329	13/08/2024 11:36	Selenium	ug/l Se	0.085	10

ZN0501AE	4955329	13/08/2024 11:36	Tetrachloroethene	ug/l	<0.8	
ZN0501AE	4955329	13/08/2024 11:36	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0501AE	4955329	13/08/2024 11:36	Tetrachloromethane	ug/l	<0.4	3
ZN0501AE	4955329	13/08/2024 11:36	Total - Residual disinfectant	mg Cl/l	0.69	
ZN0501AE	4955329	13/08/2024 11:36	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4955329	13/08/2024 11:36	Total Organic Carbon	mg C/l	2.9	
ZN0501AE	4955329	13/08/2024 11:36	Total Trihalomethanes	ug/l	58	100
ZN0501AE	4955329	13/08/2024 11:36	Trichloroethene	ug/l	<0.7	
ZN0501AE	4955329	13/08/2024 11:36	WHO Index		0.43	1
ZN0102AE	4955332	13/08/2024 12:20	E. coli	CFU/100 ml	0	0
ZN0102AE	4955332	13/08/2024 12:20	Free - Residual disinfectant	mg Cl/l	0.26	
ZN0102AE	4955332	13/08/2024 12:20	Odour	Diln No	0	0
ZN0102AE	4955332	13/08/2024 12:20	Odour - Nature		No odour	
ZN0102AE	4955332	13/08/2024 12:20	Taste	Diln No	0	0
ZN0102AE	4955332	13/08/2024 12:20	Taste - Nature		No taste	
ZN0102AE	4955332	13/08/2024 12:20	Total - Residual disinfectant	mg Cl/l	0.44	
ZN0102AE	4955332	13/08/2024 12:20	Total Coliforms	CFU/100 ml	0	0
ZN0502AE	4955024	14/08/2024 09:20	1,2 Dichloroethane	ug/l	<0.4	3
ZN0502AE	4955024	14/08/2024 09:20	Aluminium	ug Al/l	32	200
ZN0502AE	4955024	14/08/2024 09:20	Antimony	ug/l Sb	0.13	5
ZN0502AE	4955024	14/08/2024 09:20	Arsenic	ug/l As	0.36	10
ZN0502AE	4955024	14/08/2024 09:20	Benzene	ug/l	<0.15	1
ZN0502AE	4955024	14/08/2024 09:20	Boron	mg/l B	<0.0586	1
ZN0502AE	4955024	14/08/2024 09:20	Bromodichloromethane	ug/l	16	
ZN0502AE	4955024	14/08/2024 09:20	Bromoform	ug/l	<3.5	
ZN0502AE	4955024	14/08/2024 09:20	Cadmium	ug/l Cd	<0.042	5
ZN0502AE	4955024	14/08/2024 09:20	Chloroform	ug/l	41	
ZN0502AE	4955024	14/08/2024 09:20	Chromium	ug/l Cr	<0.260	50
ZN0502AE	4955024	14/08/2024 09:20	Dibromochloromethane	ug/l	5.2	
ZN0502AE	4955024	14/08/2024 09:20	E. coli	CFU/100 ml	0	0
ZN0502AE	4955024	14/08/2024 09:20	Free - Residual disinfectant	mg Cl/l	0.2	
ZN0502AE	4955024	14/08/2024 09:20	Iron	ug/l Fe	27	200
ZN0502AE	4955024	14/08/2024 09:20	Manganese	ug Mn/l	1.2	50
ZN0502AE	4955024	14/08/2024 09:20	Selenium	ug/l Se	0.062	10
ZN0502AE	4955024	14/08/2024 09:20	Tetrachloroethene	ug/l	<0.8	
ZN0502AE	4955024	14/08/2024 09:20	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0502AE	4955024	14/08/2024 09:20	Tetrachloromethane	ug/l	<0.4	3
ZN0502AE	4955024	14/08/2024 09:20	Total - Residual disinfectant	mg Cl/l	0.24	

ZN0502AE	4955024	14/08/2024 09:20	Total Coliforms	CFU/100 ml	0	0
ZN0502AE	4955024	14/08/2024 09:20	Total Organic Carbon	mg C/l	2.7	
ZN0502AE	4955024	14/08/2024 09:20	Total Trihalomethanes	ug/l	63	100
ZN0502AE	4955024	14/08/2024 09:20	Trichloroethene	ug/l	<0.7	
ZN0502AE	4955024	14/08/2024 09:20	WHO Index		0.46	1
ZN0804AE	4955043	14/08/2024 10:13	Aluminium	ug Al/l	44	200
ZN0804AE	4955043	14/08/2024 10:13	E. coli	CFU/100 ml	0	0
ZN0804AE	4955043	14/08/2024 10:13	Free - Residual disinfectant	mg Cl/l	0.94	
ZN0804AE	4955043	14/08/2024 10:13	Iron	ug/l Fe	3.3	200
ZN0804AE	4955043	14/08/2024 10:13	Manganese	ug Mn/l	2.2	50
ZN0804AE	4955043	14/08/2024 10:13	Total - Residual disinfectant	mg Cl/l	1.1	
ZN0804AE	4955043	14/08/2024 10:13	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4955571	14/08/2024 10:15	E. coli	CFU/100 ml	0	0
ZN0102AE	4955571	14/08/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.13	
ZN0102AE	4955571	14/08/2024 10:15	Total - Residual disinfectant	mg Cl/l	0.23	
ZN0102AE	4955571	14/08/2024 10:15	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4955309	14/08/2024 10:30	E. coli	CFU/100 ml	0	0
ZS0809AE	4955309	14/08/2024 10:30	Free - Residual disinfectant	mg Cl/l	0.35	
ZS0809AE	4955309	14/08/2024 10:30	Total - Residual disinfectant	mg Cl/l	0.51	
ZS0809AE	4955309	14/08/2024 10:30	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4955310	14/08/2024 11:32	1,2 Dichloroethane	ug/l	<0.4	3
ZN1102AE	4955310	14/08/2024 11:32	Aluminium	ug Al/l	5.1	200
ZN1102AE	4955310	14/08/2024 11:32	Ammonium	mg NH4/l	<0.01	0.5
ZN1102AE	4955310	14/08/2024 11:32	Antimony	ug/l Sb	0.086	5
ZN1102AE	4955310	14/08/2024 11:32	Arsenic	ug/l As	0.47	10
ZN1102AE	4955310	14/08/2024 11:32	Benzene	ug/l	<0.15	1
ZN1102AE	4955310	14/08/2024 11:32	Boron	mg/l B	<0.0586	1
ZN1102AE	4955310	14/08/2024 11:32	Bromodichloromethane	ug/l	15	
ZN1102AE	4955310	14/08/2024 11:32	Bromoform	ug/l	<3.5	
ZN1102AE	4955310	14/08/2024 11:32	Cadmium	ug/l Cd	<0.042	5
ZN1102AE	4955310	14/08/2024 11:32	Calcium	mg/l	29	
ZN1102AE	4955310	14/08/2024 11:32	Chloroform	ug/l	41	
ZN1102AE	4955310	14/08/2024 11:32	Chromium	ug/l Cr	<0.260	50
ZN1102AE	4955310	14/08/2024 11:32	Colony Counts 22	CFU/1 ml	0	
ZN1102AE	4955310	14/08/2024 11:32	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN1102AE	4955310	14/08/2024 11:32	Colour	mg/l Pt/Co	<4.56	20
ZN1102AE	4955310	14/08/2024 11:32	Conductivity	uS/cm 20 C	390	2500
ZN1102AE	4955310	14/08/2024 11:32	Copper	mg Cu/l	<0.546	2

ZN1102AE	4955310	14/08/2024 11:32	Dibromochloromethane	ug/l	4.2	
ZN1102AE	4955310	14/08/2024 11:32	E. coli	CFU/100 ml	0	0
ZN1102AE	4955310	14/08/2024 11:32	Enterococci	CFU/100ml	0	0
ZN1102AE	4955310	14/08/2024 11:32	Free - Residual disinfectant	mg Cl/l	0.41	
ZN1102AE	4955310	14/08/2024 11:32	Hydrogen Ion	pH value	7.6	9.5
ZN1102AE	4955310	14/08/2024 11:32	Iron	ug/l Fe	<1.538	200
ZN1102AE	4955310	14/08/2024 11:32	Lead	ug Pb/l	<0.095	10
ZN1102AE	4955310	14/08/2024 11:32	Magnesium	mg/l	7.7	
ZN1102AE	4955310	14/08/2024 11:32	Manganese	ug Mn/l	0.96	50
ZN1102AE	4955310	14/08/2024 11:32	Mercury	ug per l	<0.041	1
ZN1102AE	4955310	14/08/2024 11:32	Nickel	ug Ni/l	1.9	20
ZN1102AE	4955310	14/08/2024 11:32	Odour	Diln No	0	0
ZN1102AE	4955310	14/08/2024 11:32	Odour - Nature		No odour	
ZN1102AE	4955310	14/08/2024 11:32	Potassium	mg/l	4.4	
ZN1102AE	4955310	14/08/2024 11:32	Selenium	ug/l Se	<0.057	10
ZN1102AE	4955310	14/08/2024 11:32	Sodium	mg Na/l	52	200
ZN1102AE	4955310	14/08/2024 11:32	Taste	Diln No	0	0
ZN1102AE	4955310	14/08/2024 11:32	Taste - Nature		No taste	
ZN1102AE	4955310	14/08/2024 11:32	Tetrachloroethene	ug/l	<0.8	
ZN1102AE	4955310	14/08/2024 11:32	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN1102AE	4955310	14/08/2024 11:32	Tetrachloromethane	ug/l	<0.4	3
ZN1102AE	4955310	14/08/2024 11:32	Total - Residual disinfectant	mg Cl/l	0.56	
ZN1102AE	4955310	14/08/2024 11:32	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4955310	14/08/2024 11:32	Total hardness	mg/l	42	
ZN1102AE	4955310	14/08/2024 11:32	Total Organic Carbon	mg C/l	3.1	
ZN1102AE	4955310	14/08/2024 11:32	Total Trihalomethanes	ug/l	61	100
ZN1102AE	4955310	14/08/2024 11:32	Trichloroethene	ug/l	<0.7	
ZN1102AE	4955310	14/08/2024 11:32	Turbidity	NTU	<0.09	4
ZN1102AE	4955310	14/08/2024 11:32	WHO Index		0.44	1
ZS0811AE	4955342	14/08/2024 12:45	1,2 Dichloroethane	ug/l	<0.4	3
ZS0811AE	4955342	14/08/2024 12:45	Aluminium	ug Al/l	10	200
ZS0811AE	4955342	14/08/2024 12:45	Ammonium	mg NH4/l	<0.01	0.5
ZS0811AE	4955342	14/08/2024 12:45	Antimony	ug/l Sb	0.14	5
ZS0811AE	4955342	14/08/2024 12:45	Arsenic	ug/l As	0.22	10
ZS0811AE	4955342	14/08/2024 12:45	Benzene	ug/l	<0.15	1
ZS0811AE	4955342	14/08/2024 12:45	Boron	mg/l B	<0.0586	1
ZS0811AE	4955342	14/08/2024 12:45	Bromodichloromethane	ug/l	14	
ZS0811AE	4955342	14/08/2024 12:45	Bromoform	ug/l	<3.5	

ZS0811AE	4955342	14/08/2024 12:45	Cadmium	ug/l Cd	<0.042	5
ZS0811AE	4955342	14/08/2024 12:45	Calcium	mg/l	53	
ZS0811AE	4955342	14/08/2024 12:45	Chloroform	ug/l	36	
ZS0811AE	4955342	14/08/2024 12:45	Chromium	ug/l Cr	<0.260	50
ZS0811AE	4955342	14/08/2024 12:45	Colony Counts 22	CFU/1 ml	0	
ZS0811AE	4955342	14/08/2024 12:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0811AE	4955342	14/08/2024 12:45	Colour	mg/l Pt/Co	<4.56	20
ZS0811AE	4955342	14/08/2024 12:45	Conductivity	uS/cm 20 C	380	2500
ZS0811AE	4955342	14/08/2024 12:45	Copper	mg Cu/l	<0.546	2
ZS0811AE	4955342	14/08/2024 12:45	Dibromochloromethane	ug/l	5.9	
ZS0811AE	4955342	14/08/2024 12:45	E. coli	CFU/100 ml	0	0
ZS0811AE	4955342	14/08/2024 12:45	Enterococci	CFU/100ml	0	0
ZS0811AE	4955342	14/08/2024 12:45	Free - Residual disinfectant	mg Cl/l	0.53	
ZS0811AE	4955342	14/08/2024 12:45	Hydrogen Ion	pH value	7.5	9.5
ZS0811AE	4955342	14/08/2024 12:45	Iron	ug/l Fe	2.1	200
ZS0811AE	4955342	14/08/2024 12:45	Lead	ug Pb/l	<0.095	10
ZS0811AE	4955342	14/08/2024 12:45	Magnesium	mg/l	8.6	
ZS0811AE	4955342	14/08/2024 12:45	Manganese	ug Mn/l	<0.642	50
ZS0811AE	4955342	14/08/2024 12:45	Mercury	ug per l	<0.041	1
ZS0811AE	4955342	14/08/2024 12:45	Nickel	ug Ni/l	1.3	20
ZS0811AE	4955342	14/08/2024 12:45	Odour	Diln No	0	0
ZS0811AE	4955342	14/08/2024 12:45	Odour - Nature		No odour	
ZS0811AE	4955342	14/08/2024 12:45	Potassium	mg/l	3.8	
ZS0811AE	4955342	14/08/2024 12:45	Selenium	ug/l Se	<0.057	10
ZS0811AE	4955342	14/08/2024 12:45	Sodium	mg Na/l	17	200
ZS0811AE	4955342	14/08/2024 12:45	Taste	Diln No	0	0
ZS0811AE	4955342	14/08/2024 12:45	Taste - Nature		No taste	
ZS0811AE	4955342	14/08/2024 12:45	Tetrachloroethene	ug/l	<0.8	
ZS0811AE	4955342	14/08/2024 12:45	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZS0811AE	4955342	14/08/2024 12:45	Tetrachloromethane	ug/l	<0.4	3
ZS0811AE	4955342	14/08/2024 12:45	Total - Residual disinfectant	mg Cl/l	0.62	
ZS0811AE	4955342	14/08/2024 12:45	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4955342	14/08/2024 12:45	Total hardness	mg/l	67	
ZS0811AE	4955342	14/08/2024 12:45	Total Organic Carbon	mg C/l	2.7	
ZS0811AE	4955342	14/08/2024 12:45	Total Trihalomethanes	ug/l	57	100
ZS0811AE	4955342	14/08/2024 12:45	Trichloroethene	ug/l	<0.7	
ZS0811AE	4955342	14/08/2024 12:45	Turbidity	NTU	<0.09	4
ZS0811AE	4955342	14/08/2024 12:45	WHO Index		0.42	1

ZS0809AE	4955562	15/08/2024 09:53	E. coli	CFU/100 ml	0	0
ZS0809AE	4955562	15/08/2024 09:53	Free - Residual disinfectant	mg Cl/l	0.78	
ZS0809AE	4955562	15/08/2024 09:53	Total - Residual disinfectant	mg Cl/l	0.97	
ZS0809AE	4955562	15/08/2024 09:53	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4955574	15/08/2024 10:37	E. coli	CFU/100 ml	0	0
ZS0811AE	4955574	15/08/2024 10:37	Free - Residual disinfectant	mg Cl/l	0.36	
ZS0811AE	4955574	15/08/2024 10:37	Total - Residual disinfectant	mg Cl/l	0.54	
ZS0811AE	4955574	15/08/2024 10:37	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4958099	19/08/2024 09:30	Aluminium	ug Al/l	18	200
ZS0809AE	4958099	19/08/2024 09:30	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZS0809AE	4958099	19/08/2024 09:30	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZS0809AE	4958099	19/08/2024 09:30	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZS0809AE	4958099	19/08/2024 09:30	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZS0809AE	4958099	19/08/2024 09:30	Bromate	ug BrO3/l	<0.50	10
ZS0809AE	4958099	19/08/2024 09:30	Colony Counts 22	CFU/1 ml	0	
ZS0809AE	4958099	19/08/2024 09:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0809AE	4958099	19/08/2024 09:30	Colour	mg/l Pt/Co	<4.56	20
ZS0809AE	4958099	19/08/2024 09:30	Conductivity	uS/cm 20 C	380	2500
ZS0809AE	4958099	19/08/2024 09:30	E. coli	CFU/100 ml	0	0
ZS0809AE	4958099	19/08/2024 09:30	Free - Residual disinfectant	mg Cl/l	0.58	
ZS0809AE	4958099	19/08/2024 09:30	Hydrogen Ion	pH value	7.7	9.5
ZS0809AE	4958099	19/08/2024 09:30	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZS0809AE	4958099	19/08/2024 09:30	Iron	ug/l Fe	1.9	200
ZS0809AE	4958099	19/08/2024 09:30	Manganese	ug Mn/l	<0.80	50
ZS0809AE	4958099	19/08/2024 09:30	Odour	Diln No	0	0
ZS0809AE	4958099	19/08/2024 09:30	Odour - Nature		No odour	
ZS0809AE	4958099	19/08/2024 09:30	PAH - Sum of four substances	ug/l	0	0.1
ZS0809AE	4958099	19/08/2024 09:30	Taste	Diln No	0	0
ZS0809AE	4958099	19/08/2024 09:30	Taste - Nature		No taste	
ZS0809AE	4958099	19/08/2024 09:30	Total - Residual disinfectant	mg Cl/l	0.74	
ZS0809AE	4958099	19/08/2024 09:30	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4958099	19/08/2024 09:30	Turbidity	NTU	0.094	4
ZN0504AE	4958096	19/08/2024 09:48	1,2 Dichloroethane	ug/l	<0.4	3
ZN0504AE	4958096	19/08/2024 09:48	Aluminium	ug Al/l	72	200
ZN0504AE	4958096	19/08/2024 09:48	Benzene	ug/l	<0.15	1
ZN0504AE	4958096	19/08/2024 09:48	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN0504AE	4958096	19/08/2024 09:48	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0504AE	4958096	19/08/2024 09:48	Benzo(ghi)perylene	ug/l	<0.0022	0.1

ZN0504AE	4958096	19/08/2024 09:48	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0504AE	4958096	19/08/2024 09:48	Bromate	ug BrO3/l	0.57	10
ZN0504AE	4958096	19/08/2024 09:48	Colony Counts 22	CFU/1 ml	0	
ZN0504AE	4958096	19/08/2024 09:48	Colony Counts 37 (48hrs)	CFU/1 ml	6	
ZN0504AE	4958096	19/08/2024 09:48	Colour	mg/l Pt/Co	<4.56	20
ZN0504AE	4958096	19/08/2024 09:48	Conductivity	uS/cm 20 C	350	2500
ZN0504AE	4958096	19/08/2024 09:48	E. coli	CFU/100 ml	0	0
ZN0504AE	4958096	19/08/2024 09:48	Free - Residual disinfectant	mg Cl/l	<0.05	
ZN0504AE	4958096	19/08/2024 09:48	Hydrogen Ion	pH value	7.7	9.5
ZN0504AE	4958096	19/08/2024 09:48	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0504AE	4958096	19/08/2024 09:48	Iron	ug/l Fe	490	200
ZN0504AE	4958096	19/08/2024 09:48	Manganese	ug Mn/l	28	50
ZN0504AE	4958096	19/08/2024 09:48	Odour	Diln No	0	0
ZN0504AE	4958096	19/08/2024 09:48	Odour - Nature		No odour	
ZN0504AE	4958096	19/08/2024 09:48	PAH - Sum of four substances	ug/l	0	0.1
ZN0504AE	4958096	19/08/2024 09:48	Taste	Diln No	0	0
ZN0504AE	4958096	19/08/2024 09:48	Taste - Nature		No taste	
ZN0504AE	4958096	19/08/2024 09:48	Tetrachloroethene	ug/l	<0.8	
ZN0504AE	4958096	19/08/2024 09:48	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0504AE	4958096	19/08/2024 09:48	Tetrachloromethane	ug/l	<0.4	3
ZN0504AE	4958096	19/08/2024 09:48	Total - Residual disinfectant	mg Cl/l	<0.05	
ZN0504AE	4958096	19/08/2024 09:48	Total Coliforms	CFU/100 ml	0	0
ZN0504AE	4958096	19/08/2024 09:48	Trichloroethene	ug/l	<0.7	
ZN0504AE	4958096	19/08/2024 09:48	Turbidity	NTU	0.28	4
ZS0811CUST	4970495	19/08/2024 10:00	E. coli	CFU/100 ml	0	0
ZS0811CUST	4970495	19/08/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.65	
ZS0811CUST	4970495	19/08/2024 10:00	Odour	Diln No	0	0
ZS0811CUST	4970495	19/08/2024 10:00	Odour - Nature		No odour	
ZS0811CUST	4970495	19/08/2024 10:00	Taste	Diln No	0	0
ZS0811CUST	4970495	19/08/2024 10:00	Taste - Nature		No taste	
ZS0811CUST	4970495	19/08/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.72	
ZS0811CUST	4970495	19/08/2024 10:00	Total Coliforms	CFU/100 ml	0	0
ZS0811CUST	4970496	19/08/2024 10:15	E. coli	CFU/100 ml	0	0
ZS0811CUST	4970496	19/08/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.71	
ZS0811CUST	4970496	19/08/2024 10:15	Odour	Diln No	0	0
ZS0811CUST	4970496	19/08/2024 10:15	Odour - Nature		No odour	
ZS0811CUST	4970496	19/08/2024 10:15	Taste	Diln No	0	0
ZS0811CUST	4970496	19/08/2024 10:15	Taste - Nature		No taste	

ZS0811CUST	4970496	19/08/2024 10:15	Total - Residual disinfectant	mg Cl/l	0.79	
ZS0811CUST	4970496	19/08/2024 10:15	Total Coliforms	CFU/100 ml	0	0
ZN0706AE	4958122	19/08/2024 10:27	Ammonium	mg NH4/l	<0.01	0.5
ZN0706AE	4958122	19/08/2024 10:27	Antimony	ug/l Sb	0.067	5
ZN0706AE	4958122	19/08/2024 10:27	Arsenic	ug/l As	0.34	10
ZN0706AE	4958122	19/08/2024 10:27	Boron	mg/l B	<0.0586	1
ZN0706AE	4958122	19/08/2024 10:27	Cadmium	ug/l Cd	<0.042	5
ZN0706AE	4958122	19/08/2024 10:27	Chromium	ug/l Cr	0.29	50
ZN0706AE	4958122	19/08/2024 10:27	E. coli	CFU/100 ml	0	0
ZN0706AE	4958122	19/08/2024 10:27	Free - Residual disinfectant	mg Cl/l	0.38	
ZN0706AE	4958122	19/08/2024 10:27	Selenium	ug/l Se	<0.057	10
ZN0706AE	4958122	19/08/2024 10:27	Sodium	mg Na/l	7.9	200
ZN0706AE	4958122	19/08/2024 10:27	Total - Residual disinfectant	mg Cl/l	0.45	
ZN0706AE	4958122	19/08/2024 10:27	Total Coliforms	CFU/100 ml	0	0
ZS0811CUST	4970497	19/08/2024 10:30	E. coli	CFU/100 ml	0	0
ZS0811CUST	4970497	19/08/2024 10:30	Free - Residual disinfectant	mg Cl/l	0.63	
ZS0811CUST	4970497	19/08/2024 10:30	Odour	Diln No	0	0
ZS0811CUST	4970497	19/08/2024 10:30	Odour - Nature		No odour	
ZS0811CUST	4970497	19/08/2024 10:30	Taste	Diln No	0	0
ZS0811CUST	4970497	19/08/2024 10:30	Taste - Nature		No taste	
ZS0811CUST	4970497	19/08/2024 10:30	Total - Residual disinfectant	mg Cl/l	0.7	
ZS0811CUST	4970497	19/08/2024 10:30	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4958150	19/08/2024 10:33	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN0804AE	4958150	19/08/2024 10:33	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0804AE	4958150	19/08/2024 10:33	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0804AE	4958150	19/08/2024 10:33	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0804AE	4958150	19/08/2024 10:33	Bromate	ug BrO3/l	2.2	10
ZN0804AE	4958150	19/08/2024 10:33	E. coli	CFU/100 ml	0	0
ZN0804AE	4958150	19/08/2024 10:33	Free - Residual disinfectant	mg Cl/l	0.16	
ZN0804AE	4958150	19/08/2024 10:33	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0804AE	4958150	19/08/2024 10:33	PAH - Sum of four substances	ug/l	0	0.1
ZN0804AE	4958150	19/08/2024 10:33	Total - Residual disinfectant	mg Cl/l	0.25	
ZN0804AE	4958150	19/08/2024 10:33	Total Coliforms	CFU/100 ml	0	0
ZN0502AE	4958130	19/08/2024 11:04	1,2 Dichloroethane	ug/l	<0.4	3
ZN0502AE	4958130	19/08/2024 11:04	Aluminium	ug Al/l	15	200
ZN0502AE	4958130	19/08/2024 11:04	Ammonium	mg NH4/l	<0.01	0.5
ZN0502AE	4958130	19/08/2024 11:04	Antimony	ug/l Sb	0.076	5
ZN0502AE	4958130	19/08/2024 11:04	Arsenic	ug/l As	0.14	10

ZN0502AE	4958130	19/08/2024 11:04	Benzene	ug/l	<0.15	1
ZN0502AE	4958130	19/08/2024 11:04	Boron	mg/l B	<0.0586	1
ZN0502AE	4958130	19/08/2024 11:04	Bromodichloromethane	ug/l	12	
ZN0502AE	4958130	19/08/2024 11:04	Bromoform	ug/l	<3.5	
ZN0502AE	4958130	19/08/2024 11:04	Cadmium	ug/l Cd	<0.042	5
ZN0502AE	4958130	19/08/2024 11:04	Calcium	mg/l	15	
ZN0502AE	4958130	19/08/2024 11:04	Chloroform	ug/l	60	
ZN0502AE	4958130	19/08/2024 11:04	Chromium	ug/l Cr	<0.260	50
ZN0502AE	4958130	19/08/2024 11:04	Colony Counts 22	CFU/1 ml	0	
ZN0502AE	4958130	19/08/2024 11:04	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0502AE	4958130	19/08/2024 11:04	Colour	mg/l Pt/Co	<4.56	20
ZN0502AE	4958130	19/08/2024 11:04	Conductivity	uS/cm 20 C	120	2500
ZN0502AE	4958130	19/08/2024 11:04	Copper	mg Cu/l	<0.546	2
ZN0502AE	4958130	19/08/2024 11:04	Dibromochloromethane	ug/l	<1.6	
ZN0502AE	4958130	19/08/2024 11:04	E. coli	CFU/100 ml	0	0
ZN0502AE	4958130	19/08/2024 11:04	Enterococci	CFU/100ml	0	0
ZN0502AE	4958130	19/08/2024 11:04	Free - Residual disinfectant	mg Cl/l	0.2	
ZN0502AE	4958130	19/08/2024 11:04	Hydrogen Ion	pH value	7.2	9.5
ZN0502AE	4958130	19/08/2024 11:04	Iron	ug/l Fe	21	200
ZN0502AE	4958130	19/08/2024 11:04	Lead	ug Pb/l	<0.095	10
ZN0502AE	4958130	19/08/2024 11:04	Magnesium	mg/l	2.4	
ZN0502AE	4958130	19/08/2024 11:04	Manganese	ug Mn/l	<0.642	50
ZN0502AE	4958130	19/08/2024 11:04	Mercury	ug per l	<0.041	1
ZN0502AE	4958130	19/08/2024 11:04	Nickel	ug Ni/l	0.68	20
ZN0502AE	4958130	19/08/2024 11:04	Odour	Diln No	0	0
ZN0502AE	4958130	19/08/2024 11:04	Odour - Nature		No odour	
ZN0502AE	4958130	19/08/2024 11:04	Potassium	mg/l	<0.5	
ZN0502AE	4958130	19/08/2024 11:04	Selenium	ug/l Se	<0.057	10
ZN0502AE	4958130	19/08/2024 11:04	Sodium	mg Na/l	5.3	200
ZN0502AE	4958130	19/08/2024 11:04	Taste	Diln No	0	0
ZN0502AE	4958130	19/08/2024 11:04	Taste - Nature		No taste	
ZN0502AE	4958130	19/08/2024 11:04	Tetrachloroethene	ug/l	<0.8	
ZN0502AE	4958130	19/08/2024 11:04	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0502AE	4958130	19/08/2024 11:04	Tetrachloromethane	ug/l	<0.4	3
ZN0502AE	4958130	19/08/2024 11:04	Total - Residual disinfectant	mg Cl/l	0.5	
ZN0502AE	4958130	19/08/2024 11:04	Total Coliforms	CFU/100 ml	0	0
ZN0502AE	4958130	19/08/2024 11:04	Total hardness	mg/l	19	
ZN0502AE	4958130	19/08/2024 11:04	Total Organic Carbon	mg C/l	2.1	

ZN0502AE	4958130	19/08/2024 11:04	Total Trihalomethanes	ug/l	74	100
ZN0502AE	4958130	19/08/2024 11:04	Trichloroethene	ug/l	<0.7	
ZN0502AE	4958130	19/08/2024 11:04	Turbidity	NTU	0.13	4
ZN0502AE	4958130	19/08/2024 11:04	WHO Index		0.42	1
ZN0705AE	4958152	19/08/2024 11:07	Aluminium	ug Al/l	8.9	200
ZN0705AE	4958152	19/08/2024 11:07	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN0705AE	4958152	19/08/2024 11:07	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0705AE	4958152	19/08/2024 11:07	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0705AE	4958152	19/08/2024 11:07	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0705AE	4958152	19/08/2024 11:07	Bromate	ug BrO3/l	1.1	10
ZN0705AE	4958152	19/08/2024 11:07	Colony Counts 22	CFU/1 ml	0	
ZN0705AE	4958152	19/08/2024 11:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0705AE	4958152	19/08/2024 11:07	Colour	mg/l Pt/Co	<4.56	20
ZN0705AE	4958152	19/08/2024 11:07	Conductivity	uS/cm 20 C	120	2500
ZN0705AE	4958152	19/08/2024 11:07	E. coli	CFU/100 ml	0	0
ZN0705AE	4958152	19/08/2024 11:07	Free - Residual disinfectant	mg Cl/l	0.26	
ZN0705AE	4958152	19/08/2024 11:07	Hydrogen Ion	pH value	7.5	9.5
ZN0705AE	4958152	19/08/2024 11:07	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0705AE	4958152	19/08/2024 11:07	Iron	ug/l Fe	9.1	200
ZN0705AE	4958152	19/08/2024 11:07	Manganese	ug Mn/l	<0.80	50
ZN0705AE	4958152	19/08/2024 11:07	Odour	Diln No	0	0
ZN0705AE	4958152	19/08/2024 11:07	Odour - Nature		No odour	
ZN0705AE	4958152	19/08/2024 11:07	PAH - Sum of four substances	ug/l	0	0.1
ZN0705AE	4958152	19/08/2024 11:07	Taste	Diln No	0	0
ZN0705AE	4958152	19/08/2024 11:07	Taste - Nature		No taste	
ZN0705AE	4958152	19/08/2024 11:07	Total - Residual disinfectant	mg Cl/l	0.42	
ZN0705AE	4958152	19/08/2024 11:07	Total Coliforms	CFU/100 ml	0	0
ZN0705AE	4958152	19/08/2024 11:07	Turbidity	NTU	<0.09	4
ZN0501AE	4958126	19/08/2024 11:42	Aluminium	ug Al/l	34	200
ZN0501AE	4958126	19/08/2024 11:42	Colony Counts 22	CFU/1 ml	0	
ZN0501AE	4958126	19/08/2024 11:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0501AE	4958126	19/08/2024 11:42	Colour	mg/l Pt/Co	<4.56	20
ZN0501AE	4958126	19/08/2024 11:42	Conductivity	uS/cm 20 C	370	2500
ZN0501AE	4958126	19/08/2024 11:42	E. coli	CFU/100 ml	0	0
ZN0501AE	4958126	19/08/2024 11:42	Free - Residual disinfectant	mg Cl/l	0.52	
ZN0501AE	4958126	19/08/2024 11:42	Hydrogen Ion	pH value	7.7	9.5
ZN0501AE	4958126	19/08/2024 11:42	Iron	ug/l Fe	<1.538	200
ZN0501AE	4958126	19/08/2024 11:42	Manganese	ug Mn/l	<0.80	50

ZN0501AE	4958126	19/08/2024 11:42	Odour	Diln No	0	0
ZN0501AE	4958126	19/08/2024 11:42	Odour - Nature		No odour	
ZN0501AE	4958126	19/08/2024 11:42	Taste	Diln No	0	0
ZN0501AE	4958126	19/08/2024 11:42	Taste - Nature		No taste	
ZN0501AE	4958126	19/08/2024 11:42	Total - Residual disinfectant	mg Cl/l	0.76	
ZN0501AE	4958126	19/08/2024 11:42	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4958126	19/08/2024 11:42	Turbidity	NTU	<0.09	4
ZN0502AE	4958415	20/08/2024 10:09	Aluminium	ug Al/l	13	200
ZN0502AE	4958415	20/08/2024 10:09	Colony Counts 22	CFU/1 ml	0	
ZN0502AE	4958415	20/08/2024 10:09	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0502AE	4958415	20/08/2024 10:09	Colour	mg/l Pt/Co	<4.56	20
ZN0502AE	4958415	20/08/2024 10:09	Conductivity	uS/cm 20 C	120	2500
ZN0502AE	4958415	20/08/2024 10:09	Free - Residual disinfectant	mg Cl/l	0.21	
ZN0502AE	4958415	20/08/2024 10:09	Hydrogen Ion	pH value	7.4	9.5
ZN0502AE	4958415	20/08/2024 10:09	Iron	ug/l Fe	3	200
ZN0502AE	4958415	20/08/2024 10:09	Manganese	ug Mn/l	<0.80	50
ZN0502AE	4958415	20/08/2024 10:09	Odour	Diln No	0	0
ZN0502AE	4958415	20/08/2024 10:09	Odour - Nature		No odour	
ZN0502AE	4958415	20/08/2024 10:09	Taste	Diln No	0	0
ZN0502AE	4958415	20/08/2024 10:09	Taste - Nature		No taste	
ZN0502AE	4958415	20/08/2024 10:09	Total - Residual disinfectant	mg Cl/l	0.25	
ZN0502AE	4958415	20/08/2024 10:09	Turbidity	NTU	<0.09	4
ZN0501AE	4958412	20/08/2024 10:15	Antimony	ug/l Sb	0.16	5
ZN0501AE	4958412	20/08/2024 10:15	Arsenic	ug/l As	0.26	10
ZN0501AE	4958412	20/08/2024 10:15	Boron	mg/l B	<0.0586	1
ZN0501AE	4958412	20/08/2024 10:15	Cadmium	ug/l Cd	<0.042	5
ZN0501AE	4958412	20/08/2024 10:15	Chromium	ug/l Cr	0.33	50
ZN0501AE	4958412	20/08/2024 10:15	E. coli	CFU/100 ml	0	0
ZN0501AE	4958412	20/08/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.1	
ZN0501AE	4958412	20/08/2024 10:15	Selenium	ug/l Se	0.064	10
ZN0501AE	4958412	20/08/2024 10:15	Total - Residual disinfectant	mg Cl/l	0.14	
ZN0501AE	4958412	20/08/2024 10:15	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4958129	20/08/2024 11:30	Aluminium	ug Al/l	24	200
ZN0102AE	4958129	20/08/2024 11:30	Colony Counts 22	CFU/1 ml	0	
ZN0102AE	4958129	20/08/2024 11:30	Colony Counts 37 (48hrs)	CFU/1 ml	1	
ZN0102AE	4958129	20/08/2024 11:30	Colour	mg/l Pt/Co	<4.56	20
ZN0102AE	4958129	20/08/2024 11:30	Conductivity	uS/cm 20 C	340	2500
ZN0102AE	4958129	20/08/2024 11:30	E. coli	CFU/100 ml	0	0

ZN0102AE	4958129	20/08/2024 11:30	Free - Residual disinfectant	mg Cl/l	0.33	
ZN0102AE	4958129	20/08/2024 11:30	Hydrogen Ion	pH value	7.7	9.5
ZN0102AE	4958129	20/08/2024 11:30	Iron	ug/l Fe	4.9	200
ZN0102AE	4958129	20/08/2024 11:30	Manganese	ug Mn/l	1.5	50
ZN0102AE	4958129	20/08/2024 11:30	Odour	Diln No	0	0
ZN0102AE	4958129	20/08/2024 11:30	Odour - Nature		No odour	
ZN0102AE	4958129	20/08/2024 11:30	Taste	Diln No	0	0
ZN0102AE	4958129	20/08/2024 11:30	Taste - Nature		No taste	
ZN0102AE	4958129	20/08/2024 11:30	Total - Residual disinfectant	mg Cl/l	0.44	
ZN0102AE	4958129	20/08/2024 11:30	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4958129	20/08/2024 11:30	Turbidity	NTU	0.09	4
ZN0706CUST	4972392	21/08/2024 08:50	E. coli	CFU/100 ml	0	0
ZN0706CUST	4972392	21/08/2024 08:50	Odour	Diln No	0	0
ZN0706CUST	4972392	21/08/2024 08:50	Odour - Nature		No odour	
ZN0706CUST	4972392	21/08/2024 08:50	Taste	Diln No	0	0
ZN0706CUST	4972392	21/08/2024 08:50	Taste - Nature		No taste	
ZN0706CUST	4972392	21/08/2024 08:50	Total Coliforms	CFU/100 ml	0	0
ZN0706CUST	4972383	21/08/2024 08:50	E. coli	CFU/100 ml	0	0
ZN0706CUST	4972383	21/08/2024 08:50	Free - Residual disinfectant	mg Cl/l	0.08	
ZN0706CUST	4972383	21/08/2024 08:50	Odour	Diln No	0	0
ZN0706CUST	4972383	21/08/2024 08:50	Odour - Nature		No odour	
ZN0706CUST	4972383	21/08/2024 08:50	Taste	Diln No	0	0
ZN0706CUST	4972383	21/08/2024 08:50	Taste - Nature		No taste	
ZN0706CUST	4972383	21/08/2024 08:50	Total - Residual disinfectant	mg Cl/l	0.28	
ZN0706CUST	4972383	21/08/2024 08:50	Total Coliforms	CFU/100 ml	0	0
ZN0706CUST	4972393	21/08/2024 08:50	E. coli	CFU/100 ml	0	0
ZN0706CUST	4972393	21/08/2024 08:50	Odour	Diln No	0	0
ZN0706CUST	4972393	21/08/2024 08:50	Odour - Nature		No odour	
ZN0706CUST	4972393	21/08/2024 08:50	Taste	Diln No	0	0
ZN0706CUST	4972393	21/08/2024 08:50	Taste - Nature		No taste	
ZN0706CUST	4972393	21/08/2024 08:50	Total Coliforms	CFU/100 ml	0	0
ZN0706CUST	4972394	21/08/2024 08:50	E. coli	CFU/100 ml	0	0
ZN0706CUST	4972394	21/08/2024 08:50	Odour	Diln No	10	0
ZN0706CUST	4972394	21/08/2024 08:50	Odour - Nature		Petrochemical	
ZN0706CUST	4972394	21/08/2024 08:50	Taste - Nature		is performed due to odour contravention	
ZN0706CUST	4972394	21/08/2024 08:50	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4955343	21/08/2024 09:25	1,2 Dichloroethane	ug/l	<0.4	3
ZN0804AE	4955343	21/08/2024 09:25	Ammonium	mg NH4/l	<0.01	0.5

ZN0804AE	4955343	21/08/2024 09:25	Benzene	ug/l	<0.15	1
ZN0804AE	4955343	21/08/2024 09:25	Bromodichloromethane	ug/l	18	
ZN0804AE	4955343	21/08/2024 09:25	Bromoform	ug/l	<3.5	
ZN0804AE	4955343	21/08/2024 09:25	Calcium	mg/l	50	
ZN0804AE	4955343	21/08/2024 09:25	Chloroform	ug/l	64	
ZN0804AE	4955343	21/08/2024 09:25	Copper	mg Cu/l	<0.546	2
ZN0804AE	4955343	21/08/2024 09:25	Dibromochloromethane	ug/l	4.5	
ZN0804AE	4955343	21/08/2024 09:25	E. coli	CFU/100 ml	0	0
ZN0804AE	4955343	21/08/2024 09:25	Enterococci	CFU/100ml	0	0
ZN0804AE	4955343	21/08/2024 09:25	Free - Residual disinfectant	mg Cl/l	0.24	
ZN0804AE	4955343	21/08/2024 09:25	Lead	ug Pb/l	<0.095	10
ZN0804AE	4955343	21/08/2024 09:25	Magnesium	mg/l	3.8	
ZN0804AE	4955343	21/08/2024 09:25	Mercury	ug per l	<0.041	1
ZN0804AE	4955343	21/08/2024 09:25	Nickel	ug Ni/l	0.75	20
ZN0804AE	4955343	21/08/2024 09:25	Potassium	mg/l	2.4	
ZN0804AE	4955343	21/08/2024 09:25	Sodium	mg Na/l	39	200
ZN0804AE	4955343	21/08/2024 09:25	Tetrachloroethene	ug/l	<0.8	
ZN0804AE	4955343	21/08/2024 09:25	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0804AE	4955343	21/08/2024 09:25	Tetrachloromethane	ug/l	<0.4	3
ZN0804AE	4955343	21/08/2024 09:25	Total - Residual disinfectant	mg Cl/l	0.31	
ZN0804AE	4955343	21/08/2024 09:25	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4955343	21/08/2024 09:25	Total hardness	mg/l	56	
ZN0804AE	4955343	21/08/2024 09:25	Total Organic Carbon	mg C/l	2.6	
ZN0804AE	4955343	21/08/2024 09:25	Total Trihalomethanes	ug/l	87	100
ZN0804AE	4955343	21/08/2024 09:25	Trichloroethene	ug/l	<0.7	
ZN0804AE	4955343	21/08/2024 09:25	WHO Index		0.56	1
ZN1102AE	4958390	21/08/2024 09:52	Aluminium	ug Al/l	11	200
ZN1102AE	4958390	21/08/2024 09:52	Colony Counts 22	CFU/1 ml	0	
ZN1102AE	4958390	21/08/2024 09:52	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN1102AE	4958390	21/08/2024 09:52	Colour	mg/l Pt/Co	<4.56	20
ZN1102AE	4958390	21/08/2024 09:52	Conductivity	uS/cm 20 C	400	2500
ZN1102AE	4958390	21/08/2024 09:52	E. coli	CFU/100 ml	0	0
ZN1102AE	4958390	21/08/2024 09:52	Free - Residual disinfectant	mg Cl/l	0.6	
ZN1102AE	4958390	21/08/2024 09:52	Hydrogen Ion	pH value	7.3	9.5
ZN1102AE	4958390	21/08/2024 09:52	Iron	ug/l Fe	<1.538	200
ZN1102AE	4958390	21/08/2024 09:52	Manganese	ug Mn/l	<0.80	50
ZN1102AE	4958390	21/08/2024 09:52	Odour	Diln No	0	0
ZN1102AE	4958390	21/08/2024 09:52	Odour - Nature		No odour	

ZN1102AE	4958390	21/08/2024 09:52	Taste	Diln No	0	0
ZN1102AE	4958390	21/08/2024 09:52	Taste - Nature		No taste	
ZN1102AE	4958390	21/08/2024 09:52	Total - Residual disinfectant	mg Cl/l	0.76	
ZN1102AE	4958390	21/08/2024 09:52	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4958390	21/08/2024 09:52	Turbidity	NTU	0.095	4
ZN0504AE	4958386	21/08/2024 09:54	Aluminium	ug Al/l	21	200
ZN0504AE	4958386	21/08/2024 09:54	Colony Counts 22	CFU/1 ml	0	
ZN0504AE	4958386	21/08/2024 09:54	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0504AE	4958386	21/08/2024 09:54	Colour	mg/l Pt/Co	<4.56	20
ZN0504AE	4958386	21/08/2024 09:54	Conductivity	uS/cm 20 C	260	2500
ZN0504AE	4958386	21/08/2024 09:54	E. coli	CFU/100 ml	0	0
ZN0504AE	4958386	21/08/2024 09:54	Free - Residual disinfectant	mg Cl/l	<0.05	
ZN0504AE	4958386	21/08/2024 09:54	Hydrogen Ion	pH value	7.4	9.5
ZN0504AE	4958386	21/08/2024 09:54	Iron	ug/l Fe	70	200
ZN0504AE	4958386	21/08/2024 09:54	Manganese	ug Mn/l	3.3	50
ZN0504AE	4958386	21/08/2024 09:54	Odour	Diln No	0	0
ZN0504AE	4958386	21/08/2024 09:54	Odour - Nature		No odour	
ZN0504AE	4958386	21/08/2024 09:54	Taste	Diln No	0	0
ZN0504AE	4958386	21/08/2024 09:54	Taste - Nature		No taste	
ZN0504AE	4958386	21/08/2024 09:54	Total - Residual disinfectant	mg Cl/l	0.16	
ZN0504AE	4958386	21/08/2024 09:54	Total Coliforms	CFU/100 ml	0	0
ZN0504AE	4958386	21/08/2024 09:54	Turbidity	NTU	0.24	4
ZS0811AE	4958431	21/08/2024 10:42	Aluminium	ug Al/l	13	200
ZS0811AE	4958431	21/08/2024 10:42	Colony Counts 22	CFU/1 ml	0	
ZS0811AE	4958431	21/08/2024 10:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0811AE	4958431	21/08/2024 10:42	Colour	mg/l Pt/Co	<4.56	20
ZS0811AE	4958431	21/08/2024 10:42	Conductivity	uS/cm 20 C	380	2500
ZS0811AE	4958431	21/08/2024 10:42	E. coli	CFU/100 ml	0	0
ZS0811AE	4958431	21/08/2024 10:42	Free - Residual disinfectant	mg Cl/l	0.19	
ZS0811AE	4958431	21/08/2024 10:42	Hydrogen Ion	pH value	7.5	9.5
ZS0811AE	4958431	21/08/2024 10:42	Iron	ug/l Fe	<1.538	200
ZS0811AE	4958431	21/08/2024 10:42	Manganese	ug Mn/l	<0.80	50
ZS0811AE	4958431	21/08/2024 10:42	Odour	Diln No	0	0
ZS0811AE	4958431	21/08/2024 10:42	Odour - Nature		No odour	
ZS0811AE	4958431	21/08/2024 10:42	Taste	Diln No	0	0
ZS0811AE	4958431	21/08/2024 10:42	Taste - Nature		No taste	
ZS0811AE	4958431	21/08/2024 10:42	Total - Residual disinfectant	mg Cl/l	0.51	
ZS0811AE	4958431	21/08/2024 10:42	Total Coliforms	CFU/100 ml	0	0

ZS0811AE	4958431	21/08/2024 10:42	Turbidity	NTU	0.12	4
ZN0705AE	4958433	21/08/2024 10:45	Aluminium	ug Al/l	16	200
ZN0705AE	4958433	21/08/2024 10:45	Colony Counts 22	CFU/1 ml	0	
ZN0705AE	4958433	21/08/2024 10:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0705AE	4958433	21/08/2024 10:45	Colour	mg/l Pt/Co	<4.56	20
ZN0705AE	4958433	21/08/2024 10:45	Conductivity	uS/cm 20 C	170	2500
ZN0705AE	4958433	21/08/2024 10:45	E. coli	CFU/100 ml	0	0
ZN0705AE	4958433	21/08/2024 10:45	Free - Residual disinfectant	mg Cl/l	0.43	
ZN0705AE	4958433	21/08/2024 10:45	Hydrogen Ion	pH value	7.5	9.5
ZN0705AE	4958433	21/08/2024 10:45	Iron	ug/l Fe	5.4	200
ZN0705AE	4958433	21/08/2024 10:45	Manganese	ug Mn/l	0.92	50
ZN0705AE	4958433	21/08/2024 10:45	Odour	Diln No	0	0
ZN0705AE	4958433	21/08/2024 10:45	Odour - Nature		No odour	
ZN0705AE	4958433	21/08/2024 10:45	Taste	Diln No	0	0
ZN0705AE	4958433	21/08/2024 10:45	Taste - Nature		No taste	
ZN0705AE	4958433	21/08/2024 10:45	Total - Residual disinfectant	mg Cl/l	0.6	
ZN0705AE	4958433	21/08/2024 10:45	Total Coliforms	CFU/100 ml	0	0
ZN0705AE	4958433	21/08/2024 10:45	Turbidity	NTU	<0.09	4
ZN0102AE	4958414	22/08/2024 09:30	E. coli	CFU/100 ml	0	0
ZN0102AE	4958414	22/08/2024 09:30	Free - Residual disinfectant	mg Cl/l	0.39	
ZN0102AE	4958414	22/08/2024 09:30	Mercury	ug per l	<0.041	1
ZN0102AE	4958414	22/08/2024 09:30	Odour	Diln No	0	0
ZN0102AE	4958414	22/08/2024 09:30	Odour - Nature		No odour	
ZN0102AE	4958414	22/08/2024 09:30	Taste	Diln No	0	0
ZN0102AE	4958414	22/08/2024 09:30	Taste - Nature		No taste	
ZN0102AE	4958414	22/08/2024 09:30	Total - Residual disinfectant	mg Cl/l	0.53	
ZN0102AE	4958414	22/08/2024 09:30	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4958149	22/08/2024 09:33	E. coli	CFU/100 ml	0	0
ZS0811AE	4958149	22/08/2024 09:33	Free - Residual disinfectant	mg Cl/l	0.27	
ZS0811AE	4958149	22/08/2024 09:33	Total - Residual disinfectant	mg Cl/l	0.49	
ZS0811AE	4958149	22/08/2024 09:33	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4958389	22/08/2024 10:14	Aluminium	ug Al/l	20	200
ZS0809AE	4958389	22/08/2024 10:14	E. coli	CFU/100 ml	0	0
ZS0809AE	4958389	22/08/2024 10:14	Free - Residual disinfectant	mg Cl/l	1.04	
ZS0809AE	4958389	22/08/2024 10:14	Iron	ug/l Fe	10	200
ZS0809AE	4958389	22/08/2024 10:14	Manganese	ug Mn/l	<0.80	50
ZS0809AE	4958389	22/08/2024 10:14	Total - Residual disinfectant	mg Cl/l	1.27	
ZS0809AE	4958389	22/08/2024 10:14	Total Coliforms	CFU/100 ml	0	0

ZN1102AE	4958100	22/08/2024 11:19	Ammonium	mg NH4/l	<0.01	0.5
ZN1102AE	4958100	22/08/2024 11:19	E. coli	CFU/100 ml	0	0
ZN1102AE	4958100	22/08/2024 11:19	Free - Residual disinfectant	mg Cl/l	0.25	
ZN1102AE	4958100	22/08/2024 11:19	Sodium	mg Na/l	19	200
ZN1102AE	4958100	22/08/2024 11:19	Total - Residual disinfectant	mg Cl/l	0.46	
ZN1102AE	4958100	22/08/2024 11:19	Total Coliforms	CFU/100 ml	0	0
ZN0706CUST	4972861	23/08/2024 10:00	Aluminium	ug Al/l	16	200
ZN0706CUST	4972861	23/08/2024 10:00	Colour	mg/l Pt/Co	<4.56	20
ZN0706CUST	4972861	23/08/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.44	
ZN0706CUST	4972861	23/08/2024 10:00	Hydrogen Ion	pH value	7.6	9.5
ZN0706CUST	4972861	23/08/2024 10:00	Iron	ug/l Fe	6.5	200
ZN0706CUST	4972861	23/08/2024 10:00	Lead	ug Pb/l	<0.095	10
ZN0706CUST	4972861	23/08/2024 10:00	Manganese	ug Mn/l	<0.642	50
ZN0706CUST	4972861	23/08/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.5	
ZN0706CUST	4972861	23/08/2024 10:00	Turbidity	NTU	<0.09	4
ZN0706CUST	4972863	23/08/2024 10:15	Aluminium	ug Al/l	16	200
ZN0706CUST	4972863	23/08/2024 10:15	Colour	mg/l Pt/Co	<4.56	20
ZN0706CUST	4972863	23/08/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.47	
ZN0706CUST	4972863	23/08/2024 10:15	Hydrogen Ion	pH value	7.6	9.5
ZN0706CUST	4972863	23/08/2024 10:15	Iron	ug/l Fe	5.6	200
ZN0706CUST	4972863	23/08/2024 10:15	Lead	ug Pb/l	<0.095	10
ZN0706CUST	4972863	23/08/2024 10:15	Manganese	ug Mn/l	<0.642	50
ZN0706CUST	4972863	23/08/2024 10:15	Total - Residual disinfectant	mg Cl/l	0.51	
ZN0706CUST	4972863	23/08/2024 10:15	Turbidity	NTU	<0.09	4
ZN0706CUST	4972864	23/08/2024 10:30	Aluminium	ug Al/l	18	200
ZN0706CUST	4972864	23/08/2024 10:30	Colour	mg/l Pt/Co	<4.56	20
ZN0706CUST	4972864	23/08/2024 10:30	Free - Residual disinfectant	mg Cl/l	0.45	
ZN0706CUST	4972864	23/08/2024 10:30	Hydrogen Ion	pH value	7.6	9.5
ZN0706CUST	4972864	23/08/2024 10:30	Iron	ug/l Fe	13	200
ZN0706CUST	4972864	23/08/2024 10:30	Lead	ug Pb/l	0.13	10
ZN0706CUST	4972864	23/08/2024 10:30	Manganese	ug Mn/l	1.9	50
ZN0706CUST	4972864	23/08/2024 10:30	Total - Residual disinfectant	mg Cl/l	0.5	
ZN0706CUST	4972864	23/08/2024 10:30	Turbidity	NTU	<0.09	4
ZN0706CUST	4972865	23/08/2024 10:45	Aluminium	ug Al/l	17	200
ZN0706CUST	4972865	23/08/2024 10:45	Colour	mg/l Pt/Co	<4.56	20
ZN0706CUST	4972865	23/08/2024 10:45	Free - Residual disinfectant	mg Cl/l	0.46	
ZN0706CUST	4972865	23/08/2024 10:45	Hydrogen Ion	pH value	7.6	9.5
ZN0706CUST	4972865	23/08/2024 10:45	Iron	ug/l Fe	9.4	200

ZN0706CUST	4972865	23/08/2024 10:45	Lead	ug Pb/l	0.13	10
ZN0706CUST	4972865	23/08/2024 10:45	Manganese	ug Mn/l	0.8	50
ZN0706CUST	4972865	23/08/2024 10:45	Total - Residual disinfectant	mg Cl/l	0.52	
ZN0706CUST	4972865	23/08/2024 10:45	Turbidity	NTU	<0.09	4
ZN0501CUST	4974467	27/08/2024 09:00	Aluminium	ug Al/l	27	200
ZN0501CUST	4974467	27/08/2024 09:00	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4974467	27/08/2024 09:00	E. coli	CFU/100 ml	0	0
ZN0501CUST	4974467	27/08/2024 09:00	Free - Residual disinfectant	mg Cl/l	0.09	
ZN0501CUST	4974467	27/08/2024 09:00	Hydrogen Ion	pH value	7.7	9.5
ZN0501CUST	4974467	27/08/2024 09:00	Iron	ug/l Fe	<1.538	200
ZN0501CUST	4974467	27/08/2024 09:00	Manganese	ug Mn/l	<0.642	50
ZN0501CUST	4974467	27/08/2024 09:00	Odour	Diln No	0	0
ZN0501CUST	4974467	27/08/2024 09:00	Odour - Nature		No odour	
ZN0501CUST	4974467	27/08/2024 09:00	Taste	Diln No	0	0
ZN0501CUST	4974467	27/08/2024 09:00	Taste - Nature		No taste	
ZN0501CUST	4974467	27/08/2024 09:00	Total - Residual disinfectant	mg Cl/l	0.12	
ZN0501CUST	4974467	27/08/2024 09:00	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4974467	27/08/2024 09:00	Turbidity	NTU	0.1	4
ZN0502AE	4961264	27/08/2024 09:24	E. coli	CFU/100 ml	0	0
ZN0502AE	4961264	27/08/2024 09:24	Free - Residual disinfectant	mg Cl/l	0.52	
ZN0502AE	4961264	27/08/2024 09:24	Total - Residual disinfectant	mg Cl/l	0.61	
ZN0502AE	4961264	27/08/2024 09:24	Total Coliforms	CFU/100 ml	0	0
ZN0706AE	4961256	27/08/2024 09:41	Aluminium	ug Al/l	12	200
ZN0706AE	4961256	27/08/2024 09:41	Colony Counts 22	CFU/1 ml	0	
ZN0706AE	4961256	27/08/2024 09:41	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0706AE	4961256	27/08/2024 09:41	Colour	mg/l Pt/Co	<4.56	20
ZN0706AE	4961256	27/08/2024 09:41	Conductivity	uS/cm 20 C	180	2500
ZN0706AE	4961256	27/08/2024 09:41	E. coli	CFU/100 ml	0	0
ZN0706AE	4961256	27/08/2024 09:41	Free - Residual disinfectant	mg Cl/l	0.16	
ZN0706AE	4961256	27/08/2024 09:41	Hydrogen Ion	pH value	7.6	9.5
ZN0706AE	4961256	27/08/2024 09:41	Iron	ug/l Fe	9.7	200
ZN0706AE	4961256	27/08/2024 09:41	Manganese	ug Mn/l	0.8	50
ZN0706AE	4961256	27/08/2024 09:41	Odour	Diln No	0	0
ZN0706AE	4961256	27/08/2024 09:41	Odour - Nature		No odour	
ZN0706AE	4961256	27/08/2024 09:41	Taste	Diln No	0	0
ZN0706AE	4961256	27/08/2024 09:41	Taste - Nature		No taste	
ZN0706AE	4961256	27/08/2024 09:41	Total - Residual disinfectant	mg Cl/l	0.24	
ZN0706AE	4961256	27/08/2024 09:41	Total Coliforms	CFU/100 ml	0	0

ZN0706AE	4961256	27/08/2024 09:41	Turbidity	NTU	<0.09	4
ZS0809AE	4961233	27/08/2024 10:29	Aluminium	ug Al/l	17	200
ZS0809AE	4961233	27/08/2024 10:29	Colony Counts 22	CFU/1 ml	0	
ZS0809AE	4961233	27/08/2024 10:29	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0809AE	4961233	27/08/2024 10:29	Colour	mg/l Pt/Co	<4.56	20
ZS0809AE	4961233	27/08/2024 10:29	Conductivity	uS/cm 20 C	380	2500
ZS0809AE	4961233	27/08/2024 10:29	E. coli	CFU/100 ml	0	0
ZS0809AE	4961233	27/08/2024 10:29	Free - Residual disinfectant	mg Cl/l	0.21	
ZS0809AE	4961233	27/08/2024 10:29	Hydrogen Ion	pH value	7.6	9.5
ZS0809AE	4961233	27/08/2024 10:29	Iron	ug/l Fe	3.2	200
ZS0809AE	4961233	27/08/2024 10:29	Manganese	ug Mn/l	<0.80	50
ZS0809AE	4961233	27/08/2024 10:29	Odour	Diln No	0	0
ZS0809AE	4961233	27/08/2024 10:29	Odour - Nature		No odour	
ZS0809AE	4961233	27/08/2024 10:29	Taste	Diln No	0	0
ZS0809AE	4961233	27/08/2024 10:29	Taste - Nature		No taste	
ZS0809AE	4961233	27/08/2024 10:29	Total - Residual disinfectant	mg Cl/l	0.44	
ZS0809AE	4961233	27/08/2024 10:29	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4961233	27/08/2024 10:29	Turbidity	NTU	<0.09	4
ZS0811AE	4961283	27/08/2024 11:10	Aluminium	ug Al/l	19	200
ZS0811AE	4961283	27/08/2024 11:10	Colony Counts 22	CFU/1 ml	0	
ZS0811AE	4961283	27/08/2024 11:10	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0811AE	4961283	27/08/2024 11:10	Colour	mg/l Pt/Co	<4.56	20
ZS0811AE	4961283	27/08/2024 11:10	Conductivity	uS/cm 20 C	370	2500
ZS0811AE	4961283	27/08/2024 11:10	E. coli	CFU/100 ml	0	0
ZS0811AE	4961283	27/08/2024 11:10	Free - Residual disinfectant	mg Cl/l	0.25	
ZS0811AE	4961283	27/08/2024 11:10	Hydrogen Ion	pH value	7.6	9.5
ZS0811AE	4961283	27/08/2024 11:10	Iron	ug/l Fe	13	200
ZS0811AE	4961283	27/08/2024 11:10	Manganese	ug Mn/l	<0.80	50
ZS0811AE	4961283	27/08/2024 11:10	Odour	Diln No	0	0
ZS0811AE	4961283	27/08/2024 11:10	Odour - Nature		No odour	
ZS0811AE	4961283	27/08/2024 11:10	Taste	Diln No	0	0
ZS0811AE	4961283	27/08/2024 11:10	Taste - Nature		No taste	
ZS0811AE	4961283	27/08/2024 11:10	Total - Residual disinfectant	mg Cl/l	0.46	
ZS0811AE	4961283	27/08/2024 11:10	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4961283	27/08/2024 11:10	Turbidity	NTU	<0.09	4
ZN0102AE	4961263	27/08/2024 11:55	Aluminium	ug Al/l	14	200
ZN0102AE	4961263	27/08/2024 11:55	Colony Counts 22	CFU/1 ml	0	
ZN0102AE	4961263	27/08/2024 11:55	Colony Counts 37 (48hrs)	CFU/1 ml	1	

ZN0102AE	4961263	27/08/2024 11:55	Colour	mg/l Pt/Co	<4.56	20
ZN0102AE	4961263	27/08/2024 11:55	Conductivity	uS/cm 20 C	330	2500
ZN0102AE	4961263	27/08/2024 11:55	E. coli	CFU/100 ml	0	0
ZN0102AE	4961263	27/08/2024 11:55	Free - Residual disinfectant	mg Cl/l	0.19	
ZN0102AE	4961263	27/08/2024 11:55	Hydrogen Ion	pH value	7.7	9.5
ZN0102AE	4961263	27/08/2024 11:55	Iron	ug/l Fe	47	200
ZN0102AE	4961263	27/08/2024 11:55	Manganese	ug Mn/l	3.9	50
ZN0102AE	4961263	27/08/2024 11:55	Odour	Diln No	0	0
ZN0102AE	4961263	27/08/2024 11:55	Odour - Nature		No odour	
ZN0102AE	4961263	27/08/2024 11:55	Taste	Diln No	0	0
ZN0102AE	4961263	27/08/2024 11:55	Taste - Nature		No taste	
ZN0102AE	4961263	27/08/2024 11:55	Total - Residual disinfectant	mg Cl/l	0.3	
ZN0102AE	4961263	27/08/2024 11:55	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4961263	27/08/2024 11:55	Turbidity	NTU	0.11	4
ZN0706CUST	4974748	28/08/2024 08:50	E. coli	CFU/100 ml	0	0
ZN0706CUST	4974748	28/08/2024 08:50	Free - Residual disinfectant	mg Cl/l	0.28	
ZN0706CUST	4974748	28/08/2024 08:50	Odour	Diln No	10	0
ZN0706CUST	4974748	28/08/2024 08:50	Odour - Nature		Petrochemical	
ZN0706CUST	4974748	28/08/2024 08:50	Taste	Diln No	99	0
ZN0706CUST	4974748	28/08/2024 08:50	Taste - Nature		is performed due to odour contravention	
ZN0706CUST	4974748	28/08/2024 08:50	Total - Residual disinfectant	mg Cl/l	0.39	
ZN0706CUST	4974748	28/08/2024 08:50	Total Coliforms	CFU/100 ml	0	0
ZN0706CUST	4974746	28/08/2024 09:00	E. coli	CFU/100 ml	0	0
ZN0706CUST	4974746	28/08/2024 09:00	Free - Residual disinfectant	mg Cl/l	0.27	
ZN0706CUST	4974746	28/08/2024 09:00	Odour	Diln No	0	0
ZN0706CUST	4974746	28/08/2024 09:00	Odour - Nature		No odour	
ZN0706CUST	4974746	28/08/2024 09:00	Taste	Diln No	0	0
ZN0706CUST	4974746	28/08/2024 09:00	Taste - Nature		No taste	
ZN0706CUST	4974746	28/08/2024 09:00	Total - Residual disinfectant	mg Cl/l	0.38	
ZN0706CUST	4974746	28/08/2024 09:00	Total Coliforms	CFU/100 ml	0	0
ZN0706CUST	4974745	28/08/2024 09:10	E. coli	CFU/100 ml	0	0
ZN0706CUST	4974745	28/08/2024 09:10	Free - Residual disinfectant	mg Cl/l	0.26	
ZN0706CUST	4974745	28/08/2024 09:10	Odour	Diln No	0	0
ZN0706CUST	4974745	28/08/2024 09:10	Odour - Nature		No odour	
ZN0706CUST	4974745	28/08/2024 09:10	Taste	Diln No	0	0
ZN0706CUST	4974745	28/08/2024 09:10	Taste - Nature		No taste	
ZN0706CUST	4974745	28/08/2024 09:10	Total - Residual disinfectant	mg Cl/l	0.38	
ZN0706CUST	4974745	28/08/2024 09:10	Total Coliforms	CFU/100 ml	0	0

ZN0706CUST	4974737	28/08/2024 09:20	E. coli	CFU/100 ml	0	0
ZN0706CUST	4974737	28/08/2024 09:20	Free - Residual disinfectant	mg Cl/l	0.28	
ZN0706CUST	4974737	28/08/2024 09:20	Odour	Diln No	0	0
ZN0706CUST	4974737	28/08/2024 09:20	Odour - Nature		No odour	
ZN0706CUST	4974737	28/08/2024 09:20	Taste	Diln No	0	0
ZN0706CUST	4974737	28/08/2024 09:20	Taste - Nature		No taste	
ZN0706CUST	4974737	28/08/2024 09:20	Total - Residual disinfectant	mg Cl/l	0.39	
ZN0706CUST	4974737	28/08/2024 09:20	Total Coliforms	CFU/100 ml	0	0
ZN0706CUST	4974747	28/08/2024 09:30	E. coli	CFU/100 ml	0	0
ZN0706CUST	4974747	28/08/2024 09:30	Free - Residual disinfectant	mg Cl/l	0.2	
ZN0706CUST	4974747	28/08/2024 09:30	Odour	Diln No	0	0
ZN0706CUST	4974747	28/08/2024 09:30	Odour - Nature		No odour	
ZN0706CUST	4974747	28/08/2024 09:30	Taste	Diln No	0	0
ZN0706CUST	4974747	28/08/2024 09:30	Taste - Nature		No taste	
ZN0706CUST	4974747	28/08/2024 09:30	Total - Residual disinfectant	mg Cl/l	0.3	
ZN0706CUST	4974747	28/08/2024 09:30	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4958432	28/08/2024 09:50	Aluminium	ug Al/l	31	200
ZN0804AE	4958432	28/08/2024 09:50	Colony Counts 22	CFU/1 ml	0	
ZN0804AE	4958432	28/08/2024 09:50	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0804AE	4958432	28/08/2024 09:50	Colour	mg/l Pt/Co	<4.56	20
ZN0804AE	4958432	28/08/2024 09:50	Conductivity	uS/cm 20 C	410	2500
ZN0804AE	4958432	28/08/2024 09:50	E. coli	CFU/100 ml	0	0
ZN0804AE	4958432	28/08/2024 09:50	Free - Residual disinfectant	mg Cl/l	0.6	
ZN0804AE	4958432	28/08/2024 09:50	Hydrogen Ion	pH value	7.9	9.5
ZN0804AE	4958432	28/08/2024 09:50	Iron	ug/l Fe	4.8	200
ZN0804AE	4958432	28/08/2024 09:50	Manganese	ug Mn/l	0.94	50
ZN0804AE	4958432	28/08/2024 09:50	Odour	Diln No	0	0
ZN0804AE	4958432	28/08/2024 09:50	Odour - Nature		No odour	
ZN0804AE	4958432	28/08/2024 09:50	Taste	Diln No	0	0
ZN0804AE	4958432	28/08/2024 09:50	Taste - Nature		No taste	
ZN0804AE	4958432	28/08/2024 09:50	Total - Residual disinfectant	mg Cl/l	0.92	
ZN0804AE	4958432	28/08/2024 09:50	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4958432	28/08/2024 09:50	Turbidity	NTU	<0.09	4
ZN0501AE	4961259	28/08/2024 10:30	Aluminium	ug Al/l	26	200
ZN0501AE	4961259	28/08/2024 10:30	Colony Counts 22	CFU/1 ml	0	
ZN0501AE	4961259	28/08/2024 10:30	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0501AE	4961259	28/08/2024 10:30	Colour	mg/l Pt/Co	<4.56	20
ZN0501AE	4961259	28/08/2024 10:30	Conductivity	uS/cm 20 C	370	2500

ZN0501AE	4961259	28/08/2024 10:30	E. coli	CFU/100 ml	0	0
ZN0501AE	4961259	28/08/2024 10:30	Free - Residual disinfectant	mg Cl/l	<0.05	
ZN0501AE	4961259	28/08/2024 10:30	Hydrogen Ion	pH value	7.6	9.5
ZN0501AE	4961259	28/08/2024 10:30	Iron	ug/l Fe	3.6	200
ZN0501AE	4961259	28/08/2024 10:30	Manganese	ug Mn/l	<0.80	50
ZN0501AE	4961259	28/08/2024 10:30	Odour	Diln No	0	0
ZN0501AE	4961259	28/08/2024 10:30	Odour - Nature		No odour	
ZN0501AE	4961259	28/08/2024 10:30	Taste	Diln No	0	0
ZN0501AE	4961259	28/08/2024 10:30	Taste - Nature		No taste	
ZN0501AE	4961259	28/08/2024 10:30	Total - Residual disinfectant	mg Cl/l	0.24	
ZN0501AE	4961259	28/08/2024 10:30	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4961259	28/08/2024 10:30	Turbidity	NTU	<0.09	4
ZN0102AE	4974779	28/08/2024 12:05	Aluminium	ug Al/l	18	200
ZN0102AE	4974779	28/08/2024 12:05	Iron	ug/l Fe	24	200
ZN0102AE	4974779	28/08/2024 12:05	Manganese	ug Mn/l	1.4	50
ZN0102AE	4974780	28/08/2024 12:10	Aluminium	ug Al/l	18	200
ZN0102AE	4974780	28/08/2024 12:10	Iron	ug/l Fe	24	200
ZN0102AE	4974780	28/08/2024 12:10	Manganese	ug Mn/l	1.5	50
ZN1102AE	4961235	28/08/2024 12:17	E. coli	CFU/100 ml	0	0
ZN1102AE	4961235	28/08/2024 12:17	Free - Residual disinfectant	mg Cl/l	0.71	
ZN1102AE	4961235	28/08/2024 12:17	Total - Residual disinfectant	mg Cl/l	0.86	
ZN1102AE	4961235	28/08/2024 12:17	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4974781	28/08/2024 12:20	Aluminium	ug Al/l	17	200
ZN0102AE	4974781	28/08/2024 12:20	Iron	ug/l Fe	23	200
ZN0102AE	4974781	28/08/2024 12:20	Manganese	ug Mn/l	1.3	50
ZS0809AE	4961518	28/08/2024 13:06	E. coli	CFU/100 ml	0	0
ZS0809AE	4961518	28/08/2024 13:06	Free - Residual disinfectant	mg Cl/l	0.38	
ZS0809AE	4961518	28/08/2024 13:06	Total - Residual disinfectant	mg Cl/l	0.54	
ZS0809AE	4961518	28/08/2024 13:06	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4961732	29/08/2024 09:39	E. coli	CFU/100 ml	0	0
ZS0809AE	4961732	29/08/2024 09:39	Free - Residual disinfectant	mg Cl/l	0.72	
ZS0809AE	4961732	29/08/2024 09:39	Total - Residual disinfectant	mg Cl/l	0.86	
ZS0809AE	4961732	29/08/2024 09:39	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4961559	29/08/2024 09:43	1,2 Dichloroethane	ug/l	<0.4	3
ZN0804AE	4961559	29/08/2024 09:43	Benzene	ug/l	<0.15	1
ZN0804AE	4961559	29/08/2024 09:43	E. coli	CFU/100 ml	0	0
ZN0804AE	4961559	29/08/2024 09:43	Free - Residual disinfectant	mg Cl/l	0.37	
ZN0804AE	4961559	29/08/2024 09:43	Iron	ug/l Fe	28	200

ZN0804AE	4961559	29/08/2024 09:43	Tetrachloroethene	ug/l	<0.8	
ZN0804AE	4961559	29/08/2024 09:43	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0804AE	4961559	29/08/2024 09:43	Tetrachloromethane	ug/l	<0.4	3
ZN0804AE	4961559	29/08/2024 09:43	Total - Residual disinfectant	mg Cl/l	0.45	
ZN0804AE	4961559	29/08/2024 09:43	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4961559	29/08/2024 09:43	Trichloroethene	ug/l	<0.7	
ZN0706AE	4961539	29/08/2024 10:21	Bromodichloromethane	ug/l	11	
ZN0706AE	4961539	29/08/2024 10:21	Bromoform	ug/l	<3.5	
ZN0706AE	4961539	29/08/2024 10:21	Chloroform	ug/l	51	
ZN0706AE	4961539	29/08/2024 10:21	Dibromochloromethane	ug/l	1.8	
ZN0706AE	4961539	29/08/2024 10:21	E. coli	CFU/100 ml	0	0
ZN0706AE	4961539	29/08/2024 10:21	Free - Residual disinfectant	mg Cl/l	0.26	
ZN0706AE	4961539	29/08/2024 10:21	Total - Residual disinfectant	mg Cl/l	0.45	
ZN0706AE	4961539	29/08/2024 10:21	Total Coliforms	CFU/100 ml	0	0
ZN0706AE	4961539	29/08/2024 10:21	Total Organic Carbon	mg C/l	2.6	
ZN0706AE	4961539	29/08/2024 10:21	Total Trihalomethanes	ug/l	64	100
ZN0706AE	4961539	29/08/2024 10:21	WHO Index		0.38	1
ZN1102AE	4961521	29/08/2024 10:25	E. coli	CFU/100 ml	0	0
ZN1102AE	4961521	29/08/2024 10:25	Free - Residual disinfectant	mg Cl/l	0.7	
ZN1102AE	4961521	29/08/2024 10:25	Total - Residual disinfectant	mg Cl/l	0.87	
ZN1102AE	4961521	29/08/2024 10:25	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4961560	29/08/2024 10:53	E. coli	CFU/100 ml	0	0
ZS0811AE	4961560	29/08/2024 10:53	Free - Residual disinfectant	mg Cl/l	0.78	
ZS0811AE	4961560	29/08/2024 10:53	Total - Residual disinfectant	mg Cl/l	0.94	
ZS0811AE	4961560	29/08/2024 10:53	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4961542	29/08/2024 10:56	E. coli	CFU/100 ml	0	0
ZN0501AE	4961542	29/08/2024 10:56	Free - Residual disinfectant	mg Cl/l	0.74	
ZN0501AE	4961542	29/08/2024 10:56	Total - Residual disinfectant	mg Cl/l	0.86	
ZN0501AE	4961542	29/08/2024 10:56	Total Coliforms	CFU/100 ml	0	0
ZN0706CUST	4975476	30/08/2024 08:50	E. coli	CFU/100 ml	0	0
ZN0706CUST	4975476	30/08/2024 08:50	Free - Residual disinfectant	mg Cl/l	0.14	
ZN0706CUST	4975476	30/08/2024 08:50	Total - Residual disinfectant	mg Cl/l	0.26	
ZN0706CUST	4975476	30/08/2024 08:50	Total Coliforms	CFU/100 ml	0	0
ZN0706CUST	4975477	30/08/2024 09:00	E. coli	CFU/100 ml	0	0
ZN0706CUST	4975477	30/08/2024 09:00	Total Coliforms	CFU/100 ml	0	0
ZN0706CUST	4975478	30/08/2024 09:10	E. coli	CFU/100 ml	0	0
ZN0706CUST	4975478	30/08/2024 09:10	Free - Residual disinfectant	mg Cl/l	0.27	
ZN0706CUST	4975478	30/08/2024 09:10	Total - Residual disinfectant	mg Cl/l	0.37	

ZN0706CUST	4975478	30/08/2024 09:10	Total Coliforms	CFU/100 ml	0	0
ZN0706CUST	4975479	30/08/2024 09:10	E. coli	CFU/100 ml	0	0
ZN0706CUST	4975479	30/08/2024 09:10	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4961740	30/08/2024 09:16	E. coli	CFU/100 ml	0	0
ZN0102AE	4961740	30/08/2024 09:16	Free - Residual disinfectant	mg Cl/l	0.61	
ZN0102AE	4961740	30/08/2024 09:16	Total - Residual disinfectant	mg Cl/l	0.93	
ZN0102AE	4961740	30/08/2024 09:16	Total Coliforms	CFU/100 ml	0	0
ZN0706CUST	4975469	30/08/2024 09:20	E. coli	CFU/100 ml	0	0
ZN0706CUST	4975469	30/08/2024 09:20	Free - Residual disinfectant	mg Cl/l	0.3	
ZN0706CUST	4975469	30/08/2024 09:20	Total - Residual disinfectant	mg Cl/l	0.39	
ZN0706CUST	4975469	30/08/2024 09:20	Total Coliforms	CFU/100 ml	0	0
ZN0706CUST	4975475	30/08/2024 09:30	E. coli	CFU/100 ml	0	0
ZN0706CUST	4975475	30/08/2024 09:30	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4961544	30/08/2024 09:45	E. coli	CFU/100 ml	0	0
ZN0102AE	4961544	30/08/2024 09:45	Free - Residual disinfectant	mg Cl/l	<0.05	
ZN0102AE	4961544	30/08/2024 09:45	Total - Residual disinfectant	mg Cl/l	0.09	
ZN0102AE	4961544	30/08/2024 09:45	Total Coliforms	CFU/100 ml	0	0
ZS0809CUST	4975640	30/08/2024 10:10	Aluminium	ug Al/l	18	200
ZS0809CUST	4975640	30/08/2024 10:10	Colour	mg/l Pt/Co	<4.56	20
ZS0809CUST	4975640	30/08/2024 10:10	E. coli	CFU/100 ml	0	0
ZS0809CUST	4975640	30/08/2024 10:10	Free - Residual disinfectant	mg Cl/l	0.54	
ZS0809CUST	4975640	30/08/2024 10:10	Hydrogen Ion	pH value	7.7	9.5
ZS0809CUST	4975640	30/08/2024 10:10	Iron	ug/l Fe	7.7	200
ZS0809CUST	4975640	30/08/2024 10:10	Manganese	ug Mn/l	<0.642	50
ZS0809CUST	4975640	30/08/2024 10:10	Total - Residual disinfectant	mg Cl/l	0.74	
ZS0809CUST	4975640	30/08/2024 10:10	Total Coliforms	CFU/100 ml	0	0
ZS0809CUST	4975640	30/08/2024 10:10	Turbidity	NTU	<0.09	4
ZN0502AE	4961545	30/08/2024 10:45	E. coli	CFU/100 ml	0	0
ZN0502AE	4961545	30/08/2024 10:45	Free - Residual disinfectant	mg Cl/l	0.43	
ZN0502AE	4961545	30/08/2024 10:45	Total - Residual disinfectant	mg Cl/l	0.54	
ZN0502AE	4961545	30/08/2024 10:45	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4961744	30/08/2024 11:45	E. coli	CFU/100 ml	0	0
ZS0811AE	4961744	30/08/2024 11:45	Free - Residual disinfectant	mg Cl/l	0.28	
ZS0811AE	4961744	30/08/2024 11:45	Total - Residual disinfectant	mg Cl/l	0.49	
ZS0811AE	4961744	30/08/2024 11:45	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4964127	02/09/2024 09:47	E. coli	CFU/100 ml	0	0
ZN0501AE	4964127	02/09/2024 09:47	Free - Residual disinfectant	mg Cl/l	0.18	
ZN0501AE	4964127	02/09/2024 09:47	Total - Residual disinfectant	mg Cl/l	0.29	

ZN0501AE	4964127	02/09/2024 09:47	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4961282	02/09/2024 09:48	Aluminium	ug Al/l	41	200
ZN0804AE	4961282	02/09/2024 09:48	Colony Counts 22	CFU/1 ml	0	
ZN0804AE	4961282	02/09/2024 09:48	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0804AE	4961282	02/09/2024 09:48	Colour	mg/l Pt/Co	<4.56	20
ZN0804AE	4961282	02/09/2024 09:48	Conductivity	uS/cm 20 C	410	2500
ZN0804AE	4961282	02/09/2024 09:48	E. coli	CFU/100 ml	0	0
ZN0804AE	4961282	02/09/2024 09:48	Free - Residual disinfectant	mg Cl/l	0.84	
ZN0804AE	4961282	02/09/2024 09:48	Hydrogen Ion	pH value	8	9.5
ZN0804AE	4961282	02/09/2024 09:48	Iron	ug/l Fe	15	200
ZN0804AE	4961282	02/09/2024 09:48	Manganese	ug Mn/l	2.3	50
ZN0804AE	4961282	02/09/2024 09:48	Odour	Diln No	0	0
ZN0804AE	4961282	02/09/2024 09:48	Odour - Nature		No odour	
ZN0804AE	4961282	02/09/2024 09:48	Taste	Diln No	0	0
ZN0804AE	4961282	02/09/2024 09:48	Taste - Nature		No taste	
ZN0804AE	4961282	02/09/2024 09:48	Total - Residual disinfectant	mg Cl/l	0.97	
ZN0804AE	4961282	02/09/2024 09:48	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4961282	02/09/2024 09:48	Turbidity	NTU	<0.09	4
ZN0102AE	4964129	02/09/2024 10:02	Aluminium	ug Al/l	32	200
ZN0102AE	4964129	02/09/2024 10:02	Colony Counts 22	CFU/1 ml	0	
ZN0102AE	4964129	02/09/2024 10:02	Colony Counts 37 (48hrs)	CFU/1 ml	1	
ZN0102AE	4964129	02/09/2024 10:02	Colour	mg/l Pt/Co	<4.56	20
ZN0102AE	4964129	02/09/2024 10:02	Conductivity	uS/cm 20 C	330	2500
ZN0102AE	4964129	02/09/2024 10:02	E. coli	CFU/100 ml	0	0
ZN0102AE	4964129	02/09/2024 10:02	Free - Residual disinfectant	mg Cl/l	0.58	
ZN0102AE	4964129	02/09/2024 10:02	Hydrogen Ion	pH value	7.5	9.5
ZN0102AE	4964129	02/09/2024 10:02	Iron	ug/l Fe	6.2	200
ZN0102AE	4964129	02/09/2024 10:02	Manganese	ug Mn/l	1.3	50
ZN0102AE	4964129	02/09/2024 10:02	Odour	Diln No	0	0
ZN0102AE	4964129	02/09/2024 10:02	Odour - Nature		No odour	
ZN0102AE	4964129	02/09/2024 10:02	Taste	Diln No	0	0
ZN0102AE	4964129	02/09/2024 10:02	Taste - Nature		No taste	
ZN0102AE	4964129	02/09/2024 10:02	Total - Residual disinfectant	mg Cl/l	0.68	
ZN0102AE	4964129	02/09/2024 10:02	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4964129	02/09/2024 10:02	Turbidity	NTU	0.1	4
ZN1102AE	4964106	02/09/2024 10:40	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN1102AE	4964106	02/09/2024 10:40	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN1102AE	4964106	02/09/2024 10:40	Benzo(ghi)perylene	ug/l	<0.0022	0.1

ZN1102AE	4964106	02/09/2024 10:40	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN1102AE	4964106	02/09/2024 10:40	Bromate	ug BrO3/l	<0.50	10
ZN1102AE	4964106	02/09/2024 10:40	E. coli	CFU/100 ml	0	0
ZN1102AE	4964106	02/09/2024 10:40	Free - Residual disinfectant	mg Cl/l	0.27	
ZN1102AE	4964106	02/09/2024 10:40	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN1102AE	4964106	02/09/2024 10:40	PAH - Sum of four substances	ug/l	0	0.1
ZN1102AE	4964106	02/09/2024 10:40	Total - Residual disinfectant	mg Cl/l	0.42	
ZN1102AE	4964106	02/09/2024 10:40	Total Coliforms	CFU/100 ml	0	0
ZN0505AE	4961261	02/09/2024 11:02	1,2 Dichloroethane	ug/l	<0.4	3
ZN0505AE	4961261	02/09/2024 11:02	Antimony	ug/l Sb	0.16	5
ZN0505AE	4961261	02/09/2024 11:02	Arsenic	ug/l As	0.32	10
ZN0505AE	4961261	02/09/2024 11:02	Benzene	ug/l	<0.15	1
ZN0505AE	4961261	02/09/2024 11:02	Boron	mg/l B	<0.0586	1
ZN0505AE	4961261	02/09/2024 11:02	Bromodichloromethane	ug/l	13	
ZN0505AE	4961261	02/09/2024 11:02	Bromoform	ug/l	<3.5	
ZN0505AE	4961261	02/09/2024 11:02	Cadmium	ug/l Cd	<0.042	5
ZN0505AE	4961261	02/09/2024 11:02	Chloroform	ug/l	37	
ZN0505AE	4961261	02/09/2024 11:02	Chromium	ug/l Cr	0.31	50
ZN0505AE	4961261	02/09/2024 11:02	Dibromochloromethane	ug/l	5.2	
ZN0505AE	4961261	02/09/2024 11:02	E. coli	CFU/100 ml	0	0
ZN0505AE	4961261	02/09/2024 11:02	Free - Residual disinfectant	mg Cl/l	<0.05	
ZN0505AE	4961261	02/09/2024 11:02	Selenium	ug/l Se	0.071	10
ZN0505AE	4961261	02/09/2024 11:02	Tetrachloroethene	ug/l	<0.8	
ZN0505AE	4961261	02/09/2024 11:02	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0505AE	4961261	02/09/2024 11:02	Tetrachloromethane	ug/l	<0.4	3
ZN0505AE	4961261	02/09/2024 11:02	Total - Residual disinfectant	mg Cl/l	0.25	
ZN0505AE	4961261	02/09/2024 11:02	Total Coliforms	CFU/100 ml	0	0
ZN0505AE	4961261	02/09/2024 11:02	Total Organic Carbon	mg C/l	2.7	
ZN0505AE	4961261	02/09/2024 11:02	Total Trihalomethanes	ug/l	56	100
ZN0505AE	4961261	02/09/2024 11:02	Trichloroethene	ug/l	<0.7	
ZN0505AE	4961261	02/09/2024 11:02	WHO Index		0.4	1
ZS0811AE	4964149	02/09/2024 11:20	E. coli	CFU/100 ml	0	0
ZS0811AE	4964149	02/09/2024 11:20	Free - Residual disinfectant	mg Cl/l	0.21	
ZS0811AE	4964149	02/09/2024 11:20	Total - Residual disinfectant	mg Cl/l	0.39	
ZS0811AE	4964149	02/09/2024 11:20	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4964104	03/09/2024 09:45	Aluminium	ug Al/l	50	200
ZS0809AE	4964104	03/09/2024 09:45	Colony Counts 22	CFU/1 ml	0	
ZS0809AE	4964104	03/09/2024 09:45	Colony Counts 37 (48hrs)	CFU/1 ml	0	

ZS0809AE	4964104	03/09/2024 09:45	Colour	mg/l Pt/Co	<4.56	20
ZS0809AE	4964104	03/09/2024 09:45	Conductivity	uS/cm 20 C	370	2500
ZS0809AE	4964104	03/09/2024 09:45	E. coli	CFU/100 ml	0	0
ZS0809AE	4964104	03/09/2024 09:45	Free - Residual disinfectant	mg Cl/l	0.34	
ZS0809AE	4964104	03/09/2024 09:45	Hydrogen Ion	pH value	7.6	9.5
ZS0809AE	4964104	03/09/2024 09:45	Iron	ug/l Fe	11	200
ZS0809AE	4964104	03/09/2024 09:45	Manganese	ug Mn/l	1.8	50
ZS0809AE	4964104	03/09/2024 09:45	Odour	Diln No	0	0
ZS0809AE	4964104	03/09/2024 09:45	Odour - Nature		No odour	
ZS0809AE	4964104	03/09/2024 09:45	Taste	Diln No	0	0
ZS0809AE	4964104	03/09/2024 09:45	Taste - Nature		No taste	
ZS0809AE	4964104	03/09/2024 09:45	Total - Residual disinfectant	mg Cl/l	0.59	
ZS0809AE	4964104	03/09/2024 09:45	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4964104	03/09/2024 09:45	Turbidity	NTU	0.16	4
ZN1102AE	4964579	03/09/2024 10:34	Aluminium	ug Al/l	4.9	200
ZN1102AE	4964579	03/09/2024 10:34	Colony Counts 22	CFU/1 ml	0	
ZN1102AE	4964579	03/09/2024 10:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN1102AE	4964579	03/09/2024 10:34	Colour	mg/l Pt/Co	<4.56	20
ZN1102AE	4964579	03/09/2024 10:34	Conductivity	uS/cm 20 C	400	2500
ZN1102AE	4964579	03/09/2024 10:34	E. coli	CFU/100 ml	0	0
ZN1102AE	4964579	03/09/2024 10:34	Free - Residual disinfectant	mg Cl/l	0.6	
ZN1102AE	4964579	03/09/2024 10:34	Hydrogen Ion	pH value	7.4	9.5
ZN1102AE	4964579	03/09/2024 10:34	Iron	ug/l Fe	8.3	200
ZN1102AE	4964579	03/09/2024 10:34	Manganese	ug Mn/l	0.92	50
ZN1102AE	4964579	03/09/2024 10:34	Odour	Diln No	0	0
ZN1102AE	4964579	03/09/2024 10:34	Odour - Nature		No odour	
ZN1102AE	4964579	03/09/2024 10:34	Taste	Diln No	0	0
ZN1102AE	4964579	03/09/2024 10:34	Taste - Nature		No taste	
ZN1102AE	4964579	03/09/2024 10:34	Total - Residual disinfectant	mg Cl/l	0.74	
ZN1102AE	4964579	03/09/2024 10:34	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4964579	03/09/2024 10:34	Turbidity	NTU	<0.09	4
ZN0501AE	4964596	03/09/2024 10:55	E. coli	CFU/100 ml	0	0
ZN0501AE	4964596	03/09/2024 10:55	Free - Residual disinfectant	mg Cl/l	0.6	
ZN0501AE	4964596	03/09/2024 10:55	Total - Residual disinfectant	mg Cl/l	0.88	
ZN0501AE	4964596	03/09/2024 10:55	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4964609	03/09/2024 11:33	Aluminium	ug Al/l	14	200
ZS0811AE	4964609	03/09/2024 11:33	Colony Counts 22	CFU/1 ml	0	
ZS0811AE	4964609	03/09/2024 11:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	

ZS0811AE	4964609	03/09/2024 11:33	Colour	mg/l Pt/Co	<4.56	20
ZS0811AE	4964609	03/09/2024 11:33	Conductivity	uS/cm 20 C	370	2500
ZS0811AE	4964609	03/09/2024 11:33	E. coli	CFU/100 ml	0	0
ZS0811AE	4964609	03/09/2024 11:33	Free - Residual disinfectant	mg Cl/l	0.65	
ZS0811AE	4964609	03/09/2024 11:33	Hydrogen Ion	pH value	7.5	9.5
ZS0811AE	4964609	03/09/2024 11:33	Iron	ug/l Fe	11	200
ZS0811AE	4964609	03/09/2024 11:33	Manganese	ug Mn/l	<0.80	50
ZS0811AE	4964609	03/09/2024 11:33	Odour	Diln No	0	0
ZS0811AE	4964609	03/09/2024 11:33	Odour - Nature		No odour	
ZS0811AE	4964609	03/09/2024 11:33	Taste	Diln No	0	0
ZS0811AE	4964609	03/09/2024 11:33	Taste - Nature		No taste	
ZS0811AE	4964609	03/09/2024 11:33	Total - Residual disinfectant	mg Cl/l	0.84	
ZS0811AE	4964609	03/09/2024 11:33	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4964609	03/09/2024 11:33	Turbidity	NTU	<0.09	4
ZN0102AE	4964597	03/09/2024 12:41	E. coli	CFU/100 ml	0	0
ZN0102AE	4964597	03/09/2024 12:41	Free - Residual disinfectant	mg Cl/l	0.16	
ZN0102AE	4964597	03/09/2024 12:41	Total - Residual disinfectant	mg Cl/l	0.39	
ZN0102AE	4964597	03/09/2024 12:41	Total Coliforms	CFU/100 ml	0	0
ZN0502AE	4964130	04/09/2024 10:39	E. coli	CFU/100 ml	0	0
ZN0502AE	4964130	04/09/2024 10:39	Free - Residual disinfectant	mg Cl/l	0.48	
ZN0502AE	4964130	04/09/2024 10:39	Total - Residual disinfectant	mg Cl/l	0.57	
ZN0502AE	4964130	04/09/2024 10:39	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4964781	04/09/2024 11:00	E. coli	CFU/100 ml	0	0
ZN0102AE	4964781	04/09/2024 11:00	Free - Residual disinfectant	mg Cl/l	0.43	
ZN0102AE	4964781	04/09/2024 11:00	Total - Residual disinfectant	mg Cl/l	0.64	
ZN0102AE	4964781	04/09/2024 11:00	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4964785	04/09/2024 11:48	E. coli	CFU/100 ml	0	0
ZS0811AE	4964785	04/09/2024 11:48	Free - Residual disinfectant	mg Cl/l	0.61	
ZS0811AE	4964785	04/09/2024 11:48	Total - Residual disinfectant	mg Cl/l	0.85	
ZS0811AE	4964785	04/09/2024 11:48	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4964773	05/09/2024 09:24	E. coli	CFU/100 ml	0	0
ZS0809AE	4964773	05/09/2024 09:24	Free - Residual disinfectant	mg Cl/l	0.7	
ZS0809AE	4964773	05/09/2024 09:24	Total - Residual disinfectant	mg Cl/l	0.86	
ZS0809AE	4964773	05/09/2024 09:24	Total Coliforms	CFU/100 ml	0	0
ZN0504AE	4978048	05/09/2024 09:25	Aluminium	ug Al/l	21	200
ZN0504AE	4978048	05/09/2024 09:25	Iron	ug/l Fe	52	200
ZN0504AE	4978048	05/09/2024 09:25	Manganese	ug Mn/l	2.3	50
ZN0504AE	4978049	05/09/2024 09:35	Aluminium	ug Al/l	18	200

ZN0504AE	4978049	05/09/2024 09:35	Iron	ug/l Fe	32	200
ZN0504AE	4978049	05/09/2024 09:35	Manganese	ug Mn/l	1.4	50
ZN0504AE	4978047	05/09/2024 09:45	Aluminium	ug Al/l	29	200
ZN0504AE	4978047	05/09/2024 09:45	Iron	ug/l Fe	570	200
ZN0504AE	4978047	05/09/2024 09:45	Manganese	ug Mn/l	13	50
ZN0504AE	4978050	05/09/2024 09:50	Aluminium	ug Al/l	19	200
ZN0504AE	4978050	05/09/2024 09:50	Iron	ug/l Fe	49	200
ZN0504AE	4978050	05/09/2024 09:50	Manganese	ug Mn/l	2.4	50
ZN0804CUST	4978496	06/09/2024 07:30	Aluminium	ug Al/l	57	200
ZN0804CUST	4978496	06/09/2024 07:30	Antimony	ug/l Sb	0.046	5
ZN0804CUST	4978496	06/09/2024 07:30	Arsenic	ug/l As	0.37	10
ZN0804CUST	4978496	06/09/2024 07:30	Boron	mg/l B	<0.0586	1000
ZN0804CUST	4978496	06/09/2024 07:30	Cadmium	ug/l Cd	<0.042	5
ZN0804CUST	4978496	06/09/2024 07:30	Chromium	ug/l Cr	<0.260	50
ZN0804CUST	4978496	06/09/2024 07:30	Free - Residual disinfectant	mg Cl/l	0.7	
ZN0804CUST	4978496	06/09/2024 07:30	Iron	ug/l Fe	19	200
ZN0804CUST	4978496	06/09/2024 07:30	Manganese	ug Mn/l	9.8	50
ZN0804CUST	4978496	06/09/2024 07:30	Selenium	ug/l Se	0.07	10
ZN0804CUST	4978496	06/09/2024 07:30	Total - Residual disinfectant	mg Cl/l	0.96	
ZN0804CUST	4978495	06/09/2024 07:30	Aluminium	ug Al/l	110	200
ZN0804CUST	4978495	06/09/2024 07:30	Free - Residual disinfectant	mg Cl/l	0.76	
ZN0804CUST	4978495	06/09/2024 07:30	Iron	ug/l Fe	5.8	200
ZN0804CUST	4978495	06/09/2024 07:30	Manganese	ug Mn/l	1.8	50
ZN0804CUST	4978495	06/09/2024 07:30	Total - Residual disinfectant	mg Cl/l	0.98	
ZS0809AE	4964576	06/09/2024 09:21	E. coli	CFU/100 ml	0	0
ZS0809AE	4964576	06/09/2024 09:21	Free - Residual disinfectant	mg Cl/l	0.17	
ZS0809AE	4964576	06/09/2024 09:21	Total - Residual disinfectant	mg Cl/l	0.32	
ZS0809AE	4964576	06/09/2024 09:21	Total Coliforms	CFU/100 ml	0	0
ZN0706AE	4964124	06/09/2024 10:21	E. coli	CFU/100 ml	0	0
ZN0706AE	4964124	06/09/2024 10:21	Free - Residual disinfectant	mg Cl/l	0.09	
ZN0706AE	4964124	06/09/2024 10:21	Total - Residual disinfectant	mg Cl/l	0.15	
ZN0706AE	4964124	06/09/2024 10:21	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4978593	06/09/2024 10:30	Aluminium	ug Al/l	30	200
ZN0504CUST	4978593	06/09/2024 10:30	Colour	mg/l Pt/Co	<4.56	20
ZN0504CUST	4978593	06/09/2024 10:30	E. coli	CFU/100 ml	0	0
ZN0504CUST	4978593	06/09/2024 10:30	Free - Residual disinfectant	mg Cl/l	0.13	
ZN0504CUST	4978593	06/09/2024 10:30	Iron	ug/l Fe	130	200
ZN0504CUST	4978593	06/09/2024 10:30	Manganese	ug Mn/l	7	50

ZN0504CUST	4978593	06/09/2024 10:30	Total - Residual disinfectant	mg Cl/l	0.32	
ZN0504CUST	4978593	06/09/2024 10:30	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4978593	06/09/2024 10:30	Turbidity	NTU	0.36	4
ZS0809CUST	4978461	06/09/2024 10:30	Colour	mg/l Pt/Co	<4.56	20
ZS0809CUST	4978461	06/09/2024 10:30	E. coli	CFU/100 ml	0	0
ZS0809CUST	4978461	06/09/2024 10:30	Free - Residual disinfectant	mg Cl/l	0.63	
ZS0809CUST	4978461	06/09/2024 10:30	Total - Residual disinfectant	mg Cl/l	0.97	
ZS0809CUST	4978461	06/09/2024 10:30	Total Coliforms	CFU/100 ml	0	0
ZS0809CUST	4978461	06/09/2024 10:30	Turbidity	NTU	0.23	4
ZN0804AE	4964148	06/09/2024 11:30	E. coli	CFU/100 ml	0	0
ZN0804AE	4964148	06/09/2024 11:30	Free - Residual disinfectant	mg Cl/l	0.49	
ZN0804AE	4964148	06/09/2024 11:30	Total - Residual disinfectant	mg Cl/l	0.58	
ZN0804AE	4964148	06/09/2024 11:30	Total Coliforms	CFU/100 ml	0	0
ZN0505CUST	4978601	06/09/2024 14:00	Aluminium	ug Al/l	54	200
ZN0505CUST	4978601	06/09/2024 14:00	Colour	mg/l Pt/Co	<4.56	20
ZN0505CUST	4978601	06/09/2024 14:00	E. coli	CFU/100 ml	0	0
ZN0505CUST	4978601	06/09/2024 14:00	Free - Residual disinfectant	mg Cl/l	0.18	
ZN0505CUST	4978601	06/09/2024 14:00	Iron	ug/l Fe	160	200
ZN0505CUST	4978601	06/09/2024 14:00	Manganese	ug Mn/l	4	50
ZN0505CUST	4978601	06/09/2024 14:00	Total - Residual disinfectant	mg Cl/l	0.3	
ZN0505CUST	4978601	06/09/2024 14:00	Total Coliforms	CFU/100 ml	0	0
ZN0505CUST	4978601	06/09/2024 14:00	Turbidity	NTU	0.57	4
ZN0501CUST	4978992	09/09/2024 09:00	Aluminium	ug Al/l	28	200
ZN0501CUST	4978992	09/09/2024 09:00	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4978992	09/09/2024 09:00	E. coli	CFU/100 ml	0	0
ZN0501CUST	4978992	09/09/2024 09:00	Free - Residual disinfectant	mg Cl/l	0.1	
ZN0501CUST	4978992	09/09/2024 09:00	Hydrogen Ion	pH value	7.6	9.5
ZN0501CUST	4978992	09/09/2024 09:00	Iron	ug/l Fe	<1.538	200
ZN0501CUST	4978992	09/09/2024 09:00	Manganese	ug Mn/l	<0.642	50
ZN0501CUST	4978992	09/09/2024 09:00	Odour	Diln No	0	0
ZN0501CUST	4978992	09/09/2024 09:00	Odour - Nature		No odour	
ZN0501CUST	4978992	09/09/2024 09:00	Taste	Diln No	0	0
ZN0501CUST	4978992	09/09/2024 09:00	Taste - Nature		No taste	
ZN0501CUST	4978992	09/09/2024 09:00	Total - Residual disinfectant	mg Cl/l	0.14	
ZN0501CUST	4978992	09/09/2024 09:00	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4978992	09/09/2024 09:00	Turbidity	NTU	0.096	4
ZS0811AE	4967433	09/09/2024 09:47	E. coli	CFU/100 ml	0	0
ZS0811AE	4967433	09/09/2024 09:47	Free - Residual disinfectant	mg Cl/l	0.18	

ZS0811AE	4967433	09/09/2024 09:47	Total - Residual disinfectant	mg Cl/l	0.43	
ZS0811AE	4967433	09/09/2024 09:47	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4964608	09/09/2024 10:05	Aluminium	ug Al/l	32	200
ZN0804AE	4964608	09/09/2024 10:05	Bromodichloromethane	ug/l	14	
ZN0804AE	4964608	09/09/2024 10:05	Bromoform	ug/l	<3.5	
ZN0804AE	4964608	09/09/2024 10:05	Chloroform	ug/l	56	
ZN0804AE	4964608	09/09/2024 10:05	Colony Counts 22	CFU/1 ml	0	
ZN0804AE	4964608	09/09/2024 10:05	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0804AE	4964608	09/09/2024 10:05	Colour	mg/l Pt/Co	<4.56	20
ZN0804AE	4964608	09/09/2024 10:05	Conductivity	uS/cm 20 C	420	2500
ZN0804AE	4964608	09/09/2024 10:05	Dibromochloromethane	ug/l	3.4	
ZN0804AE	4964608	09/09/2024 10:05	E. coli	CFU/100 ml	0	0
ZN0804AE	4964608	09/09/2024 10:05	Free - Residual disinfectant	mg Cl/l	0.8	
ZN0804AE	4964608	09/09/2024 10:05	Hydrogen Ion	pH value	8	9.5
ZN0804AE	4964608	09/09/2024 10:05	Iron	ug/l Fe	5.2	200
ZN0804AE	4964608	09/09/2024 10:05	Manganese	ug Mn/l	1.5	50
ZN0804AE	4964608	09/09/2024 10:05	Odour	Diln No	0	0
ZN0804AE	4964608	09/09/2024 10:05	Odour - Nature		No odour	
ZN0804AE	4964608	09/09/2024 10:05	Taste	Diln No	0	0
ZN0804AE	4964608	09/09/2024 10:05	Taste - Nature		No taste	
ZN0804AE	4964608	09/09/2024 10:05	Total - Residual disinfectant	mg Cl/l	0.92	
ZN0804AE	4964608	09/09/2024 10:05	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4964608	09/09/2024 10:05	Total Trihalomethanes	ug/l	74	100
ZN0804AE	4964608	09/09/2024 10:05	Turbidity	NTU	0.16	4
ZN0804AE	4964608	09/09/2024 10:05	WHO Index		0.46	1
ZN0504CUST	4978982	09/09/2024 10:10	Aluminium	ug Al/l	18	200
ZN0504CUST	4978982	09/09/2024 10:10	Colour	mg/l Pt/Co	<4.56	20
ZN0504CUST	4978982	09/09/2024 10:10	E. coli	CFU/100 ml	0	0
ZN0504CUST	4978982	09/09/2024 10:10	Free - Residual disinfectant	mg Cl/l	0.11	
ZN0504CUST	4978982	09/09/2024 10:10	Hydrogen Ion	pH value	7.4	9.5
ZN0504CUST	4978982	09/09/2024 10:10	Iron	ug/l Fe	2.5	200
ZN0504CUST	4978982	09/09/2024 10:10	Manganese	ug Mn/l	<0.642	50
ZN0504CUST	4978982	09/09/2024 10:10	Odour	Diln No	0	0
ZN0504CUST	4978982	09/09/2024 10:10	Odour - Nature		No odour	
ZN0504CUST	4978982	09/09/2024 10:10	Taste	Diln No	0	0
ZN0504CUST	4978982	09/09/2024 10:10	Taste - Nature		No taste	
ZN0504CUST	4978982	09/09/2024 10:10	Total - Residual disinfectant	mg Cl/l	0.13	
ZN0504CUST	4978982	09/09/2024 10:10	Total Coliforms	CFU/100 ml	0	0

ZN0504CUST	4978982	09/09/2024 10:10	Turbidity	NTU	0.19	4
ZN0502AE	4967414	09/09/2024 10:12	Aluminium	ug Al/l	15	200
ZN0502AE	4967414	09/09/2024 10:12	E. coli	CFU/100 ml	0	0
ZN0502AE	4967414	09/09/2024 10:12	Free - Residual disinfectant	mg Cl/l	0.45	
ZN0502AE	4967414	09/09/2024 10:12	Iron	ug/l Fe	18	200
ZN0502AE	4967414	09/09/2024 10:12	Manganese	ug Mn/l	<0.642	50
ZN0502AE	4967414	09/09/2024 10:12	Total - Residual disinfectant	mg Cl/l	0.48	
ZN0502AE	4967414	09/09/2024 10:12	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4967386	09/09/2024 10:25	Aluminium	ug Al/l	15	200
ZS0809AE	4967386	09/09/2024 10:25	Colony Counts 22	CFU/1 ml	0	
ZS0809AE	4967386	09/09/2024 10:25	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0809AE	4967386	09/09/2024 10:25	Colour	mg/l Pt/Co	<4.56	20
ZS0809AE	4967386	09/09/2024 10:25	Conductivity	uS/cm 20 C	380	2500
ZS0809AE	4967386	09/09/2024 10:25	E. coli	CFU/100 ml	0	0
ZS0809AE	4967386	09/09/2024 10:25	Free - Residual disinfectant	mg Cl/l	0.36	
ZS0809AE	4967386	09/09/2024 10:25	Hydrogen Ion	pH value	7.5	9.5
ZS0809AE	4967386	09/09/2024 10:25	Iron	ug/l Fe	3.6	200
ZS0809AE	4967386	09/09/2024 10:25	Manganese	ug Mn/l	<0.80	50
ZS0809AE	4967386	09/09/2024 10:25	Odour	Diln No	0	0
ZS0809AE	4967386	09/09/2024 10:25	Odour - Nature		No odour	
ZS0809AE	4967386	09/09/2024 10:25	Taste	Diln No	0	0
ZS0809AE	4967386	09/09/2024 10:25	Taste - Nature		No taste	
ZS0809AE	4967386	09/09/2024 10:25	Total - Residual disinfectant	mg Cl/l	0.6	
ZS0809AE	4967386	09/09/2024 10:25	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4967386	09/09/2024 10:25	Turbidity	NTU	<0.09	4
ZN0501CUST	4978983	09/09/2024 11:00	Aluminium	ug Al/l	29	200
ZN0501CUST	4978983	09/09/2024 11:00	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4978983	09/09/2024 11:00	E. coli	CFU/100 ml	0	0
ZN0501CUST	4978983	09/09/2024 11:00	Free - Residual disinfectant	mg Cl/l	0.29	
ZN0501CUST	4978983	09/09/2024 11:00	Hydrogen Ion	pH value	7.5	9.5
ZN0501CUST	4978983	09/09/2024 11:00	Iron	ug/l Fe	1.9	200
ZN0501CUST	4978983	09/09/2024 11:00	Manganese	ug Mn/l	<0.642	50
ZN0501CUST	4978983	09/09/2024 11:00	Odour	Diln No	10	0
ZN0501CUST	4978983	09/09/2024 11:00	Odour - Nature		Earthy	
ZN0501CUST	4978983	09/09/2024 11:00	Taste	Diln No	10	0
ZN0501CUST	4978983	09/09/2024 11:00	Taste - Nature		Earthy	
ZN0501CUST	4978983	09/09/2024 11:00	Total - Residual disinfectant	mg Cl/l	0.39	
ZN0501CUST	4978983	09/09/2024 11:00	Total Coliforms	CFU/100 ml	0	0

ZN0501CUST	4978983	09/09/2024 11:00	Turbidity	NTU	0.091	4
ZN0501CUST	4978980	09/09/2024 11:00	Aluminium	ug Al/l	28	200
ZN0501CUST	4978980	09/09/2024 11:00	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4978980	09/09/2024 11:00	E. coli	CFU/100 ml	0	0
ZN0501CUST	4978980	09/09/2024 11:00	Free - Residual disinfectant	mg Cl/l	0.46	
ZN0501CUST	4978980	09/09/2024 11:00	Hydrogen Ion	pH value	7.6	9.5
ZN0501CUST	4978980	09/09/2024 11:00	Iron	ug/l Fe	<1.538	200
ZN0501CUST	4978980	09/09/2024 11:00	Manganese	ug Mn/l	<0.642	50
ZN0501CUST	4978980	09/09/2024 11:00	Odour	Diln No	10	0
ZN0501CUST	4978980	09/09/2024 11:00	Odour - Nature		Chemical/Earthy	
ZN0501CUST	4978980	09/09/2024 11:00	Taste	Diln No	>99	0
ZN0501CUST	4978980	09/09/2024 11:00	Taste - Nature		is performed due to odour contravention	
ZN0501CUST	4978980	09/09/2024 11:00	Total - Residual disinfectant	mg Cl/l	0.73	
ZN0501CUST	4978980	09/09/2024 11:00	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4978980	09/09/2024 11:00	Turbidity	NTU	0.091	4
ZN1102AE	4967389	09/09/2024 11:04	E. coli	CFU/100 ml	0	0
ZN1102AE	4967389	09/09/2024 11:04	Free - Residual disinfectant	mg Cl/l	0.63	
ZN1102AE	4967389	09/09/2024 11:04	Total - Residual disinfectant	mg Cl/l	0.76	
ZN1102AE	4967389	09/09/2024 11:04	Total Coliforms	CFU/100 ml	0	0
ZN0706AE	4967408	09/09/2024 11:34	Aluminium	ug Al/l	17	200
ZN0706AE	4967408	09/09/2024 11:34	Colony Counts 22	CFU/1 ml	0	
ZN0706AE	4967408	09/09/2024 11:34	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0706AE	4967408	09/09/2024 11:34	Colour	mg/l Pt/Co	<4.56	20
ZN0706AE	4967408	09/09/2024 11:34	Conductivity	uS/cm 20 C	180	2500
ZN0706AE	4967408	09/09/2024 11:34	E. coli	CFU/100 ml	0	0
ZN0706AE	4967408	09/09/2024 11:34	Free - Residual disinfectant	mg Cl/l	0.27	
ZN0706AE	4967408	09/09/2024 11:34	Hydrogen Ion	pH value	7.5	9.5
ZN0706AE	4967408	09/09/2024 11:34	Iron	ug/l Fe	10	200
ZN0706AE	4967408	09/09/2024 11:34	Manganese	ug Mn/l	1.3	50
ZN0706AE	4967408	09/09/2024 11:34	Odour	Diln No	0	0
ZN0706AE	4967408	09/09/2024 11:34	Odour - Nature		No odour	
ZN0706AE	4967408	09/09/2024 11:34	Taste	Diln No	0	0
ZN0706AE	4967408	09/09/2024 11:34	Taste - Nature		No taste	
ZN0706AE	4967408	09/09/2024 11:34	Total - Residual disinfectant	mg Cl/l	0.38	
ZN0706AE	4967408	09/09/2024 11:34	Total Coliforms	CFU/100 ml	0	0
ZN0706AE	4967408	09/09/2024 11:34	Turbidity	NTU	<0.09	4
ZN0102AE	4967413	09/09/2024 12:11	Aluminium	ug Al/l	24	200
ZN0102AE	4967413	09/09/2024 12:11	Colony Counts 22	CFU/1 ml	0	

ZN0102AE	4967413	09/09/2024 12:11	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0102AE	4967413	09/09/2024 12:11	Colour	mg/l Pt/Co	<4.56	20
ZN0102AE	4967413	09/09/2024 12:11	Conductivity	uS/cm 20 C	330	2500
ZN0102AE	4967413	09/09/2024 12:11	E. coli	CFU/100 ml	0	0
ZN0102AE	4967413	09/09/2024 12:11	Free - Residual disinfectant	mg Cl/l	0.26	
ZN0102AE	4967413	09/09/2024 12:11	Hydrogen Ion	pH value	7.6	9.5
ZN0102AE	4967413	09/09/2024 12:11	Iron	ug/l Fe	6.5	200
ZN0102AE	4967413	09/09/2024 12:11	Manganese	ug Mn/l	1	50
ZN0102AE	4967413	09/09/2024 12:11	Odour	Diln No	0	0
ZN0102AE	4967413	09/09/2024 12:11	Odour - Nature		No odour	
ZN0102AE	4967413	09/09/2024 12:11	Taste	Diln No	0	0
ZN0102AE	4967413	09/09/2024 12:11	Taste - Nature		No taste	
ZN0102AE	4967413	09/09/2024 12:11	Total - Residual disinfectant	mg Cl/l	0.41	
ZN0102AE	4967413	09/09/2024 12:11	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4967413	09/09/2024 12:11	Turbidity	NTU	<0.09	4
ZN0501CUST	4979042	09/09/2024 13:45	Aluminium	ug Al/l	32	200
ZN0501CUST	4979042	09/09/2024 13:45	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4979042	09/09/2024 13:45	E. coli	CFU/100 ml	0	0
ZN0501CUST	4979042	09/09/2024 13:45	Free - Residual disinfectant	mg Cl/l	0.29	
ZN0501CUST	4979042	09/09/2024 13:45	Hydrogen Ion	pH value	7.7	9.5
ZN0501CUST	4979042	09/09/2024 13:45	Iron	ug/l Fe	7.1	200
ZN0501CUST	4979042	09/09/2024 13:45	Manganese	ug Mn/l	<0.642	50
ZN0501CUST	4979042	09/09/2024 13:45	Odour	Diln No	9	0
ZN0501CUST	4979042	09/09/2024 13:45	Odour - Nature		Earthy	
ZN0501CUST	4979042	09/09/2024 13:45	Taste	Diln No	9	0
ZN0501CUST	4979042	09/09/2024 13:45	Taste - Nature		Earthy	
ZN0501CUST	4979042	09/09/2024 13:45	Total - Residual disinfectant	mg Cl/l	0.37	
ZN0501CUST	4979042	09/09/2024 13:45	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4979042	09/09/2024 13:45	Turbidity	NTU	<0.09	4
ZN0501CUST	4979835	10/09/2024 09:45	Aluminium	ug Al/l	220	200
ZN0501CUST	4979835	10/09/2024 09:45	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4979835	10/09/2024 09:45	E. coli	CFU/100 ml	0	0
ZN0501CUST	4979835	10/09/2024 09:45	Free - Residual disinfectant	mg Cl/l	0.82	
ZN0501CUST	4979835	10/09/2024 09:45	Hydrogen Ion	pH value	7.7	9.5
ZN0501CUST	4979835	10/09/2024 09:45	Iron	ug/l Fe	130	200
ZN0501CUST	4979835	10/09/2024 09:45	Manganese	ug Mn/l	34	50
ZN0501CUST	4979835	10/09/2024 09:45	Odour	Diln No	0	0
ZN0501CUST	4979835	10/09/2024 09:45	Odour - Nature		No odour	

ZN0501CUST	4979835	10/09/2024 09:45	Taste	Diln No	0	0
ZN0501CUST	4979835	10/09/2024 09:45	Taste - Nature		No taste	
ZN0501CUST	4979835	10/09/2024 09:45	Total - Residual disinfectant	mg Cl/l	1.18	
ZN0501CUST	4979835	10/09/2024 09:45	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4979835	10/09/2024 09:45	Turbidity	NTU	1.2	4
ZS0809AE	4967733	10/09/2024 09:53	E. coli	CFU/100 ml	0	0
ZS0809AE	4967733	10/09/2024 09:53	Free - Residual disinfectant	mg Cl/l	0.83	
ZS0809AE	4967733	10/09/2024 09:53	Total - Residual disinfectant	mg Cl/l	1	
ZS0809AE	4967733	10/09/2024 09:53	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4979836	10/09/2024 10:30	Aluminium	ug Al/l	28	200
ZN0501CUST	4979836	10/09/2024 10:30	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4979836	10/09/2024 10:30	E. coli	CFU/100 ml	0	0
ZN0501CUST	4979836	10/09/2024 10:30	Free - Residual disinfectant	mg Cl/l	0.8	
ZN0501CUST	4979836	10/09/2024 10:30	Hydrogen Ion	pH value	7.7	9.5
ZN0501CUST	4979836	10/09/2024 10:30	Iron	ug/l Fe	4	200
ZN0501CUST	4979836	10/09/2024 10:30	Manganese	ug Mn/l	<0.642	50
ZN0501CUST	4979836	10/09/2024 10:30	Odour	Diln No	0	0
ZN0501CUST	4979836	10/09/2024 10:30	Odour - Nature		No odour	
ZN0501CUST	4979836	10/09/2024 10:30	Taste	Diln No	0	0
ZN0501CUST	4979836	10/09/2024 10:30	Taste - Nature		No taste	
ZN0501CUST	4979836	10/09/2024 10:30	Total - Residual disinfectant	mg Cl/l	0.86	
ZN0501CUST	4979836	10/09/2024 10:30	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4979836	10/09/2024 10:30	Turbidity	NTU	<0.09	4
ZN1102AE	4967736	10/09/2024 10:37	Aluminium	ug Al/l	6.2	200
ZN1102AE	4967736	10/09/2024 10:37	Bromodichloromethane	ug/l	21	
ZN1102AE	4967736	10/09/2024 10:37	Bromoform	ug/l	<3.5	
ZN1102AE	4967736	10/09/2024 10:37	Chloroform	ug/l	65	
ZN1102AE	4967736	10/09/2024 10:37	Colony Counts 22	CFU/1 ml	0	
ZN1102AE	4967736	10/09/2024 10:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN1102AE	4967736	10/09/2024 10:37	Colour	mg/l Pt/Co	<4.56	20
ZN1102AE	4967736	10/09/2024 10:37	Conductivity	uS/cm 20 C	370	2500
ZN1102AE	4967736	10/09/2024 10:37	Dibromochloromethane	ug/l	4.8	
ZN1102AE	4967736	10/09/2024 10:37	E. coli	CFU/100 ml	0	0
ZN1102AE	4967736	10/09/2024 10:37	Free - Residual disinfectant	mg Cl/l	0.32	
ZN1102AE	4967736	10/09/2024 10:37	Hydrogen Ion	pH value	7.6	9.5
ZN1102AE	4967736	10/09/2024 10:37	Iron	ug/l Fe	6.8	200
ZN1102AE	4967736	10/09/2024 10:37	Manganese	ug Mn/l	<0.80	50
ZN1102AE	4967736	10/09/2024 10:37	Odour	Diln No	0	0

ZN1102AE	4967736	10/09/2024 10:37	Odour - Nature		No odour	
ZN1102AE	4967736	10/09/2024 10:37	Taste	Diln No	0	0
ZN1102AE	4967736	10/09/2024 10:37	Taste - Nature		No taste	
ZN1102AE	4967736	10/09/2024 10:37	Total - Residual disinfectant	mg Cl/l	0.52	
ZN1102AE	4967736	10/09/2024 10:37	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4967736	10/09/2024 10:37	Total Trihalomethanes	ug/l	91	100
ZN1102AE	4967736	10/09/2024 10:37	Turbidity	NTU	<0.09	4
ZN1102AE	4967736	10/09/2024 10:37	WHO Index		0.62	1
ZN0505CUST	4979837	10/09/2024 12:00	Aluminium	ug Al/l	28	200
ZN0505CUST	4979837	10/09/2024 12:00	Colour	mg/l Pt/Co	<4.56	20
ZN0505CUST	4979837	10/09/2024 12:00	E. coli	CFU/100 ml	0	0
ZN0505CUST	4979837	10/09/2024 12:00	Free - Residual disinfectant	mg Cl/l	0.34	
ZN0505CUST	4979837	10/09/2024 12:00	Hydrogen Ion	pH value	7.8	9.5
ZN0505CUST	4979837	10/09/2024 12:00	Iron	ug/l Fe	21	200
ZN0505CUST	4979837	10/09/2024 12:00	Manganese	ug Mn/l	1.2	50
ZN0505CUST	4979837	10/09/2024 12:00	Odour	Diln No	0	0
ZN0505CUST	4979837	10/09/2024 12:00	Odour - Nature		No odour	
ZN0505CUST	4979837	10/09/2024 12:00	Taste	Diln No	0	0
ZN0505CUST	4979837	10/09/2024 12:00	Taste - Nature		No taste	
ZN0505CUST	4979837	10/09/2024 12:00	Total - Residual disinfectant	mg Cl/l	0.53	
ZN0505CUST	4979837	10/09/2024 12:00	Total Coliforms	CFU/100 ml	0	0
ZN0505CUST	4979837	10/09/2024 12:00	Turbidity	NTU	0.094	4
ZS0811AE	4967768	10/09/2024 12:06	Aluminium	ug Al/l	37	200
ZS0811AE	4967768	10/09/2024 12:06	Colony Counts 22	CFU/1 ml	0	
ZS0811AE	4967768	10/09/2024 12:06	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0811AE	4967768	10/09/2024 12:06	Colour	mg/l Pt/Co	<4.56	20
ZS0811AE	4967768	10/09/2024 12:06	Conductivity	uS/cm 20 C	380	2500
ZS0811AE	4967768	10/09/2024 12:06	E. coli	CFU/100 ml	0	0
ZS0811AE	4967768	10/09/2024 12:06	Free - Residual disinfectant	mg Cl/l	0.39	
ZS0811AE	4967768	10/09/2024 12:06	Hydrogen Ion	pH value	7.7	9.5
ZS0811AE	4967768	10/09/2024 12:06	Iron	ug/l Fe	37	200
ZS0811AE	4967768	10/09/2024 12:06	Manganese	ug Mn/l	3.5	50
ZS0811AE	4967768	10/09/2024 12:06	Odour	Diln No	0	0
ZS0811AE	4967768	10/09/2024 12:06	Odour - Nature		No odour	
ZS0811AE	4967768	10/09/2024 12:06	Taste	Diln No	0	0
ZS0811AE	4967768	10/09/2024 12:06	Taste - Nature		No taste	
ZS0811AE	4967768	10/09/2024 12:06	Total - Residual disinfectant	mg Cl/l	0.55	
ZS0811AE	4967768	10/09/2024 12:06	Total Coliforms	CFU/100 ml	0	0

ZS0811AE	4967768	10/09/2024 12:06	Turbidity	NTU	<0.09	4
ZN0502CUST	4979838	10/09/2024 13:00	Aluminium	ug Al/l	120	200
ZN0502CUST	4979838	10/09/2024 13:00	Colour	mg/l Pt/Co	<4.56	20
ZN0502CUST	4979838	10/09/2024 13:00	E. coli	CFU/100 ml	0	0
ZN0502CUST	4979838	10/09/2024 13:00	Free - Residual disinfectant	mg Cl/l	0.06	
ZN0502CUST	4979838	10/09/2024 13:00	Hydrogen Ion	pH value	7.7	9.5
ZN0502CUST	4979838	10/09/2024 13:00	Iron	ug/l Fe	650	200
ZN0502CUST	4979838	10/09/2024 13:00	Manganese	ug Mn/l	12	50
ZN0502CUST	4979838	10/09/2024 13:00	Odour	Diln No	0	0
ZN0502CUST	4979838	10/09/2024 13:00	Odour - Nature		No odour	
ZN0502CUST	4979838	10/09/2024 13:00	Taste	Diln No	0	0
ZN0502CUST	4979838	10/09/2024 13:00	Taste - Nature		No taste	
ZN0502CUST	4979838	10/09/2024 13:00	Total - Residual disinfectant	mg Cl/l	0.26	
ZN0502CUST	4979838	10/09/2024 13:00	Total Coliforms	CFU/100 ml	0	0
ZN0502CUST	4979838	10/09/2024 13:00	Turbidity	NTU	1.6	4
ZN0504CUST	4980215	11/09/2024 09:00	Aluminium	ug Al/l	32	200
ZN0504CUST	4980215	11/09/2024 09:00	Colour	mg/l Pt/Co	<4.56	20
ZN0504CUST	4980215	11/09/2024 09:00	E. coli	CFU/100 ml	0	0
ZN0504CUST	4980215	11/09/2024 09:00	Hydrogen Ion	pH value	7.7	9.5
ZN0504CUST	4980215	11/09/2024 09:00	Iron	ug/l Fe	12	200
ZN0504CUST	4980215	11/09/2024 09:00	Manganese	ug Mn/l	0.65	50
ZN0504CUST	4980215	11/09/2024 09:00	Odour	Diln No	0	0
ZN0504CUST	4980215	11/09/2024 09:00	Odour - Nature		No odour	
ZN0504CUST	4980215	11/09/2024 09:00	Taste	Diln No	0	0
ZN0504CUST	4980215	11/09/2024 09:00	Taste - Nature		No taste	
ZN0504CUST	4980215	11/09/2024 09:00	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4980215	11/09/2024 09:00	Turbidity	NTU	0.15	4
ZS0811CUST	4980132	11/09/2024 09:00	Aluminium	ug Al/l	16	200
ZS0811CUST	4980132	11/09/2024 09:00	Colour	mg/l Pt/Co	<4.56	20
ZS0811CUST	4980132	11/09/2024 09:00	E. coli	CFU/100 ml	0	0
ZS0811CUST	4980132	11/09/2024 09:00	Free - Residual disinfectant	mg Cl/l	0.4	
ZS0811CUST	4980132	11/09/2024 09:00	Hydrogen Ion	pH value	7.6	9.5
ZS0811CUST	4980132	11/09/2024 09:00	Iron	ug/l Fe	6.4	200
ZS0811CUST	4980132	11/09/2024 09:00	Manganese	ug Mn/l	<0.642	50
ZS0811CUST	4980132	11/09/2024 09:00	Odour	Diln No	0	0
ZS0811CUST	4980132	11/09/2024 09:00	Odour - Nature		No odour	
ZS0811CUST	4980132	11/09/2024 09:00	Taste - Nature		lysis due to bacteriological exceedance	
ZS0811CUST	4980132	11/09/2024 09:00	Total - Residual disinfectant	mg Cl/l	0.6	

ZS0811CUST	4980132	11/09/2024 09:00	Total Coliforms	CFU/100 ml	6	0
ZS0811CUST	4980132	11/09/2024 09:00	Turbidity	NTU	0.23	4
ZN1102CUST	4980133	11/09/2024 09:15	E. coli	CFU/100 ml	0	0
ZN1102CUST	4980133	11/09/2024 09:15	Free - Residual disinfectant	mg Cl/l	0.18	
ZN1102CUST	4980133	11/09/2024 09:15	Total - Residual disinfectant	mg Cl/l	0.29	
ZN1102CUST	4980133	11/09/2024 09:15	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4980211	11/09/2024 09:45	Aluminium	ug Al/l	27	200
ZN0504CUST	4980211	11/09/2024 09:45	Colour	mg/l Pt/Co	<4.56	20
ZN0504CUST	4980211	11/09/2024 09:45	E. coli	CFU/100 ml	0	0
ZN0504CUST	4980211	11/09/2024 09:45	Free - Residual disinfectant	mg Cl/l	0.42	
ZN0504CUST	4980211	11/09/2024 09:45	Hydrogen Ion	pH value	7.7	9.5
ZN0504CUST	4980211	11/09/2024 09:45	Iron	ug/l Fe	36	200
ZN0504CUST	4980211	11/09/2024 09:45	Manganese	ug Mn/l	2.1	50
ZN0504CUST	4980211	11/09/2024 09:45	Odour	Diln No	0	0
ZN0504CUST	4980211	11/09/2024 09:45	Odour - Nature		No odour	
ZN0504CUST	4980211	11/09/2024 09:45	Taste	Diln No	0	0
ZN0504CUST	4980211	11/09/2024 09:45	Taste - Nature		No taste	
ZN0504CUST	4980211	11/09/2024 09:45	Total - Residual disinfectant	mg Cl/l	0.66	
ZN0504CUST	4980211	11/09/2024 09:45	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4980211	11/09/2024 09:45	Turbidity	NTU	0.14	4
ZN0804AE	4967767	11/09/2024 10:07	Aluminium	ug Al/l	41	200
ZN0804AE	4967767	11/09/2024 10:07	Colony Counts 22	CFU/1 ml	7	
ZN0804AE	4967767	11/09/2024 10:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0804AE	4967767	11/09/2024 10:07	Colour	mg/l Pt/Co	<4.56	20
ZN0804AE	4967767	11/09/2024 10:07	Conductivity	uS/cm 20 C	420	2500
ZN0804AE	4967767	11/09/2024 10:07	E. coli	CFU/100 ml	0	0
ZN0804AE	4967767	11/09/2024 10:07	Free - Residual disinfectant	mg Cl/l	0.88	
ZN0804AE	4967767	11/09/2024 10:07	Hydrogen Ion	pH value	8.1	9.5
ZN0804AE	4967767	11/09/2024 10:07	Iron	ug/l Fe	4.2	200
ZN0804AE	4967767	11/09/2024 10:07	Manganese	ug Mn/l	1.3	50
ZN0804AE	4967767	11/09/2024 10:07	Odour	Diln No	0	0
ZN0804AE	4967767	11/09/2024 10:07	Odour - Nature		No odour	
ZN0804AE	4967767	11/09/2024 10:07	Taste	Diln No	0	0
ZN0804AE	4967767	11/09/2024 10:07	Taste - Nature		No taste	
ZN0804AE	4967767	11/09/2024 10:07	Total - Residual disinfectant	mg Cl/l	0.95	
ZN0804AE	4967767	11/09/2024 10:07	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4967767	11/09/2024 10:07	Turbidity	NTU	0.19	4
ZN0504CUST	4980212	11/09/2024 10:20	Aluminium	ug Al/l	31	200

ZN0504CUST	4980212	11/09/2024 10:20	Colour	mg/l Pt/Co	<4.56	20
ZN0504CUST	4980212	11/09/2024 10:20	E. coli	CFU/100 ml	0	0
ZN0504CUST	4980212	11/09/2024 10:20	Free - Residual disinfectant	mg Cl/l	0.16	
ZN0504CUST	4980212	11/09/2024 10:20	Hydrogen Ion	pH value	7.6	9.5
ZN0504CUST	4980212	11/09/2024 10:20	Iron	ug/l Fe	21	200
ZN0504CUST	4980212	11/09/2024 10:20	Manganese	ug Mn/l	1.9	50
ZN0504CUST	4980212	11/09/2024 10:20	Odour	Diln No	0	0
ZN0504CUST	4980212	11/09/2024 10:20	Odour - Nature		No odour	
ZN0504CUST	4980212	11/09/2024 10:20	Taste	Diln No	0	0
ZN0504CUST	4980212	11/09/2024 10:20	Taste - Nature		No taste	
ZN0504CUST	4980212	11/09/2024 10:20	Total - Residual disinfectant	mg Cl/l	0.36	
ZN0504CUST	4980212	11/09/2024 10:20	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4980212	11/09/2024 10:20	Turbidity	NTU	0.11	4
ZN0504CUST	4980213	11/09/2024 10:40	Aluminium	ug Al/l	30	200
ZN0504CUST	4980213	11/09/2024 10:40	Colour	mg/l Pt/Co	<4.56	20
ZN0504CUST	4980213	11/09/2024 10:40	E. coli	CFU/100 ml	0	0
ZN0504CUST	4980213	11/09/2024 10:40	Free - Residual disinfectant	mg Cl/l	0.2	
ZN0504CUST	4980213	11/09/2024 10:40	Hydrogen Ion	pH value	7.6	9.5
ZN0504CUST	4980213	11/09/2024 10:40	Iron	ug/l Fe	22	200
ZN0504CUST	4980213	11/09/2024 10:40	Manganese	ug Mn/l	1.2	50
ZN0504CUST	4980213	11/09/2024 10:40	Odour	Diln No	0	0
ZN0504CUST	4980213	11/09/2024 10:40	Odour - Nature		No odour	
ZN0504CUST	4980213	11/09/2024 10:40	Taste	Diln No	0	0
ZN0504CUST	4980213	11/09/2024 10:40	Taste - Nature		No taste	
ZN0504CUST	4980213	11/09/2024 10:40	Total - Residual disinfectant	mg Cl/l	0.31	
ZN0504CUST	4980213	11/09/2024 10:40	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4980213	11/09/2024 10:40	Turbidity	NTU	0.098	4
ZN0501CUST	4980239	11/09/2024 11:00	Aluminium	ug Al/l	28	200
ZN0501CUST	4980239	11/09/2024 11:00	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4980239	11/09/2024 11:00	E. coli	CFU/100 ml	0	0
ZN0501CUST	4980239	11/09/2024 11:00	Free - Residual disinfectant	mg Cl/l	0.8	
ZN0501CUST	4980239	11/09/2024 11:00	Hydrogen Ion	pH value	7.6	9.5
ZN0501CUST	4980239	11/09/2024 11:00	Iron	ug/l Fe	3.4	200
ZN0501CUST	4980239	11/09/2024 11:00	Manganese	ug Mn/l	<0.642	50
ZN0501CUST	4980239	11/09/2024 11:00	Odour	Diln No	0	0
ZN0501CUST	4980239	11/09/2024 11:00	Odour - Nature		No odour	
ZN0501CUST	4980239	11/09/2024 11:00	Taste	Diln No	0	0
ZN0501CUST	4980239	11/09/2024 11:00	Taste - Nature		No taste	

ZN0501CUST	4980239	11/09/2024 11:00	Total - Residual disinfectant	mg Cl/l	1.31	
ZN0501CUST	4980239	11/09/2024 11:00	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4980239	11/09/2024 11:00	Turbidity	NTU	0.095	4
ZN0505CUST	4980214	11/09/2024 11:20	Aluminium	ug Al/l	31	200
ZN0505CUST	4980214	11/09/2024 11:20	Colour	mg/l Pt/Co	<4.56	20
ZN0505CUST	4980214	11/09/2024 11:20	E. coli	CFU/100 ml	0	0
ZN0505CUST	4980214	11/09/2024 11:20	Free - Residual disinfectant	mg Cl/l	0.05	
ZN0505CUST	4980214	11/09/2024 11:20	Hydrogen Ion	pH value	7.7	9.5
ZN0505CUST	4980214	11/09/2024 11:20	Iron	ug/l Fe	15	200
ZN0505CUST	4980214	11/09/2024 11:20	Manganese	ug Mn/l	0.9	50
ZN0505CUST	4980214	11/09/2024 11:20	Odour	Diln No	0	0
ZN0505CUST	4980214	11/09/2024 11:20	Odour - Nature		No odour	
ZN0505CUST	4980214	11/09/2024 11:20	Taste	Diln No	0	0
ZN0505CUST	4980214	11/09/2024 11:20	Taste - Nature		No taste	
ZN0505CUST	4980214	11/09/2024 11:20	Total - Residual disinfectant	mg Cl/l	0.12	
ZN0505CUST	4980214	11/09/2024 11:20	Total Coliforms	CFU/100 ml	0	0
ZN0505CUST	4980214	11/09/2024 11:20	Turbidity	NTU	0.12	4
ZN0501CUST	4980238	11/09/2024 11:30	Aluminium	ug Al/l	26	200
ZN0501CUST	4980238	11/09/2024 11:30	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4980238	11/09/2024 11:30	E. coli	CFU/100 ml	0	0
ZN0501CUST	4980238	11/09/2024 11:30	Free - Residual disinfectant	mg Cl/l	0.38	
ZN0501CUST	4980238	11/09/2024 11:30	Hydrogen Ion	pH value	7.7	9.5
ZN0501CUST	4980238	11/09/2024 11:30	Iron	ug/l Fe	5.7	200
ZN0501CUST	4980238	11/09/2024 11:30	Manganese	ug Mn/l	<0.642	50
ZN0501CUST	4980238	11/09/2024 11:30	Odour	Diln No	0	0
ZN0501CUST	4980238	11/09/2024 11:30	Odour - Nature		No odour	
ZN0501CUST	4980238	11/09/2024 11:30	Taste	Diln No	0	0
ZN0501CUST	4980238	11/09/2024 11:30	Taste - Nature		No taste	
ZN0501CUST	4980238	11/09/2024 11:30	Total - Residual disinfectant	mg Cl/l	0.6	
ZN0501CUST	4980238	11/09/2024 11:30	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4980238	11/09/2024 11:30	Turbidity	NTU	0.12	4
ZN0501CUST	4980216	11/09/2024 11:39	Aluminium	ug Al/l	32	200
ZN0501CUST	4980216	11/09/2024 11:39	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4980216	11/09/2024 11:39	E. coli	CFU/100 ml	0	0
ZN0501CUST	4980216	11/09/2024 11:39	Hydrogen Ion	pH value	7.7	9.5
ZN0501CUST	4980216	11/09/2024 11:39	Iron	ug/l Fe	2.1	200
ZN0501CUST	4980216	11/09/2024 11:39	Manganese	ug Mn/l	<0.642	50
ZN0501CUST	4980216	11/09/2024 11:39	Odour	Diln No	0	0

ZN0501CUST	4980216	11/09/2024 11:39	Odour - Nature		No odour	
ZN0501CUST	4980216	11/09/2024 11:39	Taste	Diln No	0	0
ZN0501CUST	4980216	11/09/2024 11:39	Taste - Nature		No taste	
ZN0501CUST	4980216	11/09/2024 11:39	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4980216	11/09/2024 11:39	Turbidity	NTU	0.1	4
ZN0501AE	4967411	11/09/2024 11:39	Aluminium	ug Al/l	25	200
ZN0501AE	4967411	11/09/2024 11:39	Colony Counts 22	CFU/1 ml	0	
ZN0501AE	4967411	11/09/2024 11:39	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0501AE	4967411	11/09/2024 11:39	E. coli	CFU/100 ml	0	0
ZN0501AE	4967411	11/09/2024 11:39	Free - Residual disinfectant	mg Cl/l	0.07	
ZN0501AE	4967411	11/09/2024 11:39	Iron	ug/l Fe	3.4	200
ZN0501AE	4967411	11/09/2024 11:39	Manganese	ug Mn/l	<0.80	50
ZN0501AE	4967411	11/09/2024 11:39	Odour	Diln No	3	0
ZN0501AE	4967411	11/09/2024 11:39	Odour - Nature		Musty/Earthy	
ZN0501AE	4967411	11/09/2024 11:39	Taste	Diln No	99	0
ZN0501AE	4967411	11/09/2024 11:39	Taste - Nature		is performed due to odour contravention	
ZN0501AE	4967411	11/09/2024 11:39	Total - Residual disinfectant	mg Cl/l	0.21	
ZN0501AE	4967411	11/09/2024 11:39	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4980240	11/09/2024 12:30	Aluminium	ug Al/l	28	200
ZN0501CUST	4980240	11/09/2024 12:30	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4980240	11/09/2024 12:30	E. coli	CFU/100 ml	0	0
ZN0501CUST	4980240	11/09/2024 12:30	Free - Residual disinfectant	mg Cl/l	0.74	
ZN0501CUST	4980240	11/09/2024 12:30	Hydrogen Ion	pH value	7.6	9.5
ZN0501CUST	4980240	11/09/2024 12:30	Iron	ug/l Fe	2	200
ZN0501CUST	4980240	11/09/2024 12:30	Manganese	ug Mn/l	<0.642	50
ZN0501CUST	4980240	11/09/2024 12:30	Odour	Diln No	0	0
ZN0501CUST	4980240	11/09/2024 12:30	Odour - Nature		No odour	
ZN0501CUST	4980240	11/09/2024 12:30	Taste	Diln No	0	0
ZN0501CUST	4980240	11/09/2024 12:30	Taste - Nature		No taste	
ZN0501CUST	4980240	11/09/2024 12:30	Total - Residual disinfectant	mg Cl/l	0.96	
ZN0501CUST	4980240	11/09/2024 12:30	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4980240	11/09/2024 12:30	Turbidity	NTU	0.093	4
ZN0501CUST	4980237	11/09/2024 14:30	Aluminium	ug Al/l	27	200
ZN0501CUST	4980237	11/09/2024 14:30	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4980237	11/09/2024 14:30	E. coli	CFU/100 ml	0	0
ZN0501CUST	4980237	11/09/2024 14:30	Free - Residual disinfectant	mg Cl/l	0.75	
ZN0501CUST	4980237	11/09/2024 14:30	Hydrogen Ion	pH value	7.7	9.5
ZN0501CUST	4980237	11/09/2024 14:30	Iron	ug/l Fe	3.1	200

ZN0501CUST	4980237	11/09/2024 14:30	Manganese	ug Mn/l	<0.642	50
ZN0501CUST	4980237	11/09/2024 14:30	Odour	Diln No	0	0
ZN0501CUST	4980237	11/09/2024 14:30	Odour - Nature		No odour	
ZN0501CUST	4980237	11/09/2024 14:30	Taste	Diln No	0	0
ZN0501CUST	4980237	11/09/2024 14:30	Taste - Nature		No taste	
ZN0501CUST	4980237	11/09/2024 14:30	Total - Residual disinfectant	mg Cl/l	0.96	
ZN0501CUST	4980237	11/09/2024 14:30	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4980237	11/09/2024 14:30	Turbidity	NTU	0.1	4
ZN0501CUST	4980706	12/09/2024 09:00	Aluminium	ug Al/l	29	200
ZN0501CUST	4980706	12/09/2024 09:00	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4980706	12/09/2024 09:00	E. coli	CFU/100 ml	0	0
ZN0501CUST	4980706	12/09/2024 09:00	Free - Residual disinfectant	mg Cl/l	0.3	
ZN0501CUST	4980706	12/09/2024 09:00	Hydrogen Ion	pH value	7.7	9.5
ZN0501CUST	4980706	12/09/2024 09:00	Iron	ug/l Fe	4.9	200
ZN0501CUST	4980706	12/09/2024 09:00	Manganese	ug Mn/l	0.73	50
ZN0501CUST	4980706	12/09/2024 09:00	Odour	Diln No	0	0
ZN0501CUST	4980706	12/09/2024 09:00	Odour - Nature		No odour	
ZN0501CUST	4980706	12/09/2024 09:00	Taste	Diln No	0	0
ZN0501CUST	4980706	12/09/2024 09:00	Taste - Nature		No taste	
ZN0501CUST	4980706	12/09/2024 09:00	Total - Residual disinfectant	mg Cl/l	0.53	
ZN0501CUST	4980706	12/09/2024 09:00	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4980706	12/09/2024 09:00	Turbidity	NTU	0.12	4
ZS0809CUST	4980499	12/09/2024 09:00	Aluminium	ug Al/l	21	200
ZS0809CUST	4980499	12/09/2024 09:00	Colour	mg/l Pt/Co	<4.56	20
ZS0809CUST	4980499	12/09/2024 09:00	E. coli	CFU/100 ml	0	0
ZS0809CUST	4980499	12/09/2024 09:00	Free - Residual disinfectant	mg Cl/l	0.2	
ZS0809CUST	4980499	12/09/2024 09:00	Hydrogen Ion	pH value	7.6	9.5
ZS0809CUST	4980499	12/09/2024 09:00	Iron	ug/l Fe	8.9	200
ZS0809CUST	4980499	12/09/2024 09:00	Manganese	ug Mn/l	0.78	50
ZS0809CUST	4980499	12/09/2024 09:00	Odour	Diln No	0	0
ZS0809CUST	4980499	12/09/2024 09:00	Odour - Nature		No odour	
ZS0809CUST	4980499	12/09/2024 09:00	Taste	Diln No	0	0
ZS0809CUST	4980499	12/09/2024 09:00	Taste - Nature		No taste	
ZS0809CUST	4980499	12/09/2024 09:00	Total - Residual disinfectant	mg Cl/l	0.4	
ZS0809CUST	4980499	12/09/2024 09:00	Total Coliforms	CFU/100 ml	0	0
ZS0809CUST	4980499	12/09/2024 09:00	Turbidity	NTU	0.094	4
ZN0804AE	4967432	12/09/2024 09:24	Antimony	ug/l Sb	0.074	5
ZN0804AE	4967432	12/09/2024 09:24	Arsenic	ug/l As	0.36	10

ZN0804AE	4967432	12/09/2024 09:24	Boron	mg/l B	<0.0586	1
ZN0804AE	4967432	12/09/2024 09:24	Cadmium	ug/l Cd	<0.042	5
ZN0804AE	4967432	12/09/2024 09:24	Chromium	ug/l Cr	0.51	50
ZN0804AE	4967432	12/09/2024 09:24	E. coli	CFU/100 ml	0	0
ZN0804AE	4967432	12/09/2024 09:24	Free - Residual disinfectant	mg Cl/l	0.97	
ZN0804AE	4967432	12/09/2024 09:24	Selenium	ug/l Se	0.092	10
ZN0804AE	4967432	12/09/2024 09:24	Total - Residual disinfectant	mg Cl/l	1.06	
ZN0804AE	4967432	12/09/2024 09:24	Total Coliforms	CFU/100 ml	0	0
ZS0811CUST	4980500	12/09/2024 10:30	E. coli	CFU/100 ml	1	0
ZS0811CUST	4980500	12/09/2024 10:30	Free - Residual disinfectant	mg Cl/l	0.15	
ZS0811CUST	4980500	12/09/2024 10:30	Total - Residual disinfectant	mg Cl/l	0.21	
ZS0811CUST	4980500	12/09/2024 10:30	Total Coliforms	CFU/100 ml	5	0
ZS0811CUST	4980501	12/09/2024 10:45	E. coli	CFU/100 ml	0	0
ZS0811CUST	4980501	12/09/2024 10:45	Free - Residual disinfectant	mg Cl/l	0.15	
ZS0811CUST	4980501	12/09/2024 10:45	Total - Residual disinfectant	mg Cl/l	0.22	
ZS0811CUST	4980501	12/09/2024 10:45	Total Coliforms	CFU/100 ml	0	0
ZS0811CUST	4980502	12/09/2024 11:00	E. coli	CFU/100 ml	0	0
ZS0811CUST	4980502	12/09/2024 11:00	Free - Residual disinfectant	mg Cl/l	0.16	
ZS0811CUST	4980502	12/09/2024 11:00	Total - Residual disinfectant	mg Cl/l	0.23	
ZS0811CUST	4980502	12/09/2024 11:00	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4980672	12/09/2024 11:08	E. coli	CFU/100 ml	0	0
ZN0501CUST	4980672	12/09/2024 11:08	Free - Residual disinfectant	mg Cl/l	<0.05	
ZN0501CUST	4980672	12/09/2024 11:08	Odour	Diln No	0	0
ZN0501CUST	4980672	12/09/2024 11:08	Odour - Nature		No odour	
ZN0501CUST	4980672	12/09/2024 11:08	Taste	Diln No	0	0
ZN0501CUST	4980672	12/09/2024 11:08	Taste - Nature		No taste	
ZN0501CUST	4980672	12/09/2024 11:08	Total - Residual disinfectant	mg Cl/l	0.16	
ZN0501CUST	4980672	12/09/2024 11:08	Total Coliforms	CFU/100 ml	0	0
ZN0705AE	4967435	12/09/2024 11:23	1,2 Dichloroethane	ug/l	<0.4	3
ZN0705AE	4967435	12/09/2024 11:23	Aluminium	ug Al/l	13	200
ZN0705AE	4967435	12/09/2024 11:23	Antimony	ug/l Sb	0.063	5
ZN0705AE	4967435	12/09/2024 11:23	Arsenic	ug/l As	0.18	10
ZN0705AE	4967435	12/09/2024 11:23	Benzene	ug/l	<0.15	1
ZN0705AE	4967435	12/09/2024 11:23	Boron	mg/l B	<0.0586	1
ZN0705AE	4967435	12/09/2024 11:23	Bromodichloromethane	ug/l	11	
ZN0705AE	4967435	12/09/2024 11:23	Bromoform	ug/l	<3.5	
ZN0705AE	4967435	12/09/2024 11:23	Cadmium	ug/l Cd	<0.042	5
ZN0705AE	4967435	12/09/2024 11:23	Chloroform	ug/l	48	

ZN0705AE	4967435	12/09/2024 11:23	Chromium	ug/l Cr	0.36	50
ZN0705AE	4967435	12/09/2024 11:23	Colour	mg/l Pt/Co	<4.56	20
ZN0705AE	4967435	12/09/2024 11:23	Conductivity	uS/cm 20 C	130	2500
ZN0705AE	4967435	12/09/2024 11:23	Dibromochloromethane	ug/l	1.8	
ZN0705AE	4967435	12/09/2024 11:23	E. coli	CFU/100 ml	0	0
ZN0705AE	4967435	12/09/2024 11:23	Free - Residual disinfectant	mg Cl/l	0.22	
ZN0705AE	4967435	12/09/2024 11:23	Hydrogen Ion	pH value	7.6	9.5
ZN0705AE	4967435	12/09/2024 11:23	Iron	ug/l Fe	5.2	200
ZN0705AE	4967435	12/09/2024 11:23	Manganese	ug Mn/l	0.98	50
ZN0705AE	4967435	12/09/2024 11:23	Selenium	ug/l Se	<0.057	10
ZN0705AE	4967435	12/09/2024 11:23	Tetrachloroethene	ug/l	<0.8	
ZN0705AE	4967435	12/09/2024 11:23	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0705AE	4967435	12/09/2024 11:23	Tetrachloromethane	ug/l	<0.4	3
ZN0705AE	4967435	12/09/2024 11:23	Total - Residual disinfectant	mg Cl/l	0.35	
ZN0705AE	4967435	12/09/2024 11:23	Total Coliforms	CFU/100 ml	0	0
ZN0705AE	4967435	12/09/2024 11:23	Total Trihalomethanes	ug/l	61	100
ZN0705AE	4967435	12/09/2024 11:23	Trichloroethene	ug/l	<0.7	
ZN0705AE	4967435	12/09/2024 11:23	Turbidity	NTU	0.16	4
ZN0705AE	4967435	12/09/2024 11:23	WHO Index		0.37	1
ZN0504CUST	4980709	12/09/2024 11:30	Aluminium	ug Al/l	29	200
ZN0504CUST	4980709	12/09/2024 11:30	Colour	mg/l Pt/Co	<4.56	20
ZN0504CUST	4980709	12/09/2024 11:30	E. coli	CFU/100 ml	0	0
ZN0504CUST	4980709	12/09/2024 11:30	Free - Residual disinfectant	mg Cl/l	0.19	
ZN0504CUST	4980709	12/09/2024 11:30	Hydrogen Ion	pH value	7.6	9.5
ZN0504CUST	4980709	12/09/2024 11:30	Iron	ug/l Fe	3.9	200
ZN0504CUST	4980709	12/09/2024 11:30	Manganese	ug Mn/l	<0.642	50
ZN0504CUST	4980709	12/09/2024 11:30	Odour	Diln No	0	0
ZN0504CUST	4980709	12/09/2024 11:30	Odour - Nature		No odour	
ZN0504CUST	4980709	12/09/2024 11:30	Taste	Diln No	0	0
ZN0504CUST	4980709	12/09/2024 11:30	Taste - Nature		No taste	
ZN0504CUST	4980709	12/09/2024 11:30	Total - Residual disinfectant	mg Cl/l	0.27	
ZN0504CUST	4980709	12/09/2024 11:30	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4980709	12/09/2024 11:30	Turbidity	NTU	0.094	4
ZS0809AE	4967969	12/09/2024 11:31	E. coli	CFU/100 ml	0	0
ZS0809AE	4967969	12/09/2024 11:31	Free - Residual disinfectant	mg Cl/l	0.49	
ZS0809AE	4967969	12/09/2024 11:31	Total - Residual disinfectant	mg Cl/l	0.8	
ZS0809AE	4967969	12/09/2024 11:31	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4980673	12/09/2024 11:35	E. coli	CFU/100 ml	0	0

ZN0501CUST	4980673	12/09/2024 11:35	Free - Residual disinfectant	mg Cl/l	<0.05	
ZN0501CUST	4980673	12/09/2024 11:35	Odour	Diln No	0	0
ZN0501CUST	4980673	12/09/2024 11:35	Odour - Nature		No odour	
ZN0501CUST	4980673	12/09/2024 11:35	Taste	Diln No	0	0
ZN0501CUST	4980673	12/09/2024 11:35	Taste - Nature		No taste	
ZN0501CUST	4980673	12/09/2024 11:35	Total - Residual disinfectant	mg Cl/l	0.18	
ZN0501CUST	4980673	12/09/2024 11:35	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4980674	12/09/2024 12:00	E. coli	CFU/100 ml	0	0
ZN0501CUST	4980674	12/09/2024 12:00	Free - Residual disinfectant	mg Cl/l	0.06	
ZN0501CUST	4980674	12/09/2024 12:00	Odour	Diln No	0	0
ZN0501CUST	4980674	12/09/2024 12:00	Odour - Nature		No odour	
ZN0501CUST	4980674	12/09/2024 12:00	Taste	Diln No	0	0
ZN0501CUST	4980674	12/09/2024 12:00	Taste - Nature		No taste	
ZN0501CUST	4980674	12/09/2024 12:00	Total - Residual disinfectant	mg Cl/l	0.22	
ZN0501CUST	4980674	12/09/2024 12:00	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4980708	12/09/2024 12:15	Aluminium	ug Al/l	22	200
ZN0504CUST	4980708	12/09/2024 12:15	Colour	mg/l Pt/Co	<4.56	20
ZN0504CUST	4980708	12/09/2024 12:15	E. coli	CFU/100 ml	0	0
ZN0504CUST	4980708	12/09/2024 12:15	Free - Residual disinfectant	mg Cl/l	0.12	
ZN0504CUST	4980708	12/09/2024 12:15	Hydrogen Ion	pH value	7.7	9.5
ZN0504CUST	4980708	12/09/2024 12:15	Iron	ug/l Fe	60	200
ZN0504CUST	4980708	12/09/2024 12:15	Manganese	ug Mn/l	4.5	50
ZN0504CUST	4980708	12/09/2024 12:15	Odour	Diln No	0	0
ZN0504CUST	4980708	12/09/2024 12:15	Odour - Nature		No odour	
ZN0504CUST	4980708	12/09/2024 12:15	Taste	Diln No	0	0
ZN0504CUST	4980708	12/09/2024 12:15	Taste - Nature		No taste	
ZN0504CUST	4980708	12/09/2024 12:15	Total - Residual disinfectant	mg Cl/l	0.26	
ZN0504CUST	4980708	12/09/2024 12:15	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4980708	12/09/2024 12:15	Turbidity	NTU	0.28	4
ZN0501CUST	4980707	12/09/2024 13:45	Aluminium	ug Al/l	52	200
ZN0501CUST	4980707	12/09/2024 13:45	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4980707	12/09/2024 13:45	E. coli	CFU/100 ml	0	0
ZN0501CUST	4980707	12/09/2024 13:45	Free - Residual disinfectant	mg Cl/l	0.19	
ZN0501CUST	4980707	12/09/2024 13:45	Hydrogen Ion	pH value	7.9	9.5
ZN0501CUST	4980707	12/09/2024 13:45	Iron	ug/l Fe	71	200
ZN0501CUST	4980707	12/09/2024 13:45	Manganese	ug Mn/l	3.4	50
ZN0501CUST	4980707	12/09/2024 13:45	Odour	Diln No	0	0
ZN0501CUST	4980707	12/09/2024 13:45	Odour - Nature		No odour	

ZN0501CUST	4980707	12/09/2024 13:45	Taste	Diln No	0	0
ZN0501CUST	4980707	12/09/2024 13:45	Taste - Nature		No taste	
ZN0501CUST	4980707	12/09/2024 13:45	Total - Residual disinfectant	mg Cl/l	0.36	
ZN0501CUST	4980707	12/09/2024 13:45	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4980707	12/09/2024 13:45	Turbidity	NTU	0.27	4
ZN0501CUST	4980697	12/09/2024 14:00	Aluminium	ug Al/l	26	200
ZN0501CUST	4980697	12/09/2024 14:00	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4980697	12/09/2024 14:00	E. coli	CFU/100 ml	0	0
ZN0501CUST	4980697	12/09/2024 14:00	Free - Residual disinfectant	mg Cl/l	0.3	
ZN0501CUST	4980697	12/09/2024 14:00	Hydrogen Ion	pH value	7.6	9.5
ZN0501CUST	4980697	12/09/2024 14:00	Iron	ug/l Fe	13	200
ZN0501CUST	4980697	12/09/2024 14:00	Manganese	ug Mn/l	1.2	50
ZN0501CUST	4980697	12/09/2024 14:00	Odour	Diln No	0	0
ZN0501CUST	4980697	12/09/2024 14:00	Odour - Nature		No odour	
ZN0501CUST	4980697	12/09/2024 14:00	Taste	Diln No	0	0
ZN0501CUST	4980697	12/09/2024 14:00	Taste - Nature		No taste	
ZN0501CUST	4980697	12/09/2024 14:00	Total - Residual disinfectant	mg Cl/l	0.39	
ZN0501CUST	4980697	12/09/2024 14:00	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4980697	12/09/2024 14:00	Turbidity	NTU	<0.09	4
ZN0505CUST	4980955	13/09/2024 08:36	E. coli	CFU/100 ml	0	0
ZN0505CUST	4980955	13/09/2024 08:36	Free - Residual disinfectant	mg Cl/l	0.23	
ZN0505CUST	4980955	13/09/2024 08:36	Odour	Diln No	0	0
ZN0505CUST	4980955	13/09/2024 08:36	Odour - Nature		No odour	
ZN0505CUST	4980955	13/09/2024 08:36	Taste	Diln No	0	0
ZN0505CUST	4980955	13/09/2024 08:36	Taste - Nature		No taste	
ZN0505CUST	4980955	13/09/2024 08:36	Total - Residual disinfectant	mg Cl/l	0.43	
ZN0505CUST	4980955	13/09/2024 08:36	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4981025	13/09/2024 08:45	Aluminium	ug Al/l	26	200
ZN0501CUST	4981025	13/09/2024 08:45	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4981025	13/09/2024 08:45	E. coli	CFU/100 ml	0	0
ZN0501CUST	4981025	13/09/2024 08:45	Free - Residual disinfectant	mg Cl/l	0.54	
ZN0501CUST	4981025	13/09/2024 08:45	Hydrogen Ion	pH value	7.6	9.5
ZN0501CUST	4981025	13/09/2024 08:45	Iron	ug/l Fe	3.1	200
ZN0501CUST	4981025	13/09/2024 08:45	Manganese	ug Mn/l	<0.642	50
ZN0501CUST	4981025	13/09/2024 08:45	Odour	Diln No	0	0
ZN0501CUST	4981025	13/09/2024 08:45	Odour - Nature		No odour	
ZN0501CUST	4981025	13/09/2024 08:45	Taste	Diln No	0	0
ZN0501CUST	4981025	13/09/2024 08:45	Taste - Nature		No taste	

ZN0501CUST	4981025	13/09/2024 08:45	Total - Residual disinfectant	mg Cl/l	0.89	
ZN0501CUST	4981025	13/09/2024 08:45	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4981025	13/09/2024 08:45	Turbidity	NTU	<0.09	4
ZN0501CUST	4980945	13/09/2024 09:12	E. coli	CFU/100 ml	0	0
ZN0501CUST	4980945	13/09/2024 09:12	Free - Residual disinfectant	mg Cl/l	0.12	
ZN0501CUST	4980945	13/09/2024 09:12	Odour	Diln No	0	0
ZN0501CUST	4980945	13/09/2024 09:12	Odour - Nature		No odour	
ZN0501CUST	4980945	13/09/2024 09:12	Taste	Diln No	0	0
ZN0501CUST	4980945	13/09/2024 09:12	Taste - Nature		No taste	
ZN0501CUST	4980945	13/09/2024 09:12	Total - Residual disinfectant	mg Cl/l	0.28	
ZN0501CUST	4980945	13/09/2024 09:12	Total Coliforms	CFU/100 ml	0	0
ZN0505CUST	4981016	13/09/2024 10:00	Aluminium	ug Al/l	28	200
ZN0505CUST	4981016	13/09/2024 10:00	Colour	mg/l Pt/Co	<4.56	20
ZN0505CUST	4981016	13/09/2024 10:00	E. coli	CFU/100 ml	0	0
ZN0505CUST	4981016	13/09/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.3	
ZN0505CUST	4981016	13/09/2024 10:00	Hydrogen Ion	pH value	7.7	9.5
ZN0505CUST	4981016	13/09/2024 10:00	Iron	ug/l Fe	110	200
ZN0505CUST	4981016	13/09/2024 10:00	Manganese	ug Mn/l	1.7	50
ZN0505CUST	4981016	13/09/2024 10:00	Odour	Diln No	8	0
ZN0505CUST	4981016	13/09/2024 10:00	Odour - Nature		Farmlike/yeasty/earthy	
ZN0505CUST	4981016	13/09/2024 10:00	Taste	Diln No	99	0
ZN0505CUST	4981016	13/09/2024 10:00	Taste - Nature		is performed due to odour contravention	
ZN0505CUST	4981016	13/09/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.4	
ZN0505CUST	4981016	13/09/2024 10:00	Total Coliforms	CFU/100 ml	0	0
ZN0505CUST	4981016	13/09/2024 10:00	Turbidity	NTU	0.37	4
ZN0505CUST	4980867	13/09/2024 10:15	E. coli	CFU/100 ml	0	0
ZN0505CUST	4980867	13/09/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.37	
ZN0505CUST	4980867	13/09/2024 10:15	Odour	Diln No	0	0
ZN0505CUST	4980867	13/09/2024 10:15	Odour - Nature		No odour	
ZN0505CUST	4980867	13/09/2024 10:15	Taste	Diln No	0	0
ZN0505CUST	4980867	13/09/2024 10:15	Taste - Nature		No taste	
ZN0505CUST	4980867	13/09/2024 10:15	Total - Residual disinfectant	mg Cl/l	0.45	
ZN0505CUST	4980867	13/09/2024 10:15	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4981017	13/09/2024 10:45	Aluminium	ug Al/l	28	200
ZN0501CUST	4981017	13/09/2024 10:45	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4981017	13/09/2024 10:45	E. coli	CFU/100 ml	0	0
ZN0501CUST	4981017	13/09/2024 10:45	Free - Residual disinfectant	mg Cl/l	0.08	
ZN0501CUST	4981017	13/09/2024 10:45	Hydrogen Ion	pH value	7.6	9.5

ZN0501CUST	4981017	13/09/2024 10:45	Iron	ug/l Fe	4	200
ZN0501CUST	4981017	13/09/2024 10:45	Manganese	ug Mn/l	0.81	50
ZN0501CUST	4981017	13/09/2024 10:45	Odour	Diln No	0	0
ZN0501CUST	4981017	13/09/2024 10:45	Odour - Nature		No odour	
ZN0501CUST	4981017	13/09/2024 10:45	Taste	Diln No	0	0
ZN0501CUST	4981017	13/09/2024 10:45	Taste - Nature		No taste	
ZN0501CUST	4981017	13/09/2024 10:45	Total - Residual disinfectant	mg Cl/l	0.24	
ZN0501CUST	4981017	13/09/2024 10:45	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4981017	13/09/2024 10:45	Turbidity	NTU	0.12	4
ZN0504AE	4967383	13/09/2024 11:10	1,2 Dichloroethane	ug/l	<0.4	3
ZN0504AE	4967383	13/09/2024 11:10	Benzene	ug/l	<0.15	1
ZN0504AE	4967383	13/09/2024 11:10	E. coli	CFU/100 ml	0	0
ZN0504AE	4967383	13/09/2024 11:10	Free - Residual disinfectant	mg Cl/l	0.12	
ZN0504AE	4967383	13/09/2024 11:10	Tetrachloroethene	ug/l	<0.8	
ZN0504AE	4967383	13/09/2024 11:10	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0504AE	4967383	13/09/2024 11:10	Tetrachloromethane	ug/l	<0.4	3
ZN0504AE	4967383	13/09/2024 11:10	Total - Residual disinfectant	mg Cl/l	0.28	
ZN0504AE	4967383	13/09/2024 11:10	Total Coliforms	CFU/100 ml	0	0
ZN0504AE	4967383	13/09/2024 11:10	Trichloroethene	ug/l	<0.7	
ZN0501CUST	4981018	13/09/2024 11:15	Aluminium	ug Al/l	27	200
ZN0501CUST	4981018	13/09/2024 11:15	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4981018	13/09/2024 11:15	E. coli	CFU/100 ml	0	0
ZN0501CUST	4981018	13/09/2024 11:15	Free - Residual disinfectant	mg Cl/l	0.71	
ZN0501CUST	4981018	13/09/2024 11:15	Hydrogen Ion	pH value	7.7	9.5
ZN0501CUST	4981018	13/09/2024 11:15	Iron	ug/l Fe	2.9	200
ZN0501CUST	4981018	13/09/2024 11:15	Manganese	ug Mn/l	<0.642	50
ZN0501CUST	4981018	13/09/2024 11:15	Odour	Diln No	0	0
ZN0501CUST	4981018	13/09/2024 11:15	Odour - Nature		No odour	
ZN0501CUST	4981018	13/09/2024 11:15	Taste	Diln No	0	0
ZN0501CUST	4981018	13/09/2024 11:15	Taste - Nature		No taste	
ZN0501CUST	4981018	13/09/2024 11:15	Total - Residual disinfectant	mg Cl/l	0.92	
ZN0501CUST	4981018	13/09/2024 11:15	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4981018	13/09/2024 11:15	Turbidity	NTU	0.13	4
ZS0811CUST	4980872	13/09/2024 11:30	E. coli	CFU/100 ml	0	0
ZS0811CUST	4980872	13/09/2024 11:30	Free - Residual disinfectant	mg Cl/l	0.15	
ZS0811CUST	4980872	13/09/2024 11:30	Total - Residual disinfectant	mg Cl/l	0.23	
ZS0811CUST	4980872	13/09/2024 11:30	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4981019	13/09/2024 12:00	Aluminium	ug Al/l	29	200

ZN0501CUST	4981019	13/09/2024 12:00	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4981019	13/09/2024 12:00	E. coli	CFU/100 ml	0	0
ZN0501CUST	4981019	13/09/2024 12:00	Free - Residual disinfectant	mg Cl/l	0.8	
ZN0501CUST	4981019	13/09/2024 12:00	Hydrogen Ion	pH value	7.7	9.5
ZN0501CUST	4981019	13/09/2024 12:00	Iron	ug/l Fe	<1.538	200
ZN0501CUST	4981019	13/09/2024 12:00	Manganese	ug Mn/l	<0.642	50
ZN0501CUST	4981019	13/09/2024 12:00	Odour	Diln No	0	0
ZN0501CUST	4981019	13/09/2024 12:00	Odour - Nature		No odour	
ZN0501CUST	4981019	13/09/2024 12:00	Taste	Diln No	0	0
ZN0501CUST	4981019	13/09/2024 12:00	Taste - Nature		No taste	
ZN0501CUST	4981019	13/09/2024 12:00	Total - Residual disinfectant	mg Cl/l	1.01	
ZN0501CUST	4981019	13/09/2024 12:00	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4981019	13/09/2024 12:00	Turbidity	NTU	0.1	4
ZN0501CUST	4981020	13/09/2024 13:15	Aluminium	ug Al/l	320	200
ZN0501CUST	4981020	13/09/2024 13:15	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4981020	13/09/2024 13:15	E. coli	CFU/100 ml	0	0
ZN0501CUST	4981020	13/09/2024 13:15	Free - Residual disinfectant	mg Cl/l	0.25	
ZN0501CUST	4981020	13/09/2024 13:15	Hydrogen Ion	pH value	7.9	9.5
ZN0501CUST	4981020	13/09/2024 13:15	Iron	ug/l Fe	1100	200
ZN0501CUST	4981020	13/09/2024 13:15	Manganese	ug Mn/l	32	50
ZN0501CUST	4981020	13/09/2024 13:15	Odour	Diln No	0	0
ZN0501CUST	4981020	13/09/2024 13:15	Odour - Nature		No odour	
ZN0501CUST	4981020	13/09/2024 13:15	Taste - Nature		e to sample appearance or particulate matter	
ZN0501CUST	4981020	13/09/2024 13:15	Total - Residual disinfectant	mg Cl/l	0.28	
ZN0501CUST	4981020	13/09/2024 13:15	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4981020	13/09/2024 13:15	Turbidity	NTU	3.3	4
ZS0811CUST	4981217	14/09/2024 13:00	E. coli	CFU/100 ml	0	0
ZS0811CUST	4981217	14/09/2024 13:00	Free - Residual disinfectant	mg Cl/l	<0.05	
ZS0811CUST	4981217	14/09/2024 13:00	Total - Residual disinfectant	mg Cl/l	0.14	
ZS0811CUST	4981217	14/09/2024 13:00	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4981310	15/09/2024 11:45	E. coli	CFU/100 ml	0	0
ZN0501CUST	4981310	15/09/2024 11:45	Free - Residual disinfectant	mg Cl/l	0.21	
ZN0501CUST	4981310	15/09/2024 11:45	Total - Residual disinfectant	mg Cl/l	0.92	
ZN0501CUST	4981310	15/09/2024 11:45	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4981311	15/09/2024 12:15	E. coli	CFU/100 ml	0	0
ZN0501CUST	4981311	15/09/2024 12:15	Free - Residual disinfectant	mg Cl/l	<0.05	
ZN0501CUST	4981311	15/09/2024 12:15	Total - Residual disinfectant	mg Cl/l	0.14	
ZN0501CUST	4981311	15/09/2024 12:15	Total Coliforms	CFU/100 ml	0	0

ZN1102CUST	4981370	16/09/2024 09:00	Aluminium	ug Al/l	6.5	200
ZN1102CUST	4981370	16/09/2024 09:00	Colour	mg/l Pt/Co	<4.56	20
ZN1102CUST	4981370	16/09/2024 09:00	E. coli	CFU/100 ml	0	0
ZN1102CUST	4981370	16/09/2024 09:00	Free - Residual disinfectant	mg Cl/l	0.2	
ZN1102CUST	4981370	16/09/2024 09:00	Hydrogen Ion	pH value	7.5	9.5
ZN1102CUST	4981370	16/09/2024 09:00	Iron	ug/l Fe	45	200
ZN1102CUST	4981370	16/09/2024 09:00	Manganese	ug Mn/l	1.4	50
ZN1102CUST	4981370	16/09/2024 09:00	Odour	Diln No	0	0
ZN1102CUST	4981370	16/09/2024 09:00	Odour - Nature		No odour	
ZN1102CUST	4981370	16/09/2024 09:00	Taste	Diln No	0	0
ZN1102CUST	4981370	16/09/2024 09:00	Taste - Nature		No taste	
ZN1102CUST	4981370	16/09/2024 09:00	Total - Residual disinfectant	mg Cl/l	0.45	
ZN1102CUST	4981370	16/09/2024 09:00	Total Coliforms	CFU/100 ml	0	0
ZN1102CUST	4981370	16/09/2024 09:00	Turbidity	NTU	0.19	4
ZN0102AE	4970779	16/09/2024 09:24	Aluminium	ug Al/l	24	200
ZN0102AE	4970779	16/09/2024 09:24	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN0102AE	4970779	16/09/2024 09:24	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0102AE	4970779	16/09/2024 09:24	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0102AE	4970779	16/09/2024 09:24	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0102AE	4970779	16/09/2024 09:24	Bromate	ug BrO3/l	<0.50	10
ZN0102AE	4970779	16/09/2024 09:24	Colony Counts 22	CFU/1 ml	3	
ZN0102AE	4970779	16/09/2024 09:24	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0102AE	4970779	16/09/2024 09:24	Colour	mg/l Pt/Co	<4.56	20
ZN0102AE	4970779	16/09/2024 09:24	Conductivity	uS/cm 20 C	330	2500
ZN0102AE	4970779	16/09/2024 09:24	E. coli	CFU/100 ml	0	0
ZN0102AE	4970779	16/09/2024 09:24	Free - Residual disinfectant	mg Cl/l	0.22	
ZN0102AE	4970779	16/09/2024 09:24	Hydrogen Ion	pH value	7.7	9.5
ZN0102AE	4970779	16/09/2024 09:24	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0102AE	4970779	16/09/2024 09:24	Iron	ug/l Fe	4.9	200
ZN0102AE	4970779	16/09/2024 09:24	Manganese	ug Mn/l	<0.80	50
ZN0102AE	4970779	16/09/2024 09:24	Odour	Diln No	0	0
ZN0102AE	4970779	16/09/2024 09:24	Odour - Nature		No odour	
ZN0102AE	4970779	16/09/2024 09:24	PAH - Sum of four substances	ug/l	0	0.1
ZN0102AE	4970779	16/09/2024 09:24	Taste	Diln No	0	0
ZN0102AE	4970779	16/09/2024 09:24	Taste - Nature		No taste	
ZN0102AE	4970779	16/09/2024 09:24	Total - Residual disinfectant	mg Cl/l	0.3	
ZN0102AE	4970779	16/09/2024 09:24	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4970779	16/09/2024 09:24	Turbidity	NTU	<0.09	4

ZN0504AE	4986729	16/09/2024 09:33	Aluminium	ug Al/l	14	200
ZN0504AE	4986729	16/09/2024 09:33	Colony Counts 22	CFU/1 ml	0	
ZN0504AE	4986729	16/09/2024 09:33	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0504AE	4986729	16/09/2024 09:33	Colour	mg/l Pt/Co	<4.56	20
ZN0504AE	4986729	16/09/2024 09:33	Conductivity	uS/cm 20 C	220	2500
ZN0504AE	4986729	16/09/2024 09:33	E. coli	CFU/100 ml	0	0
ZN0504AE	4986729	16/09/2024 09:33	Free - Residual disinfectant	mg Cl/l	0.2	
ZN0504AE	4986729	16/09/2024 09:33	Hydrogen Ion	pH value	7.5	9.5
ZN0504AE	4986729	16/09/2024 09:33	Iron	ug/l Fe	19	200
ZN0504AE	4986729	16/09/2024 09:33	Manganese	ug Mn/l	<0.80	50
ZN0504AE	4986729	16/09/2024 09:33	Odour	Diln No	0	0
ZN0504AE	4986729	16/09/2024 09:33	Odour - Nature		No odour	
ZN0504AE	4986729	16/09/2024 09:33	Taste	Diln No	0	0
ZN0504AE	4986729	16/09/2024 09:33	Taste - Nature		No taste	
ZN0504AE	4986729	16/09/2024 09:33	Total - Residual disinfectant	mg Cl/l	0.36	
ZN0504AE	4986729	16/09/2024 09:33	Total Coliforms	CFU/100 ml	0	0
ZN0504AE	4986729	16/09/2024 09:33	Turbidity	NTU	0.12	4
ZN0706AE	4970774	16/09/2024 09:51	1,2 Dichloroethane	ug/l	<0.4	3
ZN0706AE	4970774	16/09/2024 09:51	Benzene	ug/l	<0.15	1
ZN0706AE	4970774	16/09/2024 09:51	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN0706AE	4970774	16/09/2024 09:51	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0706AE	4970774	16/09/2024 09:51	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0706AE	4970774	16/09/2024 09:51	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0706AE	4970774	16/09/2024 09:51	Bromate	ug BrO3/l	1.2	10
ZN0706AE	4970774	16/09/2024 09:51	E. coli	CFU/100 ml	0	0
ZN0706AE	4970774	16/09/2024 09:51	Free - Residual disinfectant	mg Cl/l	0.09	
ZN0706AE	4970774	16/09/2024 09:51	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0706AE	4970774	16/09/2024 09:51	PAH - Sum of four substances	ug/l	0	0.1
ZN0706AE	4970774	16/09/2024 09:51	Tetrachloroethene	ug/l	<0.8	
ZN0706AE	4970774	16/09/2024 09:51	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0706AE	4970774	16/09/2024 09:51	Tetrachloromethane	ug/l	<0.4	3
ZN0706AE	4970774	16/09/2024 09:51	Total - Residual disinfectant	mg Cl/l	0.16	
ZN0706AE	4970774	16/09/2024 09:51	Total Coliforms	CFU/100 ml	0	0
ZN0706AE	4970774	16/09/2024 09:51	Trichloroethene	ug/l	<0.7	
ZN0505AE	4970865	16/09/2024 10:07	1,2 Dichloroethane	ug/l	<0.4	3
ZN0505AE	4970865	16/09/2024 10:07	Aluminium	ug Al/l	20	200
ZN0505AE	4970865	16/09/2024 10:07	Ammonium	mg NH4/l	<0.01	0.5
ZN0505AE	4970865	16/09/2024 10:07	Antimony	ug/l Sb	0.14	5

ZN0505AE	4970865	16/09/2024 10:07	Arsenic	ug/l As	0.5	10
ZN0505AE	4970865	16/09/2024 10:07	Benzene	ug/l	<0.15	1
ZN0505AE	4970865	16/09/2024 10:07	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN0505AE	4970865	16/09/2024 10:07	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0505AE	4970865	16/09/2024 10:07	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0505AE	4970865	16/09/2024 10:07	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0505AE	4970865	16/09/2024 10:07	Boron	mg/l B	<0.0586	1
ZN0505AE	4970865	16/09/2024 10:07	Bromate	ug BrO3/l	<0.50	10
ZN0505AE	4970865	16/09/2024 10:07	Bromodichloromethane	ug/l	12	
ZN0505AE	4970865	16/09/2024 10:07	Bromoform	ug/l	<3.5	
ZN0505AE	4970865	16/09/2024 10:07	Cadmium	ug/l Cd	<0.042	5
ZN0505AE	4970865	16/09/2024 10:07	Calcium	mg/l	56	
ZN0505AE	4970865	16/09/2024 10:07	Chloroform	ug/l	30	
ZN0505AE	4970865	16/09/2024 10:07	Chromium	ug/l Cr	0.75	50
ZN0505AE	4970865	16/09/2024 10:07	Colony Counts 22	CFU/1 ml	0	
ZN0505AE	4970865	16/09/2024 10:07	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0505AE	4970865	16/09/2024 10:07	Colour	mg/l Pt/Co	<4.56	20
ZN0505AE	4970865	16/09/2024 10:07	Conductivity	uS/cm 20 C	390	2500
ZN0505AE	4970865	16/09/2024 10:07	Copper	mg Cu/l	<0.546	2
ZN0505AE	4970865	16/09/2024 10:07	Dibromochloromethane	ug/l	6	
ZN0505AE	4970865	16/09/2024 10:07	E. coli	CFU/100 ml	0	0
ZN0505AE	4970865	16/09/2024 10:07	Enterococci	CFU/100ml	0	0
ZN0505AE	4970865	16/09/2024 10:07	Free - Residual disinfectant	mg Cl/l	0.17	
ZN0505AE	4970865	16/09/2024 10:07	Hydrogen Ion	pH value	7.7	9.5
ZN0505AE	4970865	16/09/2024 10:07	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0505AE	4970865	16/09/2024 10:07	Iron	ug/l Fe	22	200
ZN0505AE	4970865	16/09/2024 10:07	Lead	ug Pb/l	<0.095	10
ZN0505AE	4970865	16/09/2024 10:07	Magnesium	mg/l	10	
ZN0505AE	4970865	16/09/2024 10:07	Manganese	ug Mn/l	0.8	50
ZN0505AE	4970865	16/09/2024 10:07	Mercury	ug per l	<0.041	1
ZN0505AE	4970865	16/09/2024 10:07	Nickel	ug Ni/l	0.7	20
ZN0505AE	4970865	16/09/2024 10:07	Odour	Diln No	0	0
ZN0505AE	4970865	16/09/2024 10:07	Odour - Nature		No odour	
ZN0505AE	4970865	16/09/2024 10:07	PAH - Sum of four substances	ug/l	0	0.1
ZN0505AE	4970865	16/09/2024 10:07	Potassium	mg/l	3.4	
ZN0505AE	4970865	16/09/2024 10:07	Selenium	ug/l Se	0.08	10
ZN0505AE	4970865	16/09/2024 10:07	Sodium	mg Na/l	14	200
ZN0505AE	4970865	16/09/2024 10:07	Taste	Diln No	0	0

ZN0505AE	4970865	16/09/2024 10:07	Taste - Nature		No taste	
ZN0505AE	4970865	16/09/2024 10:07	Tetrachloroethene	ug/l	<0.8	
ZN0505AE	4970865	16/09/2024 10:07	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0505AE	4970865	16/09/2024 10:07	Tetrachloromethane	ug/l	<0.4	3
ZN0505AE	4970865	16/09/2024 10:07	Total - Residual disinfectant	mg Cl/l	0.35	
ZN0505AE	4970865	16/09/2024 10:07	Total Coliforms	CFU/100 ml	0	0
ZN0505AE	4970865	16/09/2024 10:07	Total hardness	mg/l	72	
ZN0505AE	4970865	16/09/2024 10:07	Total Trihalomethanes	ug/l	49	100
ZN0505AE	4970865	16/09/2024 10:07	Trichloroethene	ug/l	<0.7	
ZN0505AE	4970865	16/09/2024 10:07	Turbidity	NTU	<0.09	4
ZN0505AE	4970865	16/09/2024 10:07	WHO Index		0.37	1
ZN0505CUST	4981543	16/09/2024 10:45	Aluminium	ug Al/l	23	200
ZN0505CUST	4981543	16/09/2024 10:45	Colour	mg/l Pt/Co	<4.56	20
ZN0505CUST	4981543	16/09/2024 10:45	E. coli	CFU/100 ml	0	0
ZN0505CUST	4981543	16/09/2024 10:45	Free - Residual disinfectant	mg Cl/l	0.1	
ZN0505CUST	4981543	16/09/2024 10:45	Hydrogen Ion	pH value	7.7	9.5
ZN0505CUST	4981543	16/09/2024 10:45	Iron	ug/l Fe	25	200
ZN0505CUST	4981543	16/09/2024 10:45	Manganese	ug Mn/l	1	50
ZN0505CUST	4981543	16/09/2024 10:45	Odour	Diln No	10	0
ZN0505CUST	4981543	16/09/2024 10:45	Odour - Nature		Musty/Earthy	
ZN0505CUST	4981543	16/09/2024 10:45	Taste	Diln No	0	0
ZN0505CUST	4981543	16/09/2024 10:45	Taste - Nature		No taste	
ZN0505CUST	4981543	16/09/2024 10:45	Total - Residual disinfectant	mg Cl/l	0.34	
ZN0505CUST	4981543	16/09/2024 10:45	Total Coliforms	CFU/100 ml	0	0
ZN0505CUST	4981543	16/09/2024 10:45	Turbidity	NTU	0.1	4
ZN0705AE	4970798	16/09/2024 10:49	Aluminium	ug Al/l	11	200
ZN0705AE	4970798	16/09/2024 10:49	Colony Counts 22	CFU/1 ml	0	
ZN0705AE	4970798	16/09/2024 10:49	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0705AE	4970798	16/09/2024 10:49	Colour	mg/l Pt/Co	<4.56	20
ZN0705AE	4970798	16/09/2024 10:49	Conductivity	uS/cm 20 C	130	2500
ZN0705AE	4970798	16/09/2024 10:49	E. coli	CFU/100 ml	0	0
ZN0705AE	4970798	16/09/2024 10:49	Free - Residual disinfectant	mg Cl/l	0.47	
ZN0705AE	4970798	16/09/2024 10:49	Hydrogen Ion	pH value	7.6	9.5
ZN0705AE	4970798	16/09/2024 10:49	Iron	ug/l Fe	3	200
ZN0705AE	4970798	16/09/2024 10:49	Manganese	ug Mn/l	<0.80	50
ZN0705AE	4970798	16/09/2024 10:49	Odour	Diln No	0	0
ZN0705AE	4970798	16/09/2024 10:49	Odour - Nature		No odour	
ZN0705AE	4970798	16/09/2024 10:49	Taste	Diln No	0	0

ZN0705AE	4970798	16/09/2024 10:49	Taste - Nature		No taste	
ZN0705AE	4970798	16/09/2024 10:49	Total - Residual disinfectant	mg Cl/l	0.55	
ZN0705AE	4970798	16/09/2024 10:49	Total Coliforms	CFU/100 ml	0	0
ZN0705AE	4970798	16/09/2024 10:49	Turbidity	NTU	0.1	4
ZN0501AE	4967754	16/09/2024 11:31	E. coli	CFU/100 ml	0	0
ZN0501AE	4967754	16/09/2024 11:31	Free - Residual disinfectant	mg Cl/l	0.15	
ZN0501AE	4967754	16/09/2024 11:31	Total - Residual disinfectant	mg Cl/l	0.27	
ZN0501AE	4967754	16/09/2024 11:31	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4981551	16/09/2024 13:00	Aluminium	ug Al/l	19	200
ZN0504CUST	4981551	16/09/2024 13:00	Colour	mg/l Pt/Co	<4.56	20
ZN0504CUST	4981551	16/09/2024 13:00	E. coli	CFU/100 ml	0	0
ZN0504CUST	4981551	16/09/2024 13:00	Free - Residual disinfectant	mg Cl/l	0.31	
ZN0504CUST	4981551	16/09/2024 13:00	Hydrogen Ion	pH value	7.6	9.5
ZN0504CUST	4981551	16/09/2024 13:00	Iron	ug/l Fe	20	200
ZN0504CUST	4981551	16/09/2024 13:00	Manganese	ug Mn/l	0.75	50
ZN0504CUST	4981551	16/09/2024 13:00	Odour	Diln No	10	0
ZN0504CUST	4981551	16/09/2024 13:00	Odour - Nature		Musty/Earthy	
ZN0504CUST	4981551	16/09/2024 13:00	Taste	Diln No	0	0
ZN0504CUST	4981551	16/09/2024 13:00	Taste - Nature		No taste	
ZN0504CUST	4981551	16/09/2024 13:00	Total - Residual disinfectant	mg Cl/l	0.4	
ZN0504CUST	4981551	16/09/2024 13:00	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4981551	16/09/2024 13:00	Turbidity	NTU	0.099	4
ZN0505CUST	4981542	16/09/2024 13:45	Aluminium	ug Al/l	21	200
ZN0505CUST	4981542	16/09/2024 13:45	Colour	mg/l Pt/Co	<4.56	20
ZN0505CUST	4981542	16/09/2024 13:45	E. coli	CFU/100 ml	0	0
ZN0505CUST	4981542	16/09/2024 13:45	Free - Residual disinfectant	mg Cl/l	0.2	
ZN0505CUST	4981542	16/09/2024 13:45	Hydrogen Ion	pH value	7.7	9.5
ZN0505CUST	4981542	16/09/2024 13:45	Iron	ug/l Fe	20	200
ZN0505CUST	4981542	16/09/2024 13:45	Manganese	ug Mn/l	0.77	50
ZN0505CUST	4981542	16/09/2024 13:45	Odour	Diln No	10	0
ZN0505CUST	4981542	16/09/2024 13:45	Odour - Nature		Musty/Earthy	
ZN0505CUST	4981542	16/09/2024 13:45	Taste	Diln No	0	0
ZN0505CUST	4981542	16/09/2024 13:45	Taste - Nature		No taste	
ZN0505CUST	4981542	16/09/2024 13:45	Total - Residual disinfectant	mg Cl/l	0.3	
ZN0505CUST	4981542	16/09/2024 13:45	Total Coliforms	CFU/100 ml	0	0
ZN0505CUST	4981542	16/09/2024 13:45	Turbidity	NTU	<0.09	4
ZN0504CUST	4981777	17/09/2024 09:05	E. coli	CFU/100 ml	0	0
ZN0504CUST	4981777	17/09/2024 09:05	Free - Residual disinfectant	mg Cl/l	0.2	

ZN0504CUST	4981777	17/09/2024 09:05	Odour	Diln No	6	0
ZN0504CUST	4981777	17/09/2024 09:05	Odour - Nature		Earthy	
ZN0504CUST	4981777	17/09/2024 09:05	Taste	Diln No	6	0
ZN0504CUST	4981777	17/09/2024 09:05	Taste - Nature		Earthy	
ZN0504CUST	4981777	17/09/2024 09:05	Total - Residual disinfectant	mg Cl/l	0.32	
ZN0504CUST	4981777	17/09/2024 09:05	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4971031	17/09/2024 09:42	Aluminium	ug Al/l	9.2	200
ZN1102AE	4971031	17/09/2024 09:42	Colony Counts 22	CFU/1 ml	0	
ZN1102AE	4971031	17/09/2024 09:42	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN1102AE	4971031	17/09/2024 09:42	Colour	mg/l Pt/Co	<4.56	20
ZN1102AE	4971031	17/09/2024 09:42	Conductivity	uS/cm 20 C	380	2500
ZN1102AE	4971031	17/09/2024 09:42	E. coli	CFU/100 ml	0	0
ZN1102AE	4971031	17/09/2024 09:42	Free - Residual disinfectant	mg Cl/l	0.17	
ZN1102AE	4971031	17/09/2024 09:42	Hydrogen Ion	pH value	7.7	9.5
ZN1102AE	4971031	17/09/2024 09:42	Iron	ug/l Fe	31	200
ZN1102AE	4971031	17/09/2024 09:42	Manganese	ug Mn/l	1.2	50
ZN1102AE	4971031	17/09/2024 09:42	Odour	Diln No	0	0
ZN1102AE	4971031	17/09/2024 09:42	Odour - Nature		No odour	
ZN1102AE	4971031	17/09/2024 09:42	Taste	Diln No	0	0
ZN1102AE	4971031	17/09/2024 09:42	Taste - Nature		No taste	
ZN1102AE	4971031	17/09/2024 09:42	Total - Residual disinfectant	mg Cl/l	0.21	
ZN1102AE	4971031	17/09/2024 09:42	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4971031	17/09/2024 09:42	Turbidity	NTU	0.16	4
ZN0501CUST	4981780	17/09/2024 09:55	E. coli	CFU/100 ml	0	0
ZN0501CUST	4981780	17/09/2024 09:55	Free - Residual disinfectant	mg Cl/l	0.24	
ZN0501CUST	4981780	17/09/2024 09:55	Odour	Diln No	0	0
ZN0501CUST	4981780	17/09/2024 09:55	Odour - Nature		No odour	
ZN0501CUST	4981780	17/09/2024 09:55	Taste	Diln No	0	0
ZN0501CUST	4981780	17/09/2024 09:55	Taste - Nature		0	
ZN0501CUST	4981780	17/09/2024 09:55	Total - Residual disinfectant	mg Cl/l	0.39	
ZN0501CUST	4981780	17/09/2024 09:55	Total Coliforms	CFU/100 ml	0	0
ZN0502CUST	4981989	17/09/2024 10:00	E. coli	CFU/100 ml	0	0
ZN0502CUST	4981989	17/09/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.44	
ZN0502CUST	4981989	17/09/2024 10:00	Odour	Diln No	10	0
ZN0502CUST	4981989	17/09/2024 10:00	Odour - Nature		Oily/Petrochemical	
ZN0502CUST	4981989	17/09/2024 10:00	Taste	Diln No	99	0
ZN0502CUST	4981989	17/09/2024 10:00	Taste - Nature		is performed due to odour contravention	
ZN0502CUST	4981989	17/09/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.48	

ZN0502CUST	4981989	17/09/2024 10:00	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4970875	17/09/2024 10:00	1,2 Dichloroethane	ug/l	<0.4	3
ZN0804AE	4970875	17/09/2024 10:00	Ammonium	mg NH4/l	<0.01	0.5
ZN0804AE	4970875	17/09/2024 10:00	Antimony	ug/l Sb	0.08	5
ZN0804AE	4970875	17/09/2024 10:00	Arsenic	ug/l As	0.34	10
ZN0804AE	4970875	17/09/2024 10:00	Benzene	ug/l	<0.15	1
ZN0804AE	4970875	17/09/2024 10:00	Boron	mg/l B	<0.0586	1
ZN0804AE	4970875	17/09/2024 10:00	Bromate	ug BrO3/l	1.1	10
ZN0804AE	4970875	17/09/2024 10:00	Bromodichloromethane	ug/l	12	
ZN0804AE	4970875	17/09/2024 10:00	Bromoform	ug/l	<3.5	
ZN0804AE	4970875	17/09/2024 10:00	Cadmium	ug/l Cd	<0.042	5
ZN0804AE	4970875	17/09/2024 10:00	Calcium	mg/l	55	
ZN0804AE	4970875	17/09/2024 10:00	Chloroform	ug/l	45	
ZN0804AE	4970875	17/09/2024 10:00	Chromium	ug/l Cr	<0.260	50
ZN0804AE	4970875	17/09/2024 10:00	Copper	mg Cu/l	<0.546	2
ZN0804AE	4970875	17/09/2024 10:00	Dibromochloromethane	ug/l	3	
ZN0804AE	4970875	17/09/2024 10:00	Enterococci	CFU/100ml	0	0
ZN0804AE	4970875	17/09/2024 10:00	Lead	ug Pb/l	<0.095	10
ZN0804AE	4970875	17/09/2024 10:00	Magnesium	mg/l	4.1	
ZN0804AE	4970875	17/09/2024 10:00	Mercury	ug per l	<0.041	1
ZN0804AE	4970875	17/09/2024 10:00	Nickel	ug Ni/l	<0.625	20
ZN0804AE	4970875	17/09/2024 10:00	Potassium	mg/l	2.5	
ZN0804AE	4970875	17/09/2024 10:00	Selenium	ug/l Se	0.092	10
ZN0804AE	4970875	17/09/2024 10:00	Sodium	mg Na/l	38	200
ZN0804AE	4970875	17/09/2024 10:00	Tetrachloroethene	ug/l	<0.8	
ZN0804AE	4970875	17/09/2024 10:00	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0804AE	4970875	17/09/2024 10:00	Tetrachloromethane	ug/l	<0.4	3
ZN0804AE	4970875	17/09/2024 10:00	Total hardness	mg/l	62	
ZN0804AE	4970875	17/09/2024 10:00	Total Organic Carbon	mg C/l	2.3	
ZN0804AE	4970875	17/09/2024 10:00	Total Trihalomethanes	ug/l	61	100
ZN0804AE	4970875	17/09/2024 10:00	Trichloroethene	ug/l	<0.7	
ZN0804AE	4970875	17/09/2024 10:00	WHO Index		0.39	1
ZS0811AE	4970796	17/09/2024 10:28	E. coli	CFU/100 ml	0	0
ZS0811AE	4970796	17/09/2024 10:28	Free - Residual disinfectant	mg Cl/l	0.17	
ZS0811AE	4970796	17/09/2024 10:28	Total - Residual disinfectant	mg Cl/l	0.31	
ZS0811AE	4970796	17/09/2024 10:28	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4981779	17/09/2024 10:45	E. coli	CFU/100 ml	0	0
ZN0501CUST	4981779	17/09/2024 10:45	Free - Residual disinfectant	mg Cl/l	0.1	

ZN0501CUST	4981779	17/09/2024 10:45	Odour	Diln No	0	0
ZN0501CUST	4981779	17/09/2024 10:45	Odour - Nature		No odour	
ZN0501CUST	4981779	17/09/2024 10:45	Taste	Diln No	0	0
ZN0501CUST	4981779	17/09/2024 10:45	Taste - Nature		0	
ZN0501CUST	4981779	17/09/2024 10:45	Total - Residual disinfectant	mg Cl/l	0.3	
ZN0501CUST	4981779	17/09/2024 10:45	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4971114	17/09/2024 11:36	1,2 Dichloroethane	ug/l	<0.4	3
ZN0501AE	4971114	17/09/2024 11:36	Ammonium	mg NH4/l	<0.01	0.5
ZN0501AE	4971114	17/09/2024 11:36	Antimony	ug/l Sb	0.17	5
ZN0501AE	4971114	17/09/2024 11:36	Arsenic	ug/l As	0.27	10
ZN0501AE	4971114	17/09/2024 11:36	Benzene	ug/l	<0.15	1
ZN0501AE	4971114	17/09/2024 11:36	Benzo(a)pyrene	ug/l	<0.0021	0.01
ZN0501AE	4971114	17/09/2024 11:36	Benzo(b)fluoranthene	ug/l	<0.0046	0.1
ZN0501AE	4971114	17/09/2024 11:36	Benzo(ghi)perylene	ug/l	<0.0022	0.1
ZN0501AE	4971114	17/09/2024 11:36	Benzo(k)fluoranthene	ug/l	<0.0040	0.1
ZN0501AE	4971114	17/09/2024 11:36	Boron	mg/l B	<0.0586	1
ZN0501AE	4971114	17/09/2024 11:36	Bromate	ug BrO3/l	<0.50	10
ZN0501AE	4971114	17/09/2024 11:36	Bromodichloromethane	ug/l	13	
ZN0501AE	4971114	17/09/2024 11:36	Bromoform	ug/l	<3.5	
ZN0501AE	4971114	17/09/2024 11:36	Cadmium	ug/l Cd	<0.042	5
ZN0501AE	4971114	17/09/2024 11:36	Calcium	mg/l	56	
ZN0501AE	4971114	17/09/2024 11:36	Chloroform	ug/l	33	
ZN0501AE	4971114	17/09/2024 11:36	Chromium	ug/l Cr	<0.260	50
ZN0501AE	4971114	17/09/2024 11:36	Copper	mg Cu/l	<0.546	2
ZN0501AE	4971114	17/09/2024 11:36	Dibromochloromethane	ug/l	5.7	
ZN0501AE	4971114	17/09/2024 11:36	Enterococci	CFU/100ml	0	0
ZN0501AE	4971114	17/09/2024 11:36	Indeno(1,2,3-cd)pyrene	ug/l	<0.0021	0.1
ZN0501AE	4971114	17/09/2024 11:36	Lead	ug Pb/l	<0.095	10
ZN0501AE	4971114	17/09/2024 11:36	Magnesium	mg/l	8.8	
ZN0501AE	4971114	17/09/2024 11:36	Mercury	ug per l	<0.041	1
ZN0501AE	4971114	17/09/2024 11:36	Nickel	ug Ni/l	2.7	20
ZN0501AE	4971114	17/09/2024 11:36	PAH - Sum of four substances	ug/l	0	0.1
ZN0501AE	4971114	17/09/2024 11:36	Potassium	mg/l	3.6	
ZN0501AE	4971114	17/09/2024 11:36	Selenium	ug/l Se	0.062	10
ZN0501AE	4971114	17/09/2024 11:36	Sodium	mg Na/l	13	200
ZN0501AE	4971114	17/09/2024 11:36	Tetrachloroethene	ug/l	<0.8	
ZN0501AE	4971114	17/09/2024 11:36	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0501AE	4971114	17/09/2024 11:36	Tetrachloromethane	ug/l	<0.4	3

ZN0501AE	4971114	17/09/2024 11:36	Total hardness	mg/l	71	
ZN0501AE	4971114	17/09/2024 11:36	Total Organic Carbon	mg C/l	2.3	
ZN0501AE	4971114	17/09/2024 11:36	Total Trihalomethanes	ug/l	52	100
ZN0501AE	4971114	17/09/2024 11:36	Trichloroethene	ug/l	<0.7	
ZN0501AE	4971114	17/09/2024 11:36	WHO Index		0.39	1
ZN0501CUST	4981778	17/09/2024 11:46	E. coli	CFU/100 ml	0	0
ZN0501CUST	4981778	17/09/2024 11:46	Free - Residual disinfectant	mg Cl/l	0.07	
ZN0501CUST	4981778	17/09/2024 11:46	Odour	Diln No	0	0
ZN0501CUST	4981778	17/09/2024 11:46	Odour - Nature		No odour	
ZN0501CUST	4981778	17/09/2024 11:46	Taste	Diln No	0	0
ZN0501CUST	4981778	17/09/2024 11:46	Taste - Nature		0	
ZN0501CUST	4981778	17/09/2024 11:46	Total - Residual disinfectant	mg Cl/l	0.29	
ZN0501CUST	4981778	17/09/2024 11:46	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4982133	18/09/2024 08:45	E. coli	CFU/100 ml	0	0
ZN0501CUST	4982133	18/09/2024 08:45	Free - Residual disinfectant	mg Cl/l	0.11	
ZN0501CUST	4982133	18/09/2024 08:45	Odour	Diln No	10	0
ZN0501CUST	4982133	18/09/2024 08:45	Odour - Nature		Earthy/Musty	
ZN0501CUST	4982133	18/09/2024 08:45	Taste	Diln No	10	0
ZN0501CUST	4982133	18/09/2024 08:45	Taste - Nature		Musty	
ZN0501CUST	4982133	18/09/2024 08:45	Total - Residual disinfectant	mg Cl/l	0.15	
ZN0501CUST	4982133	18/09/2024 08:45	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4970777	18/09/2024 09:27	Aluminium	ug Al/l	28	200
ZN0501AE	4970777	18/09/2024 09:27	Colony Counts 22	CFU/1 ml	0	
ZN0501AE	4970777	18/09/2024 09:27	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0501AE	4970777	18/09/2024 09:27	Colour	mg/l Pt/Co	<4.56	20
ZN0501AE	4970777	18/09/2024 09:27	Conductivity	uS/cm 20 C	390	2500
ZN0501AE	4970777	18/09/2024 09:27	E. coli	CFU/100 ml	0	0
ZN0501AE	4970777	18/09/2024 09:27	Free - Residual disinfectant	mg Cl/l	0.77	
ZN0501AE	4970777	18/09/2024 09:27	Hydrogen Ion	pH value	7.6	9.5
ZN0501AE	4970777	18/09/2024 09:27	Iron	ug/l Fe	<1.538	200
ZN0501AE	4970777	18/09/2024 09:27	Manganese	ug Mn/l	<0.80	50
ZN0501AE	4970777	18/09/2024 09:27	Odour	Diln No	0	0
ZN0501AE	4970777	18/09/2024 09:27	Odour - Nature		No odour	
ZN0501AE	4970777	18/09/2024 09:27	Taste	Diln No	0	0
ZN0501AE	4970777	18/09/2024 09:27	Taste - Nature		No taste	
ZN0501AE	4970777	18/09/2024 09:27	Total - Residual disinfectant	mg Cl/l	1	
ZN0501AE	4970777	18/09/2024 09:27	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4970777	18/09/2024 09:27	Turbidity	NTU	0.12	4

ZN0501CUST	4982134	18/09/2024 10:00	E. coli	CFU/100 ml	0	0
ZN0501CUST	4982134	18/09/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.29	
ZN0501CUST	4982134	18/09/2024 10:00	Odour	Diln No	0	0
ZN0501CUST	4982134	18/09/2024 10:00	Odour - Nature		No odour	
ZN0501CUST	4982134	18/09/2024 10:00	Taste	Diln No	10	0
ZN0501CUST	4982134	18/09/2024 10:00	Taste - Nature		Earthy/Musty	
ZN0501CUST	4982134	18/09/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.37	
ZN0501CUST	4982134	18/09/2024 10:00	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4967755	18/09/2024 10:40	E. coli	CFU/100 ml	0	0
ZN0102AE	4967755	18/09/2024 10:40	Free - Residual disinfectant	mg Cl/l	0.73	
ZN0102AE	4967755	18/09/2024 10:40	Total - Residual disinfectant	mg Cl/l	0.87	
ZN0102AE	4967755	18/09/2024 10:40	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4982203	18/09/2024 11:10	E. coli	CFU/100 ml	0	0
ZN0504CUST	4982203	18/09/2024 11:10	Free - Residual disinfectant	mg Cl/l	0.44	
ZN0504CUST	4982203	18/09/2024 11:10	Odour	Diln No	0	0
ZN0504CUST	4982203	18/09/2024 11:10	Odour - Nature		No odour	
ZN0504CUST	4982203	18/09/2024 11:10	Taste	Diln No	0	0
ZN0504CUST	4982203	18/09/2024 11:10	Taste - Nature		No taste	
ZN0504CUST	4982203	18/09/2024 11:10	Total - Residual disinfectant	mg Cl/l	0.57	
ZN0504CUST	4982203	18/09/2024 11:10	Total Coliforms	CFU/100 ml	0	0
ZN0502AE	4970780	18/09/2024 11:15	Aluminium	ug Al/l	11	200
ZN0502AE	4970780	18/09/2024 11:15	Colony Counts 22	CFU/1 ml	0	
ZN0502AE	4970780	18/09/2024 11:15	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0502AE	4970780	18/09/2024 11:15	Colour	mg/l Pt/Co	<4.56	20
ZN0502AE	4970780	18/09/2024 11:15	Conductivity	uS/cm 20 C	140	2500
ZN0502AE	4970780	18/09/2024 11:15	E. coli	CFU/100 ml	0	0
ZN0502AE	4970780	18/09/2024 11:15	Free - Residual disinfectant	mg Cl/l	0.43	
ZN0502AE	4970780	18/09/2024 11:15	Hydrogen Ion	pH value	7.3	9.5
ZN0502AE	4970780	18/09/2024 11:15	Iron	ug/l Fe	4.7	200
ZN0502AE	4970780	18/09/2024 11:15	Manganese	ug Mn/l	<0.80	50
ZN0502AE	4970780	18/09/2024 11:15	Odour	Diln No	0	0
ZN0502AE	4970780	18/09/2024 11:15	Odour - Nature		No odour	
ZN0502AE	4970780	18/09/2024 11:15	Taste	Diln No	0	0
ZN0502AE	4970780	18/09/2024 11:15	Taste - Nature		No taste	
ZN0502AE	4970780	18/09/2024 11:15	Total - Residual disinfectant	mg Cl/l	0.47	
ZN0502AE	4970780	18/09/2024 11:15	Total Coliforms	CFU/100 ml	0	0
ZN0502AE	4970780	18/09/2024 11:15	Turbidity	NTU	<0.09	4
ZN0504AE	4970752	18/09/2024 11:36	Aluminium	ug Al/l	23	200

ZN0504AE	4970752	18/09/2024 11:36	Colony Counts 22	CFU/1 ml	0	
ZN0504AE	4970752	18/09/2024 11:36	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0504AE	4970752	18/09/2024 11:36	Colour	mg/l Pt/Co	<4.56	20
ZN0504AE	4970752	18/09/2024 11:36	Conductivity	uS/cm 20 C	370	2500
ZN0504AE	4970752	18/09/2024 11:36	E. coli	CFU/100 ml	0	0
ZN0504AE	4970752	18/09/2024 11:36	Free - Residual disinfectant	mg Cl/l	0.16	
ZN0504AE	4970752	18/09/2024 11:36	Hydrogen Ion	pH value	7.6	9.5
ZN0504AE	4970752	18/09/2024 11:36	Iron	ug/l Fe	40	200
ZN0504AE	4970752	18/09/2024 11:36	Manganese	ug Mn/l	1	50
ZN0504AE	4970752	18/09/2024 11:36	Odour	Diln No	10	0
ZN0504AE	4970752	18/09/2024 11:36	Odour - Nature		Earthy/Musty	
ZN0504AE	4970752	18/09/2024 11:36	Taste	Diln No	10	0
ZN0504AE	4970752	18/09/2024 11:36	Taste - Nature		Earthy/Musty	
ZN0504AE	4970752	18/09/2024 11:36	Total - Residual disinfectant	mg Cl/l	0.38	
ZN0504AE	4970752	18/09/2024 11:36	Total Coliforms	CFU/100 ml	0	0
ZN0504AE	4970752	18/09/2024 11:36	Turbidity	NTU	0.18	4
ZS0811AE	4971277	18/09/2024 11:39	E. coli	CFU/100 ml	0	0
ZS0811AE	4971277	18/09/2024 11:39	Free - Residual disinfectant	mg Cl/l	0.18	
ZS0811AE	4971277	18/09/2024 11:39	Total - Residual disinfectant	mg Cl/l	0.21	
ZS0811AE	4971277	18/09/2024 11:39	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4982205	18/09/2024 12:35	E. coli	CFU/100 ml	0	0
ZN0501CUST	4982205	18/09/2024 12:35	Free - Residual disinfectant	mg Cl/l	0.7	
ZN0501CUST	4982205	18/09/2024 12:35	Odour	Diln No	0	0
ZN0501CUST	4982205	18/09/2024 12:35	Odour - Nature		No odour	
ZN0501CUST	4982205	18/09/2024 12:35	Taste	Diln No	0	0
ZN0501CUST	4982205	18/09/2024 12:35	Taste - Nature		No taste	
ZN0501CUST	4982205	18/09/2024 12:35	Total - Residual disinfectant	mg Cl/l	0.72	
ZN0501CUST	4982205	18/09/2024 12:35	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4982196	18/09/2024 13:15	E. coli	CFU/100 ml	0	0
ZN0501CUST	4982196	18/09/2024 13:15	Free - Residual disinfectant	mg Cl/l	0.12	
ZN0501CUST	4982196	18/09/2024 13:15	Odour	Diln No	10	0
ZN0501CUST	4982196	18/09/2024 13:15	Odour - Nature		Earthy/Musty	
ZN0501CUST	4982196	18/09/2024 13:15	Taste	Diln No	10	0
ZN0501CUST	4982196	18/09/2024 13:15	Taste - Nature		Earthy/Musty	
ZN0501CUST	4982196	18/09/2024 13:15	Total - Residual disinfectant	mg Cl/l	0.17	
ZN0501CUST	4982196	18/09/2024 13:15	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4984150	19/09/2024 02:00	E. coli	CFU/100 ml	0	0
ZN0501CUST	4984150	19/09/2024 02:00	Free - Residual disinfectant	mg Cl/l	0.37	

ZN0501CUST	4984150	19/09/2024 02:00	Odour	Diln No	0	0
ZN0501CUST	4984150	19/09/2024 02:00	Odour - Nature		No odour	
ZN0501CUST	4984150	19/09/2024 02:00	Taste	Diln No	0	0
ZN0501CUST	4984150	19/09/2024 02:00	Taste - Nature		No taste	
ZN0501CUST	4984150	19/09/2024 02:00	Total - Residual disinfectant	mg Cl/l	0.63	
ZN0501CUST	4984150	19/09/2024 02:00	Total Coliforms	CFU/100 ml	0	0
ZS0809CUST	4984153	19/09/2024 09:00	Aluminium	ug Al/l	17	200
ZS0809CUST	4984153	19/09/2024 09:00	Colour	mg/l Pt/Co	<4.56	20
ZS0809CUST	4984153	19/09/2024 09:00	E. coli	CFU/100 ml	0	0
ZS0809CUST	4984153	19/09/2024 09:00	Free - Residual disinfectant	mg Cl/l	0.25	
ZS0809CUST	4984153	19/09/2024 09:00	Hydrogen Ion	pH value	7.7	9.5
ZS0809CUST	4984153	19/09/2024 09:00	Iron	ug/l Fe	9.5	200
ZS0809CUST	4984153	19/09/2024 09:00	Manganese	ug Mn/l	0.81	50
ZS0809CUST	4984153	19/09/2024 09:00	Total - Residual disinfectant	mg Cl/l	0.31	
ZS0809CUST	4984153	19/09/2024 09:00	Total Coliforms	CFU/100 ml	0	0
ZS0809CUST	4984153	19/09/2024 09:00	Turbidity	NTU	0.18	4
ZN0504CUST	4984146	19/09/2024 09:15	E. coli	CFU/100 ml	0	0
ZN0504CUST	4984146	19/09/2024 09:15	Free - Residual disinfectant	mg Cl/l	0.61	
ZN0504CUST	4984146	19/09/2024 09:15	Odour	Diln No	0	0
ZN0504CUST	4984146	19/09/2024 09:15	Odour - Nature		No odour	
ZN0504CUST	4984146	19/09/2024 09:15	Taste	Diln No	0	0
ZN0504CUST	4984146	19/09/2024 09:15	Taste - Nature		No taste	
ZN0504CUST	4984146	19/09/2024 09:15	Total - Residual disinfectant	mg Cl/l	0.83	
ZN0504CUST	4984146	19/09/2024 09:15	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4971028	19/09/2024 09:28	E. coli	CFU/100 ml	0	0
ZS0809AE	4971028	19/09/2024 09:28	Free - Residual disinfectant	mg Cl/l	0.55	
ZS0809AE	4971028	19/09/2024 09:28	Total - Residual disinfectant	mg Cl/l	0.93	
ZS0809AE	4971028	19/09/2024 09:28	Total Coliforms	CFU/100 ml	0	0
ZN0505CUST	4984147	19/09/2024 10:00	E. coli	CFU/100 ml	0	0
ZN0505CUST	4984147	19/09/2024 10:00	Free - Residual disinfectant	mg Cl/l	0.63	
ZN0505CUST	4984147	19/09/2024 10:00	Odour	Diln No	0	0
ZN0505CUST	4984147	19/09/2024 10:00	Odour - Nature		No odour	
ZN0505CUST	4984147	19/09/2024 10:00	Taste	Diln No	0	0
ZN0505CUST	4984147	19/09/2024 10:00	Taste - Nature		No taste	
ZN0505CUST	4984147	19/09/2024 10:00	Total - Residual disinfectant	mg Cl/l	0.89	
ZN0505CUST	4984147	19/09/2024 10:00	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4971064	19/09/2024 10:24	Aluminium	ug Al/l	16	200
ZS0811AE	4971064	19/09/2024 10:24	Colony Counts 22	CFU/1 ml	0	

ZS0811AE	4971064	19/09/2024 10:24	Colony Counts 37 (48hrs)	CFU/1 ml	1	
ZS0811AE	4971064	19/09/2024 10:24	Colour	mg/l Pt/Co	<4.56	20
ZS0811AE	4971064	19/09/2024 10:24	Conductivity	uS/cm 20 C	380	2500
ZS0811AE	4971064	19/09/2024 10:24	E. coli	CFU/100 ml	0	0
ZS0811AE	4971064	19/09/2024 10:24	Free - Residual disinfectant	mg Cl/l	0.11	
ZS0811AE	4971064	19/09/2024 10:24	Hydrogen Ion	pH value	7.4	9.5
ZS0811AE	4971064	19/09/2024 10:24	Iron	ug/l Fe	12	200
ZS0811AE	4971064	19/09/2024 10:24	Manganese	ug Mn/l	<0.80	50
ZS0811AE	4971064	19/09/2024 10:24	Odour	Diln No	0	0
ZS0811AE	4971064	19/09/2024 10:24	Odour - Nature		No odour	
ZS0811AE	4971064	19/09/2024 10:24	Taste	Diln No	0	0
ZS0811AE	4971064	19/09/2024 10:24	Taste - Nature		No taste	
ZS0811AE	4971064	19/09/2024 10:24	Total - Residual disinfectant	mg Cl/l	0.23	
ZS0811AE	4971064	19/09/2024 10:24	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4971064	19/09/2024 10:24	Turbidity	NTU	0.15	4
ZN0102AE	4971275	19/09/2024 11:03	E. coli	CFU/100 ml	0	0
ZN0102AE	4971275	19/09/2024 11:03	Free - Residual disinfectant	mg Cl/l	<0.05	
ZN0102AE	4971275	19/09/2024 11:03	Total - Residual disinfectant	mg Cl/l	0.09	
ZN0102AE	4971275	19/09/2024 11:03	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4983986	19/09/2024 11:28	Aluminium	ug Al/l	15	200
ZN0102AE	4983986	19/09/2024 11:28	Iron	ug/l Fe	290	200
ZN0102AE	4983986	19/09/2024 11:28	Manganese	ug Mn/l	4.7	50
ZN0501CUST	4984148	19/09/2024 11:30	E. coli	CFU/100 ml	0	0
ZN0501CUST	4984148	19/09/2024 11:30	Free - Residual disinfectant	mg Cl/l	1.46	
ZN0501CUST	4984148	19/09/2024 11:30	Odour	Diln No	0	0
ZN0501CUST	4984148	19/09/2024 11:30	Odour - Nature		No odour	
ZN0501CUST	4984148	19/09/2024 11:30	Taste	Diln No	0	0
ZN0501CUST	4984148	19/09/2024 11:30	Taste - Nature		No taste	
ZN0501CUST	4984148	19/09/2024 11:30	Total - Residual disinfectant	mg Cl/l	1.86	
ZN0501CUST	4984148	19/09/2024 11:30	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4983987	19/09/2024 11:55	Aluminium	ug Al/l	11	200
ZN0102AE	4983987	19/09/2024 11:55	Iron	ug/l Fe	160	200
ZN0102AE	4983987	19/09/2024 11:55	Manganese	ug Mn/l	4.6	50
ZN0501CUST	4984149	19/09/2024 12:30	E. coli	CFU/100 ml	0	0
ZN0501CUST	4984149	19/09/2024 12:30	Free - Residual disinfectant	mg Cl/l	0.44	
ZN0501CUST	4984149	19/09/2024 12:30	Odour	Diln No	0	0
ZN0501CUST	4984149	19/09/2024 12:30	Odour - Nature		No odour	
ZN0501CUST	4984149	19/09/2024 12:30	Taste	Diln No	0	0

ZN0501CUST	4984149	19/09/2024 12:30	Taste - Nature		No taste	
ZN0501CUST	4984149	19/09/2024 12:30	Total - Residual disinfectant	mg Cl/l	0.67	
ZN0501CUST	4984149	19/09/2024 12:30	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4983988	19/09/2024 12:46	Aluminium	ug Al/l	11	200
ZN0102AE	4983988	19/09/2024 12:46	Iron	ug/l Fe	120	200
ZN0102AE	4983988	19/09/2024 12:46	Manganese	ug Mn/l	3.4	50
ZN0501CUST	4984506	20/09/2024 08:20	E. coli	CFU/100 ml	0	0
ZN0501CUST	4984506	20/09/2024 08:20	Free - Residual disinfectant	mg Cl/l	<0.05	
ZN0501CUST	4984506	20/09/2024 08:20	Odour	Diln No	0	0
ZN0501CUST	4984506	20/09/2024 08:20	Odour - Nature		No odour	
ZN0501CUST	4984506	20/09/2024 08:20	Taste	Diln No	0	0
ZN0501CUST	4984506	20/09/2024 08:20	Taste - Nature		No taste	
ZN0501CUST	4984506	20/09/2024 08:20	Total - Residual disinfectant	mg Cl/l	0.33	
ZN0501CUST	4984506	20/09/2024 08:20	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4984507	20/09/2024 10:05	E. coli	CFU/100 ml	0	0
ZN0504CUST	4984507	20/09/2024 10:05	Free - Residual disinfectant	mg Cl/l	0.18	
ZN0504CUST	4984507	20/09/2024 10:05	Odour	Diln No	0	0
ZN0504CUST	4984507	20/09/2024 10:05	Odour - Nature		No odour	
ZN0504CUST	4984507	20/09/2024 10:05	Taste	Diln No	0	0
ZN0504CUST	4984507	20/09/2024 10:05	Taste - Nature		No taste	
ZN0504CUST	4984507	20/09/2024 10:05	Total - Residual disinfectant	mg Cl/l	0.43	
ZN0504CUST	4984507	20/09/2024 10:05	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4984504	20/09/2024 11:15	E. coli	CFU/100 ml	0	0
ZN0501CUST	4984504	20/09/2024 11:15	Free - Residual disinfectant	mg Cl/l	0.63	
ZN0501CUST	4984504	20/09/2024 11:15	Odour	Diln No	0	0
ZN0501CUST	4984504	20/09/2024 11:15	Odour - Nature		No odour	
ZN0501CUST	4984504	20/09/2024 11:15	Taste	Diln No	0	0
ZN0501CUST	4984504	20/09/2024 11:15	Taste - Nature		No taste	
ZN0501CUST	4984504	20/09/2024 11:15	Total - Residual disinfectant	mg Cl/l	0.83	
ZN0501CUST	4984504	20/09/2024 11:15	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4984505	20/09/2024 12:05	E. coli	CFU/100 ml	0	0
ZN0501CUST	4984505	20/09/2024 12:05	Free - Residual disinfectant	mg Cl/l	0.33	
ZN0501CUST	4984505	20/09/2024 12:05	Odour	Diln No	0	0
ZN0501CUST	4984505	20/09/2024 12:05	Odour - Nature		No odour	
ZN0501CUST	4984505	20/09/2024 12:05	Taste	Diln No	10	0
ZN0501CUST	4984505	20/09/2024 12:05	Taste - Nature		Earthy	
ZN0501CUST	4984505	20/09/2024 12:05	Total - Residual disinfectant	mg Cl/l	0.54	
ZN0501CUST	4984505	20/09/2024 12:05	Total Coliforms	CFU/100 ml	0	0

ZN0804AE	4971063	23/09/2024 00:00	E. coli	CFU/100 ml	0	0
ZN0804AE	4971063	23/09/2024 00:00	Free - Residual disinfectant	mg Cl/l	0.13	
ZN0804AE	4971063	23/09/2024 00:00	Total - Residual disinfectant	mg Cl/l	0.27	
ZN0804AE	4971063	23/09/2024 00:00	Total Coliforms	CFU/100 ml	0	0
ZN0502CUST	4985182	23/09/2024 09:00	E. coli	CFU/100 ml	0	0
ZN0502CUST	4985182	23/09/2024 09:00	Free - Residual disinfectant	mg Cl/l	0.39	
ZN0502CUST	4985182	23/09/2024 09:00	Odour	Diln No	5	0
ZN0502CUST	4985182	23/09/2024 09:00	Odour - Nature		Petrochemical	
ZN0502CUST	4985182	23/09/2024 09:00	Taste	Diln No	99	0
ZN0502CUST	4985182	23/09/2024 09:00	Taste - Nature		is performed due to odour contravention	
ZN0502CUST	4985182	23/09/2024 09:00	Total - Residual disinfectant	mg Cl/l	0.58	
ZN0502CUST	4985182	23/09/2024 09:00	Total Coliforms	CFU/100 ml	0	0
ZN0502CUST	4985183	23/09/2024 09:30	E. coli	CFU/100 ml	0	0
ZN0502CUST	4985183	23/09/2024 09:30	Free - Residual disinfectant	mg Cl/l	0.44	
ZN0502CUST	4985183	23/09/2024 09:30	Odour	Diln No	0	0
ZN0502CUST	4985183	23/09/2024 09:30	Odour - Nature		No odour	
ZN0502CUST	4985183	23/09/2024 09:30	Taste	Diln No	0	0
ZN0502CUST	4985183	23/09/2024 09:30	Taste - Nature		No taste	
ZN0502CUST	4985183	23/09/2024 09:30	Total - Residual disinfectant	mg Cl/l	0.61	
ZN0502CUST	4985183	23/09/2024 09:30	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4985193	23/09/2024 09:45	Aluminium	ug Al/l	25	200
ZN0501CUST	4985193	23/09/2024 09:45	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4985193	23/09/2024 09:45	E. coli	CFU/100 ml	0	0
ZN0501CUST	4985193	23/09/2024 09:45	Free - Residual disinfectant	mg Cl/l	0.08	
ZN0501CUST	4985193	23/09/2024 09:45	Hydrogen Ion	pH value	7.8	9.5
ZN0501CUST	4985193	23/09/2024 09:45	Iron	ug/l Fe	62	200
ZN0501CUST	4985193	23/09/2024 09:45	Manganese	ug Mn/l	2	50
ZN0501CUST	4985193	23/09/2024 09:45	Total - Residual disinfectant	mg Cl/l	0.19	
ZN0501CUST	4985193	23/09/2024 09:45	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4985193	23/09/2024 09:45	Turbidity	NTU	0.39	4
ZN0504CUST	4985196	23/09/2024 10:20	E. coli	CFU/100 ml	0	0
ZN0504CUST	4985196	23/09/2024 10:20	Free - Residual disinfectant	mg Cl/l	0.11	
ZN0504CUST	4985196	23/09/2024 10:20	Odour	Diln No	0	0
ZN0504CUST	4985196	23/09/2024 10:20	Odour - Nature		No odour	
ZN0504CUST	4985196	23/09/2024 10:20	Taste	Diln No	0	0
ZN0504CUST	4985196	23/09/2024 10:20	Taste - Nature		No taste	
ZN0504CUST	4985196	23/09/2024 10:20	Total - Residual disinfectant	mg Cl/l	0.22	
ZN0504CUST	4985196	23/09/2024 10:20	Total Coliforms	CFU/100 ml	0	0

ZN0706AE	4973324	23/09/2024 10:44	E. coli	CFU/100 ml	0	0
ZN0706AE	4973324	23/09/2024 10:44	Free - Residual disinfectant	mg Cl/l	0.12	
ZN0706AE	4973324	23/09/2024 10:44	Total - Residual disinfectant	mg Cl/l	0.16	
ZN0706AE	4973324	23/09/2024 10:44	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4985194	23/09/2024 10:51	E. coli	CFU/100 ml	0	0
ZN0504CUST	4985194	23/09/2024 10:51	Free - Residual disinfectant	mg Cl/l	<0.05	
ZN0504CUST	4985194	23/09/2024 10:51	Odour	Diln No	0	0
ZN0504CUST	4985194	23/09/2024 10:51	Odour - Nature		No odour	
ZN0504CUST	4985194	23/09/2024 10:51	Taste	Diln No	0	0
ZN0504CUST	4985194	23/09/2024 10:51	Taste - Nature		No taste	
ZN0504CUST	4985194	23/09/2024 10:51	Total - Residual disinfectant	mg Cl/l	0.19	
ZN0504CUST	4985194	23/09/2024 10:51	Total Coliforms	CFU/100 ml	0	0
ZN0502CUST	4985186	23/09/2024 10:55	E. coli	CFU/100 ml	0	0
ZN0502CUST	4985186	23/09/2024 10:55	Free - Residual disinfectant	mg Cl/l	0.41	
ZN0502CUST	4985186	23/09/2024 10:55	Odour	Diln No	0	0
ZN0502CUST	4985186	23/09/2024 10:55	Odour - Nature		No odour	
ZN0502CUST	4985186	23/09/2024 10:55	Taste	Diln No	0	0
ZN0502CUST	4985186	23/09/2024 10:55	Taste - Nature		No taste	
ZN0502CUST	4985186	23/09/2024 10:55	Total - Residual disinfectant	mg Cl/l	0.59	
ZN0502CUST	4985186	23/09/2024 10:55	Total Coliforms	CFU/100 ml	0	0
ZN0804AE	4973348	23/09/2024 11:08	E. coli	CFU/100 ml	0	0
ZN0804AE	4973348	23/09/2024 11:08	Free - Residual disinfectant	mg Cl/l	0.6	
ZN0804AE	4973348	23/09/2024 11:08	Total - Residual disinfectant	mg Cl/l	0.68	
ZN0804AE	4973348	23/09/2024 11:08	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4973305	23/09/2024 11:37	Aluminium	ug Al/l	14	200
ZS0809AE	4973305	23/09/2024 11:37	Colony Counts 22	CFU/1 ml	0	
ZS0809AE	4973305	23/09/2024 11:37	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0809AE	4973305	23/09/2024 11:37	Colour	mg/l Pt/Co	<4.56	20
ZS0809AE	4973305	23/09/2024 11:37	Conductivity	uS/cm 20 C	390	2500
ZS0809AE	4973305	23/09/2024 11:37	E. coli	CFU/100 ml	0	0
ZS0809AE	4973305	23/09/2024 11:37	Free - Residual disinfectant	mg Cl/l	0.66	
ZS0809AE	4973305	23/09/2024 11:37	Hydrogen Ion	pH value	7.7	9.5
ZS0809AE	4973305	23/09/2024 11:37	Iron	ug/l Fe	3.8	200
ZS0809AE	4973305	23/09/2024 11:37	Manganese	ug Mn/l	<0.80	50
ZS0809AE	4973305	23/09/2024 11:37	Odour	Diln No	0	0
ZS0809AE	4973305	23/09/2024 11:37	Odour - Nature		No odour	
ZS0809AE	4973305	23/09/2024 11:37	Taste	Diln No	0	0
ZS0809AE	4973305	23/09/2024 11:37	Taste - Nature		No taste	

ZS0809AE	4973305	23/09/2024 11:37	Total - Residual disinfectant	mg Cl/l	0.88	
ZS0809AE	4973305	23/09/2024 11:37	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4973305	23/09/2024 11:37	Turbidity	NTU	0.098	4
ZN1102AE	4973307	23/09/2024 11:40	E. coli	CFU/100 ml	0	0
ZN1102AE	4973307	23/09/2024 11:40	Free - Residual disinfectant	mg Cl/l	0.26	
ZN1102AE	4973307	23/09/2024 11:40	Odour	Diln No	0	0
ZN1102AE	4973307	23/09/2024 11:40	Odour - Nature		No odour	
ZN1102AE	4973307	23/09/2024 11:40	Taste	Diln No	0	0
ZN1102AE	4973307	23/09/2024 11:40	Taste - Nature		No taste	
ZN1102AE	4973307	23/09/2024 11:40	Total - Residual disinfectant	mg Cl/l	0.48	
ZN1102AE	4973307	23/09/2024 11:40	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4985195	23/09/2024 12:00	E. coli	CFU/100 ml	0	0
ZN0501CUST	4985195	23/09/2024 12:00	Free - Residual disinfectant	mg Cl/l	0.29	
ZN0501CUST	4985195	23/09/2024 12:00	Odour	Diln No	0	0
ZN0501CUST	4985195	23/09/2024 12:00	Odour - Nature		No odour	
ZN0501CUST	4985195	23/09/2024 12:00	Taste	Diln No	0	0
ZN0501CUST	4985195	23/09/2024 12:00	Taste - Nature		No taste	
ZN0501CUST	4985195	23/09/2024 12:00	Total - Residual disinfectant	mg Cl/l	0.36	
ZN0501CUST	4985195	23/09/2024 12:00	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4973329	23/09/2024 12:01	Colony Counts 22	CFU/1 ml	0	
ZN0102AE	4973329	23/09/2024 12:01	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZN0102AE	4973329	23/09/2024 12:01	Colour	mg/l Pt/Co	<4.56	20
ZN0102AE	4973329	23/09/2024 12:01	Conductivity	uS/cm 20 C	350	2500
ZN0102AE	4973329	23/09/2024 12:01	E. coli	CFU/100 ml	0	0
ZN0102AE	4973329	23/09/2024 12:01	Free - Residual disinfectant	mg Cl/l	0.11	
ZN0102AE	4973329	23/09/2024 12:01	Hydrogen Ion	pH value	7.6	9.5
ZN0102AE	4973329	23/09/2024 12:01	Odour	Diln No	0	0
ZN0102AE	4973329	23/09/2024 12:01	Odour - Nature		No odour	
ZN0102AE	4973329	23/09/2024 12:01	Taste	Diln No	0	0
ZN0102AE	4973329	23/09/2024 12:01	Taste - Nature		No taste	
ZN0102AE	4973329	23/09/2024 12:01	Total - Residual disinfectant	mg Cl/l	0.2	
ZN0102AE	4973329	23/09/2024 12:01	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4973329	23/09/2024 12:01	Turbidity	NTU	0.27	4
ZN0501AE	4973327	23/09/2024 12:43	1,2 Dichloroethane	ug/l	<0.4	3
ZN0501AE	4973327	23/09/2024 12:43	Ammonium	mg NH4/l	<0.01	0.5
ZN0501AE	4973327	23/09/2024 12:43	Antimony	ug/l Sb	0.16	5
ZN0501AE	4973327	23/09/2024 12:43	Arsenic	ug/l As	0.29	10
ZN0501AE	4973327	23/09/2024 12:43	Benzene	ug/l	<0.15	1

ZN0501AE	4973327	23/09/2024 12:43	Boron	mg/l B	<0.0586	1
ZN0501AE	4973327	23/09/2024 12:43	Bromodichloromethane	ug/l	13	
ZN0501AE	4973327	23/09/2024 12:43	Bromoform	ug/l	<3.5	
ZN0501AE	4973327	23/09/2024 12:43	Cadmium	ug/l Cd	<0.042	5
ZN0501AE	4973327	23/09/2024 12:43	Calcium	mg/l	55	
ZN0501AE	4973327	23/09/2024 12:43	Chloride	mg Cl/l	21	250
ZN0501AE	4973327	23/09/2024 12:43	Chloroform	ug/l	34	
ZN0501AE	4973327	23/09/2024 12:43	Chromium	ug/l Cr	0.62	50
ZN0501AE	4973327	23/09/2024 12:43	Copper	mg Cu/l	<0.546	2
ZN0501AE	4973327	23/09/2024 12:43	Dibromochloromethane	ug/l	6.3	
ZN0501AE	4973327	23/09/2024 12:43	E. coli	CFU/100 ml	0	0
ZN0501AE	4973327	23/09/2024 12:43	Enterococci	CFU/100ml	0	0
ZN0501AE	4973327	23/09/2024 12:43	Fluoride	mg F/l	<0.150	1.5
ZN0501AE	4973327	23/09/2024 12:43	Free - Residual disinfectant	mg Cl/l	0.05	
ZN0501AE	4973327	23/09/2024 12:43	Lead	ug Pb/l	<0.095	10
ZN0501AE	4973327	23/09/2024 12:43	Magnesium	mg/l	9.1	
ZN0501AE	4973327	23/09/2024 12:43	Mercury	ug per l	<0.041	1
ZN0501AE	4973327	23/09/2024 12:43	Nickel	ug Ni/l	1.3	20
ZN0501AE	4973327	23/09/2024 12:43	Nitrate	mg/l	3.1	50
ZN0501AE	4973327	23/09/2024 12:43	Nitrate/Nitrite Formula	mg/l	<0.062	1
ZN0501AE	4973327	23/09/2024 12:43	Nitrite	mg/l	<0.03	0.5
ZN0501AE	4973327	23/09/2024 12:43	Odour	Diln No	0	0
ZN0501AE	4973327	23/09/2024 12:43	Odour - Nature		No odour	
ZN0501AE	4973327	23/09/2024 12:43	Potassium	mg/l	3.8	
ZN0501AE	4973327	23/09/2024 12:43	Selenium	ug/l Se	0.08	10
ZN0501AE	4973327	23/09/2024 12:43	Sodium	mg Na/l	14	200
ZN0501AE	4973327	23/09/2024 12:43	Sulphate	mg SO4/l	78	250
ZN0501AE	4973327	23/09/2024 12:43	Taste	Diln No	0	0
ZN0501AE	4973327	23/09/2024 12:43	Taste - Nature		No taste	
ZN0501AE	4973327	23/09/2024 12:43	Tetrachloroethene	ug/l	<0.8	
ZN0501AE	4973327	23/09/2024 12:43	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0501AE	4973327	23/09/2024 12:43	Tetrachloromethane	ug/l	<0.4	3
ZN0501AE	4973327	23/09/2024 12:43	Total - Residual disinfectant	mg Cl/l	0.26	
ZN0501AE	4973327	23/09/2024 12:43	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4973327	23/09/2024 12:43	Total hardness	mg/l	70	
ZN0501AE	4973327	23/09/2024 12:43	Total Trihalomethanes	ug/l	54	100
ZN0501AE	4973327	23/09/2024 12:43	Trichloroethene	ug/l	<0.7	
ZN0501AE	4973327	23/09/2024 12:43	WHO Index		0.4	1

ZS0811CUST	4985600	24/09/2024 08:30	Aluminium	ug Al/l	18	200
ZS0811CUST	4985600	24/09/2024 08:30	Colour	mg/l Pt/Co	<4.56	20
ZS0811CUST	4985600	24/09/2024 08:30	E. coli	CFU/100 ml	0	0
ZS0811CUST	4985600	24/09/2024 08:30	Free - Residual disinfectant	mg Cl/l	0.67	
ZS0811CUST	4985600	24/09/2024 08:30	Hydrogen Ion	pH value	7.6	9.5
ZS0811CUST	4985600	24/09/2024 08:30	Iron	ug/l Fe	5.3	200
ZS0811CUST	4985600	24/09/2024 08:30	Manganese	ug Mn/l	0.73	50
ZS0811CUST	4985600	24/09/2024 08:30	Odour	Diln No	0	0
ZS0811CUST	4985600	24/09/2024 08:30	Odour - Nature		No odour	
ZS0811CUST	4985600	24/09/2024 08:30	Taste	Diln No	0	0
ZS0811CUST	4985600	24/09/2024 08:30	Taste - Nature		No taste	
ZS0811CUST	4985600	24/09/2024 08:30	Total - Residual disinfectant	mg Cl/l	0.8	
ZS0811CUST	4985600	24/09/2024 08:30	Total Coliforms	CFU/100 ml	0	0
ZS0811CUST	4985600	24/09/2024 08:30	Turbidity	NTU	0.12	4
ZN0501AE	4973656	24/09/2024 09:15	Colour	mg/l Pt/Co	<4.56	20
ZN0501AE	4973656	24/09/2024 09:15	Conductivity	uS/cm 20 C	370	2500
ZN0501AE	4973656	24/09/2024 09:15	E. coli	CFU/100 ml	0	0
ZN0501AE	4973656	24/09/2024 09:15	Free - Residual disinfectant	mg Cl/l	0.54	
ZN0501AE	4973656	24/09/2024 09:15	Hydrogen Ion	pH value	7.6	9.5
ZN0501AE	4973656	24/09/2024 09:15	Odour	Diln No	0	0
ZN0501AE	4973656	24/09/2024 09:15	Odour - Nature		No odour	
ZN0501AE	4973656	24/09/2024 09:15	Taste	Diln No	0	0
ZN0501AE	4973656	24/09/2024 09:15	Taste - Nature		No taste	
ZN0501AE	4973656	24/09/2024 09:15	Total - Residual disinfectant	mg Cl/l	0.71	
ZN0501AE	4973656	24/09/2024 09:15	Total Coliforms	CFU/100 ml	0	0
ZN0501AE	4973656	24/09/2024 09:15	Turbidity	NTU	0.18	4
ZN0502CUST	4985571	24/09/2024 09:42	E. coli	CFU/100 ml	0	0
ZN0502CUST	4985571	24/09/2024 09:42	Free - Residual disinfectant	mg Cl/l	0.17	
ZN0502CUST	4985571	24/09/2024 09:42	Odour	Diln No	0	0
ZN0502CUST	4985571	24/09/2024 09:42	Odour - Nature		No odour	
ZN0502CUST	4985571	24/09/2024 09:42	Taste	Diln No	0	0
ZN0502CUST	4985571	24/09/2024 09:42	Taste - Nature		No taste	
ZN0502CUST	4985571	24/09/2024 09:42	Total - Residual disinfectant	mg Cl/l	0.2	
ZN0502CUST	4985571	24/09/2024 09:42	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4973636	24/09/2024 10:05	E. coli	CFU/100 ml	0	0
ZS0809AE	4973636	24/09/2024 10:05	Free - Residual disinfectant	mg Cl/l	0.84	
ZS0809AE	4973636	24/09/2024 10:05	Total - Residual disinfectant	mg Cl/l	1.06	
ZS0809AE	4973636	24/09/2024 10:05	Total Coliforms	CFU/100 ml	0	0

ZN0501CUST	4985569	24/09/2024 10:55	E. coli	CFU/100 ml	0	0
ZN0501CUST	4985569	24/09/2024 10:55	Free - Residual disinfectant	mg Cl/l	0.56	
ZN0501CUST	4985569	24/09/2024 10:55	Odour	Diln No	0	0
ZN0501CUST	4985569	24/09/2024 10:55	Odour - Nature		No odour	
ZN0501CUST	4985569	24/09/2024 10:55	Taste	Diln No	0	0
ZN0501CUST	4985569	24/09/2024 10:55	Taste - Nature		No taste	
ZN0501CUST	4985569	24/09/2024 10:55	Total - Residual disinfectant	mg Cl/l	0.77	
ZN0501CUST	4985569	24/09/2024 10:55	Total Coliforms	CFU/100 ml	0	0
ZN1102AE	4973639	24/09/2024 10:56	E. coli	CFU/100 ml	0	0
ZN1102AE	4973639	24/09/2024 10:56	Free - Residual disinfectant	mg Cl/l	0.36	
ZN1102AE	4973639	24/09/2024 10:56	Total - Residual disinfectant	mg Cl/l	0.58	
ZN1102AE	4973639	24/09/2024 10:56	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4985572	24/09/2024 11:15	E. coli	CFU/100 ml	0	0
ZN0504CUST	4985572	24/09/2024 11:15	Free - Residual disinfectant	mg Cl/l	0.15	
ZN0504CUST	4985572	24/09/2024 11:15	Odour	Diln No	0	0
ZN0504CUST	4985572	24/09/2024 11:15	Odour - Nature		No odour	
ZN0504CUST	4985572	24/09/2024 11:15	Taste	Diln No	0	0
ZN0504CUST	4985572	24/09/2024 11:15	Taste - Nature		No taste	
ZN0504CUST	4985572	24/09/2024 11:15	Total - Residual disinfectant	mg Cl/l	0.27	
ZN0504CUST	4985572	24/09/2024 11:15	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4985570	24/09/2024 11:45	E. coli	CFU/100 ml	0	0
ZN0501CUST	4985570	24/09/2024 11:45	Free - Residual disinfectant	mg Cl/l	0.29	
ZN0501CUST	4985570	24/09/2024 11:45	Odour	Diln No	0	0
ZN0501CUST	4985570	24/09/2024 11:45	Odour - Nature		No odour	
ZN0501CUST	4985570	24/09/2024 11:45	Taste	Diln No	0	0
ZN0501CUST	4985570	24/09/2024 11:45	Taste - Nature		No taste	
ZN0501CUST	4985570	24/09/2024 11:45	Total - Residual disinfectant	mg Cl/l	0.44	
ZN0501CUST	4985570	24/09/2024 11:45	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4973657	24/09/2024 12:39	E. coli	CFU/100 ml	0	0
ZN0102AE	4973657	24/09/2024 12:39	Free - Residual disinfectant	mg Cl/l	0.61	
ZN0102AE	4973657	24/09/2024 12:39	Total - Residual disinfectant	mg Cl/l	0.7	
ZN0102AE	4973657	24/09/2024 12:39	Total Coliforms	CFU/100 ml	0	0
ZS0809CUST	4986018	25/09/2024 09:15	Aluminium	ug Al/l	8.1	200
ZS0809CUST	4986018	25/09/2024 09:15	Iron	ug/l Fe	7.1	200
ZS0809CUST	4986018	25/09/2024 09:15	Manganese	ug Mn/l	<0.642	50
ZN0501CUST	4986016	25/09/2024 09:30	Aluminium	ug Al/l	33	200
ZN0501CUST	4986016	25/09/2024 09:30	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4986016	25/09/2024 09:30	Hydrogen Ion	pH value	7.6	9.5

ZN0501CUST	4986016	25/09/2024 09:30	Iron	ug/l Fe	2.3	200
ZN0501CUST	4986016	25/09/2024 09:30	Manganese	ug Mn/l	<0.642	50
ZN0501CUST	4986016	25/09/2024 09:30	Turbidity	NTU	<0.09	4
ZS0809CUST	4986019	25/09/2024 09:30	Aluminium	ug Al/l	22	200
ZS0809CUST	4986019	25/09/2024 09:30	Iron	ug/l Fe	15	200
ZS0809CUST	4986019	25/09/2024 09:30	Manganese	ug Mn/l	3.3	50
ZN0504CUST	4985997	25/09/2024 09:50	E. coli	CFU/100 ml	0	0
ZN0504CUST	4985997	25/09/2024 09:50	Free - Residual disinfectant	mg Cl/l	0.8	
ZN0504CUST	4985997	25/09/2024 09:50	Odour	Diln No	0	0
ZN0504CUST	4985997	25/09/2024 09:50	Odour - Nature		No odour	
ZN0504CUST	4985997	25/09/2024 09:50	Taste	Diln No	0	0
ZN0504CUST	4985997	25/09/2024 09:50	Taste - Nature		No taste	
ZN0504CUST	4985997	25/09/2024 09:50	Total - Residual disinfectant	mg Cl/l	0.87	
ZN0504CUST	4985997	25/09/2024 09:50	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4985996	25/09/2024 10:20	E. coli	CFU/100 ml	0	0
ZN0504CUST	4985996	25/09/2024 10:20	Free - Residual disinfectant	mg Cl/l	0.06	
ZN0504CUST	4985996	25/09/2024 10:20	Odour	Diln No	0	0
ZN0504CUST	4985996	25/09/2024 10:20	Odour - Nature		No odour	
ZN0504CUST	4985996	25/09/2024 10:20	Taste	Diln No	0	0
ZN0504CUST	4985996	25/09/2024 10:20	Taste - Nature		No taste	
ZN0504CUST	4985996	25/09/2024 10:20	Total - Residual disinfectant	mg Cl/l	0.13	
ZN0504CUST	4985996	25/09/2024 10:20	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4986017	25/09/2024 10:30	Aluminium	ug Al/l	100	200
ZN0504CUST	4986017	25/09/2024 10:30	Colour	mg/l Pt/Co	<4.56	20
ZN0504CUST	4986017	25/09/2024 10:30	Hydrogen Ion	pH value	7.5	9.5
ZN0504CUST	4986017	25/09/2024 10:30	Iron	ug/l Fe	630	200
ZN0504CUST	4986017	25/09/2024 10:30	Manganese	ug Mn/l	39	50
ZN0504CUST	4986017	25/09/2024 10:30	Turbidity	NTU	1	4
ZN0502CUST	4985999	25/09/2024 10:45	E. coli	CFU/100 ml	0	0
ZN0502CUST	4985999	25/09/2024 10:45	Free - Residual disinfectant	mg Cl/l	0.65	
ZN0502CUST	4985999	25/09/2024 10:45	Odour	Diln No	0	0
ZN0502CUST	4985999	25/09/2024 10:45	Odour - Nature		No odour	
ZN0502CUST	4985999	25/09/2024 10:45	Taste	Diln No	0	0
ZN0502CUST	4985999	25/09/2024 10:45	Taste - Nature		No taste	
ZN0502CUST	4985999	25/09/2024 10:45	Total - Residual disinfectant	mg Cl/l	0.8	
ZN0502CUST	4985999	25/09/2024 10:45	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4973669	25/09/2024 10:53	Aluminium	ug Al/l	12	200
ZS0811AE	4973669	25/09/2024 10:53	Colony Counts 22	CFU/1 ml	0	

ZS0811AE	4973669	25/09/2024 10:53	Colony Counts 37 (48hrs)	CFU/1 ml	0	
ZS0811AE	4973669	25/09/2024 10:53	Colour	mg/l Pt/Co	<4.56	20
ZS0811AE	4973669	25/09/2024 10:53	Conductivity	uS/cm 20 C	390	2500
ZS0811AE	4973669	25/09/2024 10:53	E. coli	CFU/100 ml	0	0
ZS0811AE	4973669	25/09/2024 10:53	Free - Residual disinfectant	mg Cl/l	0.12	
ZS0811AE	4973669	25/09/2024 10:53	Hydrogen Ion	pH value	7.4	9.5
ZS0811AE	4973669	25/09/2024 10:53	Iron	ug/l Fe	17	200
ZS0811AE	4973669	25/09/2024 10:53	Manganese	ug Mn/l	1.3	50
ZS0811AE	4973669	25/09/2024 10:53	Odour	Diln No	0	0
ZS0811AE	4973669	25/09/2024 10:53	Odour - Nature		No odour	
ZS0811AE	4973669	25/09/2024 10:53	Taste	Diln No	0	0
ZS0811AE	4973669	25/09/2024 10:53	Taste - Nature		No taste	
ZS0811AE	4973669	25/09/2024 10:53	Total - Residual disinfectant	mg Cl/l	0.3	
ZS0811AE	4973669	25/09/2024 10:53	Total Coliforms	CFU/100 ml	0	0
ZS0811AE	4973669	25/09/2024 10:53	Turbidity	NTU	<0.09	4
ZN0501CUST	4985998	25/09/2024 11:30	E. coli	CFU/100 ml	0	0
ZN0501CUST	4985998	25/09/2024 11:30	Free - Residual disinfectant	mg Cl/l	0.16	
ZN0501CUST	4985998	25/09/2024 11:30	Odour	Diln No	0	0
ZN0501CUST	4985998	25/09/2024 11:30	Odour - Nature		No odour	
ZN0501CUST	4985998	25/09/2024 11:30	Taste	Diln No	0	0
ZN0501CUST	4985998	25/09/2024 11:30	Taste - Nature		No taste	
ZN0501CUST	4985998	25/09/2024 11:30	Total - Residual disinfectant	mg Cl/l	0.31	
ZN0501CUST	4985998	25/09/2024 11:30	Total Coliforms	CFU/100 ml	0	0
ZN0505CUST	4986020	25/09/2024 13:00	Aluminium	ug Al/l	19	200
ZN0505CUST	4986020	25/09/2024 13:00	Colour	mg/l Pt/Co	<4.56	20
ZN0505CUST	4986020	25/09/2024 13:00	Hydrogen Ion	pH value	7.6	9.5
ZN0505CUST	4986020	25/09/2024 13:00	Iron	ug/l Fe	25	200
ZN0505CUST	4986020	25/09/2024 13:00	Manganese	ug Mn/l	0.82	50
ZN0505CUST	4986020	25/09/2024 13:00	Turbidity	NTU	0.17	4
ZN0501CUST	4986336	26/09/2024 08:00	E. coli	CFU/100 ml	0	0
ZN0501CUST	4986336	26/09/2024 08:00	Free - Residual disinfectant	mg Cl/l	0.38	
ZN0501CUST	4986336	26/09/2024 08:00	Odour	Diln No	0	0
ZN0501CUST	4986336	26/09/2024 08:00	Odour - Nature		No odour	
ZN0501CUST	4986336	26/09/2024 08:00	Taste	Diln No	0	0
ZN0501CUST	4986336	26/09/2024 08:00	Taste - Nature		No taste	
ZN0501CUST	4986336	26/09/2024 08:00	Total - Residual disinfectant	mg Cl/l	0.45	
ZN0501CUST	4986336	26/09/2024 08:00	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4986335	26/09/2024 08:52	E. coli	CFU/100 ml	0	0

ZN0501CUST	4986335	26/09/2024 08:52	Free - Residual disinfectant	mg Cl/l	0.11	
ZN0501CUST	4986335	26/09/2024 08:52	Odour	Diln No	7	0
ZN0501CUST	4986335	26/09/2024 08:52	Odour - Nature		Earthy	
ZN0501CUST	4986335	26/09/2024 08:52	Taste	Diln No	10	0
ZN0501CUST	4986335	26/09/2024 08:52	Taste - Nature		Earthy	
ZN0501CUST	4986335	26/09/2024 08:52	Total - Residual disinfectant	mg Cl/l	0.23	
ZN0501CUST	4986335	26/09/2024 08:52	Total Coliforms	CFU/100 ml	0	0
ZN0102CUST	4986138	26/09/2024 09:10	Aluminium	ug Al/l	17	200
ZN0102CUST	4986138	26/09/2024 09:10	Colour	mg/l Pt/Co	<4.56	20
ZN0102CUST	4986138	26/09/2024 09:10	E. coli	CFU/100 ml	0	0
ZN0102CUST	4986138	26/09/2024 09:10	Free - Residual disinfectant	mg Cl/l	0.25	
ZN0102CUST	4986138	26/09/2024 09:10	Hydrogen Ion	pH value	7.6	9.5
ZN0102CUST	4986138	26/09/2024 09:10	Iron	ug/l Fe	2.9	200
ZN0102CUST	4986138	26/09/2024 09:10	Manganese	ug Mn/l	0.69	50
ZN0102CUST	4986138	26/09/2024 09:10	Odour	Diln No	0	0
ZN0102CUST	4986138	26/09/2024 09:10	Odour - Nature		No odour	
ZN0102CUST	4986138	26/09/2024 09:10	Taste	Diln No	0	0
ZN0102CUST	4986138	26/09/2024 09:10	Taste - Nature		No taste	
ZN0102CUST	4986138	26/09/2024 09:10	Total - Residual disinfectant	mg Cl/l	0.44	
ZN0102CUST	4986138	26/09/2024 09:10	Total Coliforms	CFU/100 ml	0	0
ZN0102CUST	4986138	26/09/2024 09:10	Turbidity	NTU	<0.09	4
ZN0504CUST	4986337	26/09/2024 09:35	E. coli	CFU/100 ml	0	0
ZN0504CUST	4986337	26/09/2024 09:35	Free - Residual disinfectant	mg Cl/l	0.25	
ZN0504CUST	4986337	26/09/2024 09:35	Odour	Diln No	0	0
ZN0504CUST	4986337	26/09/2024 09:35	Odour - Nature		No odour	
ZN0504CUST	4986337	26/09/2024 09:35	Taste	Diln No	0	0
ZN0504CUST	4986337	26/09/2024 09:35	Taste - Nature		No taste	
ZN0504CUST	4986337	26/09/2024 09:35	Total - Residual disinfectant	mg Cl/l	0.33	
ZN0504CUST	4986337	26/09/2024 09:35	Total Coliforms	CFU/100 ml	0	0
ZS0809AE	4973847	26/09/2024 10:12	E. coli	CFU/100 ml	0	0
ZS0809AE	4973847	26/09/2024 10:12	Free - Residual disinfectant	mg Cl/l	0.81	
ZS0809AE	4973847	26/09/2024 10:12	Total - Residual disinfectant	mg Cl/l	1.01	
ZS0809AE	4973847	26/09/2024 10:12	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4986162	26/09/2024 11:25	Aluminium	ug Al/l	25	200
ZN0501CUST	4986162	26/09/2024 11:25	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4986162	26/09/2024 11:25	E. coli	CFU/100 ml	0	0
ZN0501CUST	4986162	26/09/2024 11:25	Free - Residual disinfectant	mg Cl/l	0.16	
ZN0501CUST	4986162	26/09/2024 11:25	Hydrogen Ion	pH value	7.9	9.5

ZN0501CUST	4986162	26/09/2024 11:25	Iron	ug/l Fe	26	200
ZN0501CUST	4986162	26/09/2024 11:25	Manganese	ug Mn/l	0.87	50
ZN0501CUST	4986162	26/09/2024 11:25	Odour	Diln No	0	0
ZN0501CUST	4986162	26/09/2024 11:25	Odour - Nature		No odour	
ZN0501CUST	4986162	26/09/2024 11:25	Taste	Diln No	0	0
ZN0501CUST	4986162	26/09/2024 11:25	Taste - Nature		No taste	
ZN0501CUST	4986162	26/09/2024 11:25	Total - Residual disinfectant	mg Cl/l	0.23	
ZN0501CUST	4986162	26/09/2024 11:25	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4986162	26/09/2024 11:25	Turbidity	NTU	0.12	4
ZS0811AE	4973349	26/09/2024 11:26	E. coli	CFU/100 ml	0	0
ZS0811AE	4973349	26/09/2024 11:26	Free - Residual disinfectant	mg Cl/l	0.36	
ZS0811AE	4973349	26/09/2024 11:26	Total - Residual disinfectant	mg Cl/l	0.54	
ZS0811AE	4973349	26/09/2024 11:26	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4986338	26/09/2024 12:10	E. coli	CFU/100 ml	0	0
ZN0501CUST	4986338	26/09/2024 12:10	Free - Residual disinfectant	mg Cl/l	0.06	
ZN0501CUST	4986338	26/09/2024 12:10	Odour	Diln No	0	0
ZN0501CUST	4986338	26/09/2024 12:10	Odour - Nature		No odour	
ZN0501CUST	4986338	26/09/2024 12:10	Taste	Diln No	0	0
ZN0501CUST	4986338	26/09/2024 12:10	Taste - Nature		No taste	
ZN0501CUST	4986338	26/09/2024 12:10	Total - Residual disinfectant	mg Cl/l	0.17	
ZN0501CUST	4986338	26/09/2024 12:10	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4986721	27/09/2024 09:30	E. coli	CFU/100 ml	0	0
ZN0501CUST	4986721	27/09/2024 09:30	Free - Residual disinfectant	mg Cl/l	0.12	
ZN0501CUST	4986721	27/09/2024 09:30	Odour	Diln No	0	0
ZN0501CUST	4986721	27/09/2024 09:30	Odour - Nature		No odour	
ZN0501CUST	4986721	27/09/2024 09:30	Taste	Diln No	0	0
ZN0501CUST	4986721	27/09/2024 09:30	Taste - Nature		No taste	
ZN0501CUST	4986721	27/09/2024 09:30	Total - Residual disinfectant	mg Cl/l	0.29	
ZN0501CUST	4986721	27/09/2024 09:30	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4986720	27/09/2024 10:15	E. coli	CFU/100 ml	0	0
ZN0504CUST	4986720	27/09/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.14	
ZN0504CUST	4986720	27/09/2024 10:15	Odour	Diln No	0	0
ZN0504CUST	4986720	27/09/2024 10:15	Odour - Nature		No odour	
ZN0504CUST	4986720	27/09/2024 10:15	Taste	Diln No	0	0
ZN0504CUST	4986720	27/09/2024 10:15	Taste - Nature		No taste	
ZN0504CUST	4986720	27/09/2024 10:15	Total - Residual disinfectant	mg Cl/l	0.18	
ZN0504CUST	4986720	27/09/2024 10:15	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4986518	27/09/2024 10:25	E. coli	CFU/100 ml	0	0

ZN0501CUST	4986518	27/09/2024 10:25	Free - Residual disinfectant	mg Cl/l	0.69	
ZN0501CUST	4986518	27/09/2024 10:25	Odour	Diln No	0	0
ZN0501CUST	4986518	27/09/2024 10:25	Odour - Nature		No odour	
ZN0501CUST	4986518	27/09/2024 10:25	Taste	Diln No	10	0
ZN0501CUST	4986518	27/09/2024 10:25	Taste - Nature		Musty/Metallic	
ZN0501CUST	4986518	27/09/2024 10:25	Total - Residual disinfectant	mg Cl/l	0.76	
ZN0501CUST	4986518	27/09/2024 10:25	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4986719	27/09/2024 11:30	E. coli	CFU/100 ml	0	0
ZN0504CUST	4986719	27/09/2024 11:30	Free - Residual disinfectant	mg Cl/l	0.73	
ZN0504CUST	4986719	27/09/2024 11:30	Odour	Diln No	0	0
ZN0504CUST	4986719	27/09/2024 11:30	Odour - Nature		No odour	
ZN0504CUST	4986719	27/09/2024 11:30	Taste	Diln No	0	0
ZN0504CUST	4986719	27/09/2024 11:30	Taste - Nature		No taste	
ZN0504CUST	4986719	27/09/2024 11:30	Total - Residual disinfectant	mg Cl/l	0.83	
ZN0504CUST	4986719	27/09/2024 11:30	Total Coliforms	CFU/100 ml	0	0
ZS0809CUST	4986819	28/09/2024 00:00	E. coli	CFU/100 ml	0	0
ZS0809CUST	4986819	28/09/2024 00:00	Free - Residual disinfectant	mg Cl/l	0.81	
ZS0809CUST	4986819	28/09/2024 00:00	Odour	Diln No	0	0
ZS0809CUST	4986819	28/09/2024 00:00	Odour - Nature		No odour	
ZS0809CUST	4986819	28/09/2024 00:00	Taste	Diln No	0	0
ZS0809CUST	4986819	28/09/2024 00:00	Taste - Nature		No taste	
ZS0809CUST	4986819	28/09/2024 00:00	Total - Residual disinfectant	mg Cl/l	0.92	
ZS0809CUST	4986819	28/09/2024 00:00	Total Coliforms	CFU/100 ml	0	0
ZS0811CUST	4986820	28/09/2024 00:00	E. coli	CFU/100 ml	0	0
ZS0811CUST	4986820	28/09/2024 00:00	Free - Residual disinfectant	mg Cl/l	0.36	
ZS0811CUST	4986820	28/09/2024 00:00	Odour	Diln No	0	0
ZS0811CUST	4986820	28/09/2024 00:00	Odour - Nature		No odour	
ZS0811CUST	4986820	28/09/2024 00:00	Taste	Diln No	0	0
ZS0811CUST	4986820	28/09/2024 00:00	Taste - Nature		No taste	
ZS0811CUST	4986820	28/09/2024 00:00	Total - Residual disinfectant	mg Cl/l	0.45	
ZS0811CUST	4986820	28/09/2024 00:00	Total Coliforms	CFU/100 ml	0	0
ZS0809CUST	4986812	28/09/2024 08:50	Aluminium	ug Al/l	15	200
ZS0809CUST	4986812	28/09/2024 08:50	Colour	mg/l Pt/Co	<4.56	20
ZS0809CUST	4986812	28/09/2024 08:50	E. coli	CFU/100 ml	0	0
ZS0809CUST	4986812	28/09/2024 08:50	Free - Residual disinfectant	mg Cl/l	0.1	
ZS0809CUST	4986812	28/09/2024 08:50	Hydrogen Ion	pH value	7.4	9.5
ZS0809CUST	4986812	28/09/2024 08:50	Iron	ug/l Fe	5.3	200
ZS0809CUST	4986812	28/09/2024 08:50	Manganese	ug Mn/l	1	50

ZS0809CUST	4986812	28/09/2024 08:50	Odour	Diln No	0	0
ZS0809CUST	4986812	28/09/2024 08:50	Odour - Nature		No odour	
ZS0809CUST	4986812	28/09/2024 08:50	Taste	Diln No	0	0
ZS0809CUST	4986812	28/09/2024 08:50	Taste - Nature		No taste	
ZS0809CUST	4986812	28/09/2024 08:50	Total - Residual disinfectant	mg Cl/l	0.7	
ZS0809CUST	4986812	28/09/2024 08:50	Total Coliforms	CFU/100 ml	0	0
ZS0809CUST	4986812	28/09/2024 08:50	Turbidity	NTU	<0.09	4
ZN0505CUST	4986813	28/09/2024 09:40	Aluminium	ug Al/l	20	200
ZN0505CUST	4986813	28/09/2024 09:40	Colour	mg/l Pt/Co	<4.56	20
ZN0505CUST	4986813	28/09/2024 09:40	E. coli	CFU/100 ml	0	0
ZN0505CUST	4986813	28/09/2024 09:40	Free - Residual disinfectant	mg Cl/l	0.2	
ZN0505CUST	4986813	28/09/2024 09:40	Hydrogen Ion	pH value	7.7	9.5
ZN0505CUST	4986813	28/09/2024 09:40	Iron	ug/l Fe	22	200
ZN0505CUST	4986813	28/09/2024 09:40	Manganese	ug Mn/l	1.2	50
ZN0505CUST	4986813	28/09/2024 09:40	Odour	Diln No	0	0
ZN0505CUST	4986813	28/09/2024 09:40	Odour - Nature		No odour	
ZN0505CUST	4986813	28/09/2024 09:40	Taste	Diln No	0	0
ZN0505CUST	4986813	28/09/2024 09:40	Taste - Nature		No taste	
ZN0505CUST	4986813	28/09/2024 09:40	Total - Residual disinfectant	mg Cl/l	0.4	
ZN0505CUST	4986813	28/09/2024 09:40	Total Coliforms	CFU/100 ml	0	0
ZN0505CUST	4986813	28/09/2024 09:40	Turbidity	NTU	<0.09	4
ZN0501CUST	4986814	28/09/2024 10:26	Aluminium	ug Al/l	28	200
ZN0501CUST	4986814	28/09/2024 10:26	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4986814	28/09/2024 10:26	E. coli	CFU/100 ml	0	0
ZN0501CUST	4986814	28/09/2024 10:26	Free - Residual disinfectant	mg Cl/l	0.3	
ZN0501CUST	4986814	28/09/2024 10:26	Hydrogen Ion	pH value	7.6	9.5
ZN0501CUST	4986814	28/09/2024 10:26	Iron	ug/l Fe	6.2	200
ZN0501CUST	4986814	28/09/2024 10:26	Manganese	ug Mn/l	1.1	50
ZN0501CUST	4986814	28/09/2024 10:26	Odour	Diln No	0	0
ZN0501CUST	4986814	28/09/2024 10:26	Odour - Nature		No odour	
ZN0501CUST	4986814	28/09/2024 10:26	Taste	Diln No	0	0
ZN0501CUST	4986814	28/09/2024 10:26	Taste - Nature		No taste	
ZN0501CUST	4986814	28/09/2024 10:26	Total - Residual disinfectant	mg Cl/l	0.4	
ZN0501CUST	4986814	28/09/2024 10:26	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4986814	28/09/2024 10:26	Turbidity	NTU	<0.09	4
ZN0501CUST	4986815	28/09/2024 11:00	Aluminium	ug Al/l	29	200
ZN0501CUST	4986815	28/09/2024 11:00	Colour	mg/l Pt/Co	<4.56	20
ZN0501CUST	4986815	28/09/2024 11:00	E. coli	CFU/100 ml	0	0

ZN0501CUST	4986815	28/09/2024 11:00	Free - Residual disinfectant	mg Cl/l	0.1	
ZN0501CUST	4986815	28/09/2024 11:00	Hydrogen Ion	pH value	7.6	9.5
ZN0501CUST	4986815	28/09/2024 11:00	Iron	ug/l Fe	4.7	200
ZN0501CUST	4986815	28/09/2024 11:00	Manganese	ug Mn/l	1	50
ZN0501CUST	4986815	28/09/2024 11:00	Odour	Diln No	0	0
ZN0501CUST	4986815	28/09/2024 11:00	Odour - Nature		No odour	
ZN0501CUST	4986815	28/09/2024 11:00	Taste	Diln No	0	0
ZN0501CUST	4986815	28/09/2024 11:00	Taste - Nature		No taste	
ZN0501CUST	4986815	28/09/2024 11:00	Total - Residual disinfectant	mg Cl/l	0.3	
ZN0501CUST	4986815	28/09/2024 11:00	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4986815	28/09/2024 11:00	Turbidity	NTU	<0.09	4
ZN0501CUST	4986935	29/09/2024 09:00	E. coli	CFU/100 ml	0	0
ZN0501CUST	4986935	29/09/2024 09:00	Free - Residual disinfectant	mg Cl/l	0.08	
ZN0501CUST	4986935	29/09/2024 09:00	Odour	Diln No	6	0
ZN0501CUST	4986935	29/09/2024 09:00	Odour - Nature		woody/pencily/petrol	
ZN0501CUST	4986935	29/09/2024 09:00	Taste	Diln No	0	0
ZN0501CUST	4986935	29/09/2024 09:00	Taste - Nature		No taste	
ZN0501CUST	4986935	29/09/2024 09:00	Total - Residual disinfectant	mg Cl/l	0.11	
ZN0501CUST	4986935	29/09/2024 09:00	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4986936	29/09/2024 09:40	E. coli	CFU/100 ml	0	0
ZN0501CUST	4986936	29/09/2024 09:40	Free - Residual disinfectant	mg Cl/l	0.13	
ZN0501CUST	4986936	29/09/2024 09:40	Odour	Diln No	0	0
ZN0501CUST	4986936	29/09/2024 09:40	Odour - Nature		No odour	
ZN0501CUST	4986936	29/09/2024 09:40	Taste	Diln No	0	0
ZN0501CUST	4986936	29/09/2024 09:40	Taste - Nature		No taste	
ZN0501CUST	4986936	29/09/2024 09:40	Total - Residual disinfectant	mg Cl/l	0.15	
ZN0501CUST	4986936	29/09/2024 09:40	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4986940	29/09/2024 10:15	E. coli	CFU/100 ml	0	0
ZN0504CUST	4986940	29/09/2024 10:15	Free - Residual disinfectant	mg Cl/l	0.16	
ZN0504CUST	4986940	29/09/2024 10:15	Odour	Diln No	0	0
ZN0504CUST	4986940	29/09/2024 10:15	Odour - Nature		No odour	
ZN0504CUST	4986940	29/09/2024 10:15	Taste	Diln No	0	0
ZN0504CUST	4986940	29/09/2024 10:15	Taste - Nature		No taste	
ZN0504CUST	4986940	29/09/2024 10:15	Total - Residual disinfectant	mg Cl/l	0.28	
ZN0504CUST	4986940	29/09/2024 10:15	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4986939	29/09/2024 10:20	E. coli	CFU/100 ml	0	0
ZN0504CUST	4986939	29/09/2024 10:20	Free - Residual disinfectant	mg Cl/l	0.14	
ZN0504CUST	4986939	29/09/2024 10:20	Odour	Diln No	0	0

ZN0504CUST	4986939	29/09/2024 10:20	Odour - Nature		No odour	
ZN0504CUST	4986939	29/09/2024 10:20	Taste	Diln No	0	0
ZN0504CUST	4986939	29/09/2024 10:20	Taste - Nature		No taste	
ZN0504CUST	4986939	29/09/2024 10:20	Total - Residual disinfectant	mg Cl/l	0.18	
ZN0504CUST	4986939	29/09/2024 10:20	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4986937	29/09/2024 11:00	E. coli	CFU/100 ml	0	0
ZN0501CUST	4986937	29/09/2024 11:00	Free - Residual disinfectant	mg Cl/l	0.07	
ZN0501CUST	4986937	29/09/2024 11:00	Odour	Diln No	8	0
ZN0501CUST	4986937	29/09/2024 11:00	Odour - Nature		Earthy	
ZN0501CUST	4986937	29/09/2024 11:00	Taste - Nature		lysis due to bacteriological exceedance	
ZN0501CUST	4986937	29/09/2024 11:00	Total - Residual disinfectant	mg Cl/l	0.12	
ZN0501CUST	4986937	29/09/2024 11:00	Total Coliforms	CFU/100 ml	2	0
ZN0501CUST	4986938	29/09/2024 11:45	E. coli	CFU/100 ml	0	0
ZN0501CUST	4986938	29/09/2024 11:45	Free - Residual disinfectant	mg Cl/l	0.06	
ZN0501CUST	4986938	29/09/2024 11:45	Odour	Diln No	0	0
ZN0501CUST	4986938	29/09/2024 11:45	Odour - Nature		No odour	
ZN0501CUST	4986938	29/09/2024 11:45	Taste	Diln No	5	0
ZN0501CUST	4986938	29/09/2024 11:45	Taste - Nature		Earthy	
ZN0501CUST	4986938	29/09/2024 11:45	Total - Residual disinfectant	mg Cl/l	0.1	
ZN0501CUST	4986938	29/09/2024 11:45	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4988108	30/09/2024 07:20	E. coli	CFU/100 ml	0	0
ZN0501CUST	4988108	30/09/2024 07:20	Free - Residual disinfectant	mg Cl/l	<0.05	
ZN0501CUST	4988108	30/09/2024 07:20	Odour	Diln No	10	0
ZN0501CUST	4988108	30/09/2024 07:20	Odour - Nature		Earthy/Musty	
ZN0501CUST	4988108	30/09/2024 07:20	Taste	Diln No	10	0
ZN0501CUST	4988108	30/09/2024 07:20	Taste - Nature		Earthy/Musty	
ZN0501CUST	4988108	30/09/2024 07:20	Total - Residual disinfectant	mg Cl/l	0.21	
ZN0501CUST	4988108	30/09/2024 07:20	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4988110	30/09/2024 09:30	E. coli	CFU/100 ml	0	0
ZN0501CUST	4988110	30/09/2024 09:30	Free - Residual disinfectant	mg Cl/l	0.43	
ZN0501CUST	4988110	30/09/2024 09:30	Odour	Diln No	0	0
ZN0501CUST	4988110	30/09/2024 09:30	Odour - Nature		No odour	
ZN0501CUST	4988110	30/09/2024 09:30	Taste	Diln No	0	0
ZN0501CUST	4988110	30/09/2024 09:30	Taste - Nature		No taste	
ZN0501CUST	4988110	30/09/2024 09:30	Total - Residual disinfectant	mg Cl/l	0.44	
ZN0501CUST	4988110	30/09/2024 09:30	Total Coliforms	CFU/100 ml	0	0
ZS0809CUST	4987945	30/09/2024 09:45	Aluminium	ug Al/l	13	200
ZS0809CUST	4987945	30/09/2024 09:45	E. coli	CFU/100 ml	0	0

ZS0809CUST	4987945	30/09/2024 09:45	Free - Residual disinfectant	mg Cl/l	0.1	
ZS0809CUST	4987945	30/09/2024 09:45	Iron	ug/l Fe	13	200
ZS0809CUST	4987945	30/09/2024 09:45	Manganese	ug Mn/l	1.1	50
ZS0809CUST	4987945	30/09/2024 09:45	Odour	Diln No	0	0
ZS0809CUST	4987945	30/09/2024 09:45	Odour - Nature		No odour	
ZS0809CUST	4987945	30/09/2024 09:45	Taste	Diln No	0	0
ZS0809CUST	4987945	30/09/2024 09:45	Taste - Nature		No taste	
ZS0809CUST	4987945	30/09/2024 09:45	Total - Residual disinfectant	mg Cl/l	0.3	
ZS0809CUST	4987945	30/09/2024 09:45	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4988111	30/09/2024 10:20	E. coli	CFU/100 ml	0	0
ZN0501CUST	4988111	30/09/2024 10:20	Free - Residual disinfectant	mg Cl/l	0.2	
ZN0501CUST	4988111	30/09/2024 10:20	Odour	Diln No	0	0
ZN0501CUST	4988111	30/09/2024 10:20	Odour - Nature		No odour	
ZN0501CUST	4988111	30/09/2024 10:20	Taste	Diln No	0	0
ZN0501CUST	4988111	30/09/2024 10:20	Taste - Nature		No taste	
ZN0501CUST	4988111	30/09/2024 10:20	Total - Residual disinfectant	mg Cl/l	0.28	
ZN0501CUST	4988111	30/09/2024 10:20	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4988109	30/09/2024 10:25	E. coli	CFU/100 ml	0	0
ZN0501CUST	4988109	30/09/2024 10:25	Free - Residual disinfectant	mg Cl/l	0.2	
ZN0501CUST	4988109	30/09/2024 10:25	Odour	Diln No	0	0
ZN0501CUST	4988109	30/09/2024 10:25	Odour - Nature		No odour	
ZN0501CUST	4988109	30/09/2024 10:25	Taste	Diln No	0	0
ZN0501CUST	4988109	30/09/2024 10:25	Taste - Nature		No taste	
ZN0501CUST	4988109	30/09/2024 10:25	Total - Residual disinfectant	mg Cl/l	0.33	
ZN0501CUST	4988109	30/09/2024 10:25	Total Coliforms	CFU/100 ml	0	0
ZN0504CUST	4988112	30/09/2024 11:30	E. coli	CFU/100 ml	0	0
ZN0504CUST	4988112	30/09/2024 11:30	Free - Residual disinfectant	mg Cl/l	0.2	
ZN0504CUST	4988112	30/09/2024 11:30	Odour	Diln No	0	0
ZN0504CUST	4988112	30/09/2024 11:30	Odour - Nature		No odour	
ZN0504CUST	4988112	30/09/2024 11:30	Taste	Diln No	0	0
ZN0504CUST	4988112	30/09/2024 11:30	Taste - Nature		No taste	
ZN0504CUST	4988112	30/09/2024 11:30	Total - Residual disinfectant	mg Cl/l	0.25	
ZN0504CUST	4988112	30/09/2024 11:30	Total Coliforms	CFU/100 ml	0	0
ZN0501CUST	4988121	30/09/2024 12:00	E. coli	CFU/100 ml	0	0
ZN0501CUST	4988121	30/09/2024 12:00	Free - Residual disinfectant	mg Cl/l	0.1	
ZN0501CUST	4988121	30/09/2024 12:00	Odour	Diln No	0	0
ZN0501CUST	4988121	30/09/2024 12:00	Odour - Nature		No odour	
ZN0501CUST	4988121	30/09/2024 12:00	Taste	Diln No	0	0

ZN0501CUST	4988121	30/09/2024 12:00	Taste - Nature		No taste	
ZN0501CUST	4988121	30/09/2024 12:00	Total - Residual disinfectant	mg Cl/l	0.13	
ZN0501CUST	4988121	30/09/2024 12:00	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4976413	30/09/2024 12:17	1,2 Dichloroethane	ug/l	<0.4	3
ZN0102AE	4976413	30/09/2024 12:17	Aluminium	ug Al/l	22	200
ZN0102AE	4976413	30/09/2024 12:17	Ammonium	mg NH4/l	<0.01	0.5
ZN0102AE	4976413	30/09/2024 12:17	Antimony	ug/l Sb	0.13	5
ZN0102AE	4976413	30/09/2024 12:17	Arsenic	ug/l As	0.33	10
ZN0102AE	4976413	30/09/2024 12:17	Benzene	ug/l	<0.15	1
ZN0102AE	4976413	30/09/2024 12:17	Boron	mg/l B	<0.0586	1
ZN0102AE	4976413	30/09/2024 12:17	Bromodichloromethane	ug/l	15	
ZN0102AE	4976413	30/09/2024 12:17	Bromoform	ug/l	<3.5	
ZN0102AE	4976413	30/09/2024 12:17	Cadmium	ug/l Cd	<0.042	5
ZN0102AE	4976413	30/09/2024 12:17	Calcium	mg/l	43	
ZN0102AE	4976413	30/09/2024 12:17	Chloride	mg Cl/l	20	250
ZN0102AE	4976413	30/09/2024 12:17	Chloroform	ug/l	49	
ZN0102AE	4976413	30/09/2024 12:17	Chromium	ug/l Cr	0.61	50
ZN0102AE	4976413	30/09/2024 12:17	Colony Counts 22	CFU/1 ml	2	
ZN0102AE	4976413	30/09/2024 12:17	Colony Counts 37 (48hrs)	CFU/1 ml	2	
ZN0102AE	4976413	30/09/2024 12:17	Colour	mg/l Pt/Co	<4.56	20
ZN0102AE	4976413	30/09/2024 12:17	Conductivity	uS/cm 20 C	350	2500
ZN0102AE	4976413	30/09/2024 12:17	Copper	mg Cu/l	<0.546	2
ZN0102AE	4976413	30/09/2024 12:17	Dibromochloromethane	ug/l	3.6	
ZN0102AE	4976413	30/09/2024 12:17	E. coli	CFU/100 ml	0	0
ZN0102AE	4976413	30/09/2024 12:17	Enterococci	CFU/100ml	0	0
ZN0102AE	4976413	30/09/2024 12:17	Fluoride	mg F/l	<0.150	1.5
ZN0102AE	4976413	30/09/2024 12:17	Free - Residual disinfectant	mg Cl/l	0.58	
ZN0102AE	4976413	30/09/2024 12:17	Hydrogen Ion	pH value	7.6	9.5
ZN0102AE	4976413	30/09/2024 12:17	Iron	ug/l Fe	5.3	200
ZN0102AE	4976413	30/09/2024 12:17	Lead	ug Pb/l	<0.095	10
ZN0102AE	4976413	30/09/2024 12:17	Magnesium	mg/l	9.8	
ZN0102AE	4976413	30/09/2024 12:17	Manganese	ug Mn/l	1.6	50
ZN0102AE	4976413	30/09/2024 12:17	Mercury	ug per l	<0.041	1
ZN0102AE	4976413	30/09/2024 12:17	Nickel	ug Ni/l	1.3	20
ZN0102AE	4976413	30/09/2024 12:17	Nitrate	mg/l	2.3	50
ZN0102AE	4976413	30/09/2024 12:17	Nitrate/Nitrite Formula	mg/l	<0.046	1
ZN0102AE	4976413	30/09/2024 12:17	Nitrite	mg/l	<0.03	0.5
ZN0102AE	4976413	30/09/2024 12:17	Odour	Diln No	0	0

ZN0102AE	4976413	30/09/2024 12:17	Odour - Nature		No odour	
ZN0102AE	4976413	30/09/2024 12:17	Potassium	mg/l	2.7	
ZN0102AE	4976413	30/09/2024 12:17	Selenium	ug/l Se	0.15	10
ZN0102AE	4976413	30/09/2024 12:17	Sodium	mg Na/l	16	200
ZN0102AE	4976413	30/09/2024 12:17	Sulphate	mg SO4/l	70	250
ZN0102AE	4976413	30/09/2024 12:17	Taste	Diln No	0	0
ZN0102AE	4976413	30/09/2024 12:17	Taste - Nature		No taste	
ZN0102AE	4976413	30/09/2024 12:17	Tetrachloroethene	ug/l	<0.8	
ZN0102AE	4976413	30/09/2024 12:17	Tetrachloroethene/Trichloroethene - Sum	ug/l	<0.8	10
ZN0102AE	4976413	30/09/2024 12:17	Tetrachloromethane	ug/l	<0.4	3
ZN0102AE	4976413	30/09/2024 12:17	Total - Residual disinfectant	mg Cl/l	0.72	
ZN0102AE	4976413	30/09/2024 12:17	Total Coliforms	CFU/100 ml	0	0
ZN0102AE	4976413	30/09/2024 12:17	Total hardness	mg/l	59	
ZN0102AE	4976413	30/09/2024 12:17	Total Trihalomethanes	ug/l	68	100
ZN0102AE	4976413	30/09/2024 12:17	Trichloroethene	ug/l	<0.7	
ZN0102AE	4976413	30/09/2024 12:17	Turbidity	NTU	0.11	4
ZN0102AE	4976413	30/09/2024 12:17	WHO Index		0.46	1